



Halifax

Regional Centre for Education

**RFT# 4235 - Addendum #4
Boiler Replacement & Control Upgrades
Tantallon Sr. Elementary School**

To: All Bidders
Date: May 30, 2024
From: Nancy Rideout, Purchasing Manager
Office: (902) 464-2000 ext. 2222
Email: nrideout@hrce.ca

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

Closing of RFT# 4235 will remain as 31st May 2024 – 2.00 pm.
No further clarifications/questions will be accepted for this competition.

Clarification:

1. The Exterior Oil Piping shall be 316 Stainless to ASTM A312

End of Addendum #4

PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:

Signature

Company Name