Halifax
Regional Centre for Education

RFT# 4241 - Addendum #1
Gym Floor Replacement
Bicentennial School

To: All Bidders

Date: May 28, 2024

From: Nancy Rideout, Purchasing Manager
Office: (902) 464-2000 ext. 2222
Email: nrideout@hrce.ca

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

Question #1

Alternate request: Vendor submits Tarkett ClutchCourt Performance Core system as equal to the Standard of acceptance identified.

Response:

Tarkett ClutchCourt Performance Core system has a system profile depth of 2 ½", where the max allowable is 1 ¾" as provided by the standard of acceptance in the specification. This alternate is not accepted.

Question #2

Please confirm that the school can provide the following power supply: 3 Phase/240V/40a x2 for sanders – panel must be within 150 linear feet of the gym.

Response:

Yes, the HRCE will provide sufficient power requirements to operate sanders and hard wiring connections of contractor's floor sanding cords.

Question #3

Please confirm if Bicentennial School would like a logo at center court?

Response:

Yes, please provide their logo at center court. The HRCE will provide a vector file for the logo.

Question #4

Reference section 06 10 00: Please confirm there will be no new panels on the stage facing, and that existing panels will be cut to accommodate the new floor height.

Response:

This item is confirmed. There are no new panels in the scope of work for the stage facing. The existing panels will be cut and sealed to suit the new floor height.

Clarification #1

Reference specification section 09 64 00: Connor Sports has rebranded the *Greenplay* product as *Iso-Comfort VIII*. Please replace all references to *Greenplay* with *Iso-Comfort VIII*.

Additional documents enclosed: **Asbestos Management Program**
Hazardous Building Materials Assessment

Extended Close Date:

The close date of this RFT has been extended to Friday - May 31, 2024.

No further questions will be accepted.

RFT 4241 - End of Addendum #1

PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:

_____ _____
Signature Company Name