



**Halifax**

Regional Centre for Education

**RFP# 4243 - Addendum #1  
Roof Replacement  
Herring Cove Junior High School**

To: All Bidders  
Date: June 13, 2024  
From: Nancy Rideout, Purchasing Manager  
Office: (902) 464-2000 ext. 2222  
Email: [nrideout@hrce.ca](mailto:nrideout@hrce.ca)

---

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

The Deadline to submit questions on this project is 14<sup>th</sup> June 2024 – 2pm (ATL)

**1 Drawings**

- .1 Reference 'typical roof assembly' noted on drawings A102;
  - .1 Delete 'cold applied base sheet' and replace with torch applied base sheet.
  - .2 Delete 'cold applied vapour barrier' and replace with torch applied vapour barrier.
- .2 Reference drawings A100 and A101;
  - .1 Delete new skylight on west end of roof. Infill opening with steel deck and typical roof assembly.
- .3 Add six (6) additional pressure treated wood sleeper's c/w stainless steel covers, to replace existing paver blocks.
- .4 Demolish 2 existing curbs, approx. 24"x24" adjacent existing ductwork. Infill openings with steel deck and typical roof assembly.

**End of Addendum #1 – RFP# 4243**

---

***PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:***

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name