



Halifax

Regional Centre for Education

**RFQ# 4275
Supply & Install New Fire Hydrant
Fairview Junior High
Addendum #1**

To: All Bidders

Date: August 11th, 2025

From: Nancy Rideout, Purchasing Manager
Office: (902) 464-2000 ext. 2222
Email: nrideout@hrce.ca

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

**No further questions will be accepted for RFP# 4273.
The Closing Date of the RFP will remain as 14th August, 2025 – 2pm (ATL)**

Response to Questions & Clarifications:

1. Question: I reviewed some of the documents since the meeting and it appears as though I may have over looked a few items. This one is required to have a full test completed. Pressure testing, chlorination and de-chlorination of the line. This can take some time, typically 1-2 weeks (This is after the line is installed). For the testing itself and installation will Dillion Consulting be present for these items and for installation under HRCE? Or is it is presumed that the contractor will hire a consultant for the installation and testing requirements?

Response:

Dillon Consulting Limited will be the engineers of record for the required testing and sampling. Dillon will:

- Provide full time site review services during construction.
- Provide the test plan for Pressure Testing, Flushing, Disinfection, and Bacterial Sampling:
 - Witness and record Contractor supplied pressure test

- Witness Contractor supplied disinfection and collect and analyze water samples for chlorine levels
- Witness Contractor supplied flushing
- Collect bacterial samples and deliver them to the laboratory for analysis.
- Witness Contractor abandonment of test lead (if present).
- Communicate with Halifax Water, as per our active Permit.

RFQ# 4275 - End of Addendum #1

PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:

Signature

Company Name