

RFP # 4290
Fire Alarm & Emergency Lighting Inspections

Appendix F – Fire Alarm and Emergency
Lighting System Information

Region 1

	LOCATION: Dartmouth Operations	Device	Device address or circuit number	Annunciation	NOTES
--	--------------------------------	--------	----------------------------------	--------------	-------

Panel: Simplex Model: 400U - Single stage operation

MANUAL PULL STATIONS					
1	BY ROOM 3	MA	M1-1	P	
2	BY FIRE PANEL	MA	M1-2	P	
3	REAR EXIT	MA	M1-3	P	
4	MUSIC ROOM EXIT	MA	M1-4	P	
5	BOTTOM OF STAIRS BY FIRE PANEL(LEFT)	MA	M1-5	P	
6	BOTTOM OF STAIRS BY FIRE PANEL(RIGHT)	MA	M1-6	P	
7	STORAGE ROOM EXIT	MA	M1-7	P	
8	BOTTOM OF STAIRS BY MAIN ENTRANCE	MA	M1-8	P	
9	BOILER ROOM	MA	M1-9	P	
10	TOP OF STAIRS MAIN ENTRY	MA	M1-12		
11	PLAN'S ROOM	MA	M1-13		

SPRINKLER DEVICES					
1	SPRINKLER MAIN FLOW	FSP	M1-10	P	

NOTIFYING DEVICES					
1	IN PRESENTERS ROOM	K	SIG 1		
2	BY ROOM 4	K	SIG 1		
3	BASEMENT, BY SMALL BAND ROOM	K	SIG 1		
4	BASEMENT, BY BOILER RM	K	SIG 1		
5	BY INSTRUMENT COORDINATOR	K	SIG 1		
6	LIBRARY SERVICES	K	SIG 1		
7	REAR OF BIG BAND ROOM	K	SIG 1		
8	BY RECEPTION	K	SIG 1		

EMERGENCY LIGHTS					
Line #	EL UNIT Location	Bat. VAH	MOD #	Serial #	Manuf.
1	BY ROOM 3	6V 7.2AH			EMERGI-LITE
2	LARGE BAND ROOM	6V 7.2AH			EMERGI-LITE

3	LARGE BAND ROOM EXIT				EMERGI-LITE
4	SMALL BAND ROOM(BLUE)				EMERGI-LITE
5	STAIR BY SM BAND ROOM				EMERGI-LITE
6	BOTT STAIR BY SM BAND RM				EMERGI-LITE
7	LIBRARY SERVICES	6V 7.2AH			EMERGI-LITE
8	LIBRARY SERV STORAGE	6V 7.2AH			EMERGI-LITE
9	CELLO ROOM				EMERGI-LITE
10	BY CELLO ROOM				EMERGI-LITE
11	BOTT STAIR BY ELEC RM left				EMERGI-LITE
12	BOTT STAIR BY ELEC RM right				EMERGI-LITE
13	HALL BY BOILER ROOM				EMERGI-LITE
14	STORAGE ROOM #1				EMERGI-LITE
15	STORAGE ROOM #2				EMERGI-LITE
16	ENTRANCE BY FIRE PANEL				EMERGI-LITE
17	BY FIRE PANEL				EMERGI-LITE
18	HALL BEHIND PRESENT RM				EMERGI-LITE
19	RECEPTION	6V 7.2AH			EMERGI-LITE
20	MAIN ENTRY TOP STAIRS				EMERGI-LITE
21	MAIN ENTRANCE	6V 7.2AH			EMERGI-LITE
22	IN PRESENTER'S ROOM	6V 7.2AH			EMERGI-LITE
23	BY CONFERENCE ROOM				EMERGI-LITE
24	IN FULLERTON ROOM	6V 7.2AH			EMERGI-LITE
25	ROOM BEHIND RECEPTION				EMERGI-LITE
	BOILER ROOM				

	LOCATION: Bicentennial Jr.	Device	Zone or circuit number	Annunciatio n

	Fire Panel: Simplex 4007ES Hybrid- Single stage			
--	--	--	--	--

MANUAL PULL STATIONS

1	MAIN FL ACROSS FROM RM # 9	M	ZN 1	
2	MAIN FL EAST EXIT	M	ZN 1	
3	MAIN FL ACROSS FROM RM # 1	M	ZN 2	
4	MAIN FL EXIT BY ROOM # 2	M	ZN 2	
5	MAIN FL BY RM # 7	M	ZN 2	
6	MAIN FL CORR BY RM # 16	M	ZN 2	
7	MAIN FL WEST ENTRANCE BY MUSIC ROOM	M	ZN 3	
8	GYM EXIT	M	ZN 4	
9	GYM EXIT VESTIBULE	M	ZN 4	
10	MAIN ENTRANCE / ADMIN AREA	M	ZN 5	
11	BOTTOM FL CORR ADJ RM # 14	M	ZN 6	
12	BOTTOM FL WOODSHOP EXIT	M	ZN 6	
13	BOTTOM FL HOME ECONOMIC ROOM	M	ZN 6	
14	BOTTOM FL OUTSIDE RM # 24	M	ZN 7	
15	BOTTOM FL ENTRANCE BY ELEVATOR	M	ZN 7	
16	BOILER ROOM EXIT	M	ZN 8	

SMOKE DETECTORS

1	STAIRWELL BY ROOM #15	S	ZN 13	
2	STAIRWELL "B" BY MUSIC ROOM	S	ZN 14	
3	OLD ELECTRICAL ROOM	S	ZN 15	
4	NEW ELECTRICAL ROOM	S	ZN 15	
5	BOTTOM FL WOOD STORAGE ROOM	S	ZN 6	
6	BOTTOM FL SHEET METAL STOR RM	S	ZN 6	
7	LIBRARY	S	ZN 3	
8	BOOK STORAGE ROOM	S	ZN 3	

HEAT DETECTORS

1	BOILER ROOM ENTRY	HT	ZN 8	
---	-------------------	----	------	--

SPRINKLER DEVICES

1	BOTTOM LVL (FURNACE ROOM)	PS	ZN 10	
2	MAIN LVL (FURNACE ROOM)	TS	ZN 11	
3	SPRINKLER RM. GROUND LEVEL+B22	TS	ZN 12	
	ELEVATOR MACHINE ROOM	TS	ZN 13	
4	SPRINKLER MAIN LEVEL	PS	ZN 9	

NOTIFYING DEVICES	Model
--------------------------	-------

1	MAIN ENTRANCE	H/S	SIG 1		4906-9127
2	ACROSS FROM RM # 1	H/S	SIG 1		4906-9127
3	BY RM # 7	H/S	SIG 1		4906-9127
4	BY RM # 16	H/S	SIG 1		4906-9127
5	CORR ACROSS FROM BOOK STORAGE	H/S	SIG 1		4906-9127
6	CORR ACROSS FROM SCIENCE RM	H/S	SIG 2		4906-9127
7	GROUND FL MAIN CORR ACROSS FROM RM # 9	H/S	SIG 2		4906-9127
8	GROUND FL CORR BY RM # 14	H/S	SIG 3		4906-9127
9	WOODSHOP	H/S	SIG 3		4906-9127
10	GROUND FL COMPUTER RM	H/S	SIG 3		4906-9127
11	GROUND FL COOKING RM	H/S	SIG 3		4906-9127
12	GYM	H/S	SIG 3		4906-9127
13	BOILER RM	H/S	SIG 3		4906-9127

END OF LINE RESISTORS

1	BOILER ROOM	EOL	ZN 8	
2	GROUND FL CORR BY RM # 14	EOL	SIG 3	
3	GROUND FL MAIN CORR ACROSS FROM RM # 9	EOL	SIG 2	
4	CORR ACROSS FROM BOOK STORAGE	EOL	SIG 1	
5	NEW ELECTRICAL ROOM	EOL	ZN 15	
6	STAIRWELL "B" BY MUSIC ROOM	EOL	ZN 14	
7	STAIRWELL BY ROOM #15	EOL	ZN 13	
8	SPRINKLER GROUND LEVEL	EOL	ZN 12	
9	SPRINKLER MAIN LEVEL	EOL	ZN 11	
10	SPRINKLER BOTTOM LEVEL	EOL	ZN 10	
11	SPRINKLER MAIN LEVEL	EOL	ZN 9	
12	BOTTOM FL OUTSIDE RM # 24	EOL	ZN 7	
13	GYM EXIT	EOL	ZN 4	
14	MAIN ENTRANCE / ADMIN AREA	EOL	ZN 5	
15	MAIN FL EAST EXIT	EOL	ZN 1	
16	BOTTOM FL CORR ADJ RM # 14	EOL	ZN 6	
17	MAIN FL CORR BY RM # 16	EOL	ZN 2	
18	MAIN FL WEST ENTRANCE BY MUSIC ROOM	EOL	ZN 3	

EMERGENCY LIGHTING INSPECTION REPORT

	Location: Bicentennial Jr. EL UNIT Location	Rem ote Head	Cab. Head	C ov er	Exit Bulb AC/DC	Model
1	MAIN LEVEL					
2	East Corr By Rm # 9					
3	Across From Teachers Rm(LEFT)					
4	GYM STAGE PACK					

5	Gym					
6	Gym					
7	Gym					
8	Gym					
9	Corr By COPY ROOM					
10	Across From Office					
11	Across from Main Entrance					
12	By ROOM 4					
13	Across From Rm #1					
14	Outside Rm # 6					
15	BY LIBRARY					
16	BY ELEVATOR LOBBY MAIN LVL				# 783	
17	W/R ADJ RM 29					
	GROUND LEVEL					
18	ELEVATOR LOBBY LOWER LVL					
19	Outside By Boy's Washroom					
20	Across From Rm # 14					
21	Woodshop					Combo
22	Cooking Rm					
23	Stairwell A					Combo
24	Outside Rm # 14					

	LOCATION: Crichton Park	Device	Device address or circuit number
	Fire Panel: Edwards 2280 Single stage		
MANUAL PULL STATIONS			
1	OFFICE	M	Zone #1
2	MAIN ENTRANCE	M	Zone #1
3	106	M	Zone #1
4	FURNACE ROOM EXIT	M	Zone #2
5	CENTER EXIT	M	Zone #2
6	MAIN HALL NR ROOM 116	M	Zone #3
7	REAR EXIT (IN STAIRWELL)	M	Zone #3
8	UPPER LEVEL EMERGENCY EXIT	M	Zone #3
9	GYM ENTRANCE	M	Zone #4
10	GYM EXIT	M	Zone #4
HEAT DETECTORS			
1	CARETAKER STORAGE RM 101	RHT	Zone #1
2	OFFICE STORAGE	RHT	Zone #1
3	PRINCIPALS OFFICE STORAGE	RHT	Zone #1
4	FURNACE ROOM	RHT	Zone #2
5	JANITORS STORAGE ROOM	RHT	Zone #2
6	LOWER JANITORS ROOM 121	RHT	Zone #3
7	UPPER JANITORS ROOM 205	RHT	Zone #3
8	ART STORAGE RM BY GYM	RHT	Zone #4
9	GYM STORAGE RM 124	RHT	Zone #4
10	GYM STORAGE RM 125	RHT	Zone #4
11	ROOM 104	RHT	Zone #1
SPRINKLER DEVICES			
1	SPRINKLER FLOW (IN FURNACE ROOM)	PS	Zone #2
NOTIFYING DEVICES			
1	FRONT EXIT	H	Sig #1
2	MAIN ENTRANCE	H	Sig #1
3	CENTER EXIT	H	Sig #1
4	REAR EXIT	H	Sig #1
5	UPPER LEVEL	H	Sig #1
6	GYM ENTRANCE	H	Sig #1

7	GYM EXIT	H	Sig #1
8	CENTER HALL	H	Sig #1
	FURNACE ROOM	B	Sig #1
9	DOOR RELEASE	R	

Fire Door Number or Location

MAIN ENTRY ADJ LEFT CORRIDOR

MAIN ENTRY LEFT SIDE

MAIN ENTRY RIGHT SIDE

MAIN FOYER TO RIGHT CORRIDOR

CENTER OF RIGHT CORRIDOR

CENTER OF RIGHT CORRIDOR

FAR END OF RIGHT CORRIDOR

TOP OF STAIRS 2ND FLOOR

Crichton Park

EMERGENCY LIGHTING INSPECTION REPORT

	EL UNIT Location	Note Head	Cab. Head	Bat. VA	MOD #	Serial #	Manuf.
1	By Room 101		Y	6V, 7.5Ah	EX10W PXM36		Emergi- Lite
2	By Room 102		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
3	By Room 104		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
4	Main Entrance		Y	6V, 7.5Ah	EX10W PXM36		Emergi- Lite
5	By Room 105		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
6	By Room 107		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
7	Girls Washroom 109		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
8	By Room 110		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
9	Boys Washroom 111		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
10	By Room 113		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
11	Exit by Room 113		Y	6V, 7.5Ah			Emergi- Lite
12	By Room 114		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
13	By Room 116		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
14	By Room 118		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
15	Gym Hall		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite
16	*Girls Washroom 120	Y			REMOTE		
17	*Boys Washroom 122	Y			REMOTE		
18	Exit by Room 127		Y	6V, 7.5Ah	EX10W PXM36		Emergi- Lite
19	Stairs by Room 127		Y	6V, 7.5Ah	EX10W PXM36		Emergi- Lite
20	Gym Entrance Room 123		Y	6V, 7.5Ah	EX10W PXM36		Emergi- Lite
21	Gym Exit to Hall		Y	6V, 7.5Ah	EX10W PXM36		Emergi- Lite
22	Gym Back Exit		Y	6V, 7.5Ah	EX10W PXM36		Emergi- Lite
23	By Room 201		Y	6V, 12Ah	06 DEL 36 V11		Emergi- Lite

24	*Boys Washroom 204	Y			REMOTE	
25	*Girls Washroom 206	Y			REMOTE	
26	Emergency Exit Top Stairs		Y	6V, 12A	RG36/REI	Lumacell
27	Emergency Exit Bottom Stairs		Y	6V, 7.5A	RG36/REI	Lumacell
28	Boiler Room		Y	6V, 7.5A	EX10W PXM36	Emergi- Lite
	Rear Exit by stairs					
	Front Exit					

BREAKER IN PANEL BY MAIN OFFICE, CCT # 23, CONTROLS ALL EMERGENCY LIGHTS

	LOCATION: Dartmouth High
	Fire Panel: Notifier AFP-1000

FIRE ALARM DEVICE

Location Description	Device	Model	Address
ELECT RM ADJ FIRE ALARM	S		50
MAIN ENT.	M		16
ADJ STUDENT SERV.	S		53
BOTTOM MAIN STAIR	S		52
CAFE ADJ STAIRS	S		51
NANTUCKET ADJ 130	M		21
CORR 1 ADJ 130	S		113
CORR 2 DOORS ADJ 120	S		114
HARBOUR CORR ADJ 120	M		22
HARBOUR CORR ADJ STORAGE	M		23
MAIN OFFICE	M		10
CORR ADJ ELECT RM	M		15
CORR ADJ GYM @ DOORS	S		84
GYM CORR ADJ STAIR 1	S		103
GYM CORR ADJ ELEVATOR	S		82
STAIR 1 BOTTOM	M		77
GYM CORR ADJ GARDEN	S		104
GYM CORR ADJ ELEV	S		79
GYM CORR @ DOOR 160B	S		81

GYM CORR @ GARDEN	S		80
GYM CORR @ DOOR 160B	M		13
GYM CORR EXIT @ DOOR 160A	M		83
THISTLE 1 CTR EXIT	S		10
THISTLE 1 CTR EXIT	M		11
THISTLE 1 ADJ 108	M		9
THISTLE 1 ADJ 108	S		172
THISTLE 1 @ FIRE DOOR	S		173
THISTLE 1 @ PHYSICS LAB	S		126
THISTLE 1 @ PHYSICS LAB	M		114
THISTLE CORRIDOR	S		123
BOILER RM	S		8
THISTLE/HARBOUR EXIT	M		6
HARBOUR 1 @ FIRE DOOR	S		124
HARBOUR 1 @ BOYS W/R	S		5
HARBOUR 1 @ BOYS W/R	M		4
GYM STORAGE EXIT	M		101
HARBOUR 1 @ 118	M		1
HARBOUR 1 @ 118	S		2
STAIR #3 ADJ 213	S		47

STAIR #3 ADJ 213	M		115
HARBOUR #3 @ STAIR 3	S		130
THISTLE #2 @ STAIR 3	S		131
HARBOUR 2 @ BOYS W/R	M		43
HARBOUR 2 @ BOYS W/R	S		132
HARBOUR 2 @ 220	S		42
HARBOUR 2 @ 220	M		41
HARBOUR 2 @ 226	S		121
HARBOUR 2 @ 226	M		92
STAIR 1 HARBOUR 2 @ 223	S		133
NANTUCKET 2 @ 226	M		25
NANTUCKET 2 @ 226	S		24
COMM RM 1ST FL	S		60
TOP MAIN STAIR	S		
NANTUCKET 2 @ 201	S		26
NANTUCKET 2 @ 201	M		27
CORR @ 232 A	M		31
CORR @ 232 A	S		30
CORR @ 2ND FL STAIR 1	S		87
FOOTBALL STORAGE	S		112
STAIR 1 TOP	S		28

CORR 2ND FL @ STAIR 1	M		88
2ND FL @ ELEV	S		97
ELEVATOR MACHINE RM	S		49
GYM STORAGE	S		71
GYM STORAGE	S		68
ELECTRICAL RM 113	S		61
BY 212	S		
FOOTBALL STORAGE	S		112
CORR @ STAIR #3	H/S		
CORR @ 214	H/S		
CORR @ 210	H/S		
CORR @ 251	H/S		
CORR @ 2ND ELEV	H/S		
CORR @ 2ND STAIR 1	H/S		
CORR @ 218	H/S		
CORR @ 223	H/S		
CORR @ 226	H/S		
CORR @ 228	H/S		
CORR @ 250	H/S		
CORR @ 235	H/S		
CORR @ 207	H/S		
CORR @ 207	H/S		

CORR @ 202	H/S		
FRONT ENTRANCE	H/S		
BY RM 130B	H/S		
BY RM 119	H/S+ EOL		
IN LIBRARY	H/S		
BY KEATING HALL ENT.	H/S		
BOYS WASHRM	H/S		
GIRLS WASHRM	H/S		
BY GYM	H/S		
BY ELEV	H/S		
GYM	H/S		
GYM	H/S		
GYM	H/S		
GYM	H/S		
GYM	H/S		
GYM	H/S		
GYM	H/S		
GYM	H/S		
BY RM 130	H/S		
BY RM 104	H/S		
BY RM 101	H/S		
BOYS WASHRM BY 107	H/S		

BOYS WASHRM BY 107	H/S		
GIRLS WASHRM BY 107	H/S		
BY 107	H/S		
BY 115	H/S		
HIGH CEILING OUTSIDE GYM	S	74	
HIGH CEILING OUTSIDE GYM	S	75	
COMMON ROOM 250	S	100	
STORAGE ROOM 252	S	99	
MECHANICAL ROOM 251	HT		
WORK ROOM INSIDE MAIN OFFICE	S	55	
FOOTBALL STORAGE ROOM	S	125	
LEVEL 1 RESOURCE LIBRARY	M	120	
LEVEL 1 RESOURCE STORAGE	S	110	
THISTLE 1 CORRIDOR	S	122	
BOILER ROOM	M	7	
TECH ED PRODUCTION ROOM	M	122	
STAIR #6	S	35	
STAIR #5	S	36	
LEVEL 2 ELECTRICAL RM 274	S	62	
LEVEL 2 ELECTRICAL RM	S	66	

221			
THISTLE 2 CORRIDOR @ 212	M	46	
NEAR RM 207	S		
LEVEL 2 MAIN COMMON RM	S	65	
VICTORIA 2 NEAR STORAGE ROOM 252	S	98	
VICTORIA 2 NEAR STAIR	S	89	
MECH RM RETURN DUCT	DS	127	
MECH RM SUPPLY DUCT	DS	128	

EMERGENCY LIGHTING

Location: Dartmouth High

Location	Heads	Model
NANTUCKET #1 WOMENS W/R		REMOTE
NANTUCKET #1 @ 130		REMOTE
NANTUCKET #1 @ MUSIC		AIM-LITE
LIBRARY		REMOTE
MUSIC RM		AIM-LITE
MUSIC RM		REMOTE
HARBOUR #1 @ 119		LUMACELL
HARBOUR #1 @ STORAGE		LUMACELL
HARBOUR #1 @ STORAGE EXIT		COMBO
HARBOUR #2 NORTH STAIR		REMOTE

CENTRE #2 MENS W/R		AIM-LITE
LIBRARY		AIM-LITE
GYM NORTH		REMOTE
GYM NORTH		REMOTE
GYM SOUTH		REMOTE
GYM SOUTH		REMOTE
GYM-WEST		REMOTE
GYM MENS CHANGE RM		REMOTE
GYM WOMENS CHANGE RM		REMOTE
GYM NORTH STORAGE		AIM-LITE
GYM SOUTH STORAGE		AIM-LITE
HARBOUR #1 @ JAN RM		COMBO
HARBOUR #1 @ JAN RM		LUMACELL
HARBOUR #1 @ 113		LUMACELL
HARBOUR #1 @ 118		LUMACELL
STAIRS BY 120		
BY ELECTRICAL RM		
ADJ 130B		REMOTE
BY 222		
@ROOM 260		REMOTE

BOYS WASHROOM OFF CENTRE		AIMLITE
BOYS WASHROOM	4	REMOTE
GIRLS WASHROOM	4	REMOTE

	Location: Harbourview Elem.	Device	Device address or circuit number	Annunciation
	Fire Alarm Panel: Edwards 6500 Single stage			
	Manual Pull Stations			
1	Gym NorthWest	M	1	
2	Gym SouthEast	M	1	
3	East Hall New by stairs	M	2	
4	North Exit New	M	3	
5	West Exit New By Office	M	5	
6	Exit New North West by Staff Rm	M	4	
7	South Exit New 2nd Floor by Stairs	M	7	
8	North Hall 2nd Floor west by stairs across from Rm 201	M	9	
9	2nd Floor Center by Rm 204	M	8	
10	2nd floor southwest by stairs	M	6	
11	East 1st Floor Existing by Rm 03	M	13	
12	1st Floor west Exit	M	13	
13	1st Floor Excel Child Center Office by Copier	M	13	
14	2nd Floor south hall center by Rm 111	M	14	
15	2nd Floor south hall east across from Rm 115	M	14	
16	2nd Floor Southwest Hall by Storage Rm	M	14	
17	3rd floor south hall west across from Rm 209	M	15	
18	3rd floor south hall center by Supplies Rm	M	15	
19	3rd floor south hall east by Rm 213	M	15	
	Smoke Detectors			
1	Northeast Hall By Rm 104	Si	3	
2	New Hall Southeast Outside Boys Washroom	Si	2	
3	2nd Floor Top of Southeast Stairs	Si	7	
4	2nd Floor Northwest Hallway	Si	8	
5	New Hall South Exit By Rm 101	Si	4	
6	New Hall Southwest Outside Library	Si	5	
7	South Stairs 2nd Floor Exit	Si	6	
8	2nd Floor Northeast top of stairs by Rm 201	Si	9	
9	Sprinkler	FS	16	
	Heat Detectors			
1	Old Boiler Room	HT	16	

2	New Boiler Room	HT	16	
3	Electrical Room Vault	HT	16	
4	Boiler Entry	HT	16	
	Bells			
1	South new building main hall center	B		
2	South outside office	B		
3	south main hall east	B		
4	north main hall east	B		
5	north main hall central	B		
6	north main hall west	B		
7	gym	B		
8	southeast new section library entrance	B		
9	old section 2nd floor east	B		
10	old section 2nd floor central	B		
11	old section 2nd floor west	B		
12	old section 1st floor east	B		
13	old section 1st floor central	B		
14	old section 1st floor west	B		
15	old section 3rd floor east	B		
16	old section 3rd floor central	B		
17	old section 3rd floor west	B		
18	new section se outside girls washroom	B		
19	new section south hall	B		
20	new section south hallway east	B		
21	new section 2nd floor east hallway	B		
22	new section 2nd north hallway east	B		
23	new section 2nd north hallway west	B		

Fire Door Number or Location

1ST FLOOR SOUTH HALL, NEW BLDG
1ST FLOOR EAST HALL, NEW BLDG
1ST FLOOR NORTH HALL, NEW BLDG
2ND FLOOR SOUTH HALL, NEW BLDG
2ND FLOOR EAST HALL, NEW BLDG
2ND FLOOR NORTH HALL, NEW BLDG
1ST FLOOR EAST STAIRS, OLD BLDG
1ST FLOOR WEST STAIRS, OLD BLDG
2ND FLOOR EAST STAIRS, OLD BLDG
2ND FLOOR WEST STAIRS, OLD BLDG
3RD FLOOR EAST STAIRS, OLD BLDG
3RD FLOOR WEST STAIRS, OLD BLDG

EMERGENCY LIGHTING INSPECTION REPORT

Location:Harbour View
EL UNIT Location

Location	# of Heads	Model	C
NEW SECTION STAIRS AT STAFF ROOM		LUMACELL	
NEW SECTION NORTH CTR BY 105		LUMACELL	
NEW SECTION AT 102		LUMACELL	
NEW SECTION SOUTH BY 216		LUMACELL	
NEW SECTION NW STAIR		COMBO	
OLD SECTION 3RD FL EAST BY 208		COMBO	
OLD SECTION 3RD FL WEST 213		COMBO	
NEW SECTION CTR STAIR BY GIRLS W/R		LUMACELL	
OLD SECTION 2ND FLR WEST BY 115		COMBO	
OLD SECTION 2ND FL EAST BY 111		COMBO	
OLD SECTION 3RD FL WEST STAIR TOP		UNIT	
OLD SECTION 3RD FL EAST STAIR TOP		UNIT	
OLD SECTION 1ST FL EXIT @DENTAL		COMBO	
OLD SECTION 1ST FL CTR NEAR 03		COMBO	
OLD SECTION 1ST FL NEAR DENTAL		COMBO	
OLD SECTION AT EXCEL		UNIT	

EXCEL		
NEW SECTION SOUTH BY LIBRARY EXIT EAST		UNIT
NEW SECTION MAIN OFFICE AREA		EMERGILIT E
NEW SECTION GYM SOUTHEAST		
NEW SECTION GYM SOUTHWEST		
NEW SECTION NORTHWEST		LUMACELL
NEW SECTION GYM NORTHEAST		
NEW SECTION EAST HALL BY CARETAKER 2ND FL		LUMACELL
NEW SECTION NORTH HALL CENTRE BY 203		LUMACELL
OLD SECTION BOILER ROOM		
LIBRARY EXIT		COMBO
EXCEL OFFICE		COMBO
EXCEL OFFICE BACK		REMOTE
STAIRS NEAR 201		STANPRO
STAIRS BY 217		UNIT
MIDDLE STAIRS		UNIT
STAIRS NEAR LIBRARY		COMBO PACK
EXCEL STAIRS EXIT		COMBO PACK

GYM NORTHEAST		PACK
GYM STAGE		PACK

	LOCATION: Hawthorn	Device	Device address or circuit number
	Fire Alarm Panel: Edwards EST2		
	DEVICES		
	1ST FLOOR		
2	1ST FLR FRONT ENTRY LEFT	MA	221
3	1ST FLR FRONT ENTRY RIGHT	MA	222
4	1ST FLR BACK EXIT	MA	203
5	GYM (BACK EXIT)	MA	204
	GYM (BY STAGE)	MA	205
15	BOILER RM	RHTA	106
6	SPRINKLER GATE VALVE	SV	224
7	SPRINKLER WATER FLOW	PS	214
	2ND FLOOR		
8	2ND FLR LEFT HALL	MA	207
9	2ND FLR RIGHT HALL	MA	208
10	LIBRARY	SA	109
	3RD FLOOR		
11	3RD FLR LEFT STAIRS	SA	112
12	3RD FLR RIGHT STAIRS	SA	113
13	3RD FLR LEFT HALL	MA	210
14	3RD FLR RIGHT HALL	MA	211
16	AUDIBLES		
17	GYM	B	SIG 219
	GYM	B	SIG 219
18	1ST FLR LEFT	B	SIG 219
19	1ST FLR RIGHT	B	SIG 219
20	BACK EXIT	B	SIG 219
	BOILER RM and EOL	B	SIG 219
21	2ND FLR LEFT	B	SIG 201
22	2ND FLR RIGHT	B	SIG 201
23	2ND FLR BACK HALL and EOL	B	SIG 201
24	2ND FLR STAFF RM	B	SIG 201
25	3RD FLR LEFT	B	SIG 202

26	3RD FLR RIGHT	B	SIG 202
27	3RD FLR BACK HALL	B	SIG 202

Fire Door Number or Location

1st Floor Left Stairs

1st Floor Right Stairs

1st Floor Front Hall

1st Floor Rear Exit

2nd Floor Left Stairs

2nd Floor Right Stairs

3rd Floor Left Stairs

3rd Floor Right Stairs

Location: Hawthorne

EMERGENCY LIGHTING

	EL UNIT Location	Model	Remote Head	Cover	Bat. VAH 6V , 12AH
1	1ST FLOOR BOILER ROOM			Y	6V , 12AH
2	1ST FLOOR UNDER LEFT STAIRS			Y	6V , 12AH
3	1ST FLOOR UNDER RIGHT STAIRS			Y	
4	1ST FLOOR RIGHT GYM ENTRY		Y		
5	1ST FLOOR RIGHT GYM EXIT	Combo Ready Light plus Exit	Y		
6	1ST FLOOR LEFT GYM ENTRY	Combo Ready Light plus Exit	Y		
7	1ST FLOOR LEFT GYM EXIT	Combo Ready Light plus Exit	Y		
8	1ST FLOOR RIGHT STAIRWELL		Y		
9	1ST FLOOR LEFT STAIRWELL		Y		
10	RIGHT STAIRS FROM MAIN ENTRY		Y		

11	LEFT STAIRS FROM MAIN ENTRY		Y		
12	2ND FLOOR BY ROOM 10		Y		
13	2ND FLOOR BY ROOM 10		Y		
14	2ND FLOOR BY OFFICE	Combo Ready Light plus Exit	Y		
15	2ND FLOOR BY OFFICE		Y		
16	2ND FLOOR BY LIBRARY		Y		
17	3RD FLOOR STAIRWELL FROM LEVEL 2 (LEFT STAIRS)		Y		
18	3RD FLOOR STAIRWELL FROM LEVEL 2 (LEFT STAIRS)		Y		
19	3RD FLOOR STAIRWELL FROM LEVEL 2 (RIGHT STAIRS)		Y		
20	3RD FLOOR STAIRWELL FROM LEVEL 2 (RIGHT STAIRS)		Y		
21	3RD FLOOR BY COMPUTER RM	Combo Ready Light plus Exit	Y		

	LOCATION:John MacNeil	Device	Device address or circuit number	Annunciation
	Fire Alarm Panel: Edwards 6616			
	DEVICES			
1	MAIN ENTRY	M	ZONE # 1	
2	WEST EXIT	M	ZONE # 1	
3	EAST EXIT	M	ZONE # 1	
4	EAST EXIT	EOL	ZONE # 1	
5	GYM NORTH EXIT	M	ZONE # 2	
6	GYM ENTRY WEST	M	ZONE # 2	
7	GYM ENTRY EAST	M	ZONE # 2	
8	GYM NORTH EXIT	EOL	ZONE #2	
9	SPRINKLER ROOM	PS	ZONE # 3	
10	SPRINKLER ROOM	EOL	ZONE # 3	
	BELLS			
11	MAIN ENTRY	B	SIG # 2	
12	MAIN CORRIDOR	B	SIG # 2	
13	REAR CORRIDOR	B	SIG # 1	
14	GYM	B	SIG # 1	
15	GYM NORTH EXIT	B	SIG # 1	
16	GYM NORTH EXIT	EOL	SIG # 1	
17	EAST HALL BY ROOM # 6	EOL	SIG # 2	
	Fire Door Location			
	West hall			
	East gym exit			
	West gym exit			
	LOCATION:John MacNeil			

EMERGENCY LIGHTING INSPECTION REPORT

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Rem ote Head	Cab. Head	C ov er	Remarks	Bat. VAH	Manuf.
1	Main Lobby			Y	panel B	6V / 7AH	Emergi - Lite

2	Main Lobby Entry			Y	panel B	6V / 7AH	Emergi - Lite
3	West hall			Y	panel B	6V / 7AH	Emergi - Lite
4	WEST HALL BY WASHROOMS			Y	panel B	6V / 7AH	Emergi - Lite
5	WEST EXIT			Y	panel B	6V / 7AH	Emergi - Lite
6	East Hall			Y	panel B	6V / 7AH	Emergi - Lite
7	EAST EXIT			Y	panel B	6V / 7AH	Emergi - Lite
8	Gym Entry West			Y	panel D	6V / 7AH	Emergi - Lite
9	Gym Entry East			Y	panel D	6V / 7AH	Emergi - Lite
10	Gym West			Y	panel D	6V / 7AH	Emergi - Lite
11	Gym North Exit			Y	panel D	6V / 7AH	Emergi - Lite
12	Gym East			Y	panel D	6V / 7AH	Emergi - Lite

			Correctly installed	Requires service	Alarm confirmation	Sensitivity reading	Device address or circuit number	Annunciation	
	LOCATION:John Martin Jr.	Device							NOTES
	Fire Alarm Panel: Edwards FS								

Location Description	Device	Model	Address	Zone / Circuit #
----------------------	--------	-------	---------	------------------

IK FORSYTHE BUILDING

ELECTRICAL ROOM @ FIRE PANEL	RHT	281A		1
2ND FLOOR ADJ. ROOM 29	M	270-SPO		1
2ND FLOOR ADJ. ROOM 25	M	270-SPO		1
PRINCIPAL SECURITY	RHT	CR135	UPSTAIRS	1
ROOM 22 REAR PRINCIPAL	RHT	CR135	UPSTAIRS	1
STAFF ROOM UPSTAIRS	RHT	281A		1
ROOM 24A	RHT	CR135		1
1ST FLOOR ADJ. STORAGE	M	270-SPO		2
1ST FLOOR STORAGE	RHT	CR135		2
STORAGE IN DAYCARE	RHT	CR135		2
SPRINKLER ROOM	RHT	CR135		2
BY ENTRANCE TO BREEZEWAY	M	270PO		2
JANITORS CLOSET	RHT	CR135		2
LOWER CORRIDOR BY ROOM 24	M	2705PO		2
DAYCARE	M	270-SPO		2

JOHN MARTIN BUILDING

BY BREEZEWAY	M	270-SPO		4
--------------	---	---------	--	---

TOP STAIR ADJ. 202	S	ESC TYPE		6
TOP STAIR ADJ. 202	M	270-SPO		4
TOP ELEVATOR SHAFT	S	ESC TYPE		5
TOP STAIR BY 208	M	270-SPO		4
TOP STAIR BY 212	M	270-SPO		4
MAIN ENTRANCE	M	270-SPO		4
EXIT BACK BY GYM	M	RES-301C		4
ELEVATOR MECH RM	S	ESC TYPE		6

NOTIFYING DEVICES	B 6"			
2ND FLOOR EXISTING BUILDING	B 6"	SIG2		
2ND FLOOR BY FOUNTAIN	B 6"	SIG2		
2ND FLOOR BY WASHROOM	B 6"	SIG2		
2ND FLOOR BY ROOM 205	B 6"	SIG2		
BY ROOM 213	B 6"	SIG2		
NEW SECTION CONTINUING EDUCATION	B 6"	SIG1		
1ST FLOOR INDUSTRIAL ARTS	B 6"	SIG1		
OUTSIDE INDUSTRIAL ARTS	B 6"	SIG1		
BY HOME ECONOMICS	B 6"	SIG1		
GYM MAIN ENTRANCE	B 6"	SIG1		

FLOW SWITCH SPRINKLER RM FORSYTHE	FS			3
-----------------------------------	----	--	--	---

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

	EMERGENCY LIGHTS IN ELECTRICAL PANEL BEHIND STAGE, CCTS # 11 & # 15 , 2ND FLOOR ELECTRICAL
	PANEL BY ROOM # 202 , CCT # 40, ALL JOHN MARTIN.
	DAY CARE OFFICE CCT # 27 / ALL IK FORSYTHE .

	LOCATION:Shannon Park	Device	Device address or circuit number

Fire Alarm Panel: Edwards FS 502

EAST WING

	MAIN ENTRANCE (ADJ F/A)	M	ZN 1
	LEFT HALLWAY - MIDDLE BY ROOM 7	M	ZN 1
	EXIT BY GIRL'S LOCKER ROOM	M	ZN 1
	BAND ROOM HALL (ADJ WASHROOMS)	M	ZN 1
	TECH SUPPORT EXIT	M	ZN 1
	TECH SUPPORT OFFICE EXIT	M	ZN 1
	CAFETERIA EXIT	M	ZN 1
	1ST FLR JANITOR RM BY BOILER ACCESS	HT	ZN 1
	SUPPLY RM THRU BOILER RM	RHT	ZN 1
	LEFT HALLWAY - MIDDLE	K	SIG 2
	LEFT HALLWAY (BY COMPUTER LAB)	K	SIG 2
	BAND ROOM HALLWAY - MIDDLE	K	SIG 2
	TECH SUPPORT EXIT	K	SIG 2
	LEFT HALLWAY BY CAFETERIA	K	SIG 2
	LEFT HALLWAY - MIDDLE	EOL	ZN 1

WEST WING

	GYM STAGE	M	ZN 2
	GYM BACK EXIT DOOR (LEFT)	M	ZN 2
	GYM BACK EXIT DOOR (RIGHT)	M	ZN 2
	OUTSIDE LIBRARY	M	ZN 2
	CUSTODIAN'S OFFICE HALLWAY - MIDDLE	M	ZN 2
	CUSTODIAN'S OFFICE HALLWAY EXIT	M	ZN 2
	CUSTODIAN'S OFFICE	RHT	ZN 2
	MOP CLOSET (OPP. CUST. OFFICE)	RHT	ZN 2
	GYM EQUIPMENT STORAGE ROOM	RHT	ZN 2
	GYM BACK EXIT DOOR (RIGHT)	K	SIG 2
	OUTSIDE LIBRARY	K	SIG 2

	CUSTODIAN'S OFFICE HALLWAY - MIDDLE	K	SIG 2
	CUSTODIAN'S OFFICE HALLWAY - MIDDLE	EOL	SIG 2
	CUSTODIAN'S OFFICE HALLWAY EXIT	EOL	ZN 2

1ST FLOOR

	FRONT END OF HALLWAY	M	ZN 3
	BACK END OF HALLWAY	M	ZN 3
	FRONT END OF HALLWAY	K	SIG 1
	HALLWAY - MIDDLE	K	SIG 1
	BACK END OF HALLWAY	K	SIG 1
	BACK END OF HALLWAY	EOL	SIG 1

2ND FLOOR

	BACK END OF HALLWAY	M	ZN 4
	FRONT END OF HALLWAY	M	ZN 4
	TOP OF SOUTH STAIRS	S	ZN 4
	TOP OF NORTH STAIRS	S	ZN 4
	FRONT END OF HALL ROOM (ADJ 45)	RHT	ZN 4
	BACK END OF HALLWAY	K	SIG 1
	HALLWAY - MIDDLE	K	SIG 1
	FRONT END OF HALLWAY	K	SIG 1
	BACK END OF HALLWAY	EOL	SIG 1
	BACK END OF HALLWAY	EOL	ZN 4

BASEMENT

	BOILER ROOM	RHT	ZN 5
	COMM/ ELECTRICAL ROOM	HT	ZN 5
	JANITOR'S SUPPLY RM (LEADING TO BSMT)	RHT	ZN 1
	BOILER ROOM	K	SIG 1

EMERGENCY LIGHTING INSPECTION REPORT					
	EL UNIT Location	Remote Head	Cab. Head	Re	Bat. VAH
1	TECH SUPPORT BY STAFF W/R				
2	TECH SUPPORT RM EXIT				
3	EXIT BY GIRL'S LOCKER ROOM				
4	MAIN ENTRANCE				
5	OUTSIDE OFFICE				6V 7.2Ah
	PANEL ON STAGE, CCT #13				
6	BEHIND STAGE				

PANEL ON STAGE, CCT #11					
7	GYM BY STAGE				
8	GYM BY MEZZANINE				
9	OUTSIDE MUSIC ROOM				
PANEL BY RM 26, CCT #4					
10	ENTRANCE BY ROOM 29				
11	ABOVE ROOM 34				
12	EAST ENTRANCE BY 35				
13	OUTSIDE GRADE 5/6 ROOM				
PANEL BY RM 37, CCT #36					
14	OUTSIDE ROOM 44				
15	STAIRWELL BY ROOM 44				
16	OUTSIDE by ROOM 40				
17	STAIRWELL BY ROOM 39				
BOILER ROOM ,CCT #18					
	BOILER ROOM INNER				
BOILER ROOM ,CCT #33					
	BOILER ROOM OUTER				
	OUTSIDE CAFETERIA				
	CAFETERIA				
	REMOTE HEAD MAIN ELEC. RM.				
BOILER ROOM, CCT #35					
	COMPRESSOR ROOM				
PANEL BY GRADE 5/6 ROOM, CCT #9					
	BASEMENT EXIT				
	CAFÉ EXIT				
	CAFÉ EXIT				

	LOCATION:South Woodside	Device	Device address or circuit number	Annunciation	NOTES
Fire Alarm Panel: Edwards 6500					
MANUAL PULL STATIONS					
1	EXIT BY MULTI-PURPOSE ROOM	M	ZN 01		EOL
2	MULTI-PURPOSE ROOM	M	ZN 01		
3	HALL BY MAIN OFFICE	M	ZN 01		
4	CLASSROOM BY LIBRARY EXIT	M	ZN 02		
5	ENTRY BY FIRE PANEL	M	ZN 02		
6	LIBRARY EXIT	M	ZN 02		EOL
7	GYM ENTRANCE BY STAGE	M	ZN 03		
8	GYM EXIT NEAR STAGE	M	ZN 03		
9	GYM EXIT REAR	M	ZN 03		EOL
10	GYM EXIT BY BOYS & GIRLS WASHROOMS	M	ZN 03		
11	BOILER ROOM	M	ZN 04		EOL
12	OLD BUILDING SOUTH EXIT	M	ZN 07		
13	OLD BUILDING CENTER EXIT	M	ZN 08		
14	OLD HALL NEAR ELECTRICAL ROOM	M	ZN 09		
HEAT DETECTORS					
2	BOILER ROOM	HT	ZN 04		To be lowered
1	ELECTRICAL ROOM	HT	ZN 05		
SPRINKLER DEVICES					
1	SPRINKLER MAIN GATE	TS	ZN 14		
2	SPRINKLER MAIN GATE	SV	ZN 13		
3	SPRINKLER FLOW SWITCH	FSP	ZN 6		
NOTIFYING DEVICES					
1	NEW BUILDING EAST	B	SIG 2		
2	BOYS SHOWER	B	SIG 1		
3	GIRLS SHOWER	B	SIG 1		
4	NEW BUILDING EAST EXIT	B	SIG 2		
5	NEW BUILDING WEST EXIT	B	SIG 2		
6	GYM BY EXIT	B	SIG 1		EOL
7	GYM	B	SIG 1		
8	GYM BY STAGE EXIT	B	SIG 1		
9	BOILER ROOM	B	SIG 1		
10	OLD BUILDING SOUTH	B	SIG 1		
11	OLD BUILDING NORTH	B	SIG 1		
12	OLD BUILDING CENTER	B	SIG 1		
13	BY FIRE PANEL	B	SIG 2		
14	BY MAIN OFFICE	B	SIG 2		

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Remote Head	Cab. Head	Cover	Exit Bulb AC/DC
1	MAIN ELECTRICAL RM	X			
2	BY STATIONARY	X			
3	LIBRARY	X			
4	MULTI-PURPOSE RM	X			
5	MULTI-PURPOSE RM	X			
6	MULTI-PURPOSE RM	X			
7	BY MAIN OFFICE	X			
8	ELECTRICAL ROOM	X			
9	BY MULTI-PURPOSE RM	X			
#	BY GRADE PRIMARY	X			
#	GYM	X			
#	GYM	X			
#	BY GRADE 3	X			
#	BY CENTER ENTRY	X			
#	BY RIGHT ENTRY	X			
#	BY ELECTRICAL RM	X			
Fire Door Number or Location					
BETWEEN OLD & NEW BUILDING					

LOCATION: Southdale-North Woodside		DEVICE	Device address or circuit number
FIRE ALARM PANEL: Edwards			
MANUAL PULL STATIONS			
1	MAIN ENTRANCE STAIRS	M	ZN 1
2	CORR BY RM # 2	M	ZN 1
3	CORR OUTSIDE RM # 5	M	ZN 1
4	CORR BY RM# 7	M	ZN 1
5	CORR BY RM # 25	M	ZN 1
6	CORR OUTSIDE RM # 28	M	ZN 1
7	STAIRWELL ACROSS FROM RM # 32	M	ZN 1
8	BOILER RM	M	ZN 4
9	BY DOOR # 15	M	ZN 2
10	EXIT BY RM # 24	M	ZN 2
11	BY DOOR #19	M	ZN 2
12	ACROSS FROM RM # 23	M	ZN 2
13	SIDE DOOR EXIT BY RM # 1	M	ZN 2
14	GYM ENTRY	M	ZN 5
15	GYM ENTRY	M	ZN 5
16	GYM EXIT	M	ZN 5
17	GYM EMERGENCY BACK LEFT	M	ZN 6
SPRINKLER DEVICES			
1	SPRINKLER RM	PS	ZN 3
NOTIFYING DEVICES			
1	GROUND LEVEL ACROSS FROM RM # 23	B	SIG 2
2	MAIN LEVEL CORR OUTSIDE RM # 28	K	SIG 2
3	STAIRWELL OUTSIDE RM # 32	K	SIG 2
4	CORR BY RM # 7	K	SIG 1
5	CORR BY RM # 5	K	SIG 1
6	CORR BY RM # 2	K	SIG 1
7	CORR BY RM # 9	K	SIG 2
8	CORR BY NURSE OFFICE	K	SIG 2
	GYM RIGHT SIDE ENTRY	K	SIG 2
10	OUTSIDE CARETAKER OFFICE	K	SIG 2
11	BOILER RM	K	SIG 2
12	GYM UPPER STORAGE	K	SIG 1
13	CORRIDOR BY 19	K	SIG 1
14	ATTIC	K	SIG 1

15	BY ROOM 109	B	
END LINE RESISTORS			
1	SPRINKLER RM	EOL	ZN 3
2	CLASS RM BEHIND GYM (LEFT HANDSIDE)	EOL	ZN 6
3	BOILER RM	EOL	ZN 4
4	GYM EXIT	EOL	ZN 5
5	STAIRWELL ACROSS FROM RM # 32	EOL	ZN 1
6	ACROSS FROM RM # 23	EOL	SIG 2
7	STAIRWELL OUTSIDE RM # 32	EOL	SIG 1
8	SIDE DOOR EXIT	EOL	ZN 2

Fire Door Number or Location

LEVEL 2 FAR LEFT BY ROOM # 1
LEVEL 2 LEFT BY ROOM # 4
LEVEL 2 FAR RIGHT
LEVEL 2 RIGHT BY ROOM 5
LEVEL 2 TOP OF MAIN STAIRS
LEVEL 2 TOP OF STAIRS BY RM 32
LEVEL 2 RIGHT
LEVEL 1 BOTTOM OF STAIRS BY RM 24
LEVEL 1 CENTER HALL BY RM 18
LEVEL 1 CENTER HALL BY RM 16
LEVEL 1 CENTER HALL BY RM 14
LEVEL 1 CENTER HALL BY RM 9
LEVEL 1 CENTER HALL BY CARETAKE

EMERGENCY LIGHTING INSPECTION REPORT

Line	EL UNIT Location
#	
PANEL "2", BY ROOM 32, CCT#16	
13	BY GIRLS WASHROOM BY RM 32
PANEL "8", BY ROOM 5, CCT#14	
16	MAIN ENTRANCE
17	TOP OF STAIR BY OFFICE
PANEL "4", BY ROOM 7, CCT#21	
14	ON STAIRS LANDING BY ROOM 25
15	OUTSIDE RM # 6
PANEL "2", BY ROOM 32, CCT#17	
19	BY BOOK STORE
PANEL BY ROOM 20, CCT#10B	
10	BACK DOOR EXIT BY RM # 19
11	ACROSS FROM RM # 24
PANEL "3", BY ROOM 16, CCT#14	

9	OUTSIDE FURANCE RM
PANEL BY ROOM 15, CCT#13	
8	OUTSIDE RM # 15
SMALL PANEL IN GYM, CCT#5	
5	LEFT GYM EXIT
6	RIGHT GYM EXIT
LARGE PANEL IN GYM, CCT#13	
3	GYM ENTRY (ABOVE)
4	GYM ENTRY (ABOVE)
7	ENTRANCE TO GYM
PANEL "2", BY ROOM 32, CCT#18	
20	BY ROOM # 32 MID STAIR
PANEL "2", BY ROOM 32, CCT#17	
12	TOP STAIR BY RM # 25
INDEPENDENT(NO BREAKERS)	
1	LEFT SIDE EXIT BY RM # 1
2	OUTSIDE RM # 9
18	OUTSIDE RM # 1
	LANDING BY ROOM 9

LOCATION:Dartmouth South Academy	Device	Device address or circuit number
FIRE ALARM PANEL:Notifier NFS2-640		

SLC or Zn	Add	Type Code	FlashScan Type	Label	Extended Label	Zone Label
		MAIN	FACP	MAIN PANEL		
		ANN	ANNUCIATOR	MAIN PANEL	LED	
		ANN	ANNUCIATOR	FRONT LOBBY	LCD	
		ANN	ANNUCIATOR	FRONT LOBBY	ACTIVE GRAPIC	
ZONE 1 1ST FLOOR WEST						
L1	D53	SMOKE	ACCLIMATE	REMOTE COMM ROOM	131B	
L1	M38	PULLSTATION	MANUAL	TECH ED PRODUCTION	108	
L1	M43	PULLSTATION	MANUAL	CORRIDOR 100B WEST	STAIR 2	
L1	M45	PULLSTATION	MANUAL	CORRIDOR 100D	STAIR 3	
L1	D03	SMOKE	PHOTO	REMOTE COMM ROOM	RM 110	
ZONE 2 1ST FLOOR EAST						
L1	D29	SMOKE	ACCLIMATE	CUSTODIAL 141		
L1	D30	SMOKE	PHOTO	COMMUNICATIONS 138A		
L1	D33	SMOKE	ACCLIMATE	CORRIDOR 100F	BY ELEVATOR	
L1	D32	PULLSTATION	MANUAL	MAIN VESTABULE 101	CAFETERIA	
L1	D34	PULLSTATION	MANUAL	RECYCLE ROOM 101A		
L1	M54	PULLSTATION	MANUAL	RECEPTION	RM 130	
ZONE 3 1ST FLOOR NORTH						
L1	M27	PULL STATION	MANUAL	CORRIDOR 100H	STAIRS 1 NTH	
ZONE 4 2ND FLOOR WEST						
L2	M22	PULLSTATION	MANUAL	CORRIDOR 200B WEST	STAIR 2	
L2	M25	PULLSTATION	MANUAL	CORRIDOR 200C WEST	STAIR 3	
L2	D02	SMOKE	PHOTO	REMOTE COMMUNICATION	RM 212	
ZONE 5 2ND FLOOR EAST						
L2	D02	SMOKE	ACCLIMATE	REMOTE COMM ROOM	RM 234A	
L2	D21	SMOKE	ACCLIMATE	CORRIDOR 200D	BY ELEVATOR	
ZONE 6 2ND FLOOR NORTH						
L2	M01	PULLSTATION	MANUAL	CORRIDOR 200 E NORTH	EXIT STAIR 1	

S/LC or Z'n	Add	Type Code	FlashScan Type	Label	Extended Label	Zone Label
ZONE 7 STAIRWELL ST3						
L2	D26	SMOKE	ACCLIMATE	STAIRWELL 3 WEST		
ZONE 8 STAIRWELL ST1 - NORTH						
L2	D01	SMOKE	ACCLIMATE	STAIRWELL 1 NORTH		
ZONE 9 STAIRWELL ST4 - EAST						
ZONE 10 STAIRWELL ST2 FRONT						
L2	D23	SMOKE	ACCLIMATE	STAIRWELL 2 EAST		
ZONE 11 ELEVATOR						
L2	D45	SMOKE	ACCLIMATE	ELEVATOR SHAFT		
ZONE 12 KITCHEN HOOD SYSTEM						
L1	M37	MONITOR	MONITOR	KITCHEN HOOD SYSTEM		
ZONE 13 EXTERIOR BOILER ROOM						
L1	D52	HEAT	FIXED	BOILER ROOM E102	EXTERIOR	
L1	M50	PULLSTATION	MANUAL	BOILER ROOM E102	EXTERIOR	
ZONE 14 EXTERIOR ELECTRICAL ROOM						
L1	D01	SMOKE	ACCLIMATE	UPS ROOM 104 A	IN MAIN ELECT	
L1	D02	SMOKE	ACCLIMATE	MAIN ELECTRICAL	EXTERIOR	
L1	M47	PULLSTATION	MANUAL	MAIN ELECTRICAL E104		
ZONE 15 EXTERIOR SPRINKLER ROOM						
L1	M46	PULLSTATION	MANUAL	SPRINKLER ROOM E105	EXTERIOR	
ZONE 16 EXTERIOR STORAGE ROOM						
L1	D41	SMOKE	PHOTO	EQUIPMENT ROOM	EXTERIOR	
L1	M40	PULLSTATION	MANUAL	EQUIPMENT ROOM	RM E 101	
ZONE 17 GYMNASIUM						
L1	M48	PULLSTATION	MANUAL	GYM 133 EXIT NORTH		
L1	M49	PULLSTATION	MANUAL	GYM 133C VESTABULE		

SLC or Zn	Add	Type Code	FlashScan Type	Label	Extended Label	Zone Label
ZONE 18 2ND FLOOR MECHANICAL						
L2	D07	SMOKE	ACCLIMATE	MECHANICAL ROOM 235	DETECTOR 1	
L2	D14	SMOKE	ACCLIMATE	MECHANICAL ROOM 235	DETECTOR 2	
L2	D16	SMOKE	ACCLIMATE	MECHANICAL ROOM 235	DETECTOR 3	
ZONE 19 SPRINKLER GATE VALVES						
L1	M31	LATCH SUPERV	MONITOR	ELEVATOR PIT VALVE	SPRINKLER	
L1	M90	LATCH SUPERV	MINI DUAL	BACKFLOW 1		
L1	M91	LATCH SUPERV	MINI DUAL	BACKFLOW 2		
L1	M92	LATCH SUPERV	MINI DUAL	LEVEL 1 GATE		
L1	M94	LATCH SUPERV	MINI DUAL	WINDOW CURTAIN		
L1	M96	LATCH SUPERV	MINI DUAL	LEVEL 2 GATE		
ZONE 20 SPRINKLER FLOWS						
L1	M93	MONITOR	MINI DUAL	LEVEL 1 FLOW		

L1	M95	MONITOR	MINI DUAL	WINDOW CURTAIN		
L1	M97	MONITOR	MINI DUAL	LEVEL 2 FLOW		
ZONE 21 DUCT SENSORS						
L2	D05	SMOKE	DUCT	HRV # 2 MECH ROOM 235		
L2	D06	SMOKE	DUCT	HRV # 3 MECH ROOM 235		
L2	D10	SMOKE	DUCT	HRV # 4 MECH RM 235		
L2	D11	SMOKE	DUCT	AHU 1 MECH RM 235		
L2	D17	SMOKE	DUCT	HRV-1 MECH RM 235		
RELAYS						
L1	M28	CONTROL	RELAY	DOOR RELEASE	STAIR 1	
L1	M35	CONTROL	RELAY	KITCHEN EXHAUST FAN		
L1	M36	CONTROL	RELAY	SHUNT TRIP BREAKER		
L1	M39	CONTROL	RELAY	DOOR RELEASE	STAIR 3	
L1	M42	CONTROL	RELAY	DUST COLLECTION UNIT	RM 108	
L1	M56	CONTROL	RELAY	GYM SOUND SYSTEM		
L1	M57	CONTROL	RELAY	BAS ALARM	RM 138A	
L1	M58	GEN TROUBLE	RELAY	BAS TROUBLE	RM 138A	
L2	M02	CONTROL	RELAY	DOOR RELEASE	STAIR 1	
L2	M08	CONTROL	RELAY	AHU-1 FIRE ALARM	SHUTDOWN	
L2	M09	CONTROL	RELAY	HRV-4 FIRE ALARM	SHUTDOWN	
L2	M12	CONTROL	RELAY	HRV-3 FIRE ALARM	SHUTDOWN	
L2	M13	CONTROL	RELAY	HRV-2 FIRE ALARM	SHUTDOWN	
L2	M15	CONTROL	RELAY	HRV-1 FIRE ALARM	SHUTDOWN	

SLC or Zn	Add	Type Code	FlashScan Type	Label	Extended Label	Zone Label
RELAYS- CONTINUED						
L2	M18	CONTROL	RELAY	ELEVATOR PRIMARY		
L2	M19	CONTROL	RELAY	ELEVATOR SECONDARY		
L2	M20	CONTROL	RELAY	ELEVATOR FIRE HAT		
L2	M24	CONTROL	RELAY	FIRE DOOR RELEASE	STAIRWELL 3	
L2	M120	CONTROL	BELL CIRCUIT	OUTSIDE SPRINKLER	HORN	
L1	M29	CONTROL	RELAY	DOOR RELEASE	CORR 100 F	
SIGNALS						
2		HORN STROBE	H / S	CORRIDOR BY 152		
2		EOL	EOL	CORRIDOR BY 155		
2		HORN STROBE	H / S	CORRIDOR BY 149		
4		HORN STROBE	H / S	BATH 142		
4		HORN STROBE	H / S	CORRIDOR BY 140		
4		STROBE	S	ASSIST BATH 143		
4		HORN STROBE	H / S	JANITOR ROOM		
3		HORN STROBE	H / S	CORRIDOR BY ELEVATOR	100E	
3		HORN STROBE	H / S	ADMIN HALLWAY	130C	
1		HORN STROBE	H / S	CAFETERIA	100E	
1		HORN STROBE	H / S	KITCHEN 104		
1		HORN STROBE	H / S	RECYCLE ROOM		
		HORN STROBE	H / S	OUTSIDE STORAGE	E 101	
1		HORN STROBE	H / S	CORRIDOR BY 106		
1		HORN STROBE	H / S	CORRIDOR BY BTH 106A		
1		HORN STROBE	H / S	BATH 106		
1		HORN STROBE	H / S	TECH ED 108		
1		HORN STROBE	H / S	CORRIDOR BY 114		
1		HORN STROBE	H / S	CORRIDOR BY 117		
1		EOL	EOL	STAIR ST3.1		
1		STROBE	S	WASHROOM 107		
3		HORN STROBE	H / S	BOILER ROOM	E 102	
4		HORN STROBE	H / S	ELECTRICAL ROOM	E 104	
1		HORN STROBE	H / S	LIBRARY	102	
		HORN STROBE	H / S	SPRINKLER ROOM	E 105	
3.3		HORN STROBE	H / S	MECH ROOM 1	235	
3.3		HORN STROBE	H / S	MECH ROOM 2	235	
3.3		EOL	EOL	MECH ROOM	RM 235	
3.3		HORN STROBE	H / S	CORRIDOR BY STAIRS	2ND NORTH	200E
3.3		HORN STROBE	H / S	CORRIDOR MIDDLE	2ND NORTH	200E
3.3		HORN STROBE	H / S	CORRIDOR END	2ND NORTH	200E

SLC or Zn	Add	Type Code	FlashScan Type	Label	Extended Label	Zone Label
SIGNALS-CONTINUED						
3.3		HORN STROBE	H / S	BATHROOM	2ND NORTH	238
3.3		STROBE	S	ASSIST BATH 143	2ND NORTH	237
3.2		HORN STROBE	H / S	LOBBY	2ND EAST	228A
3.2		HORN STROBE	H / S	ART STORAGE	2ND EAST	230A
3.1		HORN STROBE	H / S	COMM ROOM	2ND EAST	234A
3.2		HORN STROBE	H / S	CORRIDOR BY STAIRS	2ND EAST	200B
3.2		HORN STROBE	H / S	STAFF ROOM	2ND EAST	204
3.2		EOL	EOL	STAFF ROOM	2ND EAST	204
3.2		STROBE	S	STAFF ROOM WASHROOM	2ND EAST	204A
3.1		HORN STROBE	H / S	CORRIDOR STAIRS END	2ND WEST	200C
3.1		EOL	EOL	CORRIDOR STAIRS END	2ND WEST	200C
3.1		HORN STROBE	H / S	CORRIDOR MIDDLE	2ND WEST	200B
3.1		HORN STROBE	H / S	FAMILY STUDIES	2ND WEST	210
3.1		HORN STROBE	H / S	FAMILY STUDIES SHOP	2ND WEST	208
3.1		HORN STROBE	H / S	WASHROOM	2ND WEST	206
3.1		HORN STROBE	H / S	GUIDANCE ROOM	2ND WEST	201
		HORN STROBE	H / S	GYM REAR	1RST EAST	133
		HORN STROBE	H / S	GYM FRONT	1RST EAST	133
		HORN STROBE	H / S	MUSIC RM (STAGE)	1RST EAST	131
		HORN STROBE	H / S	STAGE REAR ROOM	1RST EAST	131A
EXTERIOR HORNS						
		HORN STROBE	H / S	BY SPRINKLER ROOM	EXTERIOR	
		HORN STROBE	H / S	REAR GYM	EXTERIOR	
		HORN STROBE	H / S	REAR GYM SIDE	EXTERIOR	
		HORN STROBE	H / S	REAR BY TECH PRODUCTION	EXTERIOR	
		HORN STROBE	H / S	WEST END	EXTERIOR	
		HORN STROBE	H / S	FRONT STORAGE	EXTERIOR	
		HORN STROBE	H / S	FRONT NORTH	EXTERIOR	
		HORN STROBE	H / S	FRONT NORTH PARKING	EXTERIOR	
		HORN	H	FRONT NORTH WALL	EXTERIOR	SPRINKLER

ADDITIONAL

SLC or Zn	Add	Type Code	FlashScan Type	Label	Extended Label	Zone Label
--------------	-----	-----------	----------------	-------	----------------	------------

Lock Down Devices

SLC or Zn	Add	Type Code	FlashScan Type	Label	Extended Label	Zone Label
				SIGNALS CONTINUED		
	2	BOOSTER	U1A-27			
		CIR 1		100H		
		CIR 2		133		
		CIR 3		141A		
		CIR 4		NOT USED		
				1ST FLOOR		
		STROBE	STROBE	NORTH 153 HALL	1ST FLOOR	100H
		EOL	EOL	NORTH 153 HALL	1ST FLOOR	100H
		STROBE	STROBE	NORTH 148 HALL	1ST FLOOR	100H
		STROBE	STROBE	NORTH 142 BATH	1ST FLOOR	142
		STROBE	STROBE	NORTH 145 HALL	1ST FLOOR	142
		STROBE	STROBE	NORTH 141A CUSTODIAL	1ST FLOOR	142
		STROBE	STROBE	EAST 139 HALL	1ST FLOOR	142
		STROBE	STROBE	EAST COMMON BY ELEV.	1ST FLOOR	142
		STROBE	STROBE	EAST KITCHEN 103A	1ST FLOOR	101A
		STROBE	STROBE	EAST RECYCLE RM 101A	1ST FLOOR	101A
		STROBE	STROBE	EAST CAFETERIA	1ST FLOOR	101A
		EOL	EOL	EAST CAFETERIA	1ST FLOOR	101A
		STROBE	STROBE	WEST 104 HALL	1ST FLOOR	108
		STROBE	STROBE	WEST BATH 106	1ST FLOOR	101A
		STROBE	STROBE	WEST HALL 110A	1ST FLOOR	108
		STROBE	STROBE	WEST TECH ED 108	1ST FLOOR	108
		STROBE	STROBE	WEST HALL 114	1ST FLOOR	108
		STROBE	STROBE	WEST HALL 115	1ST FLOOR	108
		STROBE	STROBE	GYM LEFT	1ST FLOOR	133
		STROBE	STROBE	GYM RIGHT	1ST FLOOR	133
		STROBE	STROBE	STAGE	1ST FLOOR	133
		EOL	EOL	HALL 125	1ST FLOOR	133

		STROBE	STROBE	GYM CHANGE AREA 133D	1ST FLOOR	142
		STROBE	STROBE	BOILER RM	1ST FLOOR	141A
		STROBE	STROBE	SPRINKLER RM	1ST FLOOR	133
		STROBE	STROBE	ELECTRICAL RM	1ST FLOOR	141A
		STROBE	STROBE	OUTSIDE STORAGE	1ST FLOOR	141A
				2ND FLOOR		
		STROBE	STROBE	WEST HALL 219	2ND FLOOR	206
		EOL	EOL	WEST HALL 219	2ND FLOOR	206
		STROBE	STROBE	WEST HALL 214	2ND FLOOR	206
		STROBE	STROBE	WEST BATH 206	2ND FLOOR	206
		STROBE	STROBE	WEST HALL 204C	2ND FLOOR	233

SLC or Zn	Add	Type Code	Flash Scan Type	Label	Extended Label	Zone Label
				SIGNALS CONTINUED		
		STROBE	STROBE	EAST MAKER COMMONS 200A	2ND FLOOR	233
		STROBE	STROBE	EAST HALL 233	2ND FLOOR	233
		STROBE	STROBE	NORTH MECH 235 RIGHT	2ND FLOOR	238
		EOL	EOL	NORTH MECH 235 RIGHT	2ND FLOOR	238
		STROBE	STROBE	NORTH MECH 235 LEFT	2ND FLOOR	238
		STROBE	STROBE	NORTH BATH 238	2ND FLOOR	238
		STROBE	STROBE	NORTH HALL 239	2ND FLOOR	238
		STROBE	STROBE	NORTH HALL 241	2ND FLOOR	200E
		STROBE	STROBE	NORTH HALL 247	2ND FLOOR	200E
		STROBE	STROBE	STAFF LOUNGE	2ND FLOOR	233
				EXTERIOR		
		STROBE	STROBE	FRONT ENTRANCE	EXTERIOR	100A
		STROBE	STROBE	NORTH FRONT STAIRWELL	EXTERIOR	100H
		STROBE	STROBE	GYM REAR	EXTERIOR	133
		STROBE	STROBE	PARKING FRONT	EXTERIOR	100H
		SIGN	SIGN	MAIN ENT ABOVE ADMIN	EXTERIOR	

EMEREGNCY LIGHTING	TOTAL
Exit Lights	36
Remote Heads	57
Units	40

	LOCATION:Alderney	Device	Correctly installed	Requires service	Alarm confirmation	Sensitivity reading	Device address or circuit number
	Fire Alarm Panel: Edwards 6616						

MANUAL PULL STATIONS							
1	BY OFFICE	M					ZONE 13
2	PRINCIPALS OFFICE EXIT	M					ZONE 13
3	GRADE 6 CLASS EXIT	M					ZONE 13
4	FRONT RIGHT EXIT	M					ZONE 13
5	EXEL LUNCH EXIT	M					ZONE 13
6	RIGHT REAR EXIT	M					ZONE 13
8	LOWER FLOOR BY RESOURCE	M					ZONE 14
9	LOWER FLOOR BY MUSIC ROOM	M					ZONE 14
10	LOWER FLOOR BY WASHROOMS	M					ZONE 14
11	UPPER FLOOR BY ART ROOM	M					ZONE 3
12	UPPER FLOOR BY MEETING ROOM	M					ZONE 3
13	GYM ENTRY	M					ZONE 4
14	GYM LEFT EXIT	M					ZONE 4
15	GYM RIGHT EXIT	M					ZONE 4
16	GYM HALL	M					ZONE 4
17	BOILER ROOM	M					ZONE 14
SMOKE DETECTORS							
1	CENTER STAIRS	SI					ZONE 3
2	EAST STAIRS	SI					ZONE 3
3	WEST STAIRS	SI					ZONE 3
HEAT DETECTORS							
1	SPRINKLER ROOM	HT					ZONE 13
2	READING RECOVERY ROOM, UP LEVEL	HT					ZONE 3
3	BOYS WASHROOM MAIN FLOOR	HT					ZONE 13
4	GIRLS WASHROOM MAIN FLOOR	HT					ZONE 13
5	OFFICE	HT					ZONE 13
6	ELECTRICAL ROOM	HT					ZONE 2
7	TEACHERS ROOM	HT					ZONE 14
8	JANITORS ROOM	HT					ZONE 14
9	BOYS WASHROOM LOWER FLOOR	HT					ZONE 14
10	GIRLS WASHROOM LOWER FLOOR	HT					ZONE 14
11	MAIN OFFICE HALL	HT					ZONE 13
12	BOILER ROOM	HT					ZONE 14

SPRINKLER DEVICES

1	SPRINKLER ROOM	PS					ZONE 1
2	SPRINKLER ROOM	TS					ZONE 1

NOTIFYING DEVICES

1	UPPER HALL	B					SIG 1
2	UPPER HALL	B					SIG 1
3	UPPER HALL	B					SIG 1
4	MAIN FLOOR	B					SIG 1
5	MAIN FLOOR	B					SIG 1
6	LOWER FLOOR	B					SIG 1
7	LOWER FLOOR	B					SIG 1
8	GYM	B					SIG 1
9	GYM	B					SIG 1
10	GYM HALL	B					SIG 1

END OF LINE RESISTORS

1		EOLR					ZONE 1
2		EOLR					ZONE 2
3		EOLR					ZONE 3
4		EOLR					ZONE 4
5		EOLR					ZONE 13
6		EOLR					ZONE 14

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Remote Head	Ca b. Head	Co ver	Exit Bul b AC /D C	Remarks	Bat. VAH	Man u f.
1	MAIN CORRIDOR							
2	MAIN CORRIDOR BY OFFICE							
3	GYM HALL							
4	GYM							
5	GYM							
6	Boiler Room							

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1	Circuit breakers for the EL are: by main office - panel by office, cct 8; end of main hall - plug; gym lights - gym panel, ccts 20,21 and 22.
---	---

	LOCATION: Bel Ayr Eleementary	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6616		

MANUAL PULL STATIONS

1	BOILER ROOM	M	Zone #2
2	MAIN ENTRANCE	M	Zone #1
3	NORTH WING	M	Zone #3
4	GYM EXIT NORTH	M	Zone #6
5	GYM	M	Zone #4
6	SOUTH WING	M	Zone #5
7	GYM MAIN ENTRANCE	M	Zone #7

SMOKE DETECTORS

1	MAIN LOBBY	S	Zone #1
2	NORTH WING	S	Zone #3
3	SOUTH WING	S	Zone #5
4	GYM EXIT NORTH	S	Zone #6
5	GYM MAIN ENTRANCE	S	Zone #7

HEAT DETECTORS

1	BOILER ROOM	HT	Zone #2
---	-------------	----	---------

NOTIFYING DEVICES

1	MAIN LOBBY	B	Sig #1
2	WEST WING	B	Sig #1
3	EAST WING	B	Sig #2
4	GYM	B	Sig #2

DOOR HOLDERS

1	NORTH EXIT HALL	DH	Aux #1
2	SOUTH EXIT HALL	DH	Aux #1
3	NORTH GYM EXIT	DH	Aux #1
4	NORTH GYM TO HALL EXIT	DH	Aux #1
5	MAIN GYM EXIT HALL	DH	Aux #1

END OF LINE RESISTORS

1	SOUTH WING	EOL	Zone #5
2	BOILER ROOM	EOL	Zone #2
3	NORTH WING	EOL	Zone #3
4	GYM EXIT NORTH	EOL	Zone #6
5	GYM MAIN ENTRANCE	EOL	Zone #7
6	MAIN ENTRANCE	EOL	Zone #1

7	GYM EAST DOOR ABOVE PULL STN	EOL	Zone #4
8	MID NORTH HALL	EOL	Sig Cct 2
9	GYM EAST DOOR ABOVE PULL STN	EOL	Sig Cct 1

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH	Model	Manuf.
1	Main Entrance			6v7.2ah	Combo Unit	
2	Main Lobby			6v7.2ah		
3	Hall BY 103					
4	Exit BY 101				Combo Unit	
5	Hall BY 112					
6	Hall BY 111					
7	Hall BY 107					EX10 W PXM 36/2M
8	HALL BY COMPUTER RM			6v7.2ah		
9	Boiler Room					
10	Hall Exit BY RIGHT GYM ENTRY			6v7.2ah		
11	Hall BY JANITOR ROOM					
12	Girls W/R BY COMPUTER RM					
13	Boys W/R BY COMPUTER RM					
14	Hall Exit BY COMPUTER RM			6v7.2ah		EX10 W PXM 36 V 10
15	Gym North West Exit			6v7.2ah		
16	Gym Back Exit					
17	Gym North Exit					
18	Boys Washroom BY GYM					
19	Girls Washroom BY GYM					

	LOCATION: Brookhouse Fire Alarm Panel: Edwards EST2	Device	Annunciation

MANUAL PULL STATIONS			
1	MAIN ENTRANCE	M	
2	SOUTH EXIT OLD BUILDING	M	
3	SOUTH ENTRANCE BY GYM	M	
4	NORTH ENTRANCE BY GYM	M	
5	GYM EXIT	M	
6	NORTH EXIT OLD BUILDING	M	
7	1ST FLOOR EAST NEW SECTION	M	
8	2ND FLOOR EAST NEW SECTION	M	
9	2ND FLOOR WEST NEW SECTION	M	

HEAT DETECTORS			
1	BOILER RM	RHT	

SPRINKLER DEVICES			
1	BOILER RM CLASS ROOM 12 (ANNEX	TS	
2	BOILER RM CLASS ROOM 12 (ANNEX	PS	

NOTIFYING DEVICES			
1	SOUTH CORR. OLD BUILDING	B	
2	MAIN ENTRANCE	B	
3	GYM	B	
4	NORTH CORR. OLD BUILDING	B	
5	1ST FLOOR NEW BUILDING	B	
6	2ND FLOOR NEW BUILDING	B	

END OF LINE RESISTORS			
	NORTH CORR. OLD BUILDING	EOL	
	2ND FLOOR NEW BUILDING	EOL	

Fire Door Number or Location
BY ROOM 7
BY STAFF ROOM
BY GYM ENTRY(MAIN OFFICE AREA)
BY CANTEEN
BY LIBRARY
BOTT STAIR BY GRADE 5 CLASS
BY CLASS 24

TOP OF STAIRS BY STORAGE DOOR

EMERGENCY LIGHTING INSPECTION REPORT			
Line #	EL UNIT Location	Remote Head	Bat. VAH
1	Main Entrance		6V 12 AH
2	Front Hall BY RM 13		6V 12 AH
3	Front Hall BY RM 15		6V 12 AH
4	BY CUSTODIAN RM		6V 12 AH
5	Front Hall BY RM 9		6V 12 AH
6	Front Hall BY RM 10		6V 12 AH
7	Froth Hall BY MAIN OFFICE		6V 12 AH
8	By Caretaker Office		6V 12 AH
9	Boys Washroom	Y	6V 12 AH
10	Girls Washroom	Y	6V 12 AH
11	Gym LEFT ENTRY		6V 12 AH
12	Gym EXIT		6V 12 AH
13	Gym RIGHT EXIT		6V 12 AH
14	Boiler Rm		6V 12 AH
15	TOP OF Front Stairwell		6V 12 AH
16	BOTTOM OF Front Stairwell		6V 12 AH
17	1st Fl BY ROOM 10		6V 12 AH
18	1st Fl Back Hall BY MUSIC RM		6V 12 AH
19	1st Fl Back HALL BY EXCEL		6V 12 AH
20	1st Fl Boys Washroom Foyer	Y	6V 12 AH
21	Inside 1st Fl Boys Washroom		6V 12 AH
22	Back Stairwell Bottom		6V 12 AH
23	Back Stairwell Top		6V 12 AH
24	BY EXCEL ROOM		6V 12 AH
25	2nd Fl Hall BY GIRLS W/R		6V 12 AH
26	2ND FLOOR Girls Washroom		6V 12 AH
27	2ND FLOOR Girls W/R FOYER	Y	
28	LIBRARY	Y	6V 12 AH
29	Outside Gym South		6V 12 AH
30	By North Washroom		6V 12 AH
31	North Washroom Boys		
32	North Washroom Girls		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS	
---	--

	CCT BREAKERS FOR LIGHTS
--	-------------------------

	North hall on the wall. CCT#11
--	--------------------------------

	South Hall on the wall. CCT#23
--	--------------------------------

	Gym by north exit. CCT#5
--	--------------------------

	1st floor in rear section. CCT#25
--	-----------------------------------

	LOCATION: Caledonia	Device	Device address or circuit number		NOTES

FIRE ALARM PANEL: Edwardss 6616

1ST FLOOR					
MANUAL PULL STATIONS					
1	MAIN ENTRANCE	M		ZN 3	
2	BY ROOM 112	M		ZN 3	
3	SIDE ENTRANCE BY WOOD SHOP	M		ZN 3	
4	BOILER RM	M		ZN 3	
5	REAR ENTRANCE (BY CARETAKERS	M		ZN 3	
6	BY RM 108	M		ZN 3	
SMOKE DETECTORS					
1	BY ROOM 112	SI		ZN 3	
2	BY WOODSHOP	SI		ZN 3	
3	BY RM 104	SI		ZN 3	
4	BY RM 106	SI		ZN 3	
5	BY RM 107	SI		ZN 3	
6	BY ROOM 102	SI		ZN 3	
7	BY OFFICE	SI		ZN 3	
8	BY PRINCIPAL'S OFFICE	SI		ZN 3	
2ND FLOOR					
MANUAL PULL STATIONS					
1	TOP OF MAIN STAIRS BY ROOM 211	M		ZN 4	
2	BY BAND RM 206	M		ZN 4	
3	TOP OF STAIRS ON LANDING	M		ZN 4	
4	TOP OF MAIN STAIRS BY RM 201	M		ZN 4	
SMOKE DETECTORS					
1	BY RM 201	SI		ZN 4	
2	BY RM 202	SI		ZN 4	
3	BY RM 204	SI		ZN 4	
4	BY RM 205	SI		ZN 4	
5	BY FOOD SERVICES RM 207	SI		ZN 4	
6	BY RM 208	SI		ZN 4	
7	BY RM 210	SI		ZN 4	
8	BY RM 211	SI		ZN 4	
9	ELEVATOR SHAFT	SI		ZN 5	NO ACCESS
SPRINKLER DEVICES					
1	SPRINKLER GATE VALVE (IN BOILER	TS	P	ZN 1	
2	SPRINKLER FLOW (IN BOILER RM)	PS	P	ZN 2	
NOTIFYING DEVICES					

1	1ST FLOOR	B	P		
2	1ST FLOOR	B	P		
3	1ST FLOOR	B	P		
4	1ST FLOOR	B	P		
5	1ST FLOOR	B	P		
6	BY OFFICE	B	P		
7	WOODSHOP	B	P		
8	METAL SHOP	B	P		
9	GYM	B	P		
10	2ND FLOOR	B	P		
11	2ND FLOOR	B	P		
12	2ND FLOOR	B	P		
13	2ND FLOOR	B	P		
14	2ND FLOOR	B	P		
15	2ND FLOOR	B	P		
END OF LINE RESISTORS					
	BY RM 108	EOL	P	ZN 3	
	BOILER ROOM	EOL	P	ZN 1	
	BOILER ROOM	EOL	P	ZN 2	
	TOP OF MAIN STAIRS BY RM 201	EOL	P	ZN 4	
	BY RM 107	EOL	P		
EMERGENCY LIGHTING INSPECTION REPORT					
#	EL UNIT Location	Head	b.	VAH	Model
1ST FLOOR					
1	Boiler Rm			6V 7AH	6 PXM 36 R11
2	Main Entrance			6V 4.5AH	6 PXM 36 R11
3	Main Entry By Boys Washroom			6V 7AH	6 PXM 36 R11
4	By Rm 106			6V 12AH	6 PXM 36 R11
5	By Rm 104			6V 7AH	6 PXM 36 R11
6	Woodshop			6V 7AH	6 PXM 36 R11
7	Computer Lab			6V 7AH	6 PXM 36 R11
8	Side Exit By Elevator			6V 7AH	6 PXM 36 R11
9	By Side Exit By Computer Lab			6V 7AH	6 PXM 36 R11
10	By Woodshop			6V 7AH	6 PXM 36 R11
11	Gym Left Of Stage			6V 7AH	6 PXM 36 R11
12	Gym Right Of Stage			6V7AH	6 PXM 36 R11
13	Gym Far Right From Stage			6V 7AH	6 PXM 36 R11
14	Gym Far Left From Stage			6V 7AH	6 PXM 36 R11
15	By Principal's Office			6V 7AH	6 PXM 36 R11
16	By Rm 102			6V 7AH	6 PXM 36 R11
2ND FLOOR					
17	By Rm 211			6V 7AH	6 PXM 36 R11
18	By Rm 201			6V 7AH	6 PXM 36 R11
19	By Rm 202			6V 7AH	6 PXM 36 R11
20	By Rm 204			6V 7.5AH	6 PXM 36 R11
21	By Library			6V 7AH	6 PXM 36 R11

22	By Rm 205			6V 7AH	6 PXM 36 R11
23	By Home Ed			6V 7AH	6 PXM 36 R11
24	By Rm 208			6V 7AH	6 PXM 36 R11
25	By Rm 210			6V 7AH	6 PXM 36 R11

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

REM #1	AC breaker located on the second floor by home ed.
REM #2	AC breaker located in gym panel
REM #3	Must be unplugged in the boiler room

LOCATION:Elenvale	Device	Device address or circuit number	Annunciation

FIRE ALARM PANEL:Edwards FS 502

**LOCATION
MANUAL PULL STATIONS**

1st FLOOR BY MAIN ENTRY	M	1	
1st FLOOR ENTRY BY TROPHY CASE	M	1	
1st FLOOR ENTRY BY GIRLS WASHROOM	M	1	
2nd FLOOR TOP STAIRS BY ROOM 220	M	1	
2nd FLOOR TOP REAR STAIR BY GUIDANCE OFFICE	M	2	
1st FLOOR EXIT BY GYM ENTRANCE	M	2	
1st FLOOR EXIT BY ELECTRICAL ROOM	M	2	

SPRINKLER DEVICES

1st FLOOR BOILER RM SPRINKLER	PS	3	
-------------------------------	----	---	--

NOTIFYING DEVICES

1st FLOOR SOUTH HALLWAY	H/S	SIG 1	
1st FLOOR WEST BY OFFICE	H/S	SIG 2	
1st FLOOR WEST BY ROOM 107	H/S	SIG 2	
1st FLOOR MUSIC RM	H/S	SIG 2	
1st FLOOR NORTH HALLWAY BY RM 110	H/S	SIG 1	
1st FLOOR WOOD SHOP	H/S	SIG 2	
1st FLOOR EAST BY RM 116	H/S	SIG 1	
1st FLOOR EAST BY RM 117	H/S	SIG 2	
1st FLOOR GYM	H/S	SIG 2	
2nd FLOOR NORTH HALLWAY	H/S	SIG 2	
2nd FLOOR EAST BY RM 215	H/S	SIG 2	
2nd FLOOR S/E HALLWAY	H/S	SIG 1	
2nd FLOOR SOUTH HALLWAY	H/S	SIG 1	
2nd FLOOR WEST BY RM 201	H/S	SIG 2	
2nd FLOOR WEST BY RM 204	H/S	SIG 2	

EMERGENCY LIGHTING

Line #				
	EL UNIT Location	Remote Head	Cab. Head	Bat. Cov. VAH
1	1st Floor South Hall			

2	1st Floor Bottom South Stair				
3	1st Floor West by rm 104				
4	1st Floor West by rm 106				
5	1st Floor West by rm 108				6V 12Ah
6	1st Floor Gym S/E(BY GYM OFFICE)				6V /5Ah
7	1st Floor Gym S/W				
8	1st Floor Gym N/E				
9	1st Floor Gym N/W				
#	1st Floor Boiler Rm				
#	1st Floor Music Rm				6V / 5Ah
#	1st Floor BY MUSIC ROOM				
#	1st Floor North Hall				
#	1st Floor Wood Shop				6V / 5Ah
#	1st Floor N/E Exit				
#	1st Floor East by gym entry				
#	1st Floor East by rm 114				6V/12Ah
#	1st Floor East by rm 116				
	1st Floor Male Washroom				
	1st Floor Female Washroom				
#	2nd Floor Top South Stair				
#	2nd Floor South Hall				6V / 12Ah
#	2nd Floor West by rm 201				6V / 12Ah
#	2nd Floor West by rm 202				
#	2nd Floor West by rm 204				6V / 12Ah
#	2nd Floor North Hall N/E				
#	2nd Floor Top North Stair				
#	2nd Floor North Hall by 206				
#	2nd Floor Rm 212 Exit				
#	2nd Floor Rm 211 Exit				
#	2nd Floor East by rm 215				
#	2nd Floor East by rm 216				6V /12Ah
#	2nd Floor East by rm 219				

Beaker Panel # 6 by FACP . Cct # 31 controls units # 1, 2, 3, 4, 5, 12, 13, 15, 16, 17, 18

Breaker Panel # 10 Cct # 8 controls units # 6, 7, 8, 9

Breaker Panel # 4 Cct # 42 controls units # 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31

Boiler room (10) , Music room (11) , and Wood shop (14) are not on marked breakers. Need to be checked locally at unit

Fire Door Number or Location

1ST FL BY FACP

1ST FL BY RM 105 / ***Only one side

1ST FL BY RM 110

1ST FL BY RM 110

1ST FL BY INDUSTRIAL ARTS ENTRY

1ST FL BY RM 114 /***Only one side

1ST FL BY GIRLS WASHRM/ TROPHY

2ND FL BY RM 202

2ND FL BY RM 206

2ND FL ACCESS TO RMS 211& 212

2ND FL BY RM 214

2ND FL BY RM 218

3ND FL BY JANITOR RM

2ND FL BY RM 220

		Device	Device address or circuit number	NOTES
LOCATION: Eric Graves Memorial				
FIRE ALARM PANEL: Siemans TXL				
1000				

MANUAL PULL STATIONS				
1	MAIN ENTRANCE	M	Zone #1	
2	BOTTOM OF RAMP	M	Zone #1	
3	EAST EXIT	M	Zone #1	
4	BY ROOM 112 (COMPUTER LAB) Tech	M	Zone #1	
5	2ND FLOOR BY ROOM 214	M	Zone #2	
6	2ND FLOOR BY STAIRS	M	Zone #2	
7	GYM(BY GIRLS LOCKER ROOM)	M	Zone #3	MS-301C
8	GYM(STORAGE LEFT)	M	Zone #3	
9	GYM(STORAGE RIGHT)	M	Zone #3	
SMOKE DETECTORS				
1	EAST STAIRS	S	Zone #2	
2	WEST STAIRS	S	Zone #2	
HEAT DETECTORS				
1	WOODSHOP STORAGE	HT	Zone #1	
2	FAN ROOM 1	HT	Zone #2	
3	FAN ROOM 2	HT	Zone #2	
4	ELECTRICAL ROOM	HT	Zone #4	
5	BOILER ROOM	HT	Zone #5	
DUCT SMOKE DETECTORS				
1	FAN ROOM 1	DS	Zone #6	
2	FAN ROOM 2	DS	Zone #7	
SPRINKLER DEVICES				
1	WOODSHOP STORAGE	PS	Zone #8	
NOTIFYING DEVICES				
1	1ST FLOOR	B	Sig #1	
2	1ST FLOOR	B	Sig #1	
3	1ST FLOOR	B	Sig #1	
4	1ST FLOOR	B	Sig #1	
5	1ST FLOOR	B	Sig #1	
7	GYM	B	Sig #1	
8	COMPUTER ROOM	B	Sig #1	
9	WOODSHOP	B	Sig #1	
10	2ND FLOOR EAST	B	Sig #2	
11	2ND FLOOR EAST	B	Sig #2	
12	2ND FLOOR WEST	B	Sig #2	

END OF LINE RESISTORS					
1	2ND FLOOR WEST	EOL	Sig #2		
2	FAN ROOM 2	EOL	Zone #7		
3	1ST FLOOR	EOL	Sig #1		
4	FAN ROOM 1	EOL	Zone #6		
5	BOILER ROOM	EOL	Zone #5		
6	ELECTRICAL ROOM	EOL	Zone #4		
7	GYM	EOL	Zone #3		
8	EAST EXIT	EOL	Zone #1		
9	2ND FLOOR	EOL	Zone #2		
10	SPRINKLER CAGE	EOL	Zone #8		
EMERGENCY LIGHTING					
#	EL UNIT Location	Head	Head	MOD #	VAH
1	Main Entrance			Combo Unit	6V / 7.2Ah
2	Main Entrance Double Doors			Combo Unit	
3	Main Office				
4	Staff Room				
5	By Room 110			Lumacell	
6	By Room 112			Combo Unit	6V / 4.5Ah
7	East Exit				
8	By Room 215				6V / 7.2Ah
9	By Room 209				6V / 4.5Ah
10	By Room 207				6V / 7.2Ah
11	By Room 201				6V / 7.2Ah
12	Exit by Food Window				
13	Hallway by Room 102				
14	Gym Stage Back Hall				
15	By Room 105 Double Doors				6V / 7.2Ah
16	Exit by Bottom of Ramp				6V / 4.5Ah
17	1st Floor pipe chase rm by trophies				6V / 4.5Ah
18	*Boys Washroom	YES			
19	*Boy's Lockerroom	YES			
20	1st Floor pipe chase rm by trophies				6V / 4.5Ah
21	*Girl's Lockerrroom	YES			
22	*Girls Washroom	YES			
23	2nd Flr Batt Pack in Jani rm by 215				
24	*West Stairs	YES			
25	*By Room 212	YES			
26	*Gym, LEFT OF STAGE	YES			
29	1st Floor pipe chase rm by trophies				12V / 32Ah
30	*Across from Closet	YES			
31	*By 2nd Floor Girls Washroom	YES			
32	*By Room 208	YES			

33	*Middle of Ramp	YES			
34	*Gym	YES			
35	*By Room 104	YES			
36	2nd Floor East Battery Pack				12V / 32Ah
37	*East Stairs	YES			
38	*2nd Floor East Hall	YES			
39	*Top of Ramp	YES			
27	*Electrical Room	YES			
28	*Boiler Room	YES			
29	Bottom of Stairs by 112				
30	Service Room				
31	Service Room				
32	Gym Stage				
33	Back Stage				

FIRE ALARM NOTES AND RECOMMENDATIONS

- 1 6' Ladder Required to Access Heat Detector in Fan Room # 2
- 2 Actually need to stand on AHU to access Heat Detector in Fan Room # 1

	LOCATION: Ian Forsyth	Device	Device address or circuit number
	Fire Alarm Panel: Edwards EST 2		
MANUAL PULL STATIONS			
1	GYM LEFT EXIT	MA	207
2	GYM RIGHT EXIT	MA	205
3	BY JANITOR'S RM 113	MA	204
4	MAIN ENTRANCE	MA	203
5	WEST HALL BY RM 134	MA	
6	BY ROOM 121	MA	211
7	BY ROOM 144	MA	210
8	SECOND FLOOR NORTH EXIT BY RM 208	MA	
9	GYM RIGHT EXIT BY JANITOR'S ROOM	MA	
10	BY ROOM 200	MA	209
11	INSIDE GYM	MA	206
SMOKE DETECTORS			
1	HALL BY MUSIC ROOM	SA	105
2	HALL EXIT BY ROOM 122	SA	101
3	GYM EXIT BY ROOM 125	SA	102
4	CENTER HALL	SA	103
5	BY JANITOR'S ROOM	SA	106
6	BY LIBRARY	SA	107
7	EXIT BY ROOM 144	SA	109
8	STAIRWAY EXIT BY ROOM 200	SA	110
9	SPRINKLER ROOM	SV	214
10	STAIR BY ROOM 208	SA	108
11	TEACHERS WORK SHOP	SA	104
HEAT DETECTORS			
1	FURNACE ROOM	RHTA	112
2	KITCHEN IN GYM	H	111
SPRINKLER DEVICES			
1	SPRINKLER ROOM	PS	215
2	SPRINKLER ROOM	SV	214
NOTIFYING DEVICES			
1	GYM	B	SIG 1
2	MAIN ENTRANCE	B	SIG 1

3	MAIN CORRIDOR NORTH	B	SIG 1
4	MAIN CORRIDOR NORTH	B	SIG 1
5	FIRST FLOOR	B	SIG 1
6	SECOND FLOOR	B	SIG 1

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH
PANEL "B", BY RM 116 ,CCT # 23				
1	MAIN ENTRANCE			
2	OUT SIDE RM 104			
3	BY ROOM 117			
4	BY ROOM 119			
PANEL "B", BY RM 138, CCT#24				
5	BY ROOM 141			
	GIRLS WASHROOM 142	YES		
	BOYS WASHROOM 139			
6	ABOVE ROOM 108			
	GIRLS WASHROOM 106	YES		
	BOYS ROOM 111	YES		
PANEL "D", IN GYM ,CCT#4&15				
7	CORR BY ROOM 125	YES		
	BOYS ROOM 125			
	GIRLS ROOM 123			
8	GYM ENTRY LEFT(IN CORR)			
9	GYM ENTRY RIGHT(IN CORR)			
10	GYM ENTRY LEFT			
11	GYM ENTRY RIGHT			
12	GYM EXIT			
PANEL "A", BY RM 128, CCT#23				
	BY RM 127			6V 7AH
	BY RM 131			
	BY ROOM 135			
	BY ROOM 137			
PANEL "A", BY RM 201, CCT#27				
	BY ROOM 202			
	INDEPENDENT			
	2ND FLOOR JANITOR RM206			6V 12AH
	TOP OF STAIRS	YES		
	TOP OF STAIRS	YES		
	1ST FLOOR JANITOR RM141	UNIT		6V 12AH
	BOTTOM OF STAIRS	YES		

	BOYS WASHROOM 1ST FLOOR	YES		
	GIRLS WASHROOM 1ST FLOOR	YES		
	BOILER ROOM			6V 5AH

	LOCATION: Admiral Westphall	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex 4100U		

MANUAL PULL STATIONS			
1	BOILER RM NORTH WALL	M	ZN 2
2	SOUTHWEST EXIT OUTSIDE GYM (SOUTH)	M	ZN 3
3	GYM EXIT (SOUTHWEST)	M	ZN 3
4	GYM EXIT (NORTHWEST)	M	ZN 3
5	NORTHWEST EXIT	M	ZN 1
6	QUAD EXIT (BY OFFICE)	M	ZN 1
7	NORTHEAST HALLWAY EXIT	M	ZN 1
8	EAST STAIRWELL EXIT	M	ZN 6
9	WEST EXIT OUTSIDE GYM (NORTH)	M	ZN 6
10	NORTHWEST STAIRWELL EXIT	M	ZN 4
11	SOUTHEAST HALLWAY	M	ZN 5
SMOKE DETECTORS			
1	ELEVATOR MACHINE RM	STA	M1-2
2	ELEVATOR SHAFT	STA	M1-1
DUCT SMOKE DETECTORS			
1	FAN RM # 1 EAST (ENTRANCE IN LIBRARY)	DS	ZN 8
2	FAN RM # 2 WEST (ENTRANCE IN LIBRARY)	DS	ZN 8
HEAT DETECTORS			
1	LIBRARY SERVICES CLOSET	RHT	ZN 1
2	LIBRARY SERVICES STORAGE	RHT	ZN 1
3	COPY RM	RHT	ZN 1
4	BOILER RM NORTH CEILING	RHT	ZN 2
5	BOILER RM SOUTH CEILING	RHT	ZN 2
6	BOILER RM ELECTRICAL VAULT (LOCKED BY NSPC)	RHT	ZN 2
6	MAIN ELECTRICAL ROOM	RHT	ZN 2
7	GYM OFFICE	RHT	ZN 3
8	NORTHWEST STAIRWELL	HT	ZN 4
9	BOOK RM	RHT	ZN 5
10	LIBRARY STORAGE/ #1	HT	ZN 5
11	LIBRARY STORAGE/ #2	RHT	ZN 5
12	FAN RM # 1 EAST (ENTRANCE IN LIBRARY)	RHT	ZN 5
13	FAN RM # 2 WEST (ENTRANCE IN LIBRARY)	RHT	ZN 5
14	SOUTHEAST STAIRWELL	HT	ZN 5
15	CARETAKER'S CLOSET	HT	ZN 5

16	GYM STORAGE	RHT	ZN 6
17	CARETAKER'S STORAGE/ 1ST FLOOR	HT	ZN 6
18	ART RM STORAGE	RHT	ZN 6

SPRINKLER DEVICES

1	BOILER RM SPRINKLER TREE	PS	ZN 7
2	ELEVATOR PIT VALVE	SV	M1-4
3	ELEVATOR SHAFT VALVE	SV	M1-6
4	ELEVATOR PIT WATER FLOW	FSV	M1-3
5	ELEVATOR SHAFT WATER FLOW	FSV	M1-5

NOTIFYING DEVICES

1	BSMT BOILER RM	B	SIG
2	BSMT BOILER RM	B	SIG
3	NORTH HALLWAY 1ST FL EAST	B	SIG
4	NORTH HALLWAY 1ST FL WEST	B	SIG
5	ARTS EAST 1ST FLR	B	SIG
6	ARTS WEST 1ST FLR	B	SIG
7	SOUTH HALLWAY 1ST FL	B	SIG
8	GYM NORTHEAST	B	SIG
9	SOUTHWEST GYM ENTRANCE	B	SIG
10	QUAD ENTRANCE	B	SIG
11	SOUTH HALLWAY 2ND FL	B	SIG
12	NORTH HALLWAY 2ND FL	B	SIG
13	WOODSHOP	B	SIG

END OF LINE RESISTORS

1	BOILER RM ELECTRICAL VAULT (LOCKED BY NSPC)	EOL	ZN 2
2	BOILER RM SPRINKLER TREE	EOL	ZN 7
3	WEST EXIT OUTSIDE GYM (NORTH)	EOL	ZN 6
4	GYM	EOL	ZN 3
5	NORTHWEST EXIT (STAIRWELL) to parking lot	EOL	ZN 1
6	NORTHWEST STAIRWELL EXIT by elevator	EOL	ZN 4
7	SOUTHEAST STAIRWELL EXIT	EOL	ZN 5
8	FAN RM # 2 WEST (ENTRANCE IN LIBRARY)	EOL	ZN 8

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Model
1	1ST FL CARETAKER'S RM		EMERGI-LITE
14	CORRIDOR BY ROOM 10	Y	REMOTE
4	GYM	Y	REMOTE
5	CORRIDOR BY GYM	Y	REMOTE
6	MAIN ENTRANCE	Y	REMOTE
2	LUNCH RM # 2 CLOSET		EMERGI-LITE
13	CORRIDOR BY ROOM 8	Y	REMOTE

7	CORRIDOR BY LUNCH RM	Y	REMOTE
8	SOUTH STAIRWELL	Y	REMOTE
3	BOILER RM		EMERGI-LITE
9	TOP OF NORTH STAIRS	Y	REMOTE
10	BOTTOM NORTH STAIRS	Y	REMOTE
11	GYM STORAGE by MUSIC		UNIT
Fire Door Number or Location			
MAIN FLOOR BY SIDE ENTRANCE			
CORRIDOR BY JANITORS ROOM			
CORRIDOR BY MAIN OFFICE			
MAIN FLOOR BY ELEVATOR			
2ND FLOOR BY ELEVATOR			
2ND FLOOR BY ROOM 24 / 19			
2ND FLOOR BY LIBRARY			

		Device	Device address or circuit number
	LOCATION: Michael Wallace		

FIRE ALARM PANEL: Edwards FS

MANUAL PULL STATIONS

1	1ST FLOOR BY ROOM 30	M	ZONE 5
2	1ST FLOOR BY ROOM 18	M	ZONE 5
3	2ND FLOOR BY ROOM 15 (library)	M	ZONE 4
4	MAIN ENTRANCE mid stair	M	ZONE 4
5	NORTH EAST STAIR EXIT	M	ZONE 4
6	GYM EXIT LEFT SIDE STAGE	M	ZONE 2

HEAT DETECTORS

1	KITCHEN IN GYM	RHT	ZONE 5
2	1ST FLOOR STORAGE ROOM IN GYM	RHT	ZONE 5
3	1ST FLOOR JANITORS ROOM / SPRINKLER ROOM	RHT	ZONE 5
4	2ND FLOOR JANITORS ROOM BY GIRLS WASHROOM	RHT	ZONE 5
5	2ND FLOOR STORAGE ROOM BY BOYS W/R	RHT	ZONE 5
6	1ST FLOOR STORAGE IN BOYS WASHROOM	RHT	ZONE 5
7	BOILER ROOM	HT	ZONE 3
8	BOILER ROOM	HT	ZONE 3
9	VICE PRINCIPAL OFFICE	RHT	ZONE 4
10	STAFF KITCHEN	RHT	ZONE 4
1	ROOM 29A	RHT	ZONE 5

SPRINKLER DEVICES

1	SPRINKLER ALARM	FSP	ZONE 1 or 13
---	-----------------	-----	--------------

NOTIFYING DEVICES

1	1ST FLOOR BY ROOM 15	B	SIG 1
2	1ST FLOOR BY ROOM 13	B	SIG 1
3	1ST FLOOR BY ROOM 10	B	SIG 1
4	GYM	B	SIG 1
5	GYM EXIT	B	SIG 1
6	2ND FLOOR BY FACP	B	SIG 2
7	2ND FLOOR BY OFFICE	B	SIG 2
8	2ND FLOOR BY ROOM 8	B	SIG 2

END OF LINE RESISTORS

1	1ST FLOOR BY ROOM 15	EOL	
2	2ND FLOOR BY ROOM 15 (library)	EOL	SIG 2
3	GYM REAR EXIT	EOL	ZONE 2
4	SPRINKLER ROOM ENTRY / RM # 22	EOL	ZONE 1
5	BOILER ROOM	EOL	ZONE 3
6	GYM EXIT	EOL	SIG 1

EMERGENCY LIGHTING

Line #	EL UNIT Location	Cab. Head	MOD #	Manuf.
1	2nd Floor Main Entrance	Y	HX S W 3 R120	Lithonia,
2	2nd Floor BY FIRE PANEL	Y	HX S W 3 R120	Lithonia,
3	2nd Floor Hall BY BOYS WASHROOM	Y	06DEL3 6	Emergi-Lite
4	2nd Floor BY LIBRARY	Y	HX S W 3 R120	Lithonia,
5	1st Floor BY GYM ENTRY	Y	HX S W 3 R120	Lithonia,
7	1st Floor BY ROOM 16	Y	HX S W 3 R120	Lithonia,
8	Gym	Y	HX S W 3 R120	Lithonia,
9	By room 24	Y		
9	Gym	Y	HX S W 3 R120	Lithonia,
10	PORTABLE		Exit Combo	
11	PORTABLE		Exit Combo	

Fire Door Number or Location

UPPER FL BY TEACHER'S LOUNGE
UPPER FL BY MAIN OFFICE
UPPER FL BY LIBRARY
1ST FL BY ROOM 28
1ST FL BY ROOM 26 /NE STAIRWELL
1ST FL BY FURNACE RM

	LOCATION: Mount Edward	Device	Device address or circuit	
--	-------------------------------	---------------	----------------------------------	--

FIRE ALARM PANEL: Simplex 4010

Devices

2	FRONT ENTRANCE	M	M1-1	
3	SOUTH WING EXIT	M	M1-3	
4	ENTRANCE BY GYM SOUTH	M	M1-2	
5	NORTH HALL EXIT BY ROOM 1	M	M1-5	
6	SOUTH HALL TO GYM	M	M1-4	
7	TEACHERS ROOM	HT	M1-12	
8	JANITOR CLOSET BY WASHROOMS	HT	M1-10	
9	JANITOR CLOSET BY OFFICE	HT	M1-11	
12	BOILER ROOM	M	M1-8	
13	BOILER ROOM	HT	M1-9	
16	GYM EXIT	M	M1-7	
17	SOUTH CENTER EXIT	M	M1-6	

Signals

21	BOILER ROOM	B	SIG 1	
22	BY ROOM 5	B	SIG 1	
23	BY COMPUTER LAB	B	SIG 1	
24	BY CARETAKERS OFFICE	B	SIG 1	
25	GYM	B	SIG 1	
26	BY ROOM 5	EOL	SIG 1	
28	BY ROOM 12	B	SIG 2	
29	BY ROOM 12	EOL	SIG 2	

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Manuf.
1				
2	BY CARETAKERS OFFICE			Lite,
3	By Room 15			RG36-
4	By Room 11			Lite,
5	Boys Washroom			RG36
6	Girls Washroom			RG36
7	By Milk Fridge			Lite,
8	Main Entrance			RG36-
9	Boiler Room			Lite,

10	Gym North			RG36-
11	Gym South			RG36-
12	Gym Exit Doors			RG36-
13	Exit By Art Storage			Lite,
14	Boys Washroom			RG36
15	Girls Washroom			RG36
16	By Room 8			Lite,
17	By Room 6			M636
18	By Room 1			RG36-
19	By Computer Lab			Lite,

Fire Door Number or Location
BY READING RESOURCE CENTER
NORTH END EXIT
SOUTH END EXIT
BY JANITORS OFFICE

LOCATION:Woodlawn	Device	Device address or circuit	Annunciation
--------------------------	---------------	--	---------------------

ALARM PANEL:Edwards EST 2

VOCATIONAL SCHOOL EXIT	M	214	
ACROSS FROM GYM	M	213	
BY RM 119	M	212	
BY RM 114	M	210	
ENTRANCE AREA BY PHONES	M	223	
BY RM 118	M	207	
BY RM 121	M	206	
BY RM 124	M	205	
OUTSIDE CAFETERIA	M	204	
WORKSHOP 124	M	239	
1ST FL. NORTH WING MECH. RM.	M	224	
1ST FL. EXIT TO OFFICE	M	249	
1ST FL. MAIN ENTRY	M	248	
EXIT TO QUAD	M	221	
INSIDE NEW GYM	M	211	
MAIN ELECTRICAL RM (GYM STORAGE AREA)	S	118	
JANITOR STORE ROOM UNDER STAIRS	S	108	
1ST FL.NORTH WING MECH RM	S	120	
1ST FL.NORTH WING MECH RM DUCT	DS	119	
KITCHEN	RHT	117	
EQUIPMENT RM	HT		
1ST FL.NORTH WING MECH RM	RLY	225	

TOP OF MAIN STAIRS	M	220	
BY RM 214	M	215	
BY RM 218	M	216	
BY RM 225	M	217	
ACROSS FROM RM 229	M	218	
BY LIBRARY HALL	M	219	
EXIT , RIGHT STAGE AUDITORIUM	M	209	
EXIT , LEFT STAGE AUDITORIUM	M	208	
WORKSHOP 124	M	239	
BY ROOM 210	S	116	
BY RM 211	S	115	
STAFF LOUNGE,2ND FLOOR	S	113	
BY BOYS WASHROOM, 2ND FLOOR	S	114	

ELEVATOR SHAFT	S		
STORAGE RM LEFT, AUDITORIUM	S	109	
STORAGE RM RIGHT, AUDITORIUM	S	111	
CURTAIN MOTOR ROOM, AUDITORIUM	S	110	
Hall by STAIRWELL 3	S	126	
1ST FLOOR HOTWATER STORE ROOM	S	104	
ELECTRICAL ROOM 3 160	S	122	
1ST FLOOR ELECTRICAL ROOM ADJ. JANITORS CLOSET	S	121	
FOOTBALL STORAGE RM.	S	105	
FOOTBALL STORAGE RM.	S	110	
MECH. ROOM 1ST FLOOR CENTRE	RHT	103	

BY RM 109	B	SIG 1	
BY RM 104	B	SIG 1	
ACROSS FROM GYM	B	SIG 1	
BY RM 119	B	SIG 1	
BY RM 114	B	SIG 1	
ENTRANCE BY PHONES	B	SIG 1	
BY RM 116	B	SIG 1	
BY RM 118	B	SIG 1	
BY RM 121	B	SIG 1	
BY RM 124	B	SIG 1	
OUTSIDE CAFETERIA	B	SIG 1	
BY 1986 CLASS PLAQUE	B	SIG 1	
GYM A	B	SIG 1	
GYM B	B	SIG 1	
AUDITORIUM	B	SIG 1	
AUDITORIUM	B	SIG 1	
BY RM 210	B	SIG 2	
BY RM 204	B	SIG 2	
BY RM 212	B	SIG 2	
BY RM 214	B	SIG 2	
BY RM 218	B	SIG 2	
BY RM 221	B	SIG 2	
BY RM 225	B	SIG 2	
ACROSS FROM RM 229	B	SIG 2	
OUTSIDE SCIENCE DEPT	B	SIG 2	
ACROSS FROM RM 232	B	SIG 2	
BY FIRE PANEL FRONT ENT.	B	SIG 2	

OUTSIDE CAFETERIA	EOL	SIG 1	
BY RM 214	EOL	SIG 2	

SPRINKLER DEVICES

1ST FLOOR NORTH SUPERVISORY	GV	228
1ST FLOOR NORTH	FLOW	229
2ND FLOOR SPRINKLER ROOM SUPERVISORY	GV	230
2ND FLOOR SPRINKLER ROOM	FLOW	231
1ST FLOOR SHOPS CORRIDOR	GV	237
1ST FLOOR SHOPS CORRIDOR	FLOW	238
1ST FLOOR EXISTING WING SPRINKLER ROOM	GV	226
1ST FLOOR EXISTING WING SPRINKLER ROOM	FLOW	227
NORTH RISER & EXISTING WING	FLOW	234
NORTH RISER EXISTING WING	GV	235
SPRK. RM. MAIN GATE VALVE TO NORTH RISER	GV	236

ADDITIONS

ELEVATOR MACH ROOM	S	127	SIGA-PS
ELEVATOR MACH ROOM	RLY	245	SIGA-CR
ELEVATOR MACH ROOM	RLY	246	SIGA-CR
ELEVATOR MACH ROOM	RLY	247	SIGA-CR

EMERGENCY LIGHTS

Unit Location	# of	Model
---------------	------	-------

Unit #	Location	# of Heads	Model
	ELECTRICAL PANEL BY MAIN OFFICE LEV 1 CCT 21 CONTROLS LIGHTS 6, 23, 24, 27		
5	HALLWAY 101-109		
6	HALLWAY 110-120		
23	MAIN ENTRANCE LEFT SIDE		
24	MAIN ENTRANCE RIGHT SIDE		
57	OPPOSITE GYM ENTRANCE BY 109A		
	ELECTRICAL PANEL BY ROOM 110, CCT #25 CONTROLS LIGHT #7		
7	ACROSS FROM 113		
	ACROSS FROM 110		
	ELECTRICAL PANEL ACROSS FROM ROOM 116, CCT#33 CONTROLS LIGHTS 10, 11, 12 & 59		
10	ACROSS FROM ENGLISH DEPT OFFICE		
11	ACROSS FROM 116		
12	ACROSS FROM 119		
59	ART CTR EXIT BY VENDING MACHINE		
	ELECTRICAL PANEL		

	IN OLD GYM, CCT CONTROLS LIGHTS 64 & 65		
64	OLD GYM FRONT ENTRY		
65	OLD GYM SIDE EXIT TO CORRIDOR		
	ELECTRICAL PANEL BY ROOM 112, CCT #38 CONTROLS LIGHTS 14, 15, 16 & 17		
13	ABOVE JANITOR ROOM		
14	BY ROOM 123		AIMLITE
15	ACROSS FROM STAFF W/R		
16	BY ROOM 126		REMOTE
17	OUTSIDE CAFETERIA		AIMLITE
	ELECTRICAL PANEL IN BOILER ROOM CCT #5, CONTROLS LIGHTS 62 & 63		
62	BOILER ROOM		
63	BOILER ROOM BY EXIT		

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	ELECTRICAL PANEL IN JANITORS ROOM BY BOILER ROOM,		

	CCT 6, CONTROLS LIGHTS 21 & 22		
21	W/R'S	2	REMOTE
22	ELECT.RM	2	UNIT
	ELECTRICAL PANEL BY ROOM 106 CONTROLS		
2	NSCC EXIT (2) BY ROOM 101		
3	BY ROOM 104		
	ELECTRICAL PANEL BY ROOM 217 CCT #39 CONTROLS LIGHTS 42 & 43		
42	ACROSS FROM 214		
43	ACROSS FROM 217		
	ELECTRICAL PANEL ACROSS FROM ROOM 226, CCT 12 CONTROLS LIGHTS 44, 45 & 60		
44	ACROSS FROM 220		
45	ACROSS FROM 223		
60	SUNNYSIDE STAIR BY ROOM 225		
	ELECTRICAL PANEL BY ROOM 232, CCT 5 CONTROLS LIGHTS 46, 47, 53 & 54		
46	SUMMERSIDE STAIR BY 231		
47	SUMMERSIDE		

	STAIRWELL		
53	BY ROOM 230		
54	BY ROOM 232		
	ELECTRICAL PANEL ACROSS FROM LIBRARY CCT #13 CONTROLS LIGHTS 48, 49, & 50		
48	ACROSS FROM 227		
49	ACROSS FROM 228		
50	ACROSS FROM LIBRARY		
	ELECTRICAL PANEL OUTSIDE CAFETERIA CCT		
18	IN CAFETERIA FRONT EXIT		
19	IN CAFETERIA CENTRE EXIT		
20	IN CAFETERIA REAR EXIT		

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	C
	ELECTRICAL PANEL IN AUDITORIUM CCT #26 CONTROLS ALL REMOTE HEADS AT TOP OF CEILING AUDITROIUM			
	AUDITORIUM HALLS RIGHT	REMO TES		

	AUDITORIUM HALL LEFT	REMO TES		
	ELECTRICAL PANEL BY ROOM 206, CCT #32 CONTROLS LIGHTS 2, 38, 29, 40, 51, & 52			
38	TOP OF STAIR BY ROOM 201			
39	BY ROOM 204			
41	BY ROOM 212			
40	BY ROOM 208			
51	CENTRE STAIR TO RMS 232-225			
56	STAFFROOM			
	HALLWAY ROOM 232- 225			
52	BOTTOM OF STAIRS BY 232-225			
	SUNNYSIDE STAIR BY RM 225			
	INDEPENDENT			
25	AUDITOIUM LEFT OF STAGE			
26	AUDITORIUM RIGHT OF STAGE			
27	AUDITORIUM LR LEFT SIDE DOOR			
28	AUDITORIUM CTR SIDE DOOR			
29	AUDITORIUM UPPER OUTTER RIGHT			

	DOORS		
30	AUDITORIUM UPPR RIGHT FAR EXIT		
31	AUDITORIUM UPPR LEFT INNER EXIT		
32	AUDITORIUM UPR LEFT FAR EXIT		
33	REAR STAGE LEFT CORRIDOR		
34	REAR STAGE RIGHT CORRIDOR		
64	AUDITORIUM REAR CENTRE EXIT		
	ELECTRICAL ROOM OFF GYM (NEW)	2	EMERGILIT E
	ELECTRICAL ROOM OFF GYM (NEW) BACK		LUMACELL (BATTERY PACK)
	NEW GYM		EXIT

Location	Model	
NEW GYM	EXIT	FED OFF BATTERY PK ELECTRICAL RM
LED	REMOTE	FED OFF BATTERY PK ELECTRICAL RM
LED	REMOTE	FED OFF BATTERY PK ELECTRICAL RM
LED	REMOTE	FED OFF BATTERY PK ELECTRICAL RM
LED	REMOTE	FED OFF BATTERY PK ELECTRICAL RM
LED	REMOTE	FED OFF BATTERY PK

	REMOTE	ELECTRICAL RM
LED	REMOTE	FED OFF BATTERY PK ELECTRICAL RM
LED	REMOTE	FED OFF BATTERY PK ELECTRICAL RM
FRONT OFFICE ENTRANCE	UNIT (LED TYPE)	BREAKER 4 PANEL 1105
FRONT MAIN ENTRANCE R	REMOTE (LED)	
FRONT MAIN ENTRANCE L	REMOTE LED	
MAIN OFFICE	LED UNIT	BREAKER 10 PANEL 1105 CLOSET BY EXIT
MAIN OFFICE	LED UNIT	
2ND FLOOR BOYS WASHROOM NEAR RM 228	AIMLITE	
2ND FLOOR BOYS WASHROOM NEAR RM 228	REMOTE	
2ND FLOOR GIRLS WASHROOM	AIMLITE	
2ND FLOOR GIRLS WASHROOM	REMOTE	
2ND FLOOR GIRLS WASHROOM BY RM 232	AIMLITE	
2ND FLOOR GIRLS WASHROOM BY RM 232	REMOTE	
2ND FLOOR BOYS	AIMLITE	

WASHROOM BY 232	
2ND FLOOR BOYS WASHROOM BY 232	REMOTE
FRONT LEFT STAIR	EXIT COMBO
1ST FLOOR GIRLS WASHROOM NEAR RM 109A (GYM)	AIMLITE + REMOTE 2H
1ST FLOOR BOYS WASHROOM NEAR RM 109A (GYM)	AIMLITE + REMOTE 2H
WORKSHOP RM 124	AIMLITE
INDUSTRIAL ARTS RM 125	AIMLITE
OLD GYM	LED REMOTE
CORRIDOR BY BOILER RM	AIMLITE

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
76	HOME EC. 127		AIMLITE
	GYM LOCKER ROOM	2	AIMLITE
	GYM LOCKER ROOM	2R	REMOTE
	GYM LOCKER ROOM	2R	REMOTE
	ELECTRICAL ROOM IN MECH ROOM		

Fire Door Number or Location
BOTTOM STAIR BY CAFETERIA ENTRY

ENTRY TO PORTRAIT CORRIDOR 121-126
ENTRY TO CORRIDOR 110-120
ENTRY TO CORRIDOR 101-109
BY ROOM 114
BY ROOM 115
BY ROOM 120
BY ROOM 225
BY ROOM 219
BY ROOM 211
ENTRY TO CORRIDOR 201-210
ENTRY TO CORRIDOR 232-225
BY ROOM 201
BY ROOM 101

	LOCATION: Colby Village	Device	Device address or circuit number	Annunciation	NOTES
FIRE ALARM PANEL: Edwards 6500					
MANUAL PULL STATIONS					
HEAT DETECTORS					
1	MAIN ENTRANCE	M	ZN 1		
2	EAST EXIT 1ST FLOOR BY 108	M	ZN 1		
3	NORTH EXIT 1ST FLOOR	M	ZN 1		
4	2ND FL HALLWAY BY MUSIC ROOM 201	M	ZN 2		
5	BY LIBRARY ROOM 207	M	ZN 2		
6	EAST EXIT BY 211	M	ZN 2		
7	GYM ENTRY RIGHT	M	ZN 2		
8	GYM ENTRY LEFT	M	ZN 2		
10	GYM	M	ZN 2		
9	FURNACE ROOM	M	ZN 3		
1	ELECTRICAL ROOM	RHT	ZN 3		
2	ELECRIICAL VAULT	RHT	ZN 3		
DUCT SMOKE DETECTORS					
1	FURNACE ROOM (SUPPLY)	DS	ZN 5		DA-PYRO
2	FURNACE ROOM (RETURN)	DS	ZN 5		
3	2ND FL BOYS WASHROOM	DS	ZN 6		
4	2ND FL GYM TEACHER'S OFFICE	DS	ZN 6		
5	2ND FL GIRLS WASHROOM	DS	ZN 7		
6	2ND FL GIRLS WASHROOM	DS	ZN 7		
SPRINKLER DEVICES					
1	FURNACE ROOM	FSP	ZN 4		WFS-5 POTTER
NOTIFYING DEVICES					
1	SOUTH HALL 1ST FL	B	SIG 1		
2	EAST HALL 1ST FL	B	SIG 1		
3	NORTH HALL 1ST FL	B	SIG 1		
4	NORTH HALL 2ND FL	B	SIG 1		
5	EAST HALL 2ND FL	B	SIG 1		
6	GYM	B	SIG 1		
7	FURNACE ROOM	B	SIG 1		10" ADAPTABLE
Fire Door Number or Location					
1	First floor by room 100	RLY			

2	First floor by room 103	RLY
3	First floor by room 105	RLY
4	First floor by room 108	RLY
5	First floor by main office stairs	RLY
6	Second floor by room 211	RLY
7	Second floor by room 207	RLY
8	Second floor by room 201	RLY
	AHU SHUTDOWN	RLY

EMERGENCY LIGHTING

Location	# of Heads	Model
MAIN ENTRANCE		LUMACELL
STAIRS BY MAIN ENTRY		LITE
BY ROOM 102		LUMACELL
BY ROOM 107		LITE
BY ROOM 205		LUXNET
STAIRS BY MUSIC ROOM 201		LITE
STAIRS BY ROOM 108		LUMACELL
BY ROOM 209		LITE
GYM BY DOOR		LITE
BOILER ROOM		UNIT
GYM LEFT		
GYM RIGHT		
GYM BY DOOR		
GYM BY BACK DOOR		

	LOCATION: JOSEPH GILES	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
	HALL WEST	M	Zone #1
	FRONT ENTRANCE	M	Zone #1
	GYM	M	Zone #1
	JANITORS ROOM WEST	RHT	Zone #1
	HALL SOUTH	M	Zone #2
	JANITORS ROOM SOUTH	RHT	Zone #2
	LIBRARY STORAGE	RHT	Zone #2
	FAN ROOM	DS	Zone #2
	HALL NORTH	M	Zone #3
	JANITORS ROOM NORTH	RHT	Zone #3
	BOILER ROOM	M	Zone #4
	BOILER ROOM	HT	Zone #4
	ELECTRICAL ROOM	S	Zone #4
	BOILER ROOM	PS	Zone #5
	BOILER ROOM	TS	Zone #5
	UPPER HALL	FS	Zone #6
	UPPER HALL	TS	Zone #6
	BOILER ROOM	B	Sig #1
	HALL SOUTH	B	Sig #1
	HALL NORTH	B	Sig #1
	CENTER HALL	B	Sig #1
	WEST END	B	Sig #1
	WEST END	B	Sig #1
	GYM	B	Sig #1
	BY MAIN OFFICE		
	BY STAGE?		

EMERGENCY LIGHTING							
Line #	EL UNIT Location		Remote Head	Bat. VAH	Manuf.		
1	Main Entrance			6V, 7Ah	Emergi-Lite, 6 JML 36		
2	*Main Entrance		Y				
3	West Hall			6V, 7Ah	Emergi-Lite, 6 JML 36 S6		
4	Gym		Y		Emergi-Lite, 6 JML 36		
5	Center Hall			6V, 7.2A	Emergi-Lite, 6JML36		

6	Center Hall Battery Pack			6V, 7Ah	Emergi-Lite, 6 JML 36		
7	*Girls Washroom		Y				
8	*Boys Washroom		Y				
9	South Hall			6V, 7.2A	Lumacell, RG36A		
10	North Hall			6V, 7.2A	Lumacell, RG36A		
11	Boiler Room			6V, 7.2A	Emergi-Lite, 6 JML 36		
12	Gym Stage						
Fire Door Number or Location							
By classroom 3							
By classroom 9							
By main office							
By stage							

LOCATION: Cole Harbour High
Fire Alarm Panel: Edwards QS-4

Device

**Device address or
circuit number**

NOTES

MANUAL PULL STATIONS

1	SOUTH HALL 3RD FLOOR BY ELEV	M	Zone #1	
2	WEST HALL 3RD FLOOR BY RM 301	M	Zone #1	
3	EAST HALL 3RD FLOOR BY RM 314	M	Zone #2	
4	MAIN ENTRANCE	M	Zone #3	
5	STAFF BACK EXIT	M	Zone #3	
6	GYM BY MAIN ENTRY	M	Zone #3	
7	WEST HALL 2ND FLOOR BY RM 201	M	Zone #3	
8	KITCHEN	M	Zone #4	
9	CAFETORIUM	M	Zone #4	
10	GYM	M	Zone #4	
11	EAST HALL 2ND FLOOR BY 210	M	Zone #4	
12	STAGE	M	Zone #4	
13	WEST 1ST FLR HALL REAR BY RM 101	M	Zone #6	
14	WOODSHOP	M	Zone #7	
15	EAST FRONT HALL 1ST FLR BY ELEV	M	Zone #7	
16	EAST 1ST FLR HALL REAR BY RM 113	M	Zone #7	
17	BOILER ROOM	M	Zone #8	

SMOKE DETECTORS

1	WOODSHOP STORAGE	SI	Zone #7	
2	SIDE STAGE STORAGE	SI	S	

HEAT DETECTORS

1	ELEVATOR MACHINE ROOM	RHT	Zone #7	
2	ELECTRICAL ROOM	HT	Zone #8	

DUCT SMOKE DETECTORS

1	MECH. ROOM #2 (RIGHT SIDE) BY #301	DS	Zone #1	DH-400A
2	MECH. ROOM #2 LEFT SIDE) BY #301	DS	Zone #1	6480-500
3	MECH. ROOM #3 (FAR SIDE) BY #314)	DS	Zone #2	6480-500
4	MECH. ROOM #3 (NEAR DOOR ENTRY)	DS	Zone #2	6480-500
5	STORAGE ROOM #5 2ND FLR (BY #209)	DS	Zone #4	6480-500
6	STORAGE ROOM #2 (BY ROOM #206)	DS	Zone #3	DH-100-LPA
7	BOILER ROOM Closest to entry door	DS	Zone #8	ESD-2W
8	BOILER ROOM Farthest from door	DS	Zone #8	6480-500
9	MECH. ROOM BY 314	DS		

SPRINKLER DEVICES

1	SPRINKLER ROOM	FSP	Zone #09	
2	STORAGE ROOM #6 (BY ROOM #306)	FS	Zone #10	
3	STORAGE ROOM #6 (BY ROOM #306)	TS	Zone #10	
4	STORAGE ROOM #2 (BY ROOM #206)	FS	Zone #11	

5	STORAGE ROOM #2 (BY ROOM #206)	TS	Zone #11	
6	SPRINKLER ROOM	FS	Zone #12	
7	SPRINKLER ROOM 3RD FLOOR	TS	Zone #12	
8	SPRINKLER ROOM (MAIN GATE VALVE)	TS	Zone #12	

GYM/TECH ED BACFLOW 2	TS	143
GYM/TECH ED BACKFLOW	TS	144
GYM MAIN	TS	149
1ST FLOOR MAIN	TS	146
MAIN CTRL	FS	150
1ST FLOOR	FS	145
GYM / TECH RISER	FS	142

NOTIFYING DEVICES

1	WEIGHT ROOM	B	Sig #1	
2	WEST HALL 2ND FLOOR	B	Sig #1	
3	WEST HALL BY ROOM 205	B	Sig #1	
4	SOUTH HALL 2ND FLOOR	B	Sig #1	
5	SOUTH HALL 2ND FLOOR	B	Sig #1	
6	EAST HALL 2ND FLOOR	B	Sig #1	
7	STAFF ROOM HALL	B	Sig #1	
8	CAFETERIA	B	Sig #1	
9	WEST HALL 2ND FLOOR BY RCMP OFF	B	Sig #1	
10	GYM	B	Sig #2	
11	GYM	B	Sig #2	
12	WEST HALL 3RD FLOOR	B	Sig #2	
13	SOUTH HALL 3RD FLOOR	B	Sig #2	
14	EAST HALL 3RD FLOOR BY TEACHERS' W	A B	Sig #2	
15	EAST HALL 3RD FLOOR	B	Sig #2	
16	SOUTH HALL 3RD FLOOR	B	Sig #2	
17	MECHANICAL ROOM #1	B	Sig #4	
18	WEST HALL 1ST FLOOR	B	Sig #4	
19	WEST HALL 1ST FLOOR	B	Sig #4	
20	SOUTH HALL 1ST FLOOR	B	Sig #4	
21	SOUTH HALL 1ST FLOOR	B	Sig #4	
22	GRAPHIC ROOM 119	B		
23	COMPUTER LAB ROOM 111	B	Sig #4	
24	WOODSHOP	B	Sig #4	
25	EAST HALL 1ST FLOOR	B	Sig #4	
26	EAST HALL 1ST FLOOR	B	Sig #4	

END OF LINE RESISTORS

1	WEST HALL 3RD FLOOR	EOL	Zone #1	
---	---------------------	-----	---------	--

2	EAST HALL 3RD FLOOR	EOL	Zone #2	
3	WEST HALL 2ND FLOOR	EOL	Zone #3	
4	STAGE	EOL	Zone #4	
5	WEST 1ST FLOOR HALL REAR	EOL	Zone #6	
6	EAST 1ST FLOOR HALL REAR	EOL	Zone #7	
7	BOILER ROOM	EOL	Zone #8	

ZONE 14 - GYM

STORAGE 204	S	4	SIGA2-PS
STORAGE 210	S	5	SIGA2-PS
CHANGE ROOM 205	S	9	SIGA2-PS
CHANGE ROOM 206	S	13	SIGA2-PS
CHANGE ROOM 207	S	14	SIGA2-PS
CHANGE ROOM 209	S	15	SIGA2-PS
LOBBY	M	126	SIGC-270B
FRONT LEFT EXIT	M	127	SIGC-270B
BACK LEFT EXIT	M	128	SIGC-270B
BACK RIGHT EXIT	M	129	SIGC-270B
FRONT EXIT	M	139	SIGC-270B

ZONE 15 - GYM MECHANICAL RM 301

STAIR	S	1	SIGA2-PS
ELECTRICAL RM	S	2	SIGA2-PS
CENTRE	S	3	SIGA2-PS
BACK	S	8	SIGA2-PS
FRESH AIR INTAKE	S	10	SIGA2-PS
MECH. RM 301	M	137	SIGC-270B

ZONE 16 - AHU 1-GYM/TRADES DUCT SMK

MECH. 301 SUPPLY	DS	11	SIGA-SD
------------------	----	----	---------

FAN SHUTDOWN IN DETECTOR	RLY
-----------------------------	-----

ZONE 17 - AHU 2-GYM MECH RM 301

ZONE 15 - GYM MECHANICAL RM 301

MECH 301 SUPPLY	DS	6	SIGA-SD
-----------------	----	---	---------

FAN SHUTDOWN IN DETECTOR	RLY	ZONE 15 - GYM MECHANICAL RM 301	
-----------------------------	-----	---------------------------------	--

ZONE 18 - TRADES

MANUFACTURING TRADES	M	130	SIGC-270B
WELDING	M	136	SIGC-270B
MANUFACTURING SHOP	M	141	SIGC-270B
SKILLED TRADES	M	138	SIGC-270B

ZONE 19 - GYM MECH RM 301 SPK FLOW

MECH. RM 301	FS	133	SIGA-CT2
--------------	----	-----	----------

ZONE 20 - GYM/TRADES SPK FLOW			
MECH. RM 301	FS	131	SIGA-CT2

ZONE 26 0 GYM MECH RM 301 :

MECH. RM 301	TS	134	SIGA-CT2
--------------	----	-----	----------

ZONE 27 - GYM/TRADES SPK VLV

Location Description	Device Address	Model
MECH. RM 301	TS 132	SIGA-CT2

RELAYS

CAFETERIA DOOR HOLDER	CR	135	SIGA-CR
-----------------------	----	-----	---------

SAFETY DOOR HOLDER	CR	100	SIGA-CR
SECURITY DOOR 201	RLY	140	SIGA-CR

SIGNAL CCT 2 (BOOSTER) 2ND FLR

ADDITIONS TO

GYM	B	2
GYM	B	2
CHANGE RM	B	2
CHANGE RM	B	2
CHANGE RM	B	2
CHANGE RM	B	2
WELDING	B	2
WELDING	V	2
MANUFACTURING TRADES	B	2
MANUFACTURING TRADES	V	2
SKILLS TRADES	B	2
SKILLS TRADES	V	2
GYM MECH 301	B	2
GYM MECH 301	V	2
HALL AT EXIT TO MAIN SCHOOL	B	2

ADDITIONS FEBURARY 4, 2015

2ND FL STAGE RIGHT STORAGE SMOKE CO2		D004
2ND FL STAGE LEFT STORAGE SMOKE CO2		D004
ADJ CAFETERIA	S	3

ADJ CARETERIA	S	3
---------------	---	---

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	ROOM 114		REMOTE
	BOTTOM WEST STAIRS		DUAL LITE
	MIDDLE WEST STAIRS		REMOTE
	TOP EAST STAIRS		REMOTE
	TOP WEST STAIRS		REMOTE
	BY MECH ROOM1		REMOTE
	IN MECH ROOM 1		REMOTE
	3RD LIBRARY		REMOTE
	GYM S/W		AIMLITE
	GYM S/E		AIMLITE
	GYM EAST 1 REMOTE		AIMLITE
	GYM EAST 2 REMOTE		
	GYM N/E		AIMLITE
	GYM N/W		AIMLITE
	GYM NORTH		
	GYM WEST 1		
	GYM WEST 1		
	STORAGE ADJ PHYS ED		AIMLITE

	ED		
	GIRLS CHG		REMOTE
	MENS CHG		REMOTE
	MENS CHNG		AIMLITE
	GIRLS CHNG		AIMLITE
	EQUIP		AIMLITE
	ADJ EAST OFFICE		
	GYM FOYER		AIMLITE
	MECH LWR		REMOTE
	NORTH WALL		AIMLITE
	SOUTH WALL		REMOTE
	RIGHT OF LUNCH COUNTER		AIMLITE
	STUDENT COUNCIL		AIMLITE
	STUDENT COUNCIL		AIMLITE
	ADJ OFFICE BACK DR		AIMLITE
	SKILLED TRADE		AIMLITE
	SKILLED TRADE UPPER HALL		AIMLITE
	SKILLED TRADE LOWER HALL		AIMLITE
	SKILLED TRADE RIGHT WORKSHOP		AIMLITE
	SKILL TRADE LEFT WORKSHOP		AIMLITE

Unit #	Location	# of Heads	Model
	SKILLED TRADE LEFT WORKSHOP		REMOTE
	OUTSIDE STAIRS		AIMLITE

	OUTSIDE STUDENT COUNCIL		AIMLITE
	LUNCH COUNT AREA ABOUT TV OUTLET		AIMLITE
	LUNCH COUNT AREA ADJ CAFE DOORS		AIMLITE
	ADJ STUDENT SERV		AIMLITE
	CAFE N/E WALL FRONT LEFT		AIMLITE
	CAFE N/W WALL		AIMLITE
	CAFE S/W WALL		AIMLITE
	CAFE N/W WALL BACK RIGHT		AIMLITE
	STAGE FOYER		AIMLITE
	STAGE SOUTH		AIMLITE
	STAGE NORTH		AIMLITE
	IN 204		AIMLITE
	ADJ 304		AIMLITE
	3RD MEN'S W/R		REMOTE
	3RD WOMEN'S W/T		REMOTE
	3RD FLOOR EAST MECH ROOM		AIMLITE
	3RD FLOOR WEST MECH ROOM		AIMLITE
	3RD FLOOR STORAGE ROOM 6		REMOTE
	EXERCISE ROOM NEAR 202		LUMACELL
	ROOM 204 WASHROOM		REMOTE
	2ND FLOOR GREEN ROOM		AIMLITE

EMERGENCY LIGHTS

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	3RD FLOOR EAST HALL BY 309		LUMACELL
	3RD FLOOR EAST HALL BY 315		EMERGILITE
	3RD FLOOR EAST HALL BY 314		LUMACELL
	3RD FLOOR WEST HALL BY 307		LUMACELL
	3RD FLOOR WEST HALL BY 301		EMERGILITE
	TOP OF FRONT STAIRS		LUMACELL
	2ND FLOOR WEST HALL BY 207		LUMACELL
	2ND FLOOR WEST HALL BY 204		LUMACELL
	2ND FLOOR WEST HALL BY 201		LUMACELL
	1ST FLOOR WEST BY 107		LUMACELL
	1ST FLOOR WEST BY 104		LUMACELL
	1ST FLOOR WEST BY 101		LUMACELL
	1ST FLOOR EAST BY 112		EMERGILITE
	1ST FLOOR EAST BY 111		LUMACELL
	JANITORS ROOM #2 BATT PAK		EMERGILITE
	MAIN ENTRANCE		REMOTE
	BOYS WASHROOM 2ND		REMOTE
	GIRLS WASHROOM 2ND		REMOTE

	2ND		
	MIDDLE FRONT STAIRS		REMOTE
	BOTTOM OF FRONT STAIRS		REMOTE
	CAVA SHACK BATTERY PAK		LUMACELL
	BOTTOM EAST STAIRS		REMOTE
	MIDDLE EAST STAIRS		REMOTE
	TOP EAST STAIRS		REMOTE
	BY 113 1ST FLOOR		
	IN 112 CONST. TECH		
	IN 116 1		
	IN 116 2		
	TEXT BOOK STORAGE		
	ROOM 146		
	ROOM 145		
	STORAGE BESIDE 145		
	TOP EAST STAIRS		REMOTE

Fire Door Number or Location
BY CAFETERIA
BY ROOM 111
BY ROOM 118
BY ROOM 205
BY ELEVATOR MAIN LEVEL
BY ELEVATOR 3RD FLOOR
BY ROOM 317
BY ROOM 310

LOCATION:Colonel John Stuart

FIRE ALARM PANEL:Simplex 4007 ES Hybrid

FIRE ALARM DEVICE

Location Description	Device	Model	Address
AHU SHUTDOWN	RELAY	4090-9002	MI-1
FRONT ENTRANCE	PULL	4099-9004	MI-11
BOILER RM	PULL	4099-9004	MI-12
CENTRE HALL ADJ RM 109	PULL	4099-9004	MI-13
CORR ADJ RM 108	DS	4098-9792	MI-19
GYMNASIUM OFFICE RM 116	SMOKE	4098-9714	MI-20
LOWER GYMNASIUM STORAGE RM 118	SMOKE	4098-9714	MI-21
UPPER GYMNASIUM STORAGE RM 117	SMOKE	4098-9714	MI-22
UPPER GYMNASIUM STORAGE RM 119	SMOKE	4098-9714	MI-23
BOILER RM	HEAT/RE-LAY	4098-9733	MI-24
ELECTRICAL RM	SMOKE	4098-9714	MI-27
JANITORS RM	SMOKE	4098-9714	MI-28
PLAY STORAGE RM	SMOKE	4098-9714	MI-29
NORTH EXIT ADJ RM 112	PULL	4099-9004	MI-30
EAST EXIT ADJ 115	PULL	4099-9004	MI-31
BOILER RM	H/S	4096-9127	1
GYM	H/S	4096-9127	1
WEST HALL	H/S	4096-9127	1
CENTRE HALL	H/S	4096-9127	1
EAST HALL	H/S	4096-9127	1
NORTH HALL	H/S	4096-9127	1

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	GYM EXIT	2	LUMACELL
	GYM ENTRANCE	2	LUMACELL
	CENTRE HALL BY ROOM 106	2	LUMACELL
	BY 112		LUMACELL
	MAIN ENTRANCE		EMERGI-LITE
	FAR HALL BY BOYS/GIRLS WASHRM		READY-LITE

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

- 1 BREAKER #24, PANEL IN MAIN OFFICE CONTROLS GYM AND BY BOOK STORAGE LIGHTS
LIGHTS BY MAIN ENTRANCE AND CENTER HALL BY ROOM 106 ARE INDEPENDENT

	LOCATION: George Bissett	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		

MANUAL PULL STATIONS			
1	CENTRE HALL EXIT 2ND FLR BY RM 207	M	ZN 01
2	MAIN ENTRY	M	ZN 01
3	GYM EXIT	M	ZN 01
4	HALL 2ND FLOOR BY RM 237	M	ZN 02
5	HALL 2ND FLOOR BY RM 230	M	ZN 02
6	HALL 1ST FLOOR BY RM 115	M	ZN 03
7	HALL 1ST FLOOR BY RM 106(MECH RM)	M	ZN 03
8	BOILER ROOM	M	ZN 05
SMOKE DETECTORS			
1	ELECTRICAL ROOM 211	S	ZN 01
2	STAIRWELL BY 230	S	ZN 02
3	STAIRWELL BY 237	S	ZN 02
4	ELEVATOR ROOM	S	ZN 05
DUCT SMOKE DETECTORS			
1	GYM FAN ROOM	DS	ZN 01
2	MAIN FAN ROOM 227 IN ROOM 226	DS	ZN 02
HEAT DETECTORS			
1	BOILER ROOM	HT	ZN 05
NOTIFYING DEVICES			
1	BOILER ROOM	B	SIG 1
2	GYM	B	SIG 1
3	HALL 1ST FLOOR	B	SIG 1
4	HALL 1ST FLOOR	B	SIG 1
5	HALL 2ND FLOOR	B	SIG 1
6	HALL 2ND FLOOR	B	SIG 1
7	HALL 2ND FLOOR	B	SIG 1
8	HALL 2ND FLOOR	B	SIG 1
9	MAIN LOBBY	B	SIG 1
10	SOUTH HALL	B	SIG 1
END OF LINE RESISTORS			
1	GYM EXIT	EOL	ZN 01
2	HALL 2ND FLOOR BY RM 230	EOL	ZN 02
3	HALL 1ST FLOOR BY RM 115	EOL	ZN 03

4	BOILER ROOM	EOL	ZN 05
5	GYM	EOL	SIG 1

SPRINKLER

	SPRINKLER CONTROL VALVE	SV	9
	SPERINKLER	SV	4

Fire Door Number or Location
FOYER BY MAIN OFFICE
NEAR ENTRY TO GYM
BY ROOM 232
BY ELEVATOR
BY ROOM 107(ELEV MACH RM)

BREAKER: GYM STAGE PANEL C
BREAKER: MECH RM 106
BREAKER PANLES:
CRT 30 LOWER LEVEL BY ELEVATOR
GYM EXIT O/L RIGHT
GYM EXIT O/L LEFT
GYM MIDDLE

	LOCATION: Oceanview	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex 4007		

MANUAL PULL STATIONS			
1	2ND FLOOR BY 211	M	ZONE 1
2	2ND FLOOR BY 217	M	ZONE 1
3	2ND FLOOR BY 201	M	ZONE 1
4	1ST FLOOR MAIN ENTRY BY OFFICE	M	ZONE 2
5	1ST FLOOR BY LIBRARY	M	ZONE 2
6	1ST FLOOR BACK EXIT BY 110	M	ZONE 2
7	BY ROOM 102 BACK EXIT	M	ZONE 2
8	BY ROOM 107	M	ZONE 2
9	EXIT BY 124	M	ZONE 2
10	GYM BY KITCHEN	M	ZONE 3
11	GYM LEFT OF STAGE	M	ZONE 3
12	GYM	M	ZONE 3
13	BOILER ROOM	M	ZONE 4
SMOKE DETECTORS			
1	ELEV MECH ROOM	S	ZONE 11
2	ELECTRICAL ROOM	S	ZONE 5
3	STAIRS 252	S	ZONE 6
4	ELEVATOR SHAFT	S	ZONE 7
5	STAIRS 251	S	ZONE 8
6	STAIRS 250	S	ZONE 9
DUCT SMOKE DETECTORS			
1	MECH ROOM 220	DS	ZONE 10
HEAT DETECTORS			
1	FAN ROOM #1	RHT	ZONE 1
2	JANITOR BY BOY'S WASHROOM EAST	RHT	ZONE 1
3	JANITOR BY BOY'S WASHROOM WEST	RHT	ZONE 1
4	ART ROOM STORAGE	RHT	ZONE 1
5	RM 216	RHT	ZONE 1
6	OLD GUIDANCE RM BY MAIN OFFICE	RHT	ZONE 2
7	ROOM 217	RHT	ZONE 1
8	GYM STORAGE	RHT	ZONE 2
9	ROOM 123	RHT	ZONE 2
10	BOILER ROOM	RHT	ZONE 2
11	BACK STAGE STORAGE BOTT RAMP	RHT	ZONE 2

12	KITCHEN/REAR OFFICE	RHT	ZONE 2
13	MUSIC ROOM STORAGE	RHT	ZONE 2
14	LIBRARY STORAGE	RHT	ZONE 2
15	JANITOR'S ROOM 121	RHT	ZONE 2
16	CARETAKER'S OFFICE RM 108	RHT	ZONE 5
17	FAN ROOM #2	RHT	ZONE 10
18	ROOM 222	RHT	ZONE 10
19	MECH ROOM 220	RHT	ZONE 10
20	RM 208	RHT	ZONE 10

END OF LINE RESISTORS

1	2ND FLOOR BY RM # 201 PULL STATION	EOL	ZONE 1
2	EXIT BY RM # 124	EOL	ZONE 2
3	IN GYMNASIUM KITCHEN	EOL	ZONE 3
4	BOILER ROOM BY PULL STATION	EOL	ZONE 4
5	IN ELECTRICAL ROOM	EOL	ZONE 5
6	STAIRWELL BY RM # 256 WEST SIDE	EOL	ZONE 6
7	2ND FL RM # 217 FOR ELEVATOR SHAFT SMO	EOL	ZONE 7
8	STAIRWELL BY RM # 251 MAIN STAIRWELL	EOL	ZONE 8
9	STAIRWELL BY RM # 250 EAST SIDE	EOL	ZONE 9
10	1INSIDE OF ROOM # 208	EOL	ZONE 10
11	1ST FL BY ELEVATOR-SPRINKLER PIT	EOL	ZONE 11
12	BOILER ROOM BY SPRINKLER TREE	EOL	ZONE 12
13	KITCHEN BY HOOD SUPPRESSION EQUIP	EOL	ZONE 13
14	2ND FL RM # 217 FOR ELEVATOR SHAFT VALV	EOL	ZONE 14
15	FACP STATES 1ST FL SPRINK VALVE PIT	EOL	ZONE 15
16			ZONE 16
17	2ND FL BY WEST SIDE STAIRWELL	EOL	SIG # 1
18	2ND FL FAN ROOM # 1	EOL	SIG # 2

NOTIFYING DEVICES

1	HALL BY 110	B	SIG # 2
2	HALL BY 112	B	SIG # 1
3	MAIN ENTRANCE	B	SIG # 2
4	HALL BY 121	B	SIG # 1
5	HALL BY 127	B	SIG # 1
6	BOILER ROOM	B	SIG # 2
7	HALL BY 105	B	SIG # 1
8	HALL BY MUSIC ROOM	B	SIG # 1
9	HALL BY 201	B	SIG # 2
10	FAN ROOM #1	B	SIG # 2
11	BY 210	B	SIG # 1
12	GYM LOBBY	B	SIG # 2
13	HALL BY 222	B	SIG # 2
14	FAN ROOM #2	B	SIG # 1

15	HALL BY 209	B	SIG # 2
16	HALL BY 218	B	SIG # 1
17	GYM NORTH	B	SIG # 1
17	GYM SOUTH	B	SIG # 2
18	HALL BY 205	B	SIG # 1
19	HALL BY 214	B	SIG # 2
20	HALL BY ROOM # 107	B	SIG # 1

FIRE ALARM NOTES AND RECOMMENDATIONS			
1	IMPORTANT: DISCONNECT NORMALLY OPEN RELAY CONTACTS TO PREVENT KITCHEN		
	OVENS FROM SHUTTING DOWN AND FIRE DOORS FROM CLOSING DURING SILENT TESTING.		

Fire Door Number or Location
TOP OF STAIR BY 211
TOP OF STAIR BY 217
TOP OF STAIR BY 210
BY LIBRARY

EMERGENCY LIGHTING				
Line #	EL UNIT Location	Remote Head	Cab. Head	Manuf.
PANEL 1105, IN HALL BY BOILER ROOM, CCT # 18				
1	BOILER ROOM		Y	EMERGI-LITE
2	OLD SECTION HALL BY BOILER RM.		Y	EMERGI-LITE
3	OLD SECTION HALL BY 124		Y	EMERGI-LITE
4	GIRLS WASHROOM BY 121		Y	EMERGI-LITE
5	BOYS WASHROOM BY 121		Y	EMERGI-LITE
Panel 1101, by rm 112, cct # 10.				
6	CENTER LOBBY		Y	EMERGI-LITE
7	BY CLASSROOM 112		Y	EMERGI-LITE
8	GYM BY GYM OFFICE		Y	EMERGI-LITE
10	GYM STAGE		Y	EMERGI-LITE
11	MAIN STAIRS		Y	EMERGI-LITE
Panel 1107, by the kitchen, cct # 9.				
9	GYM REAR EXIT		Y	EMERGI-LITE
12	ELECTRICAL ROOM		Y	EMERGI-LITE
13	GYM ENTRANCE		Y	EMERGI-LITE
14	GYM BY KITCHEN		Y	EMERGI-LITE

15	LEARNING CENTRE		Y	EMERGI-LITE
16	BOYS LOCKER ROOM		Y	EMERGI-LITE
17	BY ELECTRICAL ROOM		Y	EMERGI-LITE
18	BY KITCHEN		Y	EMERGI-LITE
19	KITCHEN		Y	EMERGI-LITE
Panel 1201, in Janitor's rm, by 201, cct # 11.				
20	RIGHT REAR STAIRS BY RM 201		Y	EMERGI-LITE
21	BY CLASSROOM 203		Y	EMERGI-LITE
22	GIRLS WASHROOM BY 203		Y	EMERGI-LITE
23	BOYS WASHROOM BY 203		Y	EMERGI-LITE
25	BY CLASSROOM 209		Y	EMERGI-LITE
Panel 1202, in Janitor's Rm, by 210, Cct # 13.				
27				
28	BOYS WASHROOM BY RM 210		Y	EMERGI-LITE
	GIRLS WASHROOM BY RM 210		Y	EMERGI-LITE
Panel 1202, in Janitor's Rm, by 210, Cct # 19.				
24	LEFT REAR STAIRS BY RM 210		Y	EMERGI-LITE
26	BY CLASSROOM 212		Y	EMERGI-LITE
29	BY ART ROOM		Y	EMERGI-LITE

	LOCATION: Robert K. Turner	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
MANUAL PULL STATIONS			
1	FRONT ENTRANCE	M	ZONE 2
2	SOUTH EXIT	M	ZONE 2
3	GYM	M	ZONE 2
4	BOILER ROOM	M	ZONE 3
5	2ND FLOOR EXIT BY ELECTRICAL ROOM	M	ZONE 1
6	2ND FLOOR EXIT BY ROOM 201	M	ZONE 1
HEAT DETECTORS			
1	JANITORS ROOM 1ST FLOOR	RHT	ZONE 2
2	ELECTRICAL ROOM 1ST FLOOR	RHT	ZONE 3
3	JANITORS ROOM 2ND FLOOR	RHT	ZONE 1
SPRINKLER			
1	SPRINKLER WATER FLOW(BOILER RM)	PS	ZONE 4
2	SPRINKLER VALVE	SV	ZONE 4
NOTIFYING DEVICES			
1	HALL 1ST FLOOR	B	SIG 4
2	HALL 1ST FLOOR	B	SIG 4
3	HALL 2ND FLOOR	B	SIG 4
4	HALL 2ND FLOOR	B	SIG 1
5	GYM	B	SIG 1
6	BOILER ROOM	B	SIG 4
EMERGENCY LIGHTING			
#	EL UNIT Location	e	Head
1	BY MAIN OFFICE (BATT PACK)		
2	MAIN ENTRY REMOTE	Y	
3	BY LIBRARY REMOTE	Y	
4	BOILER ROOM		
5	GIRLS WASHROOM MAIN LEVEL		
6	BOYS WASHROOM MAIN LEVEL		
7	BY ROOM 101		
8	BY ROOM 105		6V 12AH
9	BACK STAIRS		
10	BACK EXIT REMOTE	Y	
11	BY ROOM 210		
12	BY ROOM 206		

13	BOYS WASHROOM 2ND LEVEL		
14	GIRLS WASHROOM 2ND LEVEL		
15	BY ROOM 203		
16	FRONT STAIRS		
17	GYM BY STAGE		
18	GYM OPPOSITE STAGE		
19	XEROX ROOM		
	Fire Door Number or Location		
	1ST FLOOR BY MAIN OFFICE		
	1ST FLOOR BY STAGE		
	2ND FLOOR ABOVE OFFICE		
	2ND FLOOR ABOVE STAGE		
EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS			
	SEE IN JANITOR ROOMS, AND ALCOVE BY COOLERS FOR BREAKERS		

	LOCATION: Seaside	Device	Device address or circuit number
	Fire Alarm Panel: Siemens TXL 1000		

MANUAL PULL STATIONS

1	FRONT ENTRY	M	12
2	GYM REAR ENTRY	M	12
3	HALL 1ST FLOOR BY RM 101	M	13
4	HALL 1ST FLOOR BY RM 105	M	13
5	HALL 2ND FLOOR BY ROOM 205	M	12
6	HALL 3RD FLOOR BY RM 310	M	11
7	HALL 3RD FLOOR BY RM 300	M	11
8	BY RECYCLING ROOM	M	13
9	COMPUTER ROOM	M	13

SMOKE DETECTORS

1	1ST FLOOR OUTSIDE ELEVATOR	SI	13
2	3RD FLOOR OUTSIDE ELEVATOR	SI	11
3	ELEVATOR SHAFT	SI	6
4	FRONT STAIRS	SI	3
5	MAIN ENTRANCE OUTSIDE ELEVATOR	SI	5
6	OFFICE BY ELEVATOR	SI	12
7	TOP OF REAR STAIRS	SI	4

DUCT SMOKE DETECTORS

1	FAN ROOM 3RD FLOOR	DS	ZN 11
2	GYM STORAGE	DS	ZN 12

HEAT DETECTORS

1	BOILER ROOM	HT	ZN 13
---	-------------	----	-------

SPRINKLER DEVICES

1	BOILER ROOM	SV	ZN 1
2	BOILER ROOM SHAFT PIT	SV	ZN 10
3	FURNACE ROOM	FSP	ZN 10

NOTIFYING DEVICES

1	AV ROOM	B	
2	CAFETERIA	B	
3	COOKING ROOM	B	
4	FURNACE ROOM	B	
5	GYM STORAGE	B	
6	HALL 1ST FLOOR	B	

7	HALL 1ST FLOOR	B	
8	HALL 2ND FLOOR	B	
9	HALL 2ND FLOOR	B	
10	HALL 3RD FLOOR	B	
11	HALL 3RD FLOOR	B	
12	METAL SHOP	B	
13	WOOD SHOP	B	
	KITCHEN SUTT DOWN		RLY

Fire Door Number or Location
MAIN ENTRY (3 DOORS)
BY ROOM 205
BOTTOM REAR STAIRS
BOTTOM STAIRS BY RM 106
TOP OF REAR STAIRS
TOP OF STAIRS BY 310

EMERGENCY LIGHTING			
Line #	EL UNIT Location	Remote Head	MOD #
		Remarks	EMERGI- LITE
1	LOWER STAIRWAY	6V 7AH	EMERGI- LITE
2	BAND ROOM	6V 7AH	EMERGI- LITE
3	OUTSIDE STAFFROOM	6V 7AH	EMERGI- LITE
4	COMPUTER LAB	6V 7AH	EMERGI- LITE
5	JANITOR ROOM	2-6V 7AH	EMERGI- LITE
7	RECYCLING ROOM	6V 7AH	EMERGI- LITE
11	STORAGE ROOM BY 211	2-6V 7AH	EMERGI- LITE
14	GYM EXIT	2-6V 7AH	EMERGI- LITE
16	GYM EXIT FRONT ENTRY	6V 7AH	EMERGI- LITE
17	GIRLS LOCKER ROOM	6V 7AH	EMERGI- LITE
18	MAIN OFFICE		EMERGI- LITE
20	OUTSIDE KITCHEN	2-6V 7AH	EMERGI- LITE
22	LIBRARY	2-6V 7AH	EMERGI- LITE
24	FRONT STAIRWAY BY RM 310	6V 7AH	EMERGI- LITE
26	HALLWAY BY BOYS WASHROOM	6V 7AH	LUMACELL
27	INSIDE JANITORS RM 311	6V 7AH	LUMACELL
28	INSIDE ROOM 308	6V 7AH	
	PHOTOCOPIER ROOM		
29	BACK OF STAIRWAY		

LR LEV ELEVATOR	LUMACELL
-----------------	----------

MACHINE ROOM		
LR LEV OUTSIDE W/R		REMOTE
LR LEV ART ROOM		EMERGILIT E
KITCHEN STORAGE		
O/S 301		EXIT COMBO
GYM SHOWER RM		
O/S MAIN OFFICE		EXIT COMBO
BY 3RD FLR FAN RM (IN RM LEADING TO FAN RM)		
BOILER RM		UNIT
BY 105		UNIT

	LOCATION: Sir Robert Borden	Device	Device address or circuit number	Annunciation
	FIRE ALARM PANEL:			

MANUAL PULL STATIONS

1	ACROSS FROM GUIDANCE OFFICE	M	1	
2	WOODSHOP(1ST FLOOR)	M	1	
3	OUTSIDE OF CLAY SHOP(1ST FLOOR)	M	1	
4	OUTSIDE CAFETERIA(1ST FL)	M	1	
5	EXIT BY CAFETERIA(1ST FL)	M	1	
6	BY ROOM 108	M	1	
7	BY ROOM 110	M	1	
8	BY OFFICE(1ST FL)	M	1	
9	TOP OF MAIN STAIRS	M	2	
10	BY BOOK ROOM(2ND FL)	M	2	
11	BY ROOM 207	M	2	
12	BY ROOM 212	M	2	
13	BY FINE ART(2ND FL)	M	2	
14	GYM	M	3	
15	GYM	M	3	

SMOKE DETECTORS

1	OUTSIDE CLAY SHOP(1ST FL)	S	1	
2	OUTSIDE CAFETERIA(1ST FL)	S	1	
3	BY MUSIC ROOM(1ST FL)	S	1	
4	BY ROOM 114	S	1	
5	BY ROOM 110	S	1	
6	BY ROOM 202 (2ND FL)	S	2	
7	BY ROOM 204	S	2	
8	BY ROOM 214	S	2	
9	BY ROOM 217(BOOK ROOM)	S	2	
10	BY LIBRARY(2ND FL)	S	2	

HEAT DETECTORS

1	CLAY SHOP STORAGE ROOM(1ST FL)	RH T	1	
2	WOOD STORAGE(1ST FL)	RH T	1	
3	STORAGE ROOM(1ST FL)	RH T	1	

4	KITCHEN(1ST FL)	RH T	1	
5	FAN ROOM (2ND FL)ADJ ENTRY	RH T	2	
6	FAN ROOM (2ND FL) TO RIGHT SIDE	RH T	2	
7	BOOK ROOM #1(2ND FL)BY LEARN CTR WASHRM	RH T	2	
8	BOOK ROOM #2 NEAR LIBRARY	RH T	2	
9	BOOK ROOM #3 NEAR ROOM 217	RH T	2	
10	GYM STORAGE	RH T	3	
11	STAGE, RIGHT	RH T	3	
12	STAGE, LEFT	RH T	3	

SPRINKLER DEVICES

1	SPRINKLER ROOM BY BOYS WASHROOM	PS	4	
---	------------------------------------	----	---	--

NOTIFYING DEVICES

1	HALL(1ST FL) BY RM 114	B	1	
2	HALL(1ST FL) BY RM 110	B	1	
3	HALL(1ST FL) BY RM 108	B	1	
4	HALL(1ST FL) BY KITCHEN ENTRY	B	1	
5	HALL(1ST FL) BY TECH ED ENTRY	B	1	
6	TECH ED(1ST FL)	B	1	
7	CLAY SHOP(1ST FL)	B	1	
8	MUSIC ROOM(1ST FL)	B	1	
9	GYM(1ST FL)	B	1	
10	HALL(2ND FL) TOP MAIN STAIR	B	2	
11	HALL(2ND FL) BY BOOK RM WEST	B	2	
12	HALL(2ND FL) BY RM 212	B	2	
13	HALL(2ND FL) BY RM 207	B	2	
14	HALL(2ND FL) BY BOOK RM EAST	B	2	
15	SPRINKLER ROOM	B	2	

END OF LINE RESISTORS

1	OUTSIDE WOODSHOP(1ST FL)	EO L	1	
2	BY BOOK ROOM(2ND FL)	EO L	2	

3	GYM	EO L	3	
---	-----	---------	---	--

EMERGENCY LIGHTING INSPECTION REPORT

#	EL UNIT Location	IT	UNIT	Remarks
1	BY TECH ED		ELL	RG 36 2H
2	BY CAFETERIA		ELL	RG 36 2H
3	BY 108		ELL	RG 36 2H
4	BY 115		ELL	RG 36 2H
5	FRONT STAIRS		ELL	RG 36 2H
6	BY 201		ELL	RG 36
7	BY 207		ELL	RD 36
8	LEFT BACK STAIRS BY 207		ELL	RG 36
9	BY 212		ELL	RG 36
10	RIGHT BACK STAIRS		ELL	RG 36
11	BY 219		ELL	6V7A
12	GYM BY SCORE CLOCK		ELL	
13	GYM ADJ WALL TO CLOCK	Y	IA	EXIT COMBO
14	GYM ON STAGE WALL			
15	GYM ON STAGE WALL			
16	GYM EXIT LEFT OF STAGE	Y		
17	GYM EXIT RIGHT OF STAGE	Y		
18	GYM EXIT			EXIT COMBO
19	GYM EXIT			EXIT COMBO
	GYM STAGE			
20	CAFETERIA			
21	CAFETERIA			
	WOODSHOP SIDE EXIT			
	2ND FLOOR FAN RT.			
	2ND FLOOR FAN LEFT	EXIT COMBO		
	GYM CORR. RIGHT SIDE	Y		
	GYM CORR. LEFT SIDE	Y		

		Device	Device address or circuit number
LOCATION: Horizon Elem			
FIRE ALARM PANEL: Simplex 4007			
MANUAL PULL STATIONS			
1	MAIN ENTRANCE(1st floor south)	M	M1 CCT 1
2	BOILER RM EXIT(1st floor south)	M	M1 CCT1
3	BOTTOM STAIRS BY RM 101(1st fl south)	M	M1 CCT1
4	BOTTOM STAIRS BY RM 117(1st floor south)	M	M1 CCT1
5	CAFETERIA EXIT	M	M1 CCT1
6	TOP OF CENTRE STAIRS 256(2nd fl south)	M	M1 CCT2
7	TOP OF STAIR 261 BY STORAGE RM 201	M	M1 CCT2
8	TOP OF STAIR 260 BY STORAGE RM 221	M	M1 CCT2
9	GYM REAR EXIT (gym)	M	M1 CCT3
10	FRONT HALL GYM EXIT (gym)	M	M1 CCT3
11	NORTH GYM (gym)	M	M1 CCT3
12	COMM CENTER ENTRY, RIGHT(comm ctr)	M	M5 CCT4
13	COMM CENTER MAIN ENTRY(comm ctr)	M	M5 CCT4
14	COMMUNITY CENTER REAR EXIT	M	M5 CCT4
15	OUTDOOR STORAGE(UNIFORM AREA)	M	M2 CCT3
16	OUTDOOR STORAGE	M	M5 CCT3
SMOKE DETECTORS			
1	ELECTRICAL RM (community center)	S	M5 CCT1
2	ELEVATOR MECHANICAL RM 109 (IN CAFETERIA)	S	M2 CCT2
3	STAIRWELL 256	S	M3 CCT1
4	STAIRWELL 260	S	M3 CCT2
5	STAIRWELL 261	S	M2 CCT4
HEAT DETECTORS			
1	BOOK STORAGE (ACROSS FROM ENTRANCE)	RHT	M1 CCT1
2	CARETAKER'S OFFICE	RHT	M1 CCT1
3	KITCHEN STORAGE	RHT	M1 CCT1
4	MECHANICAL RM	RHT	M1 CCT1
5	OIL TANK RM	RHT	M1 CCT1
6	SPRINKLER RM	RHT	M1 CCT1

7	BOILER RM	RHT	M1 CCT1
8	SERVER ROOM 112A	RHT	M1 CCT1
9	SICK RM	RHT	M1 CCT1
10	STORAGE 112	RHT	M1 CCT1
11	STORAGE 117	RHT	M1 CCT1
12	LIBRARY AUDIO VIDEO RM	RHT	M1 CCT1
13	STORAGE 101	RHT	M1 CCT1
14	ART RM DISPLAY CASE	RHT	M1 CCT2
15	ART RM STORAGE	RHT	M1 CCT2
16	FAN RM(REAR OF ROOM)	RHT	M1 CCT2
17	STORAGE 201	RHT	M1 CCT2
18	STORAGE 211	RHT	M1 CCT2
19	STORAGE 221	RHT	M1 CCT2
20	FAN RM (CLOSEST TO ENTRY)	RHT	M1 CCT2
21	FAN RM BY EF 10	RHT	M1 CCT2
22	STORAGE RM 11(communit y center)	RHT	M1 CCT3
23	STORAGE RM 12(communit y center)	RHT	M1 CCT3
24	STORAGE RM 13(communit y center)	RHT	M1 CCT3
25	STORAGE RM 14(comm center)formerly 6	RHT	M1 CCT3
26	GYM STORAGE 1	RHT	M1 CCT3
27	ELECTRICAL RM	RHT	M1 CCT4
28	OUTDOOR STORAGE	RHT	M2 CCT3
29	BOTTOM OF STAIRS 256/ CENTER STAIRS	RHT	M3 CCT1
30	KITCHEN	RHT	M4 CCT1
31	KITCHEN IN COMMUNITY CENTER	RHT	M5 CCT2
32	STORAGE RM 13B (IN CAFETERIA)	RHT	M5 CCT2
33	OUTDOOR STORAGE ,LAWN	RHT	M5 CCT3
34	COMMUNITY OFFICE STORAGE	RHT	M5 CCT4
35	STORAGE RM 01(communit y center)	RHT	M5 CCT4
36	STORAGE RM 02(communit y center)	RHT	M5 CCT4
37	STORAGE RM 03(communit y center)	RHT	M5 CCT4
38	STORAGE RM 04(communit y center)	RHT	M5 CCT4
39	STORAGE RM 05(communit y center)	RHT	M5 CCT4
40	STORAGE RM 07(communit y center)	RHT	M5 CCT4
41	STORAGE RM 08(communit y center)	RHT	M5 CCT4
42	STORAGE RM 09(communit y center)	RHT	M5 CCT4
43	STORAGE RM 10(communit y center)	RHT	M5 CCT4
44	JANITOR'S RM (communit y center)	RHT	M5 CCT4
45	STORAGE CC 07	RHT	24
SPRINKLER DEVICES			
1	SPRINKLER RM	PS	M2 CCT1
3	SPRINKLER RM	SV	ZN 5

4	ELEVATOR SPRINKLER 1ST FL	SV	ZN 25
6	ELEVATOR SPRINKLER 2ND FL	SV	ZN 26
7	BY ELEVATOR MECHANICAL RM	SV	ZN 27
8	ELECTRICAL RM	SV	ZN 28

NOTIFYING DEVICES

1ST FLOOR

1	BACK HALLWAY	B	SIG 1
2	BOILER RM	B	SIG 1
3	BOY'S LOCKER RM	B	SIG 1
4	BY GYM ENTRANCE	B	SIG 1
5	BY SICK RM	B	SIG 1
6	CAFETERIA	B	SIG 1
7	COMMUNITY CENTER	B	SIG 1
8	COMMUNITY CENTER	B	SIG 1
9	COMMUNITY CENTER OUTDOOR STORAGE	B	SIG 1
10	GIRL'S LOCKER RM	B	SIG 1
11	GYM	B	SIG 1
12	GYM	B	SIG 1
13	GYM CORR.	B	SIG 1
14	HALLWAY	B	SIG 1
15	HALLWAY	B	SIG 1
16	HALLWAY	B	SIG 1
17	HALLWAY	B	SIG 1
18	LOBBY	B	SIG 1
19	MAIN OFFICE	B	SIG 1
20	MUSIC RM	B	SIG 1
21	OUTDOOR STORAGE	B	SIG 1
22	REAR EXIT	B	SIG 1
23	REAR EXIT	B	SIG 1
24	SHOWCASE AREA	B	SIG 1

2ND FLOOR

25	HALLWAY	B	SIG 2
26	HALLWAY	B	SIG 2
27	HALLWAY	B	SIG 2
28	HALLWAY	B	SIG 2
29	TOP OF STAIRS 256	B	SIG 2
30	TOP OF STAIRS 260	B	SIG 2
31	TOP OF STAIRS 261	B	SIG 2

RELAY

DOOR RELEASE	RLY
--------------	-----

FIRE DOOR NUMBER OR LOCATION		
MAIN FOYER TO GREEN HALL		
MAIN FOYER TO GYM		
CENTRE		
MAIN FOYER TO CENTRE STAIRS		
MAIN FOYER TO BLUE HALL		
STAIRS		
TOP OF CENTRE STAIRS		
TOP OF GREEN HALL REAR		

Fire Door Number or Location
MAIN FOYER TO GREEN HALL
MAIN FOYER TO GYM
MAIN FOYER TO COMMUNITY CENTER
MAIN FOYER TO CENTER STAIRS
MAIN FOYER TO BLUE HALL
2ND FL BLUE HALL BY SOUTH STAIRS
TOP OF CENTER STAIRS
TOP OF GREEN HALL REAR

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	1ST FLOOR		
	BOILER ROOM		
	BOILER ROOM		
	ELECTRICAL ROOM		
	ACROSS FROM 102		

	ACROSS FROM 105		
	BY CAFETERIA		
	CAFETERIA		
	CAFETERIA EXIT		
	OUTSIDE LIBRARY		
	OUTSIDE MECH ROOM		
	BOTTOM OF WEST STAIRS BY 101		
	BOYS WASHROOM		
	GIRLS WASHROOM		
	CAFETERIA ENTRY		
	CORRIDOR BY 112A		
	BY ROOM 113		
	BY ROOM 116		
	EXIT BY ROOM 117		
	CENTRE LOBBY		
	BOTTOM OF CENTRE STAIRS		
	BY LOST AND FOUND		
	2ND FLOOR		
	MIDDLE OF CENTRE STAIR		
	BY 209 STORAGE		

	BY FAN ROOM		
	FAN ROOM		
	CORRIDOR BY ROOM 201		
	BOYS WASHROOM		
	GIRLS WASHROOM		
	BY 215		
	BY 219		
	STAIR BY ROOM 221		
	CORRIDOR BY ROOM 221		
	IN ART ROOM 213		
	BOTTOM STAIRS BY ROOM 116		UNIT

	COMMUNITY CENTRE/GYM		
	MIDDLE STAIR BY ROOM 203		UNIT
	BREAKER PANEL ON STAGE		
	GYM BY STORAGE 1	2	STANPRO
	GYM	2	LUMACELL
	GYM	2	LUMACELL
	GYM	2	LUMACELL
	BY GYM ENTRY	2	COMBO

BY GYM ENTRY	2	COMBO
STAGE RAMP	2	RHT
STAGE RIGHT	2	LUMACELL
STAGE RAMP	2	LUMACELL
BOYS LOCKER ROOM	2	LUMACELL
GIRLS LOCKER ROOM	2	LUMACELL
COMM CTR BY STORAGE 7		
COMM CTR BY STORAGE 9		
COMM CTR LOUNGE ROOM 6		
GYM REAR EXIT	2	
CORRIDOR BY GYM REAR EXIT	2	
BY ROOM 110	2	LUMACELL
BOYS WASHROOM BY GYM		
GIRLS WASHROOM BY GYM		
MUSIC		
COMMUNITY CENTRE ENTRY		
COMMUNITY CENTRE RECEPTION		
COMMUNITY SERVICES ROOM (BEHIND RECEPTION)		

	COMM SERVICE BY PROG RM 1		
	PROGRAM ROOM 3 LHS UNIT		
	PROGRAM ROOM 3 RHS UNIT		
	PROGRAM ROOM 4		
	PROGRAM ROOM 4		
	COMM CTR BOYS WASHROOM		
	GAMES ROOM 7		
	BY GYM OFFICE		
	COMM CTR GIRLS WASHROOM		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

	COMMUNITY CENTER SERVICES RM,PANEL"107", CCT#25 CONTROLS THE FOLLOWING LIGHTS:#'s 57-66
	COMMUNITY CENTER STORAGE RM #7, PANEL"108", CCT#14 CONTROLS THE FOLLOWING LIGHTS: #'s 44-50
	PANEL "101 BY RM 114, CCT#10 CONTROLS THE FOLLOWING LIGHTS: #'s 14-18
	PANEL "121" BY RM 215, CCT#11 CONTROLS THE FOLLOWING LIGHTS: #'s 29-33
	PANEL "122" BY RM 207, CCT#16 CONTROLS THE FOLLOWING LIGHTS: #'s 22-28
	PANEL "103" BY GYM WASHROOMS,CCT#7 CONTROLS THE FOLLOWING LIGHTS: #'s 51- 56

	PANEL "102" BY RM 103, CCT#19 CONTROLS THE FOLLOWING LIGHTS: #'s 4-13
	PANEL "108 GYM STAGE AREA, CCT#18 CONTROLS THE FOLLOWING LIGHTS: #'s 34- 43

Fire Alarm System Info - EASTERN PASSAGE EDUCATION CENTRE

1 of 6

FIRE ALARM DEVICES - System Manufacturer EDWARDS EST 2

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
DETAILS															
STAIR 02	S	SIGAIPHS	101		✓			✓	✓						
ELEVATOR SHAFT	S	SIGAIPHS	104		✓										
STAIR 01	S	SIGAIPHS	105		✓			✓	✓						
STAIR 03	S	SIGAIPHS	106		✓			✓	✓						
PENTHOUSE B	M	SIGC-270	205		✓			✓	✓						
AHU 2 SHUTDOWN	RLY	SIGA-CR	206		✓			✓							
SUPV. SPRK. ELEVATOR PIT GATE VALVE	TS	SIGA-CT1	207		✓										C1
2ND FLOOR ADJ. STAIR 03	M	SIGC-270	208		✓			✓	✓						
PENTHOUSE A	M	SIGC-270	209		✓			✓	✓						OFF ROOM 2036
AHU 4 SHUTDOWN	RLY	SIGA-CR	210		✓										
AHU 6 SHUTDOWN	RLY	SIGA-CR	211		✓			✓							
AHU 1 SHUTDOWN	RLY	SIGA-CR	212		✓										
AHU 3 SHUTDOWN	RLY	SIGA-CR	213		✓										
SUPV. SPRK. ELEV. SHAFT GATE VALVE	TS	SIGA-CT2	214		✓										C1
2ND FLOOR ADJ. STAIR 04	M	SIGC-270	215		✓			✓	✓						
2ND FLOOR ADJ. STAIR 01	M	SIGC-270	216		✓			✓	✓						
SPRINKLER FLOW 2ND FLOOR	FLOW	SIGA-CT2	217		✓										C1
2ND FLOOR GATE VALVE 2	TS	SIGA-CT2	218		✓										C1
AHU 5 SHUTDOWN	RLY	SIGA-CR	219		✓										
1ST FLOOR MECHANICAL ROOM	M	SIGC-270	220		✓			✓	✓						
1ST FLOOR ADJ. STAIR 02	M	SIGC-270	221		✓			✓	✓						
1ST FLOOR GYM EXIT 1	M	SIGC-270	222		✓										
1ST FLOOR MAIN LOBBY	M	SIGC-270	223		✓			✓	✓						
1ST FLOOR GYM EXIT 2	M	SIGC-270	224		✓										
1ST FLOOR STORAGE 1053 OFF GYM	M	SIGC-270	225		✓			✓	✓						
1ST FLOOR ADJ. STAIR 03	M	SIGC-270	226		✓			✓	✓						
1ST FLOOR ADJ. MUSIC ROOM	M	SIGC-270	227		✓			✓	✓						
2ND FLOOR ADJ. STAIR 02	M	SIGC-270	228		✓			✓	✓						
SUPV. SPRK. MAIN GATE VALVE 1	SUPV	SIGA-CT2	229		✓										C1
SUPV. 1ST FLOOR MAIN GATE VALVE	SUPV	SIGA-CT2	230		✓										C1
SPRINKLER WET SYSTEM FLOW	FLOW	SIGA-CT2	231		✓										C1

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
SUPV. SPRK. MAIN GATE VALVE 2	SUPV	SIGA-CT2	232		✓										C1
SPRINKLER FLOW PENTHOUSE	FLOW	SIGA-CT2	233		✓										C1
SUPV. SPRK. PENTHOUSE GATE VALVE	SUPV	SIGA-CT2	234		✓										C1
BOOSTER PANEL	RLY	SIGA-CR	235		✓			✓							
SUPV. BOOSTER PANEL	SUPV	SIGA-CT1	236		✓				✓						
SPRINKLER FLOW 1ST FLOOR	FLOW	SIGA-CT1	237		✓										C1
SPRINKLER ELEVATOR LIFT VALVE	TS	SIGA-CT1	238		✓										C1
PROPANE SHUTDOWN	RLY	SIGA-CR			✓			✓							
DOOR RELAY (IN FIRE PANEL)	RLY	CR			✓			✓							

SIGNAL CCT. #1

MAIN LOBBY	HORN			1	✓			✓							
NEAR CAFETERIA	HORN			1	✓			✓							
CAFETERIA	HORN			1	✓			✓							
MAIN LOBBY ADJ. ELEVATOR	HORN			1	✓			✓							
MUSIC ROOM	HORN			1	✓			✓							
POD C ADJ. CLASSROOM 1092	HORN			1	✓			✓							
POD B ADJ. CLASSROOM 1085	HORN			1	✓			✓							
POD C ADJ. CLASSROOM 2062	HORN			1	✓			✓							
POD B ADJ. CLASSROOM 2054	HORN			1	✓			✓							
ADJ. LIBRARY/RESOURCE CTR. 2021	HORN			1	✓			✓							
ADJ. LIBRARY/RESOURCE CTR. 2021	EOL			1	✓										

VISUAL CCT. #2

MAIN LOBBY	STRB			2	✓			✓							
NEAR CAFETERIA	STRB			2	✓			✓							
CAFETERIA	STRB			2	✓			✓							
MAIN LOBBY ADJ. ELEVATOR	STRB			2	✓			✓							
MUSIC ROOM	STRB			2	✓			✓							

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
POD C ADJ. CLASSROOM 1092	STRB			2	✓			✓							
POD B ADJ. CLASSROOM 1085	STRB			2	✓			✓							
POD C ADJ. CLASSROOM 2062	STRB			2	✓			✓							
POD B ADJ. CLASSROOM 2054	STRB			2	✓			✓							
ADJ. LIBRARY 2021	STRB			2	✓			✓							
MEN'S WASHROOM 1ST FLOOR	STRB			2	✓			✓							
WOMEN'S WASHROOM 1ST FLOOR	STRB			2	✓			✓							
ADJ. LIBRARY 2021	EOL			2	✓										

SIGNAL CCT. #2

ADJ. POD C 1ST FLOOR	HORN			2	✓			✓							
POD A ADJ. CLASSROOM 1076	HORN			2	✓			✓							
ADJ. POD C 2ND FLOOR	HORN			2	✓			✓							
POD A ADJ. CLASSROOM 2050	HORN			2	✓			✓							
ADJ. COMM. RM. 2044	HORN			2	✓			✓							
ADJ. OFFICE 2039	HORN			2	✓			✓							
PENTHOUSE B	HORN			2	✓			✓							
PENTHOUSE B	EOL			2	✓										

VISUAL CCT. #1

MEN'S WASHROOM 2ND FLOOR CTR.	STRB			1	✓			✓							
ADJ. POD C 1ST FLOOR	STRB			1	✓			✓							
POD A ADJ. CLASSROOM 1076	STRB			1	✓			✓							
ADJ. POD C 2ND FLOOR	STRB			1	✓			✓							
POD A ADJ. CLASSROOM 2050	STRB			1	✓			✓							
ADJ. COMM RM. 2044	STRB			1	✓			✓							
ADJ. OFFICE 2039	STRB			1	✓			✓							
PENTHOUSE B	STRB			1	✓			✓							
WOMEN'S WASHROOM 2ND FLOOR CTR.	STRB			1	✓			✓							
PENTHOUSE B	EOL			1	✓										

SIGNAL CCT. #3 - BOOSTER PANEL

GYM	HORN			3	✓			✓							
GYM	HORN			3	✓			✓							

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
ADJ. STAIR 3 1ST FLOOR	HORN			3	✓			✓							
MECHANICAL ROOM 1039	HORN			3	✓			✓							
MEN'S SHOWER GYM	STRB			3	✓			✓							
WOMEN'S SHOWER GYM	STRB			3	✓			✓							
TECH. ED. PROD. 2029	HORN			3	✓			✓							
ADJ. INFORMATION TECH. 2024	HORN			3	✓			✓							
PENTHOUSE A	HORN			3	✓			✓							
GYM	EOL			3	✓										

VISUAL CCT. #3

GYM	STRB			3	✓			✓							
GYM	STRB			3	✓			✓							
ADJ. STAIR 3 1ST FLOOR	STRB			3	✓			✓							
MEN'S WASHROOM 1ST FLOOR	STRB			3	✓			✓							
WOMEN'S WASHROOM 1ST FLOOR	STRB			3	✓			✓							
MECH. ROOM 1039	STRB			3	✓			✓							
TECH. ED. PROD. 2029	STRB			3	✓			✓							
ADJ. INFORMATION TECH. 2024	STRB			3	✓			✓							
PENTHOUSE A	STRB			3	✓			✓							
MEN'S LOCKER ROOM	STRB			3	✓			✓							
WOMEN'S LOCKER ROOM	STRB			3	✓			✓							
GYM	EOL			3	✓										

[illegible]

Fire Alarm System Information - ISLAND VIEW HIGH SCHOOL

1 of 9



FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
----------------------	--------	-------	---------	---------------------	------	-----	------	-----	-----	-----	-----	----	-----	------	---------

NOTIFIER NFS2-640 PANEL

ZONE 1 - LOWER LEVEL

CORR 100A BY STAIR 3	M		M55	1	✓			✓	✓						
CORR 100A BY STAIR 3	S		D54	1	✓			✓	✓						
CAFETERIA REAR EXIT	M		M54	1	✓			✓	✓						
STORAGE 111A	S		DO5	1	✓			✓	✓						
JANITOR ROOM 114	S		DO2	1	✓			✓	✓						
COMM LOSET RM 116	S		DO1	1	✓			✓	✓						
STORAGE 112A	S		DO7	1	✓			✓	✓						
COMM ROOM 108	S		DO8	1	✓			✓	✓						
HALLWAY 100A BSMT OF ST 2	S		DO3	1	✓			✓	✓						
HALLWAY 100A	S		DO4	1	✓			✓	✓						
PROD RM 107 (ABOVE PLANER)	RHT		DO9	1	✓			✓	✓						
PROD RM 107 (BY REAR EXIT)	RHT		D10	1	✓			✓	✓						
PROD RM 107	M		M06	1	✓			✓	✓						
CORR 100B SIDE EXIT	M		M11	1	✓			✓	✓						
CUSTODIAL RM 104	S		D16	1	✓			✓	✓						
STORAGE RM 103A	S		D13	1	✓			✓	✓						
REC RM 105	S		D12	1	✓			✓	✓						
CORR 100A BY STAIR 1	M		M15	1	✓			✓	✓						
STORAGE RM 101	S		D14	1	✓			✓	✓						
UNDER STAGE 1	S		D83	1	✓			✓	✓						
UNDER STAGE 2	S		D84	1	✓			✓	✓						
UNDER STAGE 3	S		D85	1	✓			✓	✓						
UNDER STAGE 4	S		D86	1	✓			✓	✓						
UNDER STAGE 5	S		D87	1	✓			✓	✓						
UNDER STAGE 6	S		D88	1	✓			✓	✓						

ZONE 2 - MAIN LEVEL

CORR 200 BY STAIR 3	M		M65	2	✓			✓	✓						
CORR 200 BY STAIR 3	S		D64	2	✓			✓	✓						
COMM ELEC CLOSET RM 221	S		D20	2	✓			✓	✓						
HALLWAY 200B	S		D23	2	✓			✓	✓						BT ST 2
HALLWAY 200B	S		D22	2	✓			✓	✓						BY RM 215

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
CORR 200 BY STR 1	S		D66	2	✓			✓	✓						
MAIN ENTRANCE	M		M67	2	✓			✓	✓						
COMM ELEC CLOSET	S		D21	2	✓			✓	✓						
SIDE ENTRANCE	M		M68	2	✓			✓	✓						STAIR 1
JANITOR ROOM	S		D24	2	✓			✓	✓						
COMM ROOM 110	S		D25	2	✓			✓	✓						
ADMIN AREA	M		M69	2	✓			✓	✓						

ZONE 3 - UPPER LEVEL

CORR 300A BY STAIR 3	M		M78	3											
CORR 300A BY STAIR 3	S		D49	3											BY RM 327
COMM ELEC CLOSET RM 203	S		D43	3											RM 323
STORAGE RM 315A	S		D45	3											
CHEM PREP 309A	S		D44	3											
CORR 300A BY STR 1	S		D47	3											
CORR 300A BY STR 1	M		M48	3											
COMM ROOM 306A	S		D41	3											
JANITOR ROOM 308A	S		D42	3											

ZONE 4 - REAR STAIRWELL

STAIRWELL 3	S		D31	4	✓			✓	✓						TOP FLOOR
-------------	---	--	-----	---	---	--	--	---	---	--	--	--	--	--	-----------

ZONE 5 - FRONT STAIRWELL

STAIRWELL 1	S		D32	5	✓			✓	✓						
CORR 100A BY STAIR 1	S		D51	5	✓			✓	✓						

ZONE 6 - GYMNASIUM

GYM REAR LEFT	M		M27	6	✓			✓	✓						
GYM REAR RIGHT	M		M28	6	✓			✓	✓						
STORAGE RM 202C	S		D26	6	✓			✓	✓						

ZONE 7 - ELEVATOR

ELEV MACHINE RM	S		D53	7	✓			✓	✓						
ELEV SHAFT	S		D46	7	✓			✓	✓						
PRIMARY FLOOR	R		M80	7	✓										
ALT FLOOR	R		M81	7	✓										

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
FIRE HAT	R		M82	7	✓										

ZONE 8 - KITCHEN SUPPRESSION

KITCHEN HOOD	R		M57	8	✓										
KITCHEN SHUNT	R		M58	8	✓										

ZONE 9 - OUTSIDE STORAGE

OUTSIDE STORAGE E104	S		D17	9	✓			✓	✓						
OUTSIDE STORAGE E104	M		M17	9	✓			✓	✓						

ZONE 10 - EXTERIOR SCHOOL

SPRINK RM E102	M		M60	10	✓			✓	✓						
SPRINK RM E102	S		D63	10	✓			✓	✓						
ELEC RM E101	M		M61	10	✓			✓	✓						
ELEC RM E101	S		D62	10	✓			✓	✓						
BOILER RM E103	M		M18	10	✓			✓	✓						
BOILER RM E103	RHT		D19	10	✓			✓	✓						

ZONE 11 - MECHANICAL ROOM

MECH SPACE FRONT	M		M34	11	✓			✓	✓						ROOM 308
MECH SPACE REAR	M		M35	11	✓			✓	✓						ROOM 308
MECH SPACE REAR	S		D40	11	✓			✓	✓						ROOM 308
MECH SPACE FRONT	S		D39	11	✓			✓	✓						ROOM 308

ZONE 13 - DUCT SENSOR 1

ERV #1 DUCT RM 308	DS		D36	13	✓			✓	✓						
ERV #1 DUCT RM 308	R		M70	13	✓										
ERV #1 DUCT RM 308	R		M71	13	✓										

ZONE 14 - DUCT SENSOR 2

ERV #2 DUCT RM 308	DS		D37	14	✓			✓	✓						
ERV #2 DUCT RM 308	R		M73	14	✓										
ERV #2 DUCT RM 308	R		M74	14	✓										

ZONE 15 - DUCT SENSOR 3

ERV #3 DUCT RM 308	DS		D38		✓			✓	✓						
--------------------	----	--	-----	--	---	--	--	---	---	--	--	--	--	--	--

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
ERV #3 DUCT RM 308	R		M76		✓										
ERV #3 DUCT RM 308	R		M77		✓										

ZONE 16 - SPRINKLER FLOW

LOWER LEVEL	FS		M102		✓			✓	✓						
MAIN LEVEL	FS		M104		✓			✓	✓						
TOP LEVEL	FS		M106		✓			✓	✓						
WATERFLOW HORN CONTROL	TS		M99		✓										

ZONE 17 - SPRINKLER GATES

ELEV CONTROL	TS		M52		✓			✓							
HOISTWAY SPRINK VALVE	TS		M79		✓			✓							
MAIN VALVE INTERIOR	TS		M100		✓			✓							
MAIN VALVE LOWER LEVEL	TS		M101		✓			✓							
MAIN VALVE MAIN LEVEL	TS		M103		✓			✓							
MAIN VALVE UPPER LEVEL	TS		M105		✓			✓							
TEST HEADER	TS		M107		✓			✓							

ZONE 18 - BACKFLOW 1

BACKFLOW 1 VALVE	TS		M59		✓			✓							
------------------	----	--	-----	--	---	--	--	---	--	--	--	--	--	--	--

ZONE 19 - BACKFLOW 2

BACKFLOW 2 VALVE	TS		M58		✓			✓	✓						
------------------	----	--	-----	--	---	--	--	---	---	--	--	--	--	--	--

RELAYS

AHU 1					✓			✓	✓						MECH 308
AHU 1					✓			✓	✓						MECH 308
FIRE DOORS					✓			✓	✓						STAIR 1
FIRE DOORS					✓			✓	✓						STAIR 1
FIRE DOORS					✓			✓	✓						STAIR 3
FIRE DOORS					✓			✓	✓						STAIR 3
FIRE DOORS					✓			✓	✓						STAIR 1
FIRE DOORS					✓			✓	✓						STAIR 1
FIRE DOORS					✓			✓	✓						STAIR 3
FIRE DOORS					✓			✓	✓						STAIR 3
FIRE DOORS					✓			✓	✓						STAIR 1

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
FIRE DOORS					✓			✓	✓						STAIR 1
FIRE DOORS					✓			✓	✓						STAIR 3
FIRE DOORS					✓			✓	✓						STAIR 3
AUDIO OVERRIDE					✓			✓	✓						STAGE CEILING
BUILDING CONTROL					✓			✓	✓						RM 306A
BUILDING CONTROL					✓			✓	✓						RM 306A
AUDIO OVERRIDE					✓			✓	✓						RM 202C

SIGNALS - LOWER LEVEL

CORR 100A BY STAIR 3	H/S				✓			✓							
CORR 100A BY ELECT	H/S				✓			✓							
CORR 100A BY RM 107	H/S				✓			✓							
CORR 100A BY RM 105	H/S				✓			✓							
WASHROOMS 106	H/S				✓			✓							
COR 100A BY STAIR 1	H/S				✓			✓							
CAFETERIA 122	H/S				✓			✓							
DRAMA 120 STAGE	H/S				✓			✓							
MUSIC 118	H/S				✓			✓							
MUSIC 118A	H/S				✓			✓							
MUSIC 118B	H/S				✓			✓							
ROOM 109	H/S				✓			✓							
ROOM 107	H/S				✓			✓							
CORR 100B SIDE EXIT	H/S				✓			✓							
OUTDOOR STORAGE E104	H/S				✓			✓							
BOILER RM E103	H/S				✓			✓							
SPRINK RM E102	H/S				✓			✓							
ELECT RM E101	H/S				✓			✓							
MEDIA RM 111	H/S				✓			✓							

SIGNALS - MAIN LEVEL

CORR 200B BY STR3	H/S				✓			✓							
CORR 200B BY RM 219	H/S				✓			✓							
CORR 200B RM 215	H/S				✓			✓							
CORR 200B BY 211	H/S				✓			✓							
WASHROOM 206	H/S				✓			✓							
CORR 200B BY STR 1	H/S				✓			✓							

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
CORR 200B	H/S				✓			✓							
ROOM 217	H/S				✓			✓							
ROOM 207	H/S				✓			✓							
ROOM 201 ADMIN	H/S				✓			✓							
GYM 202 REAR	H/S				✓			✓							
GYM LOCKER RM 202A	H/S				✓			✓							
GYM LOCKER RM 202B	H/S				✓			✓							
MP LEARNING RM 219	H/S				✓			✓							
MP LEARNING RM 214	H/S				✓			✓							
GYM 202 FRONT	H/S				✓			✓							

SIGNALS - TOP LEVEL

CORR 300A BY STR 3	H/S				✓			✓							
CORR 300A RM 321	H/S				✓			✓							
CORR 300A BY RM 315	H/S				✓			✓							
CORR 300A BY RM 309	H/S				✓			✓							
CORR 300A BY STR 1	H/S				✓			✓							
WASHROOMS 304	H/S				✓			✓							
ROOM 315	H/S				✓			✓							
RM 308 GRID H-FRONT	H/S				✓			✓							
RM 308 GRID L-REAR	H/S				✓			✓							
STAFF LOUNGE 305	H/S				✓			✓							
COMM RM 306A	H/S				✓			✓							
YOUTH HEALTH OFFICE	H/S				✓			✓							111A TOP LVL
WATERFLOW HORN	H/S				✓			✓							OUTSIDE FRONT

[illegible]


EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #	Start Time	Finish Time	Current (A)	Voltage (V)	Battery Date	Battery Type	Op Cnfrm	Ser vice	Notes
	ADJ 202 B7	2									✓		
	ADJ 202 B2	2									✓		
	ADJ 2902 A	2									✓		PACK
	ADJ 202 A2	2									✓		
	ADJ 202 A5	2									✓		
	202 AC1	2									✓		
	212 HEALTHY LIVING	2									✓		
	ADJ 211	2									✓		
	ADJ 206 G1	2									✓		
	ADJ 206 C1	2									✓		
	IN STAIR BETWEEN 1ST & 2ND	2									✓		
	ADJ 213	2									✓		
	ADJ 215	2									✓		
	ADJ 212	2									✓		
	ADJ 219	2									✓		
	ADJ 214	2									✓		
	ADJ 221	2									✓		
	ADJ 218	2									✓		
	ADJ 223	2									✓		
	STAIR 3 LEVEL 3	2									✓		
	STAIR 3 LEVEL 2.5	2									✓		
	STAIR 3, LEVEL 2	2									✓		
	STAIR 3 LEVEL 1.5	2									✓		
	STAIR 3 LEVEL 1	2									✓		
	ADJ 117	2									✓		PACK
	ADJ 115	2									✓		
	ADJ 113	2									✓		
	CAFETERIA (122) #1	2									✓		
	CAFETERIA #2	2									✓		
	CAFETERIA #3	2									✓		
	CAFETERIA #4	2									✓		
	ON STAGE RS	2									✓		PACK
	ON STAGE REAR	2									✓		
	ON STAGE LEFT	2									✓		
	ADJ 118	2									✓		
	ADJ 112 #1	2									✓		
	112	2									✓		PACK
	112 REAR	2									✓		
	ADJ 112 #12	2									✓		

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #	Start Time	Finish Time	Current (A)	Voltage (V)	Battery Date	Battery Type	Op Cnfrm	Ser vice	Notes
	ADJ 111	2									✓		
	ADJ 110	2									✓		
	ADJ 109	2									✓		
	ADJ 107	2									✓		
	ADJ 106 D1	2									✓		
	ADJ 106 G1	2									✓		
	ADJ 100 B1	2									✓		
	ADJ 104.1	2									✓		PACK
	ADJ 103	2									✓		
	ADJ STAIR 1 BOTTOM	2									✓		PACK
	BOILER RM	2									✓		OFF MAIN ELEV
	SPRINKLER RM	2									✓		OFF MAIN ELEV
	MAIN ELEC 101	2									✓		PACK

Fire Alarm System Information - PORTLAND ESTATES ELEMENTARY SCHOOL



FIRE ALARM DEVICES - System Manufacturer : EDWARDS Model: IO 1000

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
MECH RM BY FIRE PNL	PULL		141		✓			✓	✓						MAIN ENTRY
MECH ROOM	PULL		138		✓			✓	✓						
BY 1055	SMOKE		2		✓			✓	✓						
MAIN LOBBY	SMOKE		18		✓			✓	✓						
HALLWAY BY CAFE	STROBE/ HORN				✓			✓	✓						
CAFETERIA	STROBE/ HORN				✓			✓	✓						
CAFETERIA EXIT	PULL		149		✓			✓	✓						
BY RM 1058	SMOKE		15		✓			✓	✓						
BOTTOM STAIR 2	PULL		144		✓			✓	✓						
GYM	STROBE/ HORN				✓			✓	✓						
GYM	STROBE/ HORN				✓			✓	✓						
GYM EXIT VESTIBULE	PULL		142		✓			✓	✓						
STAIR 1	PULL		140		✓			✓	✓						
BY RM 1039	SMOKE		9		✓			✓	✓						
BY RM 1025	SMOKE		19		✓			✓	✓						
BY RM 1025	STROBE/ HORN				✓			✓	✓						
RM 1059	SMOKE		12		✓			✓	✓						
MUSIC ART STAGE	SMOKE		11		✓			✓	✓						
BY RM 1058	STROBE/ HORN				✓			✓	✓						
2ND FL MECH RM	PULL		145		✓			✓	✓						
TOP STAIRS #2 2038	SMOKE		4		✓			✓	✓						
BY STAIR 2	PULL		143		✓			✓	✓						
BY RM 2033	SMOKE		20		✓			✓	✓						
BY RM 2033	STROBE/ HORN				✓			✓	✓						
STAIR #1	SMOKE		3		✓			✓	✓						
STAIR #1	PULL		136		✓			✓	✓						
BY RM 2017	SMOKE		1		✓			✓	✓						
BY RM 2017	STROBE/ HORN				✓			✓	✓						
RM 2040	SMOKE		13		✓			✓	✓						2040 IN 2043
ELEV RM 2041	SMOKE		10		✓			✓	✓						
RM 2038 INSIDE	SMOKE		8		✓			✓	✓						STORAGE RM
RM 2039 ADJ	SMOKE		14		✓			✓	✓						
RM 2039	STROBE/ HORN				✓			✓	✓						
EXCEL RM	SMOKE		16		✓			✓	✓						

Fire Alarm System Information - PORTLAND ESTATES ELEMENTARY SCHOOL



FIRE ALARM DEVICES Cont.

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
RM 2043	STROBE/ HORN				✓			✓	✓						
GYM STORAGE	SMOKE		6		✓			✓	✓						
GYM EXIT	PULL		146		✓			✓	✓						
MECH ROOM	STROBE				✓			✓	✓						
BY BACK EXIT	PULL		137		✓			✓	✓						
OUTSIDE STORAGE	SMOKE		17		✓			✓	✓						

	LOCATION: Astral Drive Elementary FIRE ALARM PANEL: Simplex 4100U	Device	Device address or circuit number

MANUAL PULL STATIONS

1	Boiler Room Exit	M	Zone 1
2	Front Entrance	M	Zone 1
3	Left side Exit (Across from Library)	M	Zone 1
4	Playground Exit	M	Zone 1
5	Gym Exit	M	Zone 1
6	Top of Gym Stairwell (West Stairwell)	M	Zone 2
7	2nd Floor by Main Stairwell (East Stairwell)	M	Zone 2

SMOKE DETECTORS

1	Elevator machine room	S	Zone 1
2	Electrical Room	S	Zone 1
3	Gym Stairwell	S	Zone 5
4	Front Stairwell	S	Zone 8
5	Elevator Shaft	S	Zone 9

DUCT SMOKE DETECTORS

1	2nd Floor Fan Room #2 sys #4 sau	DSTA	M1-1
2	2nd Floor Janitors Office sys #4 sau	DSTA	M1-2
3	2nd Floor Boys washroom ret #1	DSTA	M1-3
4	1st Floor boys change room ret #1	DSTA	M1-4
5	2nd floor girls washroom sys #2 sau	DSTA	M1-5
6	2nd floor fan room #1syst #3 sau	DSTA	M1-6
7	2nd floor fan room #1 sys #2 sau	DSTA	M1-7
8	2nd floor girls washroom sys #3 SAU	DSTA	M1-8
9	2nd floor girls washroom sys #1 SAU	DSTA	M1-9
10	2nd Floor fan room sys #1 SAU	DSTA	M1-10

SPRINKLER DEVICES

1	sprinkler room Pressure switch	PS	Zone 3
2	sprinkler room	GV	Zone 10
3	sprinkler room	GV	Zone 4
4	sprinkler room	PS	Zone 4

NOTIFYING DEVICES

1	1st floor by #106	B	SIG 3
2	1st floor by boys washroom	B	SIG 3
3	1st floor by #115	B	SIG 3
4	1st floor by office	B	SIG 3

5	Gym	B	SIG 3
6	2nd floor fax room	B	SIG 3
7	Top of gym stairwell	B	SIG 3
8	2nd floor by #206	B	SIG 3
9	2nd Floor by boys washroom	B	SIG 3
10	2nd floor by #216	B	SIG 3
11	2nd Floor by #201	B	SIG 3
12	Gym	B	SIG 3
13	Boiler Room	B	SIG 3

	AHU SHUTDOWN	R	
--	---------------------	---	--

EMERGENCY LIGHTING				
Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. V A H MOD #
PANEL "A", CCT # 9				
	Outside Admin Office		Y	6V/7.2Ah
	East Exit BY FIRE PANEL		Y	
	South Exit BY ROOM 101	Y		
	Outside RM 109		Y	
	OUTSIDE RM 107		Y	
PANEL "B", CCT #25				
	South Exit BY GYM ENTRY		Y	
	GYM BY LOCKER ENTRY		Y	
	GYM Exit		Y	
	Outside RM 104		Y	
	Boys Washroom (Remote)	Y		
	Boys Change Room(Remote)	Y		
	Outside RM 105		Y	
	Girls washroom (Remote)	Y		
	Girls change rm (Remote)	Y		
	BOILER ROOM (NOT ON PANEL)		RG-36 K6	RG-36 K6
	BOILER ROOM CORRIDOR			6V/7.2Ah
PANEL "C", CCT # 26				
	Outside RM 208		Y	
	Outside RM 211		Y	
	TOP OF STAIRS BY RM 201		Y	
PANEL "D", CCT #31				
	Room 218		Y	

	Fan Room THROUGH GIRLS W/R		Y		
	Outside RM 206		Y	6V/7.2Ah	
	Outside RM 203		Y		
	South Stairwell by 218		Y	6V/7.2A	
	Fan Room 2 (2nd FL)		Y	6V/7.2A	
	2nd FL Boy's Washroom	Y			
	2nd Fl Girl's Washroom		Y		
	ELECTRICAL ROOM				
	PORTABLE 5				
	PORTABLE 6				
	ELECTRICAL ROOM				

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1	2nd FL Fan Rm 2 ,Panel D Breaker 31		
2	Top of 2nd FL Stairs, Panel C Breaker 26		
3	1st FL Outside Office, Panel A Breaker 9		
4	Boiler Rm 1st FL, Panel B Breaker 25		
5	Device is on Panel "B" Cct # 25		
6	DEVICE IS NOT FOUND ON ANY BREAKER PANEL . TESTED LOCALLY		

Fire Door Number or Location

MAIN ENTRY

TOP OF STAIRS BY GYM

TOP OF STAIRS MAIN ENTRY

	LOCATION: Astral Dr. Jr.	Device	Device address or circuit number	Annunciation

FIRE ALARM PANEL:Edwards EST 3X

MANNUAL PULL STATIONS				
1	BY ROOM 168	M	ZONE 1	
2	BY ROOM 164	M	ZONE 1	
3	Tech Room 165	M	Zone 1	
4	BY DOOR 180(STAFF ROOM)	M	Zone 1	
5	Gym Hall	M	Zone 1	
6	South Entry	M	Zone 1	
7	Fan Room 162 (1st Floor) (In Canteen)	M	Zone 1	
8	Gym #1	M	Zone 4	
9	Gym #2	M	Zone 4	
10	Gym #3	M	Zone 4	
11	Main Entry	M	Zone 6	
12	Center Hall #1	M	Zone 6	
13	Center Hall #2	M	Zone 6	
14	1st Floor South(ADJ EOL) BY DR 114	M	Zone 6	
15	1st Floor North BY DR 101	M	Zone 6	
16	2nd Floor South(ADJ EOL)	M	Zone 11	
17	2nd Floor North	M	Zone 11	
SMOKE DETECTORS				
1	1st Floor South	SI	Zone 6	
2	1st Floor North	SI	Zone 6	
3	North Stairs	SI	Zone 8	
4	South Stairs	SI	Zone 10	
5	2nd Floor North	SI	Zone 11	
6	2nd Floor South (ADJ EOL)	SI	Zone 11	
7	Elevator Shaft	SI	Zone 12	
DUCT SMOKE DETECTORS				
1	Fan Rm 162 1st Fl (In Canteen) Supply #	DS	Zone 2	
2	Fan Rm 162 1st Fl (In Canteen) Supply #	DS	Zone 2	
3	Fan Rm 162 1st Fl (In Canteen) Return #	DS	Zone 2	
4	Fan Rm 162 1st Fl (In Canteen) Return #	DS	Zone 2	
5	Upper Mech Room SUPPLY	DS	Zone 9	
6	Upper Mech Room RETURN	DS	Zone 9	
HEAT DETECTORS				

1	Electrical Room (room 171)	RHT	Zone 1	
SPRINKLER DEVICES				
2	Sprinkler Room	PS	Zone 7	
4	Main Hall 1st Floor Elevator tamper	SV	Zone 5	
5	Sprinkler Room	SV	Zone 7	
NOTIFYING DEVICES				
1	Gym	B	SIG	
2	Gym	B	SIG	
3	East hall	B	SIG	
4	Drafting	B	SIG	
5	Wood Shop	B	SIG	
6	Fan Room 162	B	SIG	
7	Gym Hall	B	SIG	
8	Music Room	B	SIG	
9	Boys Shower	B	SIG	
10	Girls Shower	B	SIG	
11	Hall B Block 1st Floor	B	SIG	
12	Hall B Block 1st Floor	B	SIG	
13	Hall B Block 1st Floor	B	SIG	
14	Hall B Block 2nd Floor	B	SIG	
15	Hall B Block 2nd Floor	B	SIG	
16	Hall B Block 2nd Floor	B	SIG	

FIRE ALARM NOTES AND RECOMMENDATIONS

REQUIRE EVENING OR WEEKEND
TIME TO PERFORM DESIGNATION .

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Remote Head	Cab. Head	
	2nd Floor South BY 203		Y	
	Girls washroom 2ND FL	Y		
	Boys washroom 2ND FL	Y		
	Top South Stairs	Y		
	Center Hall 2nd Flr	Y		
	2nd Floor North BY 211		Y	
	Top North Stairs (Remote)	Y		
	1st Floor North BY 113		Y	
	Bott North Stairs	Y		
	Main Hall		Y	
	Main Entry (Remote)	Y		
	Gym Hall		Y	
	South Exit (remote)	Y		

	SOUTH Hall BY 104		Y	
	Bottom south Stairs	Y		
	CORR BY Boys washroom	Y		
	Boys washroom	Y		
	Girls washroom	Y		
	South Hall (Remote)	Y		
	Boys Showers (Remote)	Y		
	Gym Back Left		Y	
	Gym Back Right		Y	
	Gym Front Left		Y	
	Girls washroom (Remote)	Y		
	Girls showers (Remote)	Y		
	Gym Front Right			
	Mech Rm. ABOVE CANTEEN			
	CORR BY RM 165			

BY ROOM 121		EXIT
BOTTOM SOUTH STAIRS		EXIT
BY ROOM 106		EXIT
BY ROOM 137		EXIT
BOTTOM NORTH STAIR		EXIT
2ND FLOOR NORTH STAIR		EXIT
2ND FLOOR SOUTH STAIR RM 221		EXIT
BY ROOM 127		EXIT
BY MAIN OFFICE		EXIT
BY MAIN ENTRANCE		EXIT
BY GENERAL OFFICE		EXIT
ACROSS FROM OFFICE 186		EXIT
GYM EXIT		EXIT

GYM EXIT		EXIT
GYM EXIT		EXIT
BY ROOM 172		EXIT
BY ROOM 164		EXIT

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS				
1	2ND FLOOR LIGHTS CONTROLLED BY PANEL "H" ,			
	CCT # 34 IN GYM STORAGE RM			
2	LIGHTS IN GYM AND MECH RM ABOVE CANTEEN			
	CONTROLLED BY PANEL "H", CCT #28 IN GYM STORAGE RM			

Fire Door Number or Location
BY LIBRARY
BOTTOM STAIR BY 137
TOP STAIR BY 237
TOP STAIR BY 221
BOTTOM STAIR BY 122

		Device	Device address or circuit number	Annunciation
	LOCATION: Auburn			
	Fire Alarm Panel: Simplex 4100			
	1ST LEVEL			
1	BOTTOM OF STAIRWELL # 1 (LOCKER SIDE)	SI	ZN 25	
2	BOTTOM OF STAIRWELL # 1	SI	ZN 25	
3	BOTTOM OF STAIRWELL # 1	EOL	ZN 25	
4	BOTTOM OF STAIRWELL # 2	M	ZN 4	
5	CORR ACROSS FROM RM # 101	M	ZN 3	
6	CORR ACROSS FROM RM # 101	EOL		
7	SOUTH ENTRANCE / EXIT	M	ZN 2	
8	SOUTH ENTRANCE / EXIT	EOL		
9	BOTTOM OF STAIRWELL #3	M	ZN 1	
10	REPAIR SHOP OUTSIDE ENTRANCE	M	ZN 1	
11	COMPRESSOR ROOM (OUTSIDE DOOR)	M	ZN 1	
	MAIN LEVEL			
1	NORTH ENTRANCE BY FIRE PANEL	M	ZN 7	
2	CAFETERIA EXIT	M	ZN 6	
3	CAFETERIA EXIT	EOL	ZN 6	
4	ENTRY TO MAIN LOBBY AREA (ADJ PH RM 2)	SI	ZN 10	
5	MAIN ENTRANCE	M	ZN 8	
6	ELECTRICAL RM	SI	ZN 26	
7	ELECTRICAL RM	EOL		
47	AUTO BODY EXIT	M	ZN 1	
8	COMMUNICATION RM	SI	ZN 10	
9	CORR TO GYM (SET OF DOUBLE DOORS)	SI	ZN 10	
10	By ROOM#219-CORRIDOR	SI	ZN 10	
11	SOUTH ENTRANCE BOTTOM STAIRWELL # 3	SI	ZN 10	
12	SOUTH ENTRANCE	M	ZN 9	
13	MAINTENANCE RM ACROSS FROM RM # 212	SI	ZN 5	
14	MAINTENANCE RM ACROSS FROM RM # 212	EOL	ZN 5	
15	OUTSIDE RM # 212	SI	ZN 10	

29	OUTSIDE RM # 212 (LOCKER SIDE)	SI	ZN 10	
30	OUTSIDE RM # 216	SI	ZN 10	
31	OUTSIDE RM # 216	EOL	ZN10	
32	OUTSIDE WOMEN'S WASHROOM	SI	ZN 10	
33	OUTSIDE WOMEN'S WASHROOM	EOL	ZN10	
	3RD LEVEL			
36	TOP OF STAIRWELL # 2	SI	ZN 14	
37	TOP OF STAIRWELL # 1	M	ZN 11	
38	TOP OF STAIRWELL # 1	SI	ZN 23	
39	TOP OF STAIRWELL # 1	EOL	ZN12	
40	OUTSIDE YOUTH HEALTH CENTRE	SI	ZN 23	
41	STAIRWELL # 1 BY ELEVATOR	SI	ZN 13	
42	TOP OF STAIRWELL # 3 (LOCKER SIDE)	M	ZN 11	
43	TOP OF STAIRWELL # 3 (LOCKER SIDE)	SI	ZN 23	
44	TOP OF STAIRWELL # 3 (LOCKER SIDE)	EOL	ZN23	
45	TOP OF STAIRWELL # 3	SI	ZN 28	
46	TOP OF STAIRWELL # 3	EOL	ZN28	
48	MAINTENANCE STORAGE CLOSET	SI	ZN 11	
49	MAINTENANCE RM 3002	M	ZN 11	
50	MAINTENANCE RM 3002	EOL	ZN11	
51	AHU # 1	DS	ZN 15	
52	AHU # 1	EOL	ZN 15	
53	AHU # 2	DS	ZN 16	
54	AHU # 2	EOL	ZN 16	
	PENTHOUSE			
57	AHU # 3	DS	ZN 17	
58	AHU # 3	EOL	ZN 17	
59	AHU # 4	DS	ZN 18	
60	AHU # 4	EOL	ZN 18	
61	AHU # 5	DS	ZN 20	
62	AHU # 5	EOL	ZN 20	
63	AHU # 6	DS	ZN 19	
64	AHU # 6	EOL	ZN 19	
	AHU #7	DS	ZN21	
65	AHU # 7	EOL	ZN 21	
	AHU #8	DS	ZN22	
	AHU #8	EOL	ZN22	
	AHU #9	DS	ZN27	
66	AHU #9	EOL		
70	AUTO BODY	TS	ZN 34	
71	PRODUCTION LAB	TS	ZN 39	
72	STAIRWELL # 1 ELEVATOR SHAFT	TS	ZN 38	
73	SPRINKLER RM (Large Riser)	TS	ZN 32	

74	SPRINKLER RM (Small Riser)	TS	ZN 31	
75	SPRINKLER RM (Main Gate Valve)	TS	ZN 33	
76	SPRINKLER RM (Large Riser)	PS	ZN 29	
77	SPRINKLER RM (Small Riser)	PS	ZN 24	
	NOTIFYING DEVICES			
	1ST LEVEL			
1	OUTSIDE CONFERENCE RM	B	SIG 3	
2	OUTSIDE RM # 101	B	SIG 3	
3	OUTSIDE RM # 104	B	SIG 3	
4	CORR TO SHOP HALLWAY	B	SIG 3	
5	WOODSHOP	V	SIG 5	
6	AUTOMOTIVE	V	SIG 5	
	MAIN LEVEL			
7	CAFETERIA	B	SIG 4	
8	OUTSIDE PHONE RM # 2	B	SIG 4	
9	LIBRARY	B	SIG 4	
10	OUTSIDE STUDENT SERVICES	B	SIG 4	
11	ACROSS FROM RM # 223	B	SIG 4	
12	ACROSS FROM RM # 212	B	SIG 4	
13	OUTSIDE RM # 214	B	SIG 4	
14	COMPUTER LAB HALLWAY	B	SIG 4	
15	ACROSS FROM RM # 202	B	SIG 4	
16	GYM	B	SIG 4	
	3RD LEVEL			
17	TOP OF STAIRWELL # 1	B	SIG 6	
18	OUTSIDE RM # 315	B	SIG 6	
19	ABOVE RM # 306	B	SIG 6	
20	OUTSIDE RM # 314	B	SIG 6	
21	OUTSIDE RM # 312	B	SIG 6	
22	MAINTENANCE STORAGE RM	B	SIG 6	
23	MECH RM 3002	B	SIG 6	
	PENTHOUSE			
24	PENTHOUSE	B	SIG 6	
25	PENTHOUSE	B	SIG 6	
	AUX POINTS			
26	DOOR HOLDER MAIN / 1ST LEVEL	RLY	AUX 3	
27	DOOR HOLDER 3RD LEVEL	RLY	AUX 4	
28	FAN SHUTDOWN	RLY	AUX 5	
29	KITCHEN HOOD SYSTEM	RLY	AUX 6	
Signal Circuits : SIG 3, SIG 4, SIG 5 , and SIG 6 must be disabled before testing				

Auxiliaries Circuits : AUX 3 , AUX 4 , AUX 5, and AUX 6 must be disabled before testing.

Fire Door Number or Location

NORTH ENTRY TO LOBBY

STAIR 2 TO LEV 1&3

STAIR 1 TO LEV 2&3

2ND FLOOR BY MUSIC ROOM

2ND FLOOR BY ROOM 212

GYM SOUTH EXIT

CORRIDOR ADJ SOUTH EXIT

BY MAIN OFFICE

3RD FLOOR BY ELEVATOR

3RD FLOOR BY 312

2ND FLOOR STAIR 3 TO LEVEL 3

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head		Cov	Bat. VAH	
	1ST LEVEL		unit			
1	Across from Elevator		unit		6V/7.2Ah	
2	Stairwell # 2		unit		6V/7.2Ah	
3	By Women w'rm by Str 2		unit		6v/12Ah	
4	By Rm # 101		unit		6V/7.2Ah	
5	By Rm # 103		unit		6V/7.2Ah	
6	By Rm # 104		unit		6V/7.2Ah	
7	By Rm # 108		yes		6V/7.2Ah	
8	Corr by Rm #111		unit		6V/7.2Ah	
9	By Rm # 112		unit		6V/4.5Ah	
10	Rm 110 WOODSHOP		unit		6V/7.2Ah	
11	Rm 111		unit		6V/7.5Ah	
12	Rm 112		unit		6V/7.2Ah	
13	bottom stairwell #1	yes				
14	By Rm #108/ Exit	yes				
15	Girls Washroom	yes				
16	Boys Washroom	yes				
17	By Rm #101/Exit	yes				
			unit			
	MAIN LEVEL		unit			
18	Cafeteria		unit		6V/7.2Ah	
19	Cafeteria		unit		6V/7.2Ah	
20	Cafeteria		unit		6V/7.2Ah	
21	North Ent.-By FACP.		unit		6V/7.2Ah	

22	Lobby Area		unit		6V/7.2Ah
23	By Library		yes		6V/7.2Ah
24	By Student Services		unit		6V/7.2Ah
25	Student Services		yes		6V/7.2Ah
26	Student Services		unit		6V/7.2Ah
27	Office		unit		6V/7.2Ah
28	Main Entrance	yes			6V/7.2Ah
29	Lobby Area by Phones		unit		6V/7.2Ah
30	By Rm # 225		unit		6V/7.2Ah
31	By Rm # 221		unit		6V/7.2Ah
32	Electrical Rm		unit		6V/7.2Ah
33	Gym-By Score Clock		unit		6V/7.2Ah
34	Gym		unit		6V/7.2Ah
35	Gym		unit		6V/7.2Ah
36	Gym		unit		6V/7.2Ah
37	By Rm # 212		unit		6V/7.2Ah
38	Outside Gym/South		unit		6V/7.2Ah
39	South Entrance		unit		6V/7.2Ah
40	By Rm #211		unit		6V/7.2Ah
41	By Rm # 209		unit		6V/7.2Ah
42	By Rm # 205		unit		6V/7.2Ah
43	By Rm # 202		yes		6V/7.2Ah
44	By Boy's Washroom		unit		6V/7.2Ah
45	Stairwell # 2		yes		6V/7.2Ah
46	BY 215		unit		6V/7.2Ah
47	Kitchen		unit		6V/7.2Ah
48	Teachers Lounge		unit		6V/7.2Ah
49	Teachers Lounge Hall		unit		6V/7.2Ah
50	Library		unit		6V/7.2Ah
51	Library		unit		6V/7.2Ah
52	Library		unit		6V/7.2Ah
53	Boys washroom		unit		6V/7.2Ah
54	Girls washroom		unit		6V/7.2Ah
55	Stairs#1/Middle Landing		unit		6v/7.2Ah
	3RD LEVEL		unit		
56	Mech Rm 3002		unit		6V/7.2Ah
57	Stairwell # 3		unit		6V/12Ah
58	By Rm # 312		unit		6V/12Ah
59	By Rm # 309		unit		6V/7.2Ah
60	By Rm # 305		unit		6V/7.2Ah
61	By Rm # 301	yes			6V/7.2Ah
62	By Rm # 302		unit		6V/7.2Ah
63	By Boy's Washroom		yes		6V/7.2Ah

64	By Maintenance Storage		unit		6V/12Ah
65	By Student Health Office		unit		6V/7.2Ah
66	Stairwell # 1		unit		6V/7.2Ah
67	Stairwell # 2		unit		6V/7.2Ah
68	Maintenance Storage		unit		6V/7.2Ah
	PENTHOUSE		unit		
70	Penthouse Lr Stairs		unit		6V/12Ah
71	Penthouse Up Stairs		unit		6V/7.2Ah
72	Penthouse North		unit		6V/7.2Ah
73	Penthouse South		unit		6V/7.2Ah
74	Stage		unit		
75	Gym Storage 2nd floor		unit		

LOCATION: Bell Park Fire Alarm Panel: Edwards 6500	Device	Device address or circuit number	Annunciation
--	----------------------	--	----------------------------

MANUAL PULL STATIONS

1	BOILER ROOM	M	Zone 1	
2	MAIN ENTRANCE	M	Zone #1	
3	NORTH WING Opp Rm # 6	M	Zone 1	
4	GYM EXIT NORTH	M	Zone 1	
5	CENTER HALL	M	Zone 1	
6	SOUTH WING By Rm # 101	M	Zone 1	
	GYM	M	Zone 1	
7	GYM	EOL	Zone 1	

2 ND FLOOR

1	2 ND FLOOR SOUTH END	M	Zone #1	
2	2 ND FLOOR CENTRE HALL	M	Zone 1	
3	2 ND FLOOR NORTHEND BY VP OFFICE	M	Zone 1	
4	FAN ROOM	DS	Zone 3	
5	FAN ROOM BY ENTRANCE	DS	Zone 3	

NOTIFYING DEVICES

1	SOUTH END	B	Sig #1	
2	CENTRE HALL	B	Sig #1	
3	CENTRE HALL	B	Sig #1	
4	NORTH END	B	Sig #1	
1	GYM	B	Sig #1	
2	2 ND FLOOR SOUTH END	B	Sig #1	
3	2 ND FLOOR CENTRE HALL	B	Sig #1	
1	2ND FLOOR NORTH END	B	Sig #1	

HEAT DETECTORS

	SOUTH END STAIRWAY	HT		
	CENTRE HALL STAIRWAY	HT		

DUCT SMOKES

FAN ROOM	DS
FAN ROOM BY ENTRANCE	DS

2	
2	

SMOKE DETECTORS

SOUTH END STAIRWAY	S	2
CENTRE HALL STAIRWAY	S	2

SPRINKLER DEVICES

TANK #1	GV	3
TANK #1	FLOW	3
TANK #2	GV	3
TANK #2	FLOW	3
MAIN RISER	GV	3
MAIN RISER	FLOW	3

NORTH END STAIR	S	6
-----------------	---	---

NOTIFYING DEVICES

SOUTH END	B	SIG 1
CENTREL HALL	B	SIG 1
CENTRE HALL	B	SIG 1
NORTH END	B	SIG 1
GYM	B	SIG 1
2ND FLOOR SOUTH END	B	SIG 1
2ND FLOOR CENTRE HALL	B	SIG 1

2ND FLOOR NORTH END	B	SIG 1
---------------------	---	-------

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #
1	MAIN ENTRANCE	2	EMERGI-LITE	
4	HALL BY GYM	2	LUMACELL	
3	SOUTH STAIR			
	GYM SOUTH			
	GYM NORTH			
4	HALL BY 104		STANPRO	
7	HALL BY 106		STANPRO	
8	BOTTOM CENTRE STAIR		LUMACELL	
15	HALL BY 113			
13	HALL BY 212			
	CENTRE STAIR			
11	HALL BY 215			
9	HALL BY 217			
	TOP SOUTH STAIR			
	O/S ELECTRICAL RM		UNIT	

LOCATION:Caldwell Rd. Fire Alarm Panel: Edwards 6500	Device	Correctly installed	Requires service	Alarm confirmation	Sensitivity reading	Device address or circuit number	Annunciation
--	--------	---------------------	------------------	--------------------	---------------------	----------------------------------	--------------

MANUAL PULL STATIONS									
1	FRONT ENTRY BY ROOM 8	M						ZN -2	
2	NORTH EXIT BY ROOM 11	M						ZN -2	
3	CARETAKER'S RM 6	M						ZN -2	
4	MAIN ENTRY	M						ZN-1	
5	BACK EAST EXIT BY MUSIC RM # 122	M						ZN-1	
6	GYM BACK WALL	M						ZN-1	
7	NEW END EXIT BY RM 115	M						ZN-1	
8	HALL 2ND FLOOR BY RM 202	M						ZN-1	
9	NEW END EXIT BY RM 112A	M						ZN-1	
10	HALL 2ND FLOOR BY RM 209	M						ZN-1	
11	BOILER ROOM	M						ZN -2	
HEAT DETECTORS									
1	SOUTH STAIRWELL	HT						ZN-1	
2	WEST STAIRWAY	HT						ZN-1	
SPRINKLER DEVICES									
1	BOILER ROOM	FSP						ZN-3	
2	BOILER ROOM	SV						ZN-9	
NOTIFYING DEVICES									
1	1ST FLOOR NEW END	B						SIG 1	
2	HALL 2ND FLOOR	B						SIG 1	
3	GYM	B						SIG 1	
4	EAST EXIT	B						SIG 1	
5	MAIN LOBBY	B						SIG 1	
6	OLD HALL	B						SIG 1	
7	NORTH HALL	B						SIG 1	
8	NORTH HALL	B						SIG 1	
9	BOILER ROOM	B						SIG 1	
DUCT DEVICES									
1	Air Handel Unit	DS						5	
2	Air Handel Unit	DS						5	

FIRE ALARM NOTES AND RECOMMENDATIONS

WHEN CITY DISCONNECT IS BYPASSED
THE DOORS WILL STAY OPEN.

FIRE DOORS

BY ROOM 5

BY ROOM 3

BACK EAST HALL

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cable Head	Cover	Exit Bulb A/C/D	Batt. V A H	Manuf.	Serial #
	PANEL "A" Cct # 39 MAIN HALL							
1	Main Hall Exit By Rm 11		Y				emergi-lite	
2	Hall By Room 3		Y				lithonia	
3	Hall By Room 4		Y				emergi-lite	
4	Main Entry		Y				emergi-lite	
5	1ST Floor Hall By Rm 8		Y				emergi-lite	
	PANEL "B" Cct # 17 In Rm124							
6	East Back Hall By Rm 123		Y				emergi-lite	
7	Gym Far Wall		Y				emergi-lite	
8	Gym		Y				emergi-lite	
9	Hall By Library		Y				emergi-lite	
10	2ND Floor Hall		Y			6V	emergi-lite	
11	Top Of Stair By 202		Y				emergi-lite	
12	Bottom Of Stair By 116		Y				emergi-lite	
13	Top Of Stair By 209		Y				emergi-lite	
14	Bottom of Stair By Library		Y				emergi-lite	

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1	BREAKER PANEL "A" BY MAIN ENTRY, CCT# 39 CONTROLS LIGHTS IN OLD BUILDING & FRONT ENTRY WHICH ARE DEVICES 1 THROUGH 5							
2	BREAKER PANEL "B" IN VICE PRINCIPALS OFFICE RM 124 Cct # 17 CONTROLS LIGHTS IN GYMNASIUM AND NEW							

SECTION WHICH ARE DEVICES 6 THROUGH 14							
---	--	--	--	--	--	--	--

	LOCATION:Graham Creighton	Device	Device address or circuit number	Annunciation	NOTES
FIRE ALARM PANEL: CERBERUS MXL					
MANUAL PULL STATIONS					
1	CORR BY 175	MA	1-006		
2	CORR BY 168	MA	1-008		
3	CORR BY 181	MA	1-058		
4	LOBBY CENTER STAIRS	MA	1-013		
5	MAIN LOBBY	MA	1-016		
6	GYM EXIT	MA	1-038		
7	BY EAST STAIRS	MA	1-043		
8	CORR BY 129	MA	1-048		
9	VESTIBULE BY 130	MA	1-049		
10	CORR BY 135(IN COMMUNITY RM)	MA	1-050		
11	BOILER RM 155 (OUTDOORS)	MA	1-029		
12	ELECTRICAL RM 154 (OUTDOORS)	MA	1-034		
13	STORAGE RM 153 (OUTDOORS)	MA	1-036		
14	CORR BY 253	MA	2-002		
15	CORR BY ELECTRICAL RM 244	MA	2-008		
16	CORR BY 234	MA	2-011		
17	CORR BY CENTER STAIRS	MA	2-012		
18	EAST STAIRS	MA	2-027		
SMOKE DETECTORS					
1	CORR BY 181	SA	1-002		
2	CORR BY 186	SA	1-003		
3	CORR BY 178	SA	1-004		
4	ELECTRICAL RM 175	SA	1-005		
5	STORAGE RM 170 (IN RM 168)	SA	1-007		
6	CORR BY 169	SA	1-009		
7	CORR BY 165	SA	1-010		
8	CORR BY 161	SA	1-011		
9	MAIN LOBBY	SA	1-012		
10	COMMUNICATIONS RM 115	SA	1-014		
11	MAIN LOBBY	SA	1-015		
12	GYM STORAGE	SA	1-037		

13	CORR BY CAFETERIA	SA	1-039		
14	CORR BY CAFETERIA	SA	1-040		
15	STORAGE RM 122 (IN KITCHEN)	SA	1-041		
16	ELECTRICAL RM 123	SA	1-042		
17	RECYCLING RM 128	SA	1-044		
18	STORAGE RM 127 (IN MUSIC RM 126)	SA	1-045		
19	COMMUNITY OFFICE RM 130	SA	1-046		
20	CORR BY 126	SA	1-047		
21	STORAGE RM 133	SA	1-051		
22	STORAGE RM 135 B	SA	1-055		
23	STORAGE RM 135 A	SA	1-056		
24	UNDER STAGE	SA	1-053		
25	UNDER STAGE	SA	1-054		
26	ELECTRICAL RM 154 (OUTDOORS)	SA	1-033		
27	STORAGE RM 153 (OUTDOORS)	SA	1-035		
28	TOP OF NORTH WEST STAIRS	SA	2-001		
29	ELECTRICAL RM 244	SA	2-007		
30	TOP OF SOUTH WEST STAIRS	SA	2-009		
31	STORAGE RM 236 (IN RM 234)	SA	2-010		
32	TOP OF CENTER STAIRS	SA	2-013		
33	COMMUNICATIONS RM 207	SA	2-014		
34	RM 214	SA	2-017		
35	STORAGE RM 211 (IN RM 210)	SA	2-018		
36	ELECTRICAL RM 215	SA	2-019		
37	STORAGE RM 217	SA	2-026		
38	TOP OF EAST STAIRS	SA	2-028		
39	STORAGE RM 223 (IN RM 222)	SA	2-029		
40	STORAGE RM 224 (IN RM 222)	SA	2-030		
41	ELEVATOR SHAFT	SA	2-016		
RELAYS ,ETC					
1	ELEVATOR CAPTURE		1-057		
2	DOOR RELEASE WEST DOORS	RLY	1-032		
3	DOOR RELEASE EAST DOORS	RLY	2-032		
4	FAN CONTROL	RLY	2-036		
5	KITCHEN HOOD C02	N/O	2-037		
6	SHUNT TRIP KITCHEN RANGE & OVEN	RLY	2-038		
7	SHUNT TRIP RELAY EXHAUST FAN	RLY	2-040		
DUCT SMOKE DETECTORS					
1	FAN RM 257 SUPPLY #1	DSA	2-003		
2	FAN RM 257 SUPPLY #2	DSA	2-005		
3	FAN RM 257 SUPPLY #2	DSA	2-006		
4	RM 218 SUPPLY #3	DSA	2-020		
SPRINKLER DEVICES					

1	SPRINKLER MAIN FLOW WEST 1ST & 2ND	FS	1-017		
2	SPRINKLER MAIN TAMPER WEST 1ST & 2ND	SV	1-018		
3	SPRINKLER FLOW CENTER / EAST 2ND	FS	1-019		
4	SPRINKLER TAMPER CENTER / EAST 2ND	SV	1-020		
5	SPRINKLER FLOW CENTER / EAST 1ST	FS	1-021		
6	SPRINKLER TAMPER CENTER / EAST 1ST	SV	1-022		
7	SPRINKLER FLOW NEW EAST SECTION	FS	1-023		
8	SPRINKLER TAMPER NEW EAST SECTION	SV	1-024		
9	SPRINKLER FLOW WEST WING 1ST	FS	1-025		
10	SPRINKLER TAMPER WEST WING 1ST	SV	1-026		
11	SPRINKLER BACK FLOW PREVENTER 1	SV	1-027		
12	SPRINKLER BACK FLOW PREVENTER 2	SV	1-028		
13	SPRINKLER TAMPER ELEVATOR PIT	SV	1-031		
14	SPRINKLER SHUTOFF WELL (CHAIN LIFT)		1-052		
15	SPRINKLER VALVE ELEVATOR SHAFT	FS	2-015		
16	SPRINKLER FLOW WEST WING 2ND	FS	2-024		
17	SPRINKLER TAMPER WEST WING 2ND	SV	2-025		
NOTIFYING DEVICES					
1	CORR BY 185	MH	1-001		
2	CORR BY 178	MH	1-001		
3	CORR BY 172	MH	1-001		
4	CORR BY 164	MH	1-001		
5	CORR BY 113	MH	1-001		
6	GYM	MH	1-001		
7	GYM	MH	1-001		
8	GYM	MH	1-001		
9	GYM	MH	1-001		
10	BOYS CHANGING RM	MH	1-001		
11	GIRLS CHANGING RM	MH	1-001		
12	CORR BY CAFETERIA	MH	1-001		
13	CAFETERIA	MH	1-001		
14	MUSIC RM	MH	1-001		
15	BY 129	MH	1-001		
16	COMMUNITY ACTIVITY RM 135	MH	1-001		
17	CORR BY 249	MH	2-002		
18	RM 251	MH	2-002		
19	CORR BY 247	MH	2-002		
20	FAN RM 257	MH	2-002		
21	CENTER STAIR LOBBY	MH	2-002		
22	CORR BY 230	MH	2-002		
23	CORR BY 205	MH	2-002		
24	FAN RM 218	MH	2-002		
25	CORR BY ELEC RM 215	MH	2-002		

26	CORR BY 220	MH	2-002		
EMERGENCY LIGHTING					
Li ne #	EL UNIT Location	Chargi ng VAR	Remote Head	Ca b. He ad	Bat. VAH
ELECTRICAL RM 215, PNL"DP-3, CCT #3					
	In 215(pack w/lights)			Y	
	BY 222		Y		
	BY 219		Y		
	BY 214		Y		
	IN 218(PACK W/LIGHTS)			Y	
	STAIR BY 222		Y		
	IN 206(PACK W/LIGHTS)			Y	
	IN 208 W/R		Y		
	BY 208 W//R		Y		
	IN 204 FEM W/R		Y		
	TOP CTR STAIR		Y		
	BY CTR STAIRS		Y		
ELECRTICAL RM 244, PNL"DP-4, CCT # 3					
	BY LOCKER 456		Y		
	BY LOCKER 308		Y		
	BY LOCKER 346		Y		
	TOP STAIR BY 234(PACK)				
	BY 244		Y		
	IN 244(PACK W/LIGHTS)				
	FEM W/R BY 245		Y		
	BY 257		Y		
	BY 255		Y		
	BY 253		Y		
	IN 253 STAFF W/R		Y		
	TOP STAIR BY 253		Y		
	BOTT STAIR BY 151		Y		
	IN 175(PACK W/LIGHTS)			Y	4- 6V 12AH
	BY 184		Y		
	BY 186		Y		
	FEM W/R BY 176		Y		
	M W/R 174		Y		
	BOTT STAIR BY 168		Y		

	BY LOCKER 56			Y	
	BY LOCKER 106		Y		
	BY LOCKER 68		Y		
	BY 161		Y		
	IN 161		Y		
	113 STAFF W/R(PACK W/LIGHTS			Y	
	BOTT STAIR BY 112		Y		
	BY 112 FEM W/R		Y		
	IN 112 FEM W/R		Y		
	IN 116 M W/R		Y		
	BY 118		Y		
	RM 123(PACK W/LIGHTS			Y	
	CAFETERIA BY WINDOW		Y		
	CAFETERIA		Y		
	KITCHEN		Y		
	BY 137 GYM ENTRY		Y		
	BY 121 KITCHEN		Y		
	BY 126 MUSIC RM		Y		
	BY 138 STAGE LIFT		Y		
	STAGE LIFT AREA(PACK W/LIGHTS			Y	
	STAGE LEFT		Y		
	STAGE RIGHT		Y		
	BY 132 (PACK W/LIGHTS			Y	
	134 W/R		Y		
	COMM CORRIDOR		Y		
	PACK BY GYM STAGE				
	GYM		Y		
	GYM		Y		
	GYM		Y		
	GYM		Y		
	PACK IN GYM OFFICE				
	GYM		Y		
	GYM		Y		
	GYM		Y		
	GYM		Y		
	ELECTRICAL RM 154				READYLITE
	BOILER ROOM		Y		
	130 COMM. RM		Y		
	HRM COMMUNITY RM.		Y		
	HRM COMMUNITY RM.		Y		

	LOCATION: Humber Park	Device	Device address or circuit number	Annunciation	NOTES

FIRE ALARM PANEL: Edwards 2280

MANUAL PULL STATIONS					
1	NORTH HALL	MA	ZONE 1		
2	MAIN ENTRY	MA	ZONE 2		
3	SOUTH EXIT	MA	ZONE 3		
4	GYM	MA	ZONE 8		
5	OUTSIDE LIBRARY	MA	ZONE 8		
6	OUTSIDE GYM BY MILK FRIDGE	MA	ZONE 8		
HEAT DETECTORS					
1	JANITORS ROOM	RHT	ZONE 2		CR135
2	BOILER ROOM	HT	ZONE 2		CF 190
SPRINKLER DEVICES					
1	SPRINKLER FLOW	FS	ZONE 4		
2	SPRINKLER TAMPER	FV	ZONE 7		
NOTIFYING DEVICES					
1	GYM	B	SIG 1		
2	GYM	B	SIG 1		
3	OUTSIDE GYM	B	SIG 1		
4	NORTH HALL	B	SIG 1		
5	NORTH HALL	B	SIG 1		
6	CENTER HALL	B	SIG 2		
7	SOUTH EXIT	B	SIG 2		
END OF LINE DEVICES					
1	NORTH HALL	EOL	ZONE 1		
2	BOILER ROOM	EOL	ZONE 2		
3	SOUTH EXIT	EOL	ZONE 3		
4	OUTSIDE GYM BY MILK FRIDGE	EOL	ZONE 8		
5	NORTH HALL	EOL	SIG 1		
6	SOUTH EXIT	EOL	SIG 2		
EMERGENCY LIGHTING INSPECTION REPORT					
L i n e #		Remarks	Bat. VAH	M O D #	Serial #
	EL UNIT Location				
PANEL "D" ,CCT #28 IN JANITOR ROOM BY GYM					

1	NORTH EXIT		6V 7.2AH		
2	GYM		6V 7.2AH		
3	GYM		6V 7.2AH		
	GYM STAGE?				
PANEL BY RM 26 ,CCT # 10					
4	SOUTH HALL		6V 5AH		
5	MAIN ENTRY		6V 5AH		
6	NORTH HALL		6V 5AH		
7	NORTH HALL		6V 7.2AH		
Fire Door Number or Location					
MAIN FOYER ADJ OFFICE					
BY SOUTH EXIT					
BY ROOM 22					
NORTH EXIT BY ROOM 29					

	LOCATION: Atlantic View	Device	Device address or circuit number
	Fire Alarm Panel: Simplex 4100U		
	DEVICES		
2	WEST EXIT	M	ZN 5
3	WEST HALL	M	ZN 5
4	OLD FURNACE RM EXIT	M	ZN 5
5	OLD FURNACE RM	HT	ZN 5
	EAST EXIT	M	ZN 7
6	GYM EXIT	M	ZN 7
7	FURNACE RM / MECH ROOM	M	ZN 7
8	SPRINKLER RM	M	ZN 7
	MAIN ENTRANCE	M	ZN 7
	GYM ENTRANCE	M	ZN 7
10	SPRINKLER RM (LOW WATER TANK 1)	0	ZN 9
11	SPRINKLER RM (LOW WATER TANK 2)	0	ZN 10
12	SPRINKLER RM (LOW AIR TANK 1)	PS	ZN 1
13	SPRINKLER RM (LOW AIR TANK 2)	PS	ZN 3
14	SPRINKLER RM (TAMPER SWITCH)	SV	ZN 4
15	SPRINKLER RM (TAMPER SWITCH)	SV	ZN 4
16	SPRINKLER RM (TAMPER SWITCH)	SV	ZN 4
17	SPRINKLER RM (WATER FLOW)	FSP	ZN 2
	SPRINKLER RM DUCT SMOKE	DS	ZN 6
18	SPRINKLER RM DUCT SMOKE	DS	ZN 6
	AUDIBLES		
	OLD BLDG WEST HALL	B	SIG 1
21	OLD BLDG WEST HALL	B	SIG 1
22	OLD BLDG WEST HALL	B	SIG 1
23	NEW BLDG HALL	B	SIG 2
24	NEW BLDG HALL	B	SIG 2
25	GYM	B	SIG 2
26	FURNACE RM	B	SIG 2
27	OLD FURNACE RM	B	SIG1
28	SPRINKLER RM	B	SIG2

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH	Manuf.
1	Main Entry		Y	6V 7AH	EMER GI - LITE
2	West Hall-across from room#6		Y	6V 7AH	EMER GI - LITE
3	west Hall-By girls washroom		Y	6V 7AH	EMER GI - LITE
4	West Hall-across from room #2		Y	6V 7AH	EMER GI - LITE
5	West Hall Remote-By room #3		Y	6V 7AH	EMER GI - LITE
6	West Hall Remote-across from #8		Y	6V 7AH	EMER GI - LITE
7	East By Library		Y	6V 7AH	EMER GI - LITE
8	Office Hall Remote	Y	Y	6V 7AH	EMER GI - LITE
9	New Furnace Room		Y	6V 7AH	EMER GI - LITE
10	Electrical room Remote	Y	Y	6V 7AH	EMER GI - LITE
11	Gym		Y	6V 7AH	EMER GI - LITE
12	Gym		Y	6V 7AH	EMER GI - LITE
13	East-across from sprinkler room.		Y	6V 7AH	STAN PRO

14	across from sprinkler room				
----	----------------------------	--	--	--	--

	LOCATION: Nelson Whynder	Device	Device address or circuit number

FIRE ALARM PANEL:Simplex 4002

MANUAL PULL STATIONS

1	LIBRARY EXIT 101	M	Zone #1
2	MAIN LOBBY 120	M	Zone #1
3	EXIT CORRIDOR 123	M	Zone #1
4	VESTIBULE 151 BY ELECTRICAL RM	M	Zone #2
5	BY MECHANICAL RM EXIT	M	Zone #2
6	LOBBY	M	Zone #2
7	GYM EXIT 174	M	Zone #3
8	KITCHEN EXIT 176	M	Zone #4
9	GYM EAST EXIT 124	M	Zone #3
10	MECHANICAL ROOM 141	M	Zone #7
11	PENTHOUSE 203	M	Zone #8
12	PENTHOUSE 202	M	Zone #11
13	PENTHOUSE 201	M	Zone #12

SMOKE DETECTORS

1	AV STORAGE 103	S	Zone #1
2	BOOK STORAGE 142	S	Zone #2
3	OUTSIDE STORAGE 182	S	Zone #5
4	ELECTRICAL ROOM 147	S	Zone #6
5	TELEPHONE ROOM 158	S	Zone #2
6	MUSIC STORAGE 159	S	Zone #2
7	STORAGE 146	S	Zone #2
8	MUSIC STORAGE 160	S	Zone #2
9	GYM STORAGE 169	S	Zone #3
10	GYM STORAGE BY KITCHEN	S	Zone #3
11	GYM STORAGE RIGHT	S	Zone #3
12	KITCHEN STORAGE 175	S	Zone #4

HEAT DETECTORS

1	PENTHOUSE 202	RHT	Zone #11
2	PENTHOUSE 201	RHT	Zone #12
3	PENTHOUSE 203	HT	Zone #8
4	JANITORS ROOM 143 BY GIRLS W/R 140	HT	Zone #2
5	JANITORS ROOM 139	HT	Zone #2
6	JANITORS ROOM 113	RHT	Zone #1

7	KITCHEN 178	HT	Zone #4
8	MECHANICAL ROOM 141	HT	Zone #7
9	STORAGE RM ACROSS FROM MUSIC RM	RHT	Zone #2

DUCT SMOKE DETECTORS

1	PENTHOUSE 203/SUPPLY	DS	Zone #9
2	PENTHOUSE 203/RETURN	DS	Zone #9
3	PENTHOUSE 201/SUPPLY	DS	Zone #10
4	PENTHOUSE 201/RETURN	DS	Zone #10

SPRINKLER DEVICES

1	MECHANICAL ROOM (LOW PRESSURE)	PS	Zone #14
2	ELECTRICAL ROOM 147	TS	Zone #15
3	SPRINKLER ROOM 141	TS	Zone #16
4	WET SPRINKLER VALVE	PS	Zone #17
5	KITCHEN HOOD SUPPRESSION	AD	Zone #18
6	OUTSIDE MECHANICAL ROOM 141	TS	Zone #19
7	AHU SUTT DOWN	R	

NOTIFYING DEVICES

68	SOUTH HALL 128	B	Sig #1
69	EAST HALL 145	B	Sig #1
70	WEST HALL 145	B	Sig #1
71	MECHANICAL ROOM 141	B	Sig #1
72	HALL 152	B	Sig #1
73	GIRLS CHANGE ROOM	B	Sig #1
74	BOYS CHANGE ROOM	B	Sig #1
75	WEST GYM 174	B	Sig #1
76	WEST GYM 171	B	Sig #1
77	PENTHOUSE 202	B	Sig #1
78	PENTHOUSE 203	B	Sig #1
79	NORTH HALL	B	Sig #1
80	EAST HALL	B	Sig #1
81	LOBBY 120	B	Sig #1
82	LIBRARY 101	B	Sig #1
83	PENTHOUSE 201	B	Sig #1

END OF LINE RESISTORS

44	PENTHOUSE 201	EOL	Zone #10
50	PENTHOUSE 201	EOL	Zone #12
40	PENTHOUSE 203	EOL	Zone #9
24	KITCHEN STORAGE 175	EOL	Zone #4
20	STORAGE 181	EOL	Zone #3

EMERGENCY LIGHTING			
---------------------------	--	--	--

Line #	EL UNIT Location	Remote Head	Cab. Head
1	Main Entrance		Y
2	*Main Entrance Hall BY RM 108	Y	
3	*Fan Room 201	Y	
4	*Fan Room Stairs	Y	
5	Library		Y
6	*Library	Y	
7	*Library	Y	
8	By Staff Washroom 112		Y
9	By Room 134		Y
10	*By Room 131	Y	
11	By Music Room 157		Y
12	MECHANICAL ROOM	Y	
13	By Room 148		Y
14	*By Room 137	Y	
15	*By Storage 146	Y	
16	*Electrical Room	Y	
17	*Exit by Storage 146	Y	
18	By Room 149		Y
19	*Boys Washroom Remote	Y	
20	*Girls Washroom Remote	Y	
21	By PENTHOUSE 202		Y
22	*PENTHOUSE 202	Y	
23	*PENTHOUSE 202 Stairs	Y	
24	*Gym Entrance	Y	
25	*Lobby Entrance	Y	
26	*Handicap Male Washroom	Y	
27	*Handicap Female Washroom	Y	
28	Gym BY BOYS CHANGEROOM		Y
29	*Boys Change Room	Y	
30	Gym by GIRLS CHANGEROOM		Y
31	*Girls Change Room	Y	
32	Gym by CANTEEN		Y
33	*Kitchen	Y	
34	*Kitchen Exit	Y	
35	Gym Back Wall		Y
36	*Gym Exit	Y	
37	Hall Behind Stage		Y
38	*Mechanical Room	Y	
39	*Music Room	Y	
40	*Fan Room 203	Y	

41	*Fan Room Stairs	Y	
EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS			
1	THERE IS A BREAKER IN JANITOR ROOM 113; PANEL "A", CCT#29 THAT CONTROLS MAIN ENTRANCE, LIBRARY AREAS		
2	THERE IS A BREAKER IN MAIN ELECTRICAL RM; PANEL"B", CCT#19 THAT CONTROLS AREAS AROUND ELECTRICAL RM		
3	PANEL IN ROOM IN GYM BY GIRLS WASHROOM ,PANEL "C", CCT#45		

	LOCATION:Ross Rd.	Device	Device address or circuit number	Annunciation	NOTES
	FIRE ALARM PANEL: Simplex 4007ES				
	Devices				
1	MAIN ENTRANCE	M	ZN1		
2	ROOM 115	RHT	ZN1		
3	BY ROOM 129	M	ZN1		
4	ROOM 119	RHT	ZN1		
5	HALLWAY AT GYM MAIN DOORS	M	ZN1		
6	BY ROOM 136	M	ZN1		
7	BY ROOM 131	M	ZN1		
8	ART ROOM STORAGE	M	ZN1		
9	ART ROOM STORAGE	HT	ZN1		
10	MUSIC ROOM OFFICE	HT	ZN1		
11	MUSIC ROOM EXIT	M	ZN1		
12	GYM STORAGE	HT	ZN1		
13	GYM STORAGE	HT	ZN1		
14	GYM EXIT	M	ZN1		
15	GYM EXIT	EOL	ZN1		
16	BY ROOM 113	M	ZN2		
17	STORAGE ROOM 101	RHT	ZN2		
18	BY ROOM 106	M	ZN2		
19	FAN ROOM 104	DS	ZN2		
20	FAN ROOM 104	RHT	ZN2		
21	KITCHEN	RHT	ZN3		
22	KITCHEN STORAGE	RHT	ZN3		
23	OPPOSITE ROOM 120	M	ZN3		
24	LIBRARY	M	ZN3		
25	CAFETERIA ENTRANCE	M	ZN3		
26	CAFETERIA EXIT	M	ZN3		
27	OPPOSITE ROOM 120	EOL	ZN3		
28	EAST STARWELL	S	ZN4		
29	BY ROOM 208	M	ZN4		
30	BY ROOM 216	M	ZN4		
31	CARETAKER'S ROOM 214	RHT	ZN4		
32	ROOM 205	HT	ZN4		
33	STORAGE ROOM 200	RHT	ZN4		

34	FAN ROOM 206	RHT	ZN4		
35	FAN ROOM (INSIDE 214)	DS	ZN4		
36	FAN ROOM (INSIDE 214)	RHT	ZN4		
37	FAN ROOM (INSIDE 214)	RHT	ZN4		
38	BY ROOM 208	EOL	ZN4		
39	BOILER ROOM	M	ZN3		
40	BOILER ROOM	HT	ZN3		
41	BOILER ROOM	HT	ZN3		
42	ROOM 207	HT			
43	ROOM 135	HT			
44	MAIN SPRINKLEER	FS			
45	ROOM 212	RHT			
43	SIGNALS				
44	BY ROOM 122	B	SIG 1		
45	BY ROOM 129	B	SIG 1		
46	BY ROOM 136	B	SIG 1		
47	BY ROOM 132	B	SIG 1		
48	ART ROOM STORAGE	B	SIG 1		
49	GYM	B	SIG 1		
50	BY ROOM 113	B	SIG 1		
51	CAFETERIA	B	SIG 1		
52	BY ROOM 106	B	SIG 1		
53	BY ROOM 209	B	SIG 1		
54	BY ROOM 216	B	SIG 1		
55	BOILER ROOM	B	SIG 1		

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Remote Head	Cab. Head	Device address or circuit number
1	Mid Ramp by Gym			13
2	Top of Ramp by Gym			6
3	Gym Right			10
4	Gym Left Front			11
5	Gym Left Rear			12
6	By Music Room			7
7	Music Room Ramp			8
8	Music Room Exit			9
9	By Room 130			5
10	By Room 122			2
11	By Library			3

12	Library Exit				4
13	By Main Office				1
14	By Room 113				
15	Cafeteria Entrance				17
16	Cafeteria				18
17	By Room 102				22
18	By Room 106				
19	Boys Washroom By room 115				
20	Girls Washroom By Room 115				
21	Boys Washroom By Room 104				21
22	Girls Washroom By Room 104				
23	By Room 212				25
24	By Room 208				24
25	Stairwell By Room 208				28
26	Stairwell By Room 213				23
27	Boys Washroom 103				26
28	Girls Washroom 105				27
	ADJ ROOM 113 #16				
					16
	ADJ 108 #19				
					19
	BOYS WASHRM ADJ 108				
	GIRLS WASHRM ADJ 108				
	RM 115		Y		
	RM 104		Y		
	RM 104 THROUGH DOOR	Y			
	RM 119		Y		
			Y		
	GYM CHANGE RM GIRLS		Y		
	GYM CHANGE RM				

	BOYS		Y	

STAGE

Exit combo	
	Y
	Y
Y	
	Y
Exit combo	

GYM STOARAGE

RM 205

RM 206

2ND FL FAN RM (IN
CARETAKERS
OFFICE)

BOILER RM

	LOCATION: Eastern Shore District High FIRE ALARM PANEL: Edwards EST 2	Device	Device address or circuit number

MANUAL PULL STATIONS

1	MAIN ENTRY	M	213
2	NEAR 110	M	203
3	NEAR ELEVATOR 1ST FLOOR	M	203
4	CAFETERIA	M	203
5	NEAR 210	M	205
6	NEAR 217	M	205
7	GYM EXIT	M	206
8	GYM NEAR LOBBY	M	206
9	GYM DOOR NEAR STAGE	M	206
10	NEAR 220	M	207
11	NEAR 228	M	207
12	NEAR 116	M	208
13	BOTTOM OF STAIR BY ROOM 124B	M	208
14	BOILER ROOM	M	204
15	SKILLED TRADES CLASSROOM	M	208

SMOKE DETECTORS

1	TOP OF STAIR NEAR 217	SI	101
2	TOP OF STAIR NEAR 210	SI	102
3	TOP OF STAIR NEAR 228	SI	103
4	TOP OF STAIR NEAR 214	SI	104
5	MAIN ELECTRICAL ROOM	SI	105

HEAT DETECTORS

1	CARETAKER'S OFFICE ACROSS 103	RHT	203
2	NEW FITNESS ROOM 111B(INNER ROOM)	RHT	203
3	CAFETERIA STORAGE	HT	203
4	ROOM 212	RHT	205
5	ROOM 212 STORAGE	RHT	205
6	CHEMICAL STORAGE IN 217	HT	205
7	ROOM 211	RHT	205
8	JANITOR ROOM SECOND FLOOR	HT	205
9	GYM STORAGE LEFT	RHT	205
10	GYMNASIUM UNDER STAGE LEFT	HT	206
11	GYM STORAGE RIGHT	RHT	206
12	ROOM 214	HT	206

13	JANITOR ROOM BY 225	HT	207
14	LIBRARY STORAGE	RHT	207
15	BIOLOGY ROOM 228 STORAGE	RHT	207
16	STORAGE ROOM 121 CLEANING SUPPLY	RHT	208
17	ROOM 116 WOOD SHOP	RHT	208
18	STORAGE ROOM 111B	RHT	208
19	JANITOR ROOM BY RM 119A	HT	208
20	STORAGE ROOM IN 118	RHT	208
21	BOILER ROOM	HT	204
22	BOILER ROOM	HT	204
23	BOILER ROOM	HT	204
24	GYMNASIUM UNDER STAGE RIGHT	HT	206
25	GYMNASIUM UPPER RIGHT STAGE STORAGE	HT	206
26	ROOM 123 OLD WELDING SHOP STORAGE	HT	203
27	SKILLED TRADES CLASSROOM	HT	208
28	SKILLED TRADES CLASSROOM	HT	208
29	CAFETERIA	HT	203
30	CAFETERIA	RHT	203

SPRINKLER DEVICES

1	KITCHEN SUPPRESSION	AD	121
---	---------------------	----	-----

NOTIFYING DEVICES

1	NEAR 102	B	
2	NEAR 110	B	
3	NEAR 210	B	
4	NEAR 202	B	
5	NEAR 219B	B	
6	NEAR 215	B	
7	NEAR 220	B	
8	NEAR 123B	B	
9	NEAR 116	B	
10	ROOM 116 TECH ED.	B	
11	NEAR 115A	B	
12	GYM	B	
13	GYM OUTSIDE EXIT	B	
14	BOILER ROOM	B	
15	BOYS CHANGE ROOM	B	
16	SKILLED TRADES CLASSROOM	B/V	
17	SKILLED TRADES CLASSROOM	B/V	
18	NEAR 229	B	
19	CAFETERIA	B	

EMERGENCY LIGHTING

Line		Remote	Cab.
------	--	--------	------

#	EL UNIT Location	Head	Head
1	MAIN ENTRANCE ABOVE EXIT DOO		
2	ACROSS FROM 103		
3	BESIDE 107		
4	EXIT BY 108A		
5	Bottom of stairs by 110		
6	NEAR 210		
7	NEAR 208A		
8	ACROSS 202		
9	BESIDE 201A		
10	2ND FL MAIN STAIRWELL		
11	BESIDE 212		
12	ACROSS 213		
13	LIBRARY		
14	2ND FL SMALL STAIRWELL		
15	BESIDE 220		
16	BESIDE 222		
17	ACROSS 227		
18	BESIDE 228		
19	2ND FL LARGE STAIRWELL		
21	EXIT BY 123B		
22	BY 124B		
23	ACROSS 119B		
24	BY 119A		
25	BESIDE 116(REMOTE)	Y	
26	EXIT AFTER 116		
27	EXIT TO MAIN OFFICE		
28	GYM EXIT 1 TO CORRIDOR		
29	GYM EXIT 2 BY STAGE		
30	GYM EXIT 3 TO LOBBY		
31	GYM EXIT 4 TO CORRIDOR		
32	BY 112C		
33	TOP OF STAIRS BY 214		
34	IN TOP STAIRS BY 214		
36	CAFETERIA		
37	CAFETERIA BY EXIT		
38	BESIDE 112B		

KITCHEN

BOILER RM

BOTTOM STAGE
STORE

STORE

ENTRANCE TO GYM NEW UNIT IN CEILING	+REMOTE HEADS
--	------------------

ABOVE MAIN ENTRANCE	
------------------------	--

MENTAL HEALTH (REMOTE IN WASHROOM)	UNIT +REMOTE
--	-----------------

BY 111B (NEAR GYM DOOR)	UNIT
----------------------------	------

BY 112B	
---------	--

MAIN OFFICE	UNIT
-------------	------

BACK MAIN OFFICE	UNIT
------------------	------

BY MAIN OFFICE ON WALL	EXIT COMBO
---------------------------	---------------

ROOM 116	UNIT +REMOTE
----------	-----------------

SKILLED TRADES	UNIT +REMOTE
----------------	-----------------

ROOM 212	
----------	--

TOP OF STAIRS BY 228	EXIT COMBO
-------------------------	---------------

FLOOR 1-5 BY 210	UNIT
------------------	------

2ND FLOOR MAIN ELECTRICAL ROOM	UNIT
-----------------------------------	------

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS	
---	--

	BREAKER PANEL IN MAIN JANITOR OFFICE PANEL "A", CCT# 25 & 35
--	---

	BREAKER PANEL IN JANITOR ROOM MAIN FLOOR New Wing PANEL " LPA "CCT # 27 & 31
--	--

	BREAKER PANEL IN JANITOR ROOM SECOND FLOOR New Wing PANEL " G " Cct # 2
	BREAKER PANEL IN JANITOR ROOM SECOND FLOOR Old Wing PANEL "E" Cct # 25
	BREAKER PANEL IN JANITOR ROOM SECOND FLOOR Old Wing PANEL " E" Cct # 27 is marked for Emerg Lite but does not control any Emergency Lighting Device found
	One of the breakers shuts down the schools internet connection

Fire Door Number or Location
MAIN ENTRY
BY ROOM 208B
BY ROOM 217
BY ROOM 214
BY ROOM 220
BY ROOM 228
BY ROOM 116
BY ROOM 123B

	LOCATION: Gaetz Brook	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex		

1	DEVICES		
	1ST FLOOR		
2	BASEMENT NORTH BY 101	M	ZONE 1
3	BASEMENT SOUTH BY 107	M	ZONE 1
4	BASEMENT EAST	M	ZONE 1
5	BOILER ROOM	M	ZONE 1
	BASEMENT NORTH BY 101	EOL	ZONE 1
	BOILER ROOM	RHT	
	2ND/MAIN FLOOR		
7	MAIN ENTRANCE	M	ZONE 2
8	GYM	M	ZONE 2
9	GYM	M	ZONE 2
10	BY RM 201	M	ZONE 2
11	BY RM 206	M	ZONE 2
12	GYM	EOL	ZONE 2
	3RD FLOOR		
14	BY ROOM 307	M	ZONE 3
15	BY ROOM 301	M	ZONE 3
16	SOUTH STAIRS	RHT	ZONE 3
17	NORTH STAIRS	RHT	ZONE 3
18	BOOK STORAGE ROOM	RHT	ZONE 3
19	BY ROOM 307	EOL	ZONE 3
23	MECHANICAL ROOM	DS	ZONE 5
24	MECHANICAL ROOM	DS	ZONE 5
25	MECHANICAL ROOM ON UNIT	EOL	ZONE 5
	SPRINKLER ROOM	PS	ZONE 4
21	BOILER ROOM	EOL	ZONE 4
27	KITCHEN HOOD SYSTEM	ALARM	ZONE 6
28	KITCHEN	EOL	ZONE 6
30	SPARE		ZONE 7
31	SPARE		ZONE 8
33	SPRINKLER SYSTEM LOW AIR	PS	ZONE 9
34	BOILER ROOM	EOL	ZONE 9
36	SPRINKLER TANK 2 LOW WATER	LW	ZONE 10
37		EOL	ZONE 10

39	SPRINKLER TANK 1 LOW WATER	LW	ZONE 11	
40		EOL	ZONE 11	
41	BELLS			
43	1ST FL NORTH	B	SIG 1	
44	1ST FL SOUTH	B	SIG 1	
45	GYM	B	SIG 1	
46	2ND FL NORTH	B	SIG 1	
47	2ND FL SOUTH	B	SIG 1	
48	BASEMENT NORTH	B	SIG 1	
49	BASEMENT SOUTH	B	SIG 1	
50	BASEMENT BY WOOD SHOP	B	SIG 1	
51	2ND FL SOUTH	EOL	SIG 1	
	RELAYS			
59	CITY CONNECTION	AUX	AUX 1	
60	DOOR HOLDERS BASEMENT ,1ST,2ND FLOOR	AUX	SIG 2	
EMERGENCY LIGHTING				
Line #	EL UNIT Location	Remote Head	Cab. Head	Manuf.
1	1ST FLOOR			
	CAFETERIA/ cct A-42		Y	
2	CORR BY WOODSHOP		Y	LUMACELL
3	CORR BY COMPUTER LAB		Y	
4	CORR BY BAND RM		Y	
5	BAND RM / cct A-41		Y	
6	CORR BY RM 101 / cct. A-42		Y	
7	CORR BY RM 106		Y	
8	BASEMENT LEVEL RAMPS		Y	
9	SOUTH STAIRS		Y	
10	KITCHEN		Y	
11	WOODSHOP		Y	
	COMPUTER LAB		Y	
12	ELECTRICAL ROOM		Y	
13	BOILER RM		Y	
14	2ND FLOOR			
15	LEVEL 2 RAMP / cct. D-41		Y	
16	CORR BY 202		Y	LUMACELL
17	MAIN CORR ENTRANCE		Y	LUMACELL
18	MAIN ENTRY / cct. D-41		Y	
19	GYM		Y	
20	GYM		Y	
21	GYM		Y	
22	CORR BY RM 205		Y	

23	STAIRS EXIT BY RM 206		Y	
24	CORR TO STAGE		Y	LUMACELL
25	3RD FLOOR			
26	LEVEL 3 RAMPS / cct. E-36		Y	
27	LEVEL 4 RAMPS		Y	
28	MATH ROOM		Y	
25	MATH RM CORR		Y	
26	CORR BY 302		Y	
27	SEWING RM DORR		Y	
28	CORR BY 306		Y	
25	SOUTH STAIRS		Y	
26	FAMILY STUDIES		Y	
27	SCIENCE LAB		Y	

	LOCATION: O'Connell Drive Elem.	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards EST 2		

Location Description	Device	Model	Address
----------------------	--------	-------	---------

ZONE 1 - WEST WING

NEAR BACK EXIT	M	SIGA270B	203
----------------	---	----------	-----

ZONE 2 - CENTRE WING

MULTI-MEDIA ROOM 188B	S	SIGAIPHS	102
COMPUTER ROOM 188A	S	SIGAIPHS	103
COMMUNICATION ROOM 106	S	SIGAIPHS	104
MAIN ENTRANCE	M	SIGA270B	219

ZONE 3 - EAST WING

NEAR EXIT	M	SIGA270B	217
STORAGE ROOM 176	S	SIGAIPSH	105

ZONE 4 - GYM & CAFETERIA

GYMNASIUM EXIT - SOUTH	M	SIGA270B	204
GYMNASIUM EXIT - NORTH	M	SIGA270B	205
CAFETERIA EXIT	M	SIGA270B	225

ZONE 5 - SOUTH WING

COMMUNICATION ROOM 142B	S	SIGAIPHS	101
SOUTH EXIT	M	SIGA270B	226

ZONE 6 - SPRINKLER TANK BLDG.

ZONE 7 - WEST WING MECH. ROOM #1 (126)

MEZZANINE MECH. ROOM 1 - 203		SIGA-CT1	218
MEZZANINE MECH. ROOM 1 - 203	M	270 SPO	
MEZZANINE MECH. ROOM 1 - 203	EOL		

ZONE 8 - EAST WING MECH. ROOM #2 (121)

MEZZANINE MECHANICAL ROOM 2 - 204		SIGA-CT1	212
MEZZANINE MECHANICAL ROOM 2 - 204	M	270 SPO	
MEZZANINE MECHANICAL ROOM 2 - 204	EOL		

Location Description	Device	Model	Address
----------------------	--------	-------	---------

ZONE 9 - CENTRE WING MECHANICAL ROOM 3

MEZZANINE MECHANICAL ROOM 3 - 202		SIGA-CT1	236
MEZZANINE MECHANICAL ROOM 3 - 202	M	270 SPO	
MEZZANINE MECHANICAL ROOM 3 - 202	EOL		

ZONE 10 - ABOVE GYM MECH. RM 4 (STORAGE)

MEZZANINE MECHANICAL ROOM 4 - 201		SIGA-CT1	238
MEZZANINE MECHANICAL ROOM 4 - 201	M	270 SPO	
MEZZANINE MECHANICAL ROOM 4 - 201	EOL		

ZONE 11 - DRY SYSTEM #1

SPRINKLER TANK BUILDING		SIGA-CT2	223
SPRINKLER TANK ROOM	FS	WFS-5	
SPRINKLER TANK ROOM	EOL		

ZONE 12 - DRY SYSTEM #2

--	--	--	--

BOILER ROOM		SIGA-CT2	209
BOILER ROOM	FS	WFS-5	
BOILER ROOM	EOL		

ZONE 13 - WET SYSTEM FLOW ALARM

BOILER ROOM		SIGA-CT2	208
BOILER ROOM FLOW		WFS-5	
BOILER ROOM	EOL		

ZONE 14 - KITCHEN HOOD FLOW ALARM

KITCHEN		SIGA-CT2	220
KITCHEN		VSR-SF	
KITCHEN	EOL		

ZONE 15 - SPRINKLER TANK BLDG.

SPRINKLER TANK ROOM		SIGA-CT2	221
SPRINKLER TANK ROOM		283C	
SPRINKLER TANK ROOM		283C	

Location Description	Device	Model	Address
SPRINKLER TANK ROOM	M	270 SPO	221
SPRINKLER TANK ROOM	EOL		

ZONE 16 - BOILER ROOM DEVICES

BOILER ROOM		SIGA-CT1	211
BOILER ROOM	M	270-SPOB	
BOILER ROOM	EOL		

ZONE 17 - LOW WATER

BOILER ROOM		SIGA-CT2	233
BOILER ROOM		PSS-40	
BOILER ROOM	EOL		

BOILER ROOM	EOL		
-------------	-----	--	--

ZONE 18 - SPRK. GATE VALVES BOILER ROOM

BOILER ROOM		SIGA-CT1	210
BOILER ROOM		BFV-G199	
BOILER ROOM		BFV-G199	
BOILER ROOM	EOL		

ZONE 19 - KITCHEN HOOD GATE VALVE

KITCHEN		SIGA-CT2	229
KITCHEN		BB-SCSO	

ZONE 19 - KITCHEN HOOD GATE VALVE - CONT'D

KITCHEN	EOL		
---------	-----	--	--

ZONE 20 - TANK BUILDING LOW TEMP.

SPRINKLER TANK ROOM		SIGA-CT2	230
SPRINKLER TANK ROOM		T6031A	
SPRINKLER TANK ROOM	EOL		

ZONE 21 - SPRK. TANK 1 & 2 LOW AIR

SPRINKLER TANK ROOM		SIGA-CT2	235
SPRINKLER TANK ROOM		L404	
SPRINKLER TANK ROOM	EOL		

ZONE 22 - LOW WATER TANK #1

Location Description	Device	Model	Address
SPRINKLER TANK ROOM		SIGA-CT2	224
SPRINKLER TANK ROOM		150S	
SPRINKLER TANK ROOM	EOL		

ZONE 22 - LOW WATER TANK #2

ZONE 23 - LOW WATER TANK #2

SPRINKLER TANK ROOM		SIGA-CT2	237
SPRINKLER TANK ROOM		150S	
SPRINKLER TANK ROOM	EOL		

ZONE 24 - SPRINKLER TANK RM. GATE VALVES

SPRINKLER TANK ROOM		SIGA-CT2	222
SPRINKLER TANK ROOM		BFV-G199	
SPRINKLER TANK ROOM DRY		BFV-G199	
SPRINKLER TANK ROOM DRY		BFV-G199	
SPRINKLER TANK ROOM DRY	EOL		

ZONE 25 - SPRK. DRY SYSTEM #1 LOW AIR

SPRINKLER TANK ROOM		SIGA-CT2	231
SPRINKLER TANK ROOM		PSS-40	
SPRINKLER TANK ROOM	EOL		

ZONE 26 - SPRK. DRY SYSTEM #2 LOW AIR

SPRINKLER TANK ROOM		SIGA-CT2	234
SPRINKLER TANK ROOM		PSS-40	
SPRINKLER TANK ROOM		EOL	

ZONE 27 - ANTI-FREEZE LOOP GATE VALVE

ROOM 104 CLOSET		SIGA-CT1	232
ABOVE CEILING RM. 110 ADJ. CLOSET		BB-SCSO	
ROOM 104 CLOSET	EOL		

ZONE 32 - FIRE DEPT. BYPASSED

INSIDE F/A PANEL		SIGA-CT1	228
INSIDE F/A PANEL		CONT.	
INSIDE F/A PANEL	EOL		

Location Description	Device	Model	Address	Zone / Circuit #
----------------------	--------	-------	---------	---------------------

RELAY ZONE 1 - WEST WING AHU 1 SHUTDOWN

MEZZANINE MECHANICAL ROOM 1	RLY	SIGA-CR	206	
-----------------------------	-----	---------	-----	--

RELAY ZONE 2 - EAST WING AHU 2 SHUTDOWN

MEZZANINE MECHANICAL ROOM 2	RLY	SIGA-CR	207	
-----------------------------	-----	---------	-----	--

RELAY ZONE 3 - CENTRE WING AHU 5 SHUTDOWN

CENTRE AREA MECH. ROOM 3	RLY	SIGA-CR	213	
--------------------------	-----	---------	-----	--

RELAY ZONE 4 - CENTRE WING AHU 3 SHUTDOWN

MEZZANINE MECH. ROOM 3	RLY	SIGA-CR	214	
------------------------	-----	---------	-----	--

RELAY ZONE 5 - MECH. ROOM 4 AHU 4 SHUTDOWN

MEZZANINE MECH. ROOM 4	RLY	SIGA-CR	215	
------------------------	-----	---------	-----	--

RELAY ZONE 6 - DOOR CLOSURES

DOOR CLOSURES	RLY	SIGA-CR	216	
---------------	-----	---------	-----	--

SIGNAL CCT. #1 - WEST WING (0201)

MEZZANINE MECH. ROOM #1	H/S			1
NEAR CLASSROOM 120	H/S			1
NEAR STAFF LOUNGE 115	H/S			1
MEZZANINE MECH. ROOM #1	EOL			1
NEAR CLASSROOM 124	H/S			1

SIGNAL CCT. #2 - SOUTH WING (0202)

GYMNASIUM	H/S			2
GYMNASIUM	H/S			2
ADJ. ART ROOM 140	H/S			2
ADJ. PUMP ROOM 144	H/S			2
MEZZANINE MECH. ROOM #3	H/S			2
MEZZANINE MECH. ROOM #4	H/S			2

BOILER ROOM	H/S			2
SPRINKLER TANK BLDG	H/S			2
SPRINKLER TANK BLDG	EOL			2
CAFETERIA	H/S			2
MUSIC ROOM 149	H/S			2

Location Description	Device	Model	Address	Zone / Circuit #
----------------------	--------	-------	---------	---------------------

SIGNAL CCT. #3 - EAST WING (0227)

NEAR RESOURCE ROOM	H/S			3
NEAR CLASSROOM 186	V			3
NEAR CLASSROOM 182	H/S			3
MEZZANINE MECH. ROOM #2	H/S			3
MEZZANINE MECH. ROOM	EOL			3

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #
	WEST HALL BY EXIT		EMERGI- LITE 12 DEL 144	
	WEST HALL MECH RM BOTTOM		REMOTE	
	WEST HALL MECH RM TOP		REMOTE	
	WEST HALL BY 129A #2			
	WEST HALL BETWEEN 130 & 133		12 DEL 144	
	WEST HALL BY 134A #4			
	WEST HALL EXIT BY MENS WASHRM		EXIT	
	WEST HALL EXIT BY MENS WASHRM		EXIT	
	WEST HALL MENS 135			

	CENTRE SOUTH BY #5 MEETING RM 136			
	CENTRE SOUTH ACROSS FROM 140		REMOTE	
	CENTRE SOUTH BY 142A #6		12 DEL 144	
	CENTRE SOUTH ELECT RM 142B		12 DEL 144	
	CENTRE SOUTH BY 149 #7		12 DEL 144	
	CENTRE SOUTH IN 148 BOILER RM		REMOTE	
	CENTRE SOUTH IN 148A OVER EXIT #8		COMBO UNIT	
	CENTRE SOUTH CAFETERIA #9		12 DEL 144	
	CENTRE SOUTH CAFETERIA #10		REMOTE	
	CENTRE SOUTH CAFETERIA		EXIT	
	CENTRE SOUTH CAFETERIA #11		REMOTE	
	CENTRE SOUTH CAFETERIA EXIT TO CTR HALL		EXIT	
	CENTRE SOUTH MECHANICAL RM TOP		REMOTE	
	EAST LANE #12 BY RM 188A		12 DEL 144	
	EAST LANE BY LIBRARY		REMOTE	
	EAST LANE BY LIBRARY		EXIT	
	EAST LANE WOMENS WASHRM 167		REMOTE	
	EAST LANE MENS WASHRM 166		REMOTE	
	EAST LANE EXIT BY 170A		EXIT	
	EAST LANE EXIT BY 170A		EXIT	
	EAST LANE #13 BY 172		REMOTE	

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #
	EAST LANE #14 B/W 173 & 177		12 DEL 144	
	EAST LANE BY 182		EXIT	
	EAST LANE #15 BY 178A		REMOTE	
	EAST LANE #16 EXIT		12 DEL 144	
	EAST LANE END OF HALL MECH RM			
	END OF EAST HALL MECH RM UPSTAIRS			
	SOUTH GYM 160 #17		12 DEL 144	
	SOUTH EXIT BY 160 GYM		EXIT	
	SOUTH GYM BY 156 #18		REMOTE	
	SOUTH EXIT BY 156 GYM		EXIT	
	SOUTH GYM BY STORAGE 153 #19		12 DEL 144	
	SOUTH GYM BY 164D		EXIT	
	SOUTH BY 164C		EXIT	
	SOUTH BY 164C #20			
	SOUTH STORAGE 157			
	SOUTH MECH RM UPSTAIRS 157		REMOTE	
	SOUTH TOP OF STAIR 153		REMOTE	
	SOUTH MECH RM TOP OF 153		REMOTE	
	MAIN OFFICE		REMOTE	
	ADJ WEST MENS W/R		REMOTE	
	WOMENS W/R		REMOTE	
	MENS LOCKER RM		REMOTE	
	WOMENS LOCKER RM		REMOTE	

	ADJ BOILER RM		REMOTE	
	COMM RM		REMOTE	
	RAMP TO STAGE		REMOTE	
	WATER TANK RM VESTIBULE		UNIT	
	WATER TANK RM INSIDE BY DOOR		UNIT	

		Device	Device address or circuit number
LOCATION: Oyster Pond			
FIRE ALARM PANEL: Edwards QS4			

MANUAL PULL STATIONS			
1	2ND FLR BY STAIR 2	MA	101126
2	TOP STAIR 1 ADJ RM 2312	MA	101127
3	TOP OF STAIR 2 ADJ RM 2110	MA	101128
4	2ND FL ADJ 2208	MA	101129
5	2ND FL ADJ 2209	MA	101130
6	2ND LF ADJ 2220	MA	101131
7	PENTHOUSE MECH RM 2502	MA	101132
8	PENTHOUSE MECH RM 2501	MA	101133
9	GYM EXIT NORTH	MA	101163
10	GYM WEST EXIT	MA	101164
11	KITCHEN 1420	MA	101169
12	CAFETERIA 1419 BY 1422	MA	101170
13	BOILER ROOM	MA	101171
14	ELECTRICAL ROOM 1502	MA	101172
15	1ST FL STAIR 2 EXIT	MA	101173
16	1ST FL MAIN ENTRANCE	MA	101174
17	1ST FL WATER ROOM	MA	101175
18	1ST FL ADJ 1210 STAIR 4	MA	101176
19	1ST FL ADJ ROOM 1314	MA	101178
20	1ST FL TECH PROD RM 1201	MA	101179
SMOKE DETECTORS			
1	STAIR #2	SA	101001
2	2ND FL ADJ 2104	SA	101002
3	2ND FL ADJ RM 2303	SA	101003
4	2ND FL ADJ RM 2312	SA	101004
5	STAIR #1 ADJ RM 2312	SA	101005
6	2ND FL ELECTRICAL RM 2503	SA	101006
7	2ND FL SERVER RM 2107	SA	101007
8	ELEVATOR SHAFT SMOKE	SA	101008
9	2ND FL RM 2202 STORAGE	SA	101009
10	2ND FL ELEVATOR MECH RM 2507	SA	101010
11	2ND FL STORAGE RM 2110	SA	101011
12	2ND FL ADJ RM 2207	SA	101012
13	2ND FL RM 2203 STORAGE	SA	101013

14	2ND FL ADJ RM 2208	SA	101014
15	2ND FL ADJ RM 2209	SA	101015
16	2ND FL SERVER RM 2504	SA	101016
17	2ND FL ADJ RM 2220	SA	101017
18	STAIR #4	SA	101018
19	STAIR 3 ADJ RM 2110	SA	101019
20	TOP OF STAGE SMOKE #1	SA	101020
21	TOP OF STAGE SMOKE #2	SA	101021
22	1ST FL ADJ RM 1314	SA	101028
23	1ST FL ADJ RM 1301	SA	101029
24	1ST FL ADJ STAIR 2	SA	101030
25	1ST LF ELECTRICAL RM 1504	SA	101031
26	1ST FL COMM OFFICE 1131	SA	101032
27	1ST FL SERVER RM 1130	SA	101033
28	1ST FL LAN RM 1424	SA	101034
29	1ST FL KITCHEN STORAGE 1421	SA	101035
30	1ST FL ADJ RM 1421	SA	101036
31	1ST LF ADJ ELEVATOR	SA	101037
32	1ST FL LOBBY	SA	101038
33	1ST FL ADJ RM 1111	SA	101039
34	1ST FL COMM RM 1507	SA	101040
35	1ST FL ADJ RM 1210	SA	101041
36	1ST FL LOBBY ADJ ADMIN RM 1104	SA	101042
37	1ST FL RECYCLE RM 1422	SA	101043
38	1ST FL STAGE STORAGE RM 1418	SA	101046
39	1ST FL MULTIPURPOSE RM 1415	SA	101047
40	GYM STORAGE RM 1408	SA	101048
41	1ST FL ADJ 1415	SA	101049
42	1ST FL ADJ LIBRARY	SA	101050
43	1ST FL STAIR 4	SA	101055
44	ELECTRICAL RM 1502 SMOKE #1	SA	101056
45	ELECTRICAL RM 1502 SMOKE #2	SA	101057

DUCT SMOKE DETECTORS

1	PENTHOUSE/MECH RM 2501AHU#1 GYM	DSA	101022
---	---------------------------------	-----	--------

HEAT DETECTORS

1	2ND FL CUSTODIAL RM 2105	RHTA	101023
2	2ND FL CUSTODIAL RM 2114	RHTA	101024
3	PENTHOUSE/MECH RM 2502	RHTA	101025
4	PENTHOUSE/MECH RM 2501 HEAT #1	RHTA	101026
5	PENTHOUSE/MECH RM 2501 HEAT #2	RHTA	101027
7	1ST FL CUSTODIAL 1125	RHTA	10151
8	1ST FL SPRINKLER RM 1510	RHTA	101053
9	1ST FL WATER RM 1509	RHTA	101052

10	1ST FL CUSTODIAL 1133	RHTA	101054
11	BOILER RM	HTA	101180
12	BOILER RM	HTA	101180

SPRINKLER DEVICES

	ELEVATOR MACHINE RM GATE VALVE	SV	134
	SPRINKLER FLOW 1ST FL	FSV	143
	SPRINKLER VALVE 1ST FL	SV	144
	TEST HEADER VALVE	SV	145
	FIRE PUMP DISCHARGE VALVE	SV	146
	JOCKEY PUMP VALVE	SV	147
	JOCKEY PUMP DISCHARGE VALVE	SV	148
	MAIN SPRINKLER FLOW	FSV	149
	MAIN SPRINKLER SHUT OFF VALVE	SV	150
	FIRE PUMP CONTROLLER TROUBLE	SV	154
	RESERVOIR HIGH WATER	SV	158
	ELECTRICAL RM 1502 INVERTER TBL	SV	159
	ELEVATOR PIT SHUT OFF VALVE	SV	161
	SPARE ELEVATOR PIT VALVE	SV	162
	KITCHEN HOOD SYSTEM ALARM	AD	177
	SPRINKLER FLOW 2ND FL	FSV	181
	SPRINKLER VALVE 2ND FL	SV	182
	PENTHOUSE MECH RM FLOW	FSV	183
	PENTHOUSE /MECH RM VALVE	SV	184

NOTIFYING DEVICES

1	ELECTRICAL ROOM 1502	HS	
2	GYM BY STAGE	HS	
3	GYM EXIT TO REAR OF BUILDING	HS	
4	RM 1413 MALE JR CHANGE RM	HS	
5	RM 1409 FEMALE JE CHANGE RM	HS	
6	RM 1412 MALE ELEMENTARY CHG RM	HS	
7	RM 1414 WASHROOM/SHOWERS	HS	
8	RM 1410 FEMALE ELEMENTARY CHG RM	HS	
9	MAIN ENTRY LOBBY	HS	
10	BY RM 1111	HS	
11	RM 1113 STAFFROOM	HS	
12	FEMALE WASHROOM ADJ RM 1117	HS	
13	MALE WASHROOM ADJ RM 1117	HS	
14	ADJ RM 1210	HS	
15	ADJ 2216	HS	
16	MALE WASHROOM ADJ 2210	HS	
17	FEMALE WASHROOM ADJ 2210	HS	
18	ADJ RM 2207	HS	
19	ADJ 2503	HS	

20	MALE WASHROOM ADJ 2503	HS	
21	FEMALE WASHROOM ADJ 2503	HS	
22	ADJ RM 2303	HS	
23	ADJ RM 2309	HS	
24	ADJ RM 1313	HS	
25	ADJ STAIR 2 MAIN LEVEL	HS	
26	FEMALE WASHROOM ADJ CUST RM 1133	HS	
27	MALE WASHROOM ADJ CUST RM 1133	HS	
28	ADJ RM 1133	HS	
29	ADJ RM 1421	HS	
30	CAFETERIA BY RECYCLE RM 1422	HS	
31	MUSIC RM	HS	
32	GYM BY REAR LEFT EXIT	HS	

AUXILIARIES

1	FUTURE ELEVATOR RELAY ABOVE RM 2201	AD	137
2	FUTURE ELEVATOR RELAY ABOVE RM 2201	AD	138
3	TOP OF STAIR 1 RELAY ABOVE DR	AD	136
4	TOP STAIR 2 RELAY ABOVE DR	AD	135
5	2ND FL ADJ 2208 DOOR RELAY	AD	139
6	TOP OF STAIR 4 RELAY	AD	140
7	KITCHEN SHUNT TRIP	AUX	141
8	PENTHOUSE/MECH RM 2501 AHU#1 SHUTDOV	AD	142
12	RELAY ADJ 1314(DOOR RELEASE)	AD	165
11	RELAY 1ST FL BY STAIR 2	AD	166
10	RELAY 1ST FL CORR TO CAFETERIA	AD	167
9	RELAY ADJ 1210	AD	168
13	PENTHOUSE/MECH RM 2501 RHU#1 SHUT DO	AD	142
12	KITCHEN HOOD SYSTEM ALARM	AD	177

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
1	GYM (OVER 1409)		
2	GYM ENTRANCE(REMOTE)		
3	GYM FAR WALL BY STAGE		
4	GYM FAR WALL BY EXIT		
5	GYM BACK WALL		
6	GYM RIGHT GYM ENTRANCE		
7	CAFETERIA LEFT	Y	
8	CAFETERIA		
9	SERVER ROOM 2504		
10	SERVER ROOM 1507		
11	MECH ROOM 2502		

12	MECH ROOM 2502		
13	1502 ELECTRICAL RM FRONT		
14	1502 ELECTRICAL RM REAR		
15	2503 ELECTRICAL ROOM		
15	2107 SERVER ROOM		
	BOILER ROOM		

SPRINKLER ROOM

ELEVATOR MACHINE
RM 2507

STAIR ADJ 2104

2501 MECH TOP
STAIRS

2501 MECH
BACKWALL STAN
PRO

WATER RM 1509

	LOCATION: Porter's Lake	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards QS4		
MANUAL PULL STATIONS			
	1ST FLOOR "A" WING ADJACENT RM 166	MA	101013
	1ST FLOOR "A" WING ADJACENT RM 150	MA	101014
	1ST FLOOR COMMUNITY CTR ENTRY	MA	101126
	1ST FLOOR CAFETERIA RM 196	MA	101127
	1ST FLOOR ELECTRICAL ROOM 214	MA	101128
	1ST FLOOR "D" WING	MA	101143
	1ST FLOOR MAIN ENTRY	MA	101145
	1ST FLOOR "A" WING	MA	101147
	1ST FLOOR CORR ADJACENT RM 147	MA	101148
	1ST FLOOR "C" WING	MA	101150
	1ST FLOOR STUDIO RM 211	MA	101151
	2ND FLOOR PENTHOUSE	MA	101154
	1ST FLOOR OUTSIDE STORAGE RM 179	MA	101156
	1ST FLOOR OUTSIDE STORAGE RM 204	MA	101157
	1ST FLOOR KITCHEN	MA	101159
	1ST FLOOR RM 191	MA	101131

	MUSIC ROOM	MA	149
	SMOKE DETECTORS		
	1ST FLOOR ELECTRICAL ROOM 214	SA	101002
	1ST FLOOR KITCHEN STORAGE RM 193	SA	101003
	1ST FLOOR KITCHEN STORAGE RM 194	SA	101004
	1ST FLOOR RECYCLING ROOM 192	SA	101005
	1ST FLOOR MECHANICAL ROOM 191	SA	101006
	1ST FLOOR ELECTRICAL ROOM 132	SA	101007
	1ST FLOOR "D" WING ADJ RM 128	SA	101008
	1ST FLOOR "D" WING ADJ RM 131	SA	101009
	1ST FLOOR MAIN LOBBY	SA	101010
	1ST FLOOR COPY ROOM 175	SA	101011
	1ST FLOOR COMM ROOM	SA	101012
	1ST A WING BY RM 166		
	1ST A WING BY RM 150		
	1ST FLOOR STAGE STORAGE RM 177	SA	101015
	1ST FLOOR GYM STORAGE RM 180	SA	101016
	1ST FLOOR STORAGE ROOM 203	SA	101017
	1ST FLOOR JANITORS RM 205	SA	101018
	1ST FLOOR OUTSIDE STORAGE RM 179	SA	101019

	1ST FLOOR OUTSIDE STORAGE RM 204	SA	101020
	1ST FLOOR STUDIO RM 211 (#1 SMK)	SA	101021
	1ST FLOOR STUDIO RM 211 (#2 SMK)	SA	101022
	1ST FLOOR COMM ROOM 212	SA	101023
	1ST FLOOR STORAGE ROOM 213	SA	101024
	1ST FLOOR RM 215	SA	101025
	2ND FLOOR PENTHOUSE (#1 SMK)	SA	101027
	2ND FLOOR PENTHOUSE (#2 SMK)	SA	101028

SPRINKLER DEVICES

	SPRINKLER RISER VALVE	TS	101134
	SPRINKLER JOCKEY PUMP VALVE #2	TS	101142
	SPRINKLER JOCKEY PUMP VALVE #1	TS	101141
	SPRINKLER MAIN VALVE	TS	101140
	FIRE PUMP RUNNING	TS	101138
	FIRE PUMP CONTROLLER	TS	101137
	PENTHOUSE WATER FLOW	FSV	101133
	BUILDING RISER WATER FLOW	FSV	101132
	PENTHOUSE VALVE	TS	101135

RELAYS, ETC

	1ST FLOOR "IM" IN FIRE PANEL	IM	101001
--	------------------------------	----	--------

	2ND FLOOR "IM" IN FIRE PANEL	IM	101026
	2ND FLR PENTHOUSE KITCHEN EXHAUST	IM	101152
	2ND FLR PENTHOUSE AHU RELAY	RLY	101153
	FACP TROUBLE RELAY	RLY	101158
	1ST FLOOR "A" WING DOOR RELAY	RLY	101146
	1ST FLOOR "D" WING DOOR RELAY	RLY	101144
	KITCHEN SHUNT TRIP	RLY	101130
	KITCHEN HOOD SYSTEM BUTTON	RLY	101129
	FIRE DOOR RELAY BY GYM DOOR	RLY	101160
	FIRE PANEL BOOSTER	TRBL	

NOTIFYING DEVICES

ELECTRICAL RM	H/S
COMM CENTER BY RECEPTION	H/S
COMM CENTER BY GYM ENTRANCE	H/S
BOYS CHANGE RM	S
GIRLS CHANGE RM	S
CAFETERIA	H/S
CAFETERIA	H/S
GYM	H/S
GYM	H/S
GYM	H/S
GYM	H/S
CORRIDOR RM 195	H/S
BOYS CHANGE RM OFF GYM	H/S
GIRLS CHANGE RM OFF GYM	H/S

BOYS WASHRM	S
GIRLS WASHRM	S
CORR BY 109	H/S
CORR BY 113	H/S
LEARNING CENTRE BATHRM	H/S
PENTHOUSE	H/S
PENTHOUSE	H/S
GENERAL OFFICE BY RECEPTION	H/S
BY RM 169 INSIDE OFFICE AREA	H/S
CORR BY 168	H/S
BOYS BY 146	S
GIRLS BY 146	S
CORR BY RM 161	H/S
CORR BY RM 158	H/S

EMERGENCY LIGHTS

Location	
ELECTRICAL ROOM 214	
CAFETERIA 196	UNIT
CAFETERIA 196	REMOTE
CAFETERIA 196	REMOTE
CAFETERIA 196	REMOTE
KITCHEN	UNIT
KITCHEN	REMOTE
CORRIDOR BY CAFETERIA	UNIT
CORRIDOR BY CAFETERIA	REMOTE

CORRIDOR BY CAFETERIA	REMOTE
CORRIDOR BY CAFETERIA	REMOTE
CORRIDOR BY CAFETERIA	REMOTE
CORRIDOR BY ROOM 136	UNIT
CORRIDOR BY 136	REMOTE
CORRIDOR BY 136	UNIT
MAIN CORRIDOR BY LIBRARY	REMOTE
MAIN CORRIDOR BY LIBRARY	REMOTE
MAIN CORRIDOR BY LIBRARY	REMOTE
MAIN CORRIDOR BY LIBRARY	REMOTE
MAIN CORRIDOR BY LIBRARY	UNIT
CORRIDOR BY ROOM 121	REMOTE
CORRIDOR BY ROOM 121	REMOTE
CORRIDOR BY ROOM 121	REMOTE
CORRIDOR BY ROOM 121	REMOTE
CORRIDOR BY ROOM 121	REMOTE
CORRIDOR BY ROOM 121	REMOTE
CORRIDOR BY ROOM 121	UNIT
CORRIDOR BY ROOM 121	REMOTE
GIRLS WASHROOM BY ROOM 132	UNIT
BOYS WASHROOM BY 132	REMOTE
BY MAIN OFFICE	REMOTE
BY MAIN OFFICE	UNIT
BY MAIN OFFICE	REMOTE

BY MAIN OFFICE	REMOTE
ART/STAGE RAMP	REMOTE
ART/STAGE RAMP	REMOTE
ART/STAGE RAMP	REMOTE
ART/STAGE RAMP	REMOTE
ART/STAGE RAMP	REMOTE

GIRLS WASHROOM BY MUSIC	UNIT
BOYS WASHROOM BY MUSIC	REMOTE
CORRIDOR BY ROOM 153	UNIT
CORRIDOR BY ROOM 153	REMOTE
CORRIDOR BY ROOM 153	REMOTE
CORRIDOR BY ROOM 153	REMOTE
CORRIDOR BY ROOM 153	REMOTE
CORRIDOR BY ROOM 153	UNIT
CORRIDOR BY ROOM 147	REMOTE
CORRIDOR BY ROOM 147	UNIT
GYM NEAR STAGE	REMOTE
GYM NEAR STAGE	REMOTE
GYM NEAR STAGE	REMOTE
GYM NEAR STAGE	REMOTE
GYM NEAR STAGE	UNIT
GYM NEAR STAGE	REMOTE

GYM BACK WALL	REMOTE
GYM BACK WALL	UNIT
GYM BACK WALL	REMOTE
GYM NEAR BLEACHERS	REMOTE
GYM NEAR BLEACHERS	REMOTE
GYM NEAR BLEACHERS	REMOTE
GYM NEAR BLEACHERS	UNIT
GYM NEAR BLEACHERS	REMOTE
GYM NEAR BLEACHERS	REMOTE
GYM NEAR LOCKERS	REMOTE
GYM NEAR LOCKERS	REMOTE
GYM NEAR LOCKERS	REMOTE
GYM NEAR LOCKERS	UNIT
GYM NEAR LOCKERS	UNIT
GYM NEAR LOCKERS	UNIT
GYM NEAR LOCKERS	REMOTE
OUTDOOR STORAGE	UNIT
STAGE	REMOTE
PENTHOUSE FRONT	REMOTE
PENTHOUSE FRONT	REMOTE
PENTHOUSE REAR	UNIT
PENTHOUSE REAR	REMOTE
PENTHOUSE REAR	REMOTE
STAGE	REMOTE

COMMUNITY CENTRE	UNIT
COMMUNITY CENTRE BY GYM	UNIT
COMMUNITY CENTRE BY GYM	REMOTE
COMMUNITY CENTRE BY GYM	REMOTE
NEAR ROOM 210	UNIT
NEAR ROOM 210	REMOTE
NEAR ROOM 210	REMOTE
MULTI-PURPOSE ROOM 210	UNIT
MULTI-PURPOSE ROOM 210	REMOTE
MULTI-PURPOSE ROOM 210	REMOTE
WOMEN'S CHANGE ROOM	UNIT
MENS CHANGE ROOM	REMOTE
ROOM 124	UNIT
STAFF W/R	REMOTE
STAFF W/R	REMOTE
LIBRARY	UNIT
LIBRARY	REMOTE
LIBRARY	REMOTE
COMM RM 137	UNIT

BOILER ROOM	REMOTE
BOILER ROOM	REMOTE

	LOCATION: Dutch Settlement	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 2280		
1	DEVICES		
2	STORAGE CLOSET	RHT	ZONE 1
3	STORAGE ROOM	RHT	ZONE 1
4	OIL TANK ROOM	RHT	ZONE 1
5	BASEMENT CLASS	M	ZONE 1
	BASEMENT HALL	M	ZONE 1
6	NORTH HALL	M	ZONE 1
7	NORTH HALL EXIT	M	ZONE 1
9	MAIN ENTRY	M	ZONE 2
10	PRINCIPLE OFFICE	M	ZONE 2
11	EAST EXIT	M	ZONE 2
12	GYM FAR WALL	M	ZONE 2
13	GYM SIMPLEX	M	ZONE 2
14	FURNACE ROOM	M	ZONE 2
	GYM	EOL	ZONE 2
16	FURNACE ROOM	PS	ZONE 3
	FURNACE ROOM	PS	ZONE 4
18	FURNACE ROOM	PS	ZONE 4
19	FURNACE ROOM	PS	ZONE 4
	FURNACE ROOM LOW AIR	SUP	ZONE 5
22	FURNACE ROOM	SUP	ZONE 6
24	FURNACE ROOM	SUP	ZONE 7
	FURNACE ROOM	SUP	ZONE 8
	BELLS		
27	GYM	B	SIG 1
28	HALL	B	SIG 1
29	HALL	B	SIG 1
30	HALL	B	SIG 1
31	HALL	B	SIG 1
32	BASEMENT	B	SIG 1
33	GYM	EOL	SIG 1
	AC FEED #38 PANEL B		

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	
1	GYM ENTRY TO HALL		Y	DUAL LITE
2	HALL REMOTE	Y		DUAL LITE
3	GYM OPPOSITE GYM ENTRY		Y	DUAL LITE
4	GYM		Y	DUAL LITE
5	MAIN ENTRY		Y	DUAL LITE
6	BY OFFICE		Y	DUAL LITE
7	EAST EXIT		Y	EMERGI LITE
8	BASEMENT		Y	DUAL LITE
9	OIL TANK ROOM REMOTE	Y		REMOTE
#	NORTH HALL BY 115		Y	AIME LITE
#	NORTH EXIT BY 201		Y	AIME LITE

BY 116		DUAL LITE
BSMT CLASSRM		COMBO
GYM STAGE BY STAIR LHS		UNIT
GYM STAGE BY STAIR RHS		UNIT
GIRLS' WASHRM		UNIT
BOY'S WASHRM		REMOTE

LOCATION: Musquodoboit Rural High	Device	model	Device address or circuit number
FIRE ALARM PANEL: Edwards QS4			
FIRE ALARM DEVICES			

Location Description	Device	Model	Address
----------------------	--------	-------	---------

DETECTORS FOR PANEL 1 CARD 1

CORRIDOR ADJ. ELEVATOR	SMK	SIGA-PS	1
STUDENT SERVICES FILE STORAGE	SMK	SIGA-PS	2
WATER PUMP ROOM	HEAT	SIGA-HFS	3
CORRIDOR ADJ. 1305	SMK	SIGA-PS	4
MAIN ELECTRICAL ROOM	SMK	SIGA-PS	5
CORRIDOR ADJ. 1211	SMK	SIGA-PS	6
CORRIDOR ADJ. SOUTH/WEST FIRE DOORS	SMK	SIGA-PS	7
MAIN ENTRANCE	SMK	SIGA-PS	8
SERVER ROOM 1206	SMK	SIGA-PS	9
MULTIPURPOSE ROOM 1410	SMK	SIGA-PS	10
CUSTODIAN ROOM 1125	HEAT	SIGA-HFS	11
GYM STORAGE 1403	SMK	SIGA-PS	12
1ST FLOOR COMM. ROOM 1507	SMK	SIGA-PS	13
MECHANICAL CLOSET 1509	HEAT	SIGA-HFS	14
SPRINKLER ROOM 1507	HEAT	SIGA-HFS	15
STORAGE ROOM 1203	HEAT	SIGA-HFS	16

TECH ROOM 1204	SMK	SIGA-PS	17
MAIN ENTRANCE ADJ. LIBRARY 1127	SMK	SIGA-PS	18
ADJ. ADMIN OFFICE 1104	SMK	SIGA-PS	19
MUSIC ROOM STORAGE	SMK	SIGA-PS	20
KITCHEN STORAGE ROOM 1425	SMK	SIGA-PS	21
STAGE STORAGE ROOM	SMK	SIGA-PS	22
CORRIDOR NEAR CAFETERIA	SMK	SIGA-PS	23
CORRIDOR ADJ. SERVER ROOM	SMK	SIGA-PS	24
CORRIDOR TO TECH ED	SMK	SIGA-PS	25
BOILER ROOM HEAT #1	HEAT	SIGA-HFS	26
BOILER ROOM HEAT #2	HEAT	SIGA-HFS	27
2ND FLOOR GENERAL STOARGE ROOM 2107	SMK	SIGA-PS	28
STAGE SMOKE #2	SMK	SIGA-PS	29
2ND FLOOR CORRIDOR ADJ. 2208	SMK	SIGA-PS	30
MAIN LOBBY HIGH CEILING	SMK	SIGA-PS	31
STAIR 03 SMOKE ADJ. GYM	SMK	SIGA-PS	32
2ND FLOOR JANITORS ROOM 2108	HEAT	SIGA-HFS	33
2ND FLOOR JANITORS ROOM 2112	HEAT	SIGA-HFS	34
2ND FLOOR SERVER ROOM 2109	SMK	SIGA-PS	35
TOP OF STAIR 2 ADJ. ELEVATOR	SMK	SIGA-PS	36
2ND FLOOR CORRIDOR ADJ. WASHROOM 2110	SMK	SIGA-PS	37
2ND FLOOR CORRIDOR ADJ. 2216	SMK	SIGA-PS	38
MECHANICAL ROOM 2501	HEAT	SIGA-HFS	39
FAMILY STUDIES STORAGE ROOM	SMK	SIGA-PS	40
2ND FLOOR CORRIDOR ADJ. 2202	SMK	SIGA-PS	41

ADJ. 2202			
2ND FLOOR CORRIDOR ADJ. 2305	SMK	SIGA-PS	42
TOP OF STAIR 4 WEST	SMK	SIGA-PS	43
GYM DUCT SMOKE	DUCT	SIGA-SD	44
MECHANICAL ROOM 2105	DUCT	SIGA-SD	45
2ND FLOOR CORRIDOR ADJ. 2301	SMK	SIGA-PS	46
STAGE SMOKE #1	SMK	SIGA-PS	47
2ND FLOOR BALCONY	SMK	SIGA-PS	48
GYM DUCT SMOKE	DUCT	SIGA-SD	49
MECHANICAL ROOM 3001	SMK	SIGA-PS	50
MECHANICAL ROOM 3001	HEAT	SIGA-PS	51
TOP OF STAIR 1	SMK	SIGA-PS	52
ELEVATOR SHAFT	SMK	SIGA-PS	53
2ND FLOOR ELEVATOR MACHINE ROOM	SMK	SIGA-PS	54
RECYCLE ROOM 1423	SMK	SIGA-PS	55
GYM STORAGE 1411	SMK	SIGA-PS	56
STORAGE UNDER PENTHOUSE STAIR 2209	SMK	SIGA-PS	57
2ND FLOOR JANITORS CLOSET 2103	HEAT	SIGA-HFS	58
LEVEL 1 CORRIDOR BY ROOM 1112	SMK	SIGA-PS	59

MODULES FOR PANEL 1 CARD 1

UPPER FLOOR SPRINKLER VALVE	SUPV	SIGA-CT2	126
UPPER FLOOR SPRINKLER FLOW	FLOW	SIGA-CT2	127
Location Description	Device	Model	Address
MECHANICAL ROOM 3001 SPRINKLER VALVE	SUPV	SIGA-CT2	128
MECHANICAL ROOM 3001	FLOW	SIGA-CT2	129

SPRINKLER FLOW			
MAIN FLOOR & GYM SPRINKLER FLOW	FLOW	SIGA-CT2	130
MAIN FLOOR & GYM SPRINKLER VALVE	SUPV	SIGA-CT2	131
FIRE PUMP TEST HEADER VALVE	SUPV	SIGA-CT2	132
FIRE PUMP DISCHARGE VALVE	SUPV	SIGA-CT2	133
MAIN SPRINKLER GATE VALVE	SUPV	SIGA-CT2	134
MAIN SPRINKLER VALVE SPARE (3366)		SIGA-CT2	135
MAIN SPRINKLER ALARM	FLOW	SIGA-CT2	136
MAIN SPRINKLER LOW PRESSURE	SUPV	SIGA-CT2	137
ELEVATOR PIT GATE VALVE	SUPV	SIGA-CT2	138
ROOM 1305 EXIT	PULL	SIGC-270B	139
MAIN ENTRANCE	PULL	SIGC-270B	140
EXIT ADJ. 1305	PULL	SIGC-270B	141
CAFETERIA EXIT	PULL	SIGC-270B	142
EXIT ADJ. ELEVATOR	PULL	SIGC-270B	143
BOILER ROOM EXIT	PULL	SIGC-270B	144
1ST FLOOR TECH ED ROOM	PULL	SIGC-270B	145
1ST FLOOR CORRIDOR ADJ. 1209	PULL	SIGC-270B	146
GYM STORAGE	PULL	SIGC-270B	147
WATER PUMP ROOM	PULL	SIGC-270B	148
1ST FLOOR DOOR HOLDER NORTHEAST EXIT	RLY	SIGA-CR	149
1ST FLOOR DOOR HOLDER 1309	RLY	SIGA-CR	150
1ST FLOOR STAIR 2 FIRE DOOR HOLDER	RLY	SIGA-CR	151
1ST FLOOR CORRIDOR FIRE DOOR HOLDER	RLY	SIGA-CR	152
SOUTHWEST EXIT DOOR	RLY	SIGA-CR	153

HOLDER 1ST FLOOR			
UPS SYSTEM COMMON ALARM	SUPV	SIGA-CT2	154
UPS SYSTEM SPARE		SIGA-CT2	155
2ND FLOOR ADJ. ELEVATOR	PULL	SIGC-270B	156
MECHANICAL ROOM 3001 PENTHOUSE	PULL	SIGC-270B	157

Location Description	Device	Model	Address
2ND FLOOR CORRIDOR ADJ. 2208	PULL	SIGC-270B	158
TOP OF STAIRS ADJ. ELEVATOR	RLY	SIGA-CR	159
2ND FLOOR CORRIDOR ADJ. 2204	PULL	SIGC-270B	160
GYM BACK EXIT	PULL	SIGC-270B	161
2ND FLOOR CORRIDOR ADJ. 2202	PULL	SIGC-270B	162
GYM EXIT TO VESTIBULE	PULL	SIGC-270B	163
GYM EXIT TO VESTIBULE	PULL	SIGC-270B	164
UNKNOWN RELAY 9363	RLY	SIGA-CR	165
2ND FLOOR ADJ. 2202	RLY	SIGA-CR	166
2ND FLOOR DOORS ADJ. 2216	RLY	SIGA-CR	167
2ND FLOOR ADJ. 2216	PULL	SIGC-270B	168
2ND FLOOR IN STAIR BUS END OF SCHOOL	RLY	SIGA-CR	169
2ND FLOOR ADJ. 2308	PULL	SIGC-270B	170
MECHANICAL ROOM 3001 OUTSIDE	PULL	SIGC-270B	171
ELEVATOR MACHINE ROOM SPRINKLER VALVE	SUPV	SIGA-CT2	172
KITCHEN HOOD SUPPRESSION	ALRM	SIGA-CT2	173
KITCHEN HOOD SPARE (2680)			174
KITCHEN	PULL	SIGC-270B	175

FIRE PUMP CONTROLLER TROUBLE	SUPV	SIGA-CT2	176
FIRE PUMP ENGINE RUNNING	SUPV	SIGA-CT2	177
FIRE PUMP SPARE (3281)		SIGA-CT2	178
FIRE PUMP CONTROLLER SWITCH OFF AUTO	SUPV	SIGA-CT2	179
FIRE PUMP ENGINE TROUBLE	SUPV	SIGA-CT2	180
FIRE PUMP SPARE (1683)		SIGA-CT2	181
BOOSTER SPARE @ MAIN ENTRANCE	SUPV	SIGA-CT2	182
MAIN FLOOR BELL OOSTER TROUBLE	SUPV	SIGA-CT2	183
2ND FLOOR CENTRE DOOR HOLDER	RLY	SIGA-CR	184
LOW WATER IN RESERVOIR	MON	SIGA-CT2	185
SPARE LOW WATER IN RESERVOIR	MON	SIGA-CT2	186
TOP OF STAIRS CR ADJ. ELEVATOR	RLY	SIGA-CR	187

Location Description	Device	Model	Address	Zone / Circuit #
----------------------	--------	-------	---------	------------------

1ST FLOOR HORN/STROBES

BOILER ROOM 1501	H/S			1
CAFETERIA 1422 BY EXIT	H/S			1
KITCHEN 1424	H/S			1
MUSIC ROOM 1426	H/S			1
MUSIC ROOM 1426	H/S			1
SERVER ROOM 1206	H/S			1
MUSIC ROOM PRACTICE 1430	H/S			1
MUSIC ROOM PRACTICE 1429	H/S			1
MUSIC ROOM PRACTICE 1428	H/S			1
ROOM 1210 BY ROOM 1208	H/S			1
CORRIDOR 1212 BY ROOM 1211	H/S			1

ROOM 1207 BBY ROOM 1205	H/S			1
FEMALE WASHROOM 1202	H/S			1
MAL WASHROOM 1201	H/S			1
BY STAIR 2 NEXT TO MALE WASHROOM	H/S			1
MALE LOCKER ROOM 1414	H/S			1
SHOWERS 1415	H/S			1
SHOWERS 1413	H/S			1
LIBRARY ROOM 1126	H/S			1
ELECTRICAL ROOM	H/S			1
IN BOOSTER @ MAIN ENTRANCE	EOL			1

BOOSTER NAC1 ABOVE CEILING IN MAIN ENTRANCE

FOYER 1102 BY MAIN ENTRANCE				1
ADMIN. ROOM 1104				1
WASHROOM 1108 BY ADMIN.				1
CORRIDOR 1112 BY ROOM 1113				1
TEEN HEALTH ROOM 1119				1
STUDENT SERVICES ROOM 1118				1
ROOM 1121 NEXT TO 1122				1
ACC. WASHROOM 1302 ROOM 1306 BY ROOM 1301				1

Location Description	Device	Model	Address	Zone / Circuit #	I
CORRIDOR 1309 BY ROOM 1308				1	
TECH. PROD. ROOM 1303				1	
WATER ROOM 1506				1	
SPRINKLER ROOM 1507 BY 1506				1	
FEMALE WASHROOM 1124				1	

MALE WASHROOM 1123				1
MALE LOCKER ROOM 1406				1
SHOWERS 1407				1
FEMALE LOCKER ROOM 1408				1
SHOWERS 1409				1
SHPRINKLER ROOM	EOL			1

NAC3 - ELECTRICAL ROOM BOOSTER

OUTSIDE BACK OF BUILDING	H/S			3
OUTSIDE FRONT OF BUILDING	H/S			3
ELECTRICAL ROOM	EOL			3

NAC4 - PENTHOUSE

TOP OF STAIRS	H/S			4
EXIT TO OUTSIDE	H/S			4
EXIT TO OUTSIDE	EOL			4

2ND FLOOR HORN/STROBES

2ND FLOOR BY 2309				2
IN ROOM 2307				2
IN ROOM 2306				2
MECHANICAL ROOM BY MCC				2
MECHANICAL ROOM BY CONTROL PANEL				2
FEMALE WASHROOM 2104				2
MALE WASHROOM 2102				2
CORRIDOR BY 2202				2
CORRIDOR Y SERVER ROOM				2
SERVER ROOM 2109				2

CORRIDOR ADJ. ELEVATOR				2
---------------------------	--	--	--	---

Location Description	Device	Model	Address	Zone / Circuit #
MALE WASHROOM 2110				2
FEMALE WASHROOM 2111				2
CORRIDOR BY 2210				2
ROOM 2213				2
STAIR 5 TO PENTHOUSE				2
ROOM 2214				2
CORRIDOR ADJ. 2215				2
GYM BY VESTIBULE				2
GYM NEAR EXIT				2
GYM NEAR OFFICE				2
STAGE				2
ELECTRICAL ROOM				2
ROOM 2301				2
ROOM 2203				2
PENTHOUSE	EOL			2

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #	
	ELECTRICAL ROOM				
	BOILER ROOM				
	GYM				
	GYM				
	GYM				

	GYM			
	OFFICE			
	SPRINLER ROOM			
	PENTHOUSE BY OUTSIDE EXIT			
	PENTHOUSE			
	THROUGH SPRINKLER RM 1507			
	WOODSHOP			
	ELEVATOR MACHINE ROOM			
	CAFETERIA			
	SERVER ROOM 2109			
	BY 1305		EXIT	
	MECH RM 2501	2		
	GYM ABOVE STORAGE RM NEAT EXIT	2		
	GYM		REMOTE	
	STUDENT SERVICES 1116	2		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

	EML's are automatic.	
--	----------------------	--

LOCATION: Musquodoboit Valley School FIRE ALARM PANEL: Simplex 4010		Device	Device address or circuit number
MANUAL PULL STATIONS			
1	NORTH GYM EXIT	MA	M1-1
2	SOUTH GYM EXIT	MA	M1-2
3	OUTDOOR GYM STORAGE	MA	M1-3
4	WEST EXIT BY KITCHEN	MA	M1-4
5	KITCHEN EXIT	MA	M1-5
6	ATRIUM ENTRANCE NORTH	MA	M1-6
7	ATRIUM NORTH EXIT	MA	M1-7
8	MAIN ENTRANCE SOUTH	MA	M1-8
9	MAIN ENTRANCE NORTH	MA	M1-9
10	EAST EXIT 123	MA	M1-13
11	FORESTRY Classroom 2	MA	M1-10
12	FORESTRY CONFERENCE RM EXIT	MA	M1-12
13	FORESTRY ENTRANCE	MA	M1-11
14	MECHANICAL RM 132	MA	M1-15
15	NORTH EXIT (BY MECH RM 132)	MA	M1-14
16	PUMP HOUSE	M	M1-41
17	PUMP HOUSE WORKSHOP	M	M1-41
18	PUMP HOUSE UPPER WORKSHOP	M	M1-41
19	PUMP HOUSE UPSTAIRS	M	M1-41
SMOKE DETECTORS			
1	ELECTRICAL RM 163B(WITHIN 163B)	SA	M1-42
2	CORR BY RM 167	SA	M1-64
3	CORR BY FAMILY RECOURSE CENTER	SA	M1-63
4	DATA RM 163A	SA	M1-43
5	EAST CORR	SA	M1-23
6	EAST CORR	SA	M1-22
7	EAST CORR	SA	M1-24
8	FORESTRY HALLWAY	SA	M1-25
9	TELEPHONE RM 132A	SA	M1-20
10	ELECTRICAL RM 132A	SA	M1-21
DUCT SMOKE DETECTORS			
HEAT DETECTORS			
SPRINKLER DEVICES			

1	GYM MECHANICAL RM 183	DSA	M1-46
2	GYM MECHANICAL RM 183	DSA	M1-47
3	GYM MECHANICAL RM 183	DSA	M1-48
4	GYM MECHANICAL RM 183	DSA	M1-49
5	MECHANICAL RM 163	DSA	M1-45
6	MECHANICAL RM 163	DSA	M1-44
7	MECHANICAL RM 132	DSA	M1-16
8	MECHANICAL RM 132	DSA	M1-17
9	MECHANICAL RM 132	DSA	M1-18
10	MECHANICAL RM 132	DSA	M1-19
1	MECHANICAL RM 132	RHTA	M1-60
2	MECHANICAL RM 163	RHTA	M1-61
3	PUMP HOUSE, UPPER LEV STORAGE	RHT	M1-41
4	PUMP HOUSE , UPPER LEV MEZZANINE	RHT	M1-41
1	SPK SYS RM 141 FLOW NEW	FS	M1-26
2	SPK SYS RM 141 FLOW EXIST	FS	M1-27
3	SPK SYS RM 141 FLOW ATTIC ZONE	FS	M1-28
4	SPK SYS RM 141 LOW AIR ATTIC ZONE	SV	M1-29
5	SPK SYS RM 141 MAIN CONTROL VALVE	SV	M1-30
6	SPK SYS RM 141 NEW ADDITION VALVE	SV	M1-31
7	SPK SYS RM 141 EXIST VALVE	SV	M1-32
8	SPK SYS RM 141 ATTIC ZONE VALVE	SV	M1-33
9	CONTROL VALVE - WET PUMP HOUSE	SV	M1-35
10	ATTIC LOW AIR DRY RM 141	SV	M1-36
11	FLOW SPRINKLER - DRY- PUMP HOUSE	FS	M1-37
12	FLOW SPRINKLER -WET- PUMP HOUSE	FS	M1-38
13	ATTIC CTRL VALVE - DRY PUMP HOUSE	SV	M1-39
14	PUMP HOUSE ZONE		M1-41
15	KITCHEN SUPPRESSION	FS	M1-50
16	MAIN CONTROL VALVE 1 PUMP HOUSE	SV	M1-51
17	MAIN CONTROL VALVE 2 PUMP HOUSE	SV	M1-52
18	TEST HEADER FIRE PUMP	SV	M1-53
19	PUMP CONTROL VALVE	SV	M1-54

NOTIFYING APPLIANCES

1	FORESTRY HALL	HSP	SIG 1
2	MAIN ATRIUM	HSP	SIG 2
3	MECHANICAL RM 163	HSP	SIG 2
4	BY RM 165	HSP	SIG 2
5	ART/MUSIC RM 192	HSP	SIG 2
6	BY CAFETERIA	HSP	SIG 2
7	CAFETERIA	HSP	SIG 2
8	GYM	HSP	SIG 2
9	GYM	HSP	SIG 2
10	MECHANICAL RM 183	HSP	SIG 2
11	MALE WASHROOM 170	HSP	SIG 2
12	FEMALE WASHROOM 171	HSP	SIG 2
13	MALE LOCKER RM 185	HSP	SIG 2
14	FEMALE LOCKER RM 189	HSP	SIG 2
15	MALE WASHROOM (FORESTRY)	HSP	SIG 1
16	FEMALE WASHROOM (FORESTRY)	HSP	SIG 1
17	MALE WASHROOM 141	HSP	SIG 1
18	FEMALE WASHROOM 140	HSP	SIG 1
19	HALLWAY BY 141	HSP	SIG 1
20	HALLWAY BY 149	HSP	SIG 1
21	MECHANICAL RM 132	HSP	SIG 1
22	WASHROOM 134	HSP	SIG 1
23	WASHROOM 135	HSP	SIG 1
24	WASHROOM 168	HSP	SIG 1
25	PUMP HOUSE	B	SIG 3
26	PUMP HOUSE	B	SIG 3
27	PUMP HOUSE	B	SIG 3
28	PUMP HOUSE	B	SIG 3
29	PUMP HOUSE	B	SIG 3

RELAYS, AUXILIARIES

1	VENTILATION CONTROL	RLY	AUX 1
2	CITY DISCONNECT	RLY	AUX 2
3	DOOR HOLDERS	RLY	AUX 3

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	ENTRANCE DEPT OF NATURAL RESOURCES		EXIT

	FROM DEPT OF NATURAL RESOURCES TO SCHOOL ENTRANCE		EXIT
	SIDE EXIT NEAR NATURAL RESOURCES		LUMACELL EXIT
	NEW STAFF ROOM		LUMACELL EXIT
	NEAR SPRINKLER ROOM		LUMACELL EXIT
	EXIT NEAR 150		LUMACELL EXIT
	EXIT VESTIBULE NEAR 150		LUMACELL EXIT
	FRONT EXIT NEAR OFFICE		LUMACELL EXIT
	CORRIDOR EXIT NEAR 167		LUMACELL EXIT
	GYM REAR EXIT		LUMACELL
	GYM REAR EXIT		LUMACELL
	GYM SIDE EXIT TO VESTIBULE		LUMACELL
	GYM EXIT TO SCHOOL CORRIDOR		LUMACELL
	CAFETERIA EXIT TO VESTIBULE		LUMACELL
	CAFETERIA EXIT TO SCHOOL CORRIDOR		LUMACELL
	GENERATOR ROOM PUMPHOUSE		LUMACELL UNIT

	LOCATION: Upper Musqodoboit	Device	Device address or circuit
	FIRE ALARM PANEL: Edwards 1527-1001		
1	DEVICES		
2	NORTH EXIT	M	ZONE 1
3	SOUTH EXIT	M	ZONE 1
4	EAST EXIT	M	ZONE 1
5	SOUTH EXIT	EOL	ZONE 1
6	BELLS		
7	MAIN ENTRY	B	SIG 1
8	EAST HALL	B	SIG 1
9	WEST HALL	B	SIG 1
10	JANITORS RM ABOVE PANEL	EOL	

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH	Manuf.
1	GYM AREA BY WASHROOMS		Y		Emergi lght
2	SOUTH HALL BY RM #6		Y	6V 7 AH	Emergi lght
3	NORTH HALL		Y		Emergi lght
4	EXIT BY RM 6				Emergi lght
5	EXIT BY PRINCIPALS OFFICE				EXIT
6	EXIT BY RM 2				EXIT
7					EXIT

	LOCATION:Ash Lee Jefferson	Device	Device address or circuit number	Annunciation	NOTES
	FIRE ALARM PANEL:Edwards EST2				
1	JANITOR'S RM 105	HTA	101		
2	STORAGE RM 103 (IN 108)	SA	102		
3	STORAGE RM 108	SA	103		
4	COMM RM 110	SA	104		
5	IN ROOM 260-259 STORAGE CLOSET	SA	105		check 252
6	ELECTRICAL RM 271	SA	106		
7	CUSTODIAN RM 272	HTA	107		
8	STORAGE RM 276	SA	108		
9	STAIRWELL # 2, REAR	SA	109		
10	STORAGE RM 122	SA	110		
11	ELEVATOR SHAFT	SA	112		
12	ADMIN. STORAGE RM 215	SA	114		
13	MUSIC STORAGE RM 247	SA	115		
14	CUSTODIAN RM 244	HTA	116		
15	STAIRWELL # 1,FRONT	SA	117		
16	CUSTODIAN OFFICE 127	HTA	118		
17	KITCHEN	HTA	119		
18	COMM RM 246	SA	120		
19	RECYCLE RM 221	SA	121		
20	GYM STORAGE	SA	122		
21	FAN RM 223, IN GYM STORAGE ROOM	HTA	123		
22	FAN RM 223, IN GYM STORAGE ROOM	HTA	124		
23	KITCHEN	HTA	125		
24	SPRINKLER RM 132	HTA	126		
25	ELECTRICAL RM 129	SA	127		
26	COMM RM 131	SA	128		
27	ELEVATOR MACHINE RM 123	HTA	129		
28	NEAR RM 102	MA	203		
29	MECH RM 121	MA	204		
30	ACROSS FROM 262	MA	205		
31	BY STAIRWELL # 2	MA	206		
32	EXIT NEAR 287	MA	207		
33	GATE TANK 3	SV	208		
34	LOW WATER TANK 3	SV	209		

35	GATE TANK 2	SV	210		
36	LOW WATER TANK 2	SV	211		
37	NEAR ELEVATOR	MA	213		
38	LOW AIR # 1, 2, 3	PS	214		
39	SPRINKLER MAIN FLOW	FSP	216		
40	MAIN GATE VALVE	SV	217		
41	LOW WATER TANK 1	PS	218		
42	GATE TANK 1	SV	219		
43	2ND FL SPRINKLER	FSV	220		
44	2ND FL SPRINKLER	SV	221		
45	1ST FL SPRINKLER	FSV	222		
46	CAFETERIA EXIT	MA	223		
47	KITCHEN EXIT	MA	224		
48	1ST FL SPRINKLER	SV	225		
49	FL ADJ. COMM RM	MA	226		
50	MAIN ENTRANCE	MA	227		
51	BY STAIRWELL # 1	MA	228		
52	ELEVATOR GATE	SV	229		
53	CAFETERIA EXIT	MA	230		
54	FAN RM 223, IN GYM STORAGE ROOM	MA	231		
55	FAN RM 223, IN GYM STORAGE ROOM	MA	232		
56	GYM EXIT	MA	233		
57	GYM EXIT	MA	234		
58	MECHANICAL RM 133	HT	235		
59	MECHANICAL RM 133	HT	235		
60	MECHANICAL RM 133	HT	235		
61	MECHANICAL RM 133	HT	235		
62	ELEVATOR PIT	SV	236		
63	MECH / BOILER RM 133 Exit # 1	MA	238		
64	MECH / BOILER RM 133 EXIT # 2	MA	239		
65	NOTIFYING DEVICES				
66	GYM	HS			
67	GYM	HS			
68	CAFETERIA	HS			
69	CAFETERIA	HS			
70	FAN RM 223	HS			
71	OFFICE	HS			
72	1ST FLOOR	HS			
73	1ST FLOOR	HS			
74	1ST FLOOR	HS			
75	1ST FLOOR	HS			
76	2ND FLOOR	HS			
77	2ND FLOOR	HS			

78	2ND FLOOR	HS			
79	2ND FLOOR	HS			
80	2ND FLOOR	HS			
81	2ND FLOOR	HS			
82	2ND FLOOR	HS			
83	2ND FLOOR	HS			
84	BOILER RM	HS			
85	BOYS WASHROOM BY 244	V			
86	GIRLS WASHROOM BY 244	V			
87	BOYS CHANGE RM	V			
88	GIRLS CHANGE RM	V			
	SPRINKLER TANK 1	GV			
	SPRINKLER TANK 2	GV			
	SPRINKLER TANK 3	GV			
	TOP STAIRS #2	R	206		
	DOOR HOLDERS	R			

FIRE ALARM NOTES AND RECOMMENDATIONS

	SMOKE DETECTORS ARE PHOTO TYPE; RANGE: 0.67-3.76%,
	KITCHEN SHUNT BREAKER IN PANEL IN KITCHEN
	Fire Door Number or Location
	BY INFO CENTER
	BOTTOM OF STAIRS 1
	BOTTOM OF STAIRS 2
	TOP OF STAIRS 1
	TOP OF STAIRS 2
	BY ROOM 256
	BY MECHANICAL ROOM #3
	By Mech Rm 134
	By Elev. Mach. Rm 123
	2nd Flr by Rm 256

EMERGENCY LIGHTING					
Line #	EL UNIT Location	Remote Head	Cab. Head	Bat . V A H	MOD #
1	Stairs # 1(FRONT)		Y	12	

2	Stairs # 1	Y			
3	Stairs # 2		Y	12	
4	STAIRS #2				
5	CUSTODIAN 105		Y		
6	Staff Washroom	Y			
7	Girls Washroom	Y			
8	Boys Washroom	Y			
9	COMMS ROOM 110	Y			
10	Storage Rm 103 (inside 108)	Y			
11	By Comm Rm 110		Y		
12	Elevator Machine Rm	Y			
13	By 114	Y			
14	By 118		Y	12	
15	By Mech Rm 121	Y			
16	By Storage Rm 122	Y			
17	Elevator Machine Rm	Y			
18	By Elevator, Lower Level	Y			
19	By Electrical Rm 129		Y		
20	By Storage Rm 125	Y			
21	STORAGE ROOM 125	Y			
22	By 137	Y			
23	Bottom Stairs # 1 Exit	Y			
24	Electrical Rm 129		Y		
25	Janitor's Office 130		Y		
26	Comm Rm 131	Y			
27	CUSTODIAN 127		Y		
28	BOYS WASHROOM 126	Y			
29	GIRL'S WASHROOM 128	Y			
30	Mechanical Room 121	Y			
31	MECHANICAL ROOM 133		Y		
32	MECHANICAL ROOM 131	Y			
33	Sprinkler Rm 132	Y			
34	Kitchen		Y		
35	Kitchen	Y			
36	Kitchen	Y			
37	Gym near Cafeteria		Y		
38	Gym Storage	Y			
39	Gym	Y			
40	Gym near Stage		Y		
41	Gym	Y			
42	Cafeteria Entrance		Y		
43	CAFETERIA EXIT		Y		
44	Outside Cafeteria		Y		

45	By Office	Y			
46	By Music Room	Y			
47	By Library	Y			
48	Gym Stage Hall		Y		
49	Gym Stage ramp		Y		
50	Gym Stage ramp, TOP	Y			
51	Fan Rm 223		Y		
52	Fan Rm 223	Y			
53	Janitor's Rm 244		Y		
54	Girls Washroom	Y			
55	Boys Washroom	Y			
56	By 250		Y		
57	By 248	Y			
58	By Comm Rm 248	Y			
59	By 255		Y		
60	By 256	Y			
61	By 264	Y			
62	By 268		Y	12	
63	By 267	Y			
64	Janitor's Rm 272		Y		
65	Girls Washroom	Y			
66	Boys Washroom	Y			
67	By Storage 276		Y	12	
68	By 286	Y			
69	Storage 276	Y			
70	BY 260		Y	12	
71	GYM STAGE		Y	12	
72	GYM STAGE BY STAIRS		Y		

	LOCATION: Beaver Bank Kinsac	Device	Device address or circuit number	Remarks
	FIRE ALARM PANEL: Edwards 6500			
	MANUAL PULL STATIONS			
1	BY ROOM 206	M	ZONE 1	
2	EXIT BY 216	M	ZONE 1	
3	FURNACE ROOM	M	ZONE 1	
4	CORRIDOR EXIT BY 214	M	ZONE 1	
7	MAIN ENTRANCE	M	ZONE 3	
8	CORRIDOR BY 202 STAIRS	M	ZONE 3	
9	GYM	M	ZONE 3	
10	GYM	M	ZONE 3	
11	GYM EXIT	M	ZONE 3	
14	SPRINKLER ROOM	M	ZONE 6	
15	BASEMENT BY WASHROOMS	M	ZONE 6	
16	BASEMENT BY CLASSROOM 101	M	ZONE 6	
SMOKE DETECTORS				
19	STAIRS TO BASEMENT BY OFFICE	S	ZONE 11	
22	STAIRS TO BASEMENT BY 202	S	ZONE 10	
37	ELECTRICAL ROOM	S	ZONE 2	
DUCT SMOKE DETECTORS				
25	SPRINKLER ROOM AIR HANDLER SUPPLY	DS	ZONE 7	

28	SPRINKLER ROOM AIR HANDLER RETURN	DS	ZONE 8	
31	GYM FAN ROOM SUPPLY	DS	ZONE 4	
34	GYM FAN ROOM RETURN	DS	ZONE 5	
SPRINKLER DEVICES				
1	WATER FLOW ALARM	FSP	ZONE 9	
3	MAIN VALVE	SV	ZONE 14	
2	TANK VALVE #1	SV	ZONE 14	
4	TANK VALVE #2	SV	ZONE 14	
5	LOW WATER TANK #1	SV	ZONE 16	
6	LOW WATER TANK #2	SV	ZONE 13	
7	LOW AIR SPRINKLER SYSTEM	SV	ZONE 15	
NOTIFYING DEVICES				
1	BY 214	B		
2	BY RM 210	B		
3	BY 207	B		
4	GYM HALL	B		
5	ROOM 201	B		
6	ROOM 101	B		
7	SPRINKLER TANK ROOM	B		
8	GYM	B		
END OF LINE RESISTORS				
1	EXIT BY 215	EOL	ZONE 1	
2	GYM EXIT	EOL	ZONE 3	
3	BASEMENT BY CLASSROOM 101 BASEMEN	EOL	ZONE 6	
4	STAIRS CEILING	EOL		
5	STAIRS CEILING	EOL		
6	SPRINKLER ROOM	EOL	ZONE 7	
7	SPRINKLER ROOM	EOL	ZONE 8	

8	GYM FAN ROOM	EOL	ZONE 4	
9	GYM FAN ROOM	EOL	ZONE 5	
10	ELECTRICAL ROOM	EOL	ZONE 2	
11	SPRINKLER ROOM	EOL	ZONE 14	
12	SPRINKLER ROOM	EOL	ZONE 16	
13	SPRINKLER ROOM	EOL	ZONE 13	
14	SPRINKLER ROOM	EOL	ZONE 9	
15	SPRINKLER ROOM	EOL	ZONE 15	
16	BY 214	EOL	SIG 1	
17	BY RM 210	EOL	SIG 2	
	RELAYS, AUXILIARIES			
1	DOOR HOLDERS NEW AREA	AUX	AUX1	
2	DOOR HOLDERS OLD AREA	AUX	AUX 2	
3	CITY CONNECTION	AUX	AUX 3	

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Remarks
1	FRONT ENTRANCE			
2	CORR BY GYM			
3	CORR BY 203			
4	TOP OF STAIR BY RM 202			908 BULBS
6	STAIRS 1ST FLOOR			
7	CORR BY ELECT RM			
8	CORR BY LEARNING CENTER			
9	CORR BY 211			
10	STAIRS BY 101 BASEMENT			
11	NEAR WASHROOM BASEMENT			
14	BY RM101			
15	GYM RIGHT			
16	GYM LEFT			
	GYM EXIT		Y	COMBO
17	FAN ROOM GYM			908 BULBS
18	EXIT FROM GYM TO FIELD			

19	SPRINKLER ROOM			
	BOYS WASHROOM UPSTAIRS			
	GIRLS WASHROOM UPSTAIRS	Y		
20	BOYS WASHROOM (BASEMENT)			
21	BASEMENT STAIRS TO MAIN			
	BREAKERS			
1	By office Panel D, CCT 4			
2	By Stage Panel C, CCT 10 & 15			
3	In Boiler Rm Panel PP, CCT 2 & 4			
4	Basement Hallway Panel E, CCT 4			

	LOCATION: Beaver Bank Monarch Dr.	Device	Device address or circuit number	Annunciation
	FIRE ALARM PANEL: Edwards 6500			
	Devices			
1	MAIN ENTRANCE	M	ZN1	
2	CANTEEN	HT	ZN1	
3	BY CENTER STAIRS	M	ZN1	
4	ELEVATOR MACHINE ROOM	S	ZN10	
5	ELEVATOR MACHINE ROOM	EOL	ZN10	
6	BY ROOM 102	M	ZN1	
7	BY ROOM 123	M	ZN1	
8	BY ROOM 125	EOL	ZN1	
9	TOP OF CENTER STAIRS	M	ZN3	
10	BY ROOM 201	M	ZN3	
11	BY ROOM 225	M	ZN3	
12	BY ROOM 225	EOL	ZN3	
13	MECHANICAL/SPRINKLER ROOM	M	ZN9	
14	MECHANICAL/SPRINKLER ROOM	EOL	ZN9	
15	FAN ROOM # 2 RETURN	DS	ZN11	
16	FAN ROOM # 2 SUPPLY	DS	ZN11	
17	CENTER STAIR	S	ZN5	
18	CENTER STAIR	EOL	ZN5	
19	STAIRS BY ROOM 201	S	ZN7	
20	STAIRS BY ROOM 201	EOL	ZN7	
21	STAIRS BY ROOM 225	S	ZN8	
22	STAIRS BY ROOM 225	EOL	ZN8	
23	GYM EXIT	M	ZN2	
24	GYM EXIT	EOL	ZN2	
25	STAIRS FROM GYM TO FAN ROOM #	S	ZN4	
26	STAIRS FROM GYM TO FAN ROOM #	EOL	ZN4	
27	FAN ROOM # 1 RETURN	DS	ZN12	
28	FAN ROOM # 1 SUPPLY	DS	ZN12	
29	FAN ROOM # 1	EOL	ZN12	
	OUTSIDE STORAGE	M		
	SIGNALS			
31	SPRINKLER ROOM	B	SIG2	
32	BY ROOM 102	B	SIG2	

33	BY ROOM 104	B	SIG2	
34	1ST FLOOR BY CENTER STAIRS	B	SIG1	
35	BY ROOM 124	B	SIG2	
36	BY ROOM 220	B	SIG1	
37	BY ROOM 223	B	SIG2	
38	BY ROOM 204	B	SIG1	
39	BY ROOM 124	B	SIG2	
40	GYM EXIT	B	SIG2	
41	GYM STOARGE	B	SIG2	
42	FAN ROOM # 1	B	SIG2	

RELAYS

DOOR RELEASE	R	
AHU SHUTDOWN	R	
TANK #1	GV	20
TANK #2	GV	20
MAIN	GV	20
LOW WATER	SUP	19
SPRINKLER ALARM	ALM	13
LOW AIR	SOP	21

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	CIRCUIT
1	BY ROOM 104			1
2	BY 1ST FLOOR MACH. ROOM			2
3	MAIN ENTRY			3
4	BY ROOM 122			4
5	GYM ENTRY			
6	GYM BY GIRLS LOCKER ROOM			
7	GYM REAR			
8	BOYS LOCKER ROOM			
9	BOYS LOCKER ROOM ENTRY	Y		
10	GIRLS LOCKER ROOM			
11	GIRLS LOCKER ROOM ENTRY	Y		

12	CENTER STAIRWELL			10
13	BY ROOM 220			11
14	BY ROOM 202			12
15	BY ROOM 223			
16	BOYS WASHROOM 2ND FLOOR			14
17	BOYS WASHROOM 2ND FLR ENTRY	Y		
18	GIRLS WASHROOM 2ND FLOOR			
19	GIRLS WASHROOM 2ND FLR ENTRY	Y		
20	STAIRWELL BY ROOM 225			
21	STAIRWELL BY ROOM 201			
22	RAMP BEHIND STAGE			18
23	BOYS WASHROOM 1ST FLOOR			
24	BOYS WASHROOM 1ST FLR ENTRY	Y		
25	GIRLS WASHROOM 1ST FLOOR			
26	GIRLS WASHROOM 1ST FLR ENTRY	Y		
	PORTABLE MAIN DOOR			
	PORTABLE DOOR AT RAMP			

NOTE; PNL 101 BREAKER CONTOL DOOR HODERS

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS			
REM # 1 Panel 102, cct # 18 controls lights 1, 2, 3 & 4.			
Panel 101, cct # 18 controls lights 5 to 11 and 22. Panel in Room 210,			
cct # 13 controls lights 13 to 22			

LOCATION: George P. Vanier	Device	Device address or circuit
FIRE ALARM PANEL: Edwards 6616		

MANUAL PULL STATIONS			
1	MAIN ENTRY	M	ZN 11
2	BOTTOM STAIR 2	M	ZN 11
3	BOTTOM STAIR 3	M	ZN 11
4	BOTTOM STAIR 4	M	ZN 11
5	TOP STAIR 4	M	ZN 2
6	TOP STAIR 3	M	ZN 2
7	TOP STAIR 2	M	ZN 2
8	TOP STAIR 1	M	ZN 2
9	BOTTOM STAIR 1	M	ZN 11
10	BACK OF GYM BY EXIT(RIGHT SIDE)	M	ZN 8
11	BACK OF GYM BY EXIT(LEFT SIDE)	M	ZN 8
12	MECHANICAL ROOM 209	M	ZN 8
13	CAFETERIA	M	ZN 11
14	BOILER ROOM	M	ZN 11
15	ROOM 146 ART RM.	M	
SMOKE DETECTORS			
1	TOP STAIR 4	SI	ZN 1
2	TOP STAIR 3	SI	ZN 3
3	BOYS SHOWER ROOM	SI	ZN 11
4	GIRLS SHOWER ROOM	SI	ZN 11
5	TOP STAIR 2	SI	ZN 6
6	TOP STAIR 1	SI	ZN 5
7	ELEVATOR MACHINE ROOM 157	SI	ZN 11
8	ELEVATOR SHAFT	SI	ZN 11
DUCT SMOKE DETECTORS			
1	MECH. RM. 248/RETURN #1	DS	ZN 02
2	MECH. RM. 248/RETURN #2	DS	ZN 02
3	BOOK STORAGE 249	DS	ZN 02
4	MECH. RM. 202/RETURN #1	DS	ZN 07
5	MECH. RM. 202/RETURN #2	DS	ZN 07
6	MECH. RM. 202/SUPPLY	DS	ZN 02
7	MECH. RM.209/SUPPLY/AHU#3	DS	ZN 07
8	MECH. RM. 209/RETURN	DS	ZN 07
HEAT DETECTORS			

	BOILER ROOM	HT	ZN 11
	CAFETERIA	RHT	ZN 11
	CAFETERIA	HT	ZN 11
	KITCHEN	HT	ZN 9
	CUSTODIAN ROOM 124	HT	ZN 11
	STORAGE ROOM 112,GYM	HT	ZN 08
	STORAGE ROOM 112,GYM	HT	ZN 08
	GYM EQUIPMENT ROOM 103	HT	ZN 11
	BOOK STORAGE 132	HT	ZN 11
	CUSTODIAN ROOM 133	HT	ZN 11
	ELECTRICAL ROOM 154 (IN RM 153)	HT	ZN 11
	ART ROOM 146	HT	ZN 11
	ART ROOM 146	HT	ZN 11
	STORAGE RM 148 (IN RM 146)	HT	ZN 11
	COMPUTER LAB ROOM 164	HT	ZN 11
	COMPUTER LAB ROOM 164	HT	ZN 11
	OUTDOOR STORAGE ROOM	HT	ZN 11
	MECHANICAL ROOM 202	HT	ZN 02
	BOOK ROOM 203	HT	ZN 02
	CUSTODIAN ROOM 212	HT	ZN 02
	GYM STAIRS STORAGE ROOM 207	HT	ZN 08
	STORAGE ROOM 248	HT	ZN 02
	BOOK STORAGE 249	HT	ZN 02
	MECHANICAL ROOM 209	HT	ZN 08
	STORAGE ROOM 238	HT	ZN 02
	STORAGE ROOM 242	HT	ZN 02
	PROJECT STORAGE 147 in 146	HT	
NOTIFYING DEVICES			
1	MAIN ENTRY	B	
2	ROOM 134	B	
3	ROOM 146	B	
4	ACROSS 153	B	
5	BY 161	B	
6	BY 245	B	
7	BY 249	B	
8	MECHANICAL ROOM 248	B	
9	LIBRARY 281	B	
10	SCIENCE ROOM 220	B	
11	MECHANICAL ROOM 202	B	
12	BOTTOM STAIR 1	B	
13	GYM BY MAIN ENTRY	B	
14	GYM REAR	B	
15	CAFETERIA	B	

16	CAFETERIA	B	
17	INDUSTRIAL; ROOM 164	B	
	MUSIC ROOM	H/S	
	DOOR RELEASE	RHT	

Unit #	Location	# of Heads	Model
	BY MAIN DOOR		EXIT
9	BY MAIN DOOR		12V 144W
8	HALL BY CAFETERIA		12V 144W
	BY GUIDANCE		EXIT
	STAIRS 2		EXIT
	BY ROOM 150		12V 144W
	BY ROOM 151		EXIT
1	BY ROOM 153		12V 144W
	BY ROOM 158		EXIT
13	BY ROOM 160		12V 144W
	BY ROOM 164		EXIT
	BY ROOM 164		EXIT
	STAIRS 4		12V 144W
	BY ROOM 244		EXIT
	BY ROOM 245		12V 144W
	BY ROOM 239		EXIT
	STAIRS 3		12V 144W
	BY ROOM 249		12V 144W
	BY ROOM 235		EXIT
	BY ROOM 230		12V 144W

	BY ROOM 219		EXIT
29	BY TOP OF STAIRS 2		12V 144W
	BY ROOM 216		COMBO
	BY ROOM 215		EXIT
24	BY ROOM 202		12V 144W
	BY ROOM 205		EXIT
	BOTTOM OF STAIRS 1		EXIT
12	CAFETERIA		COMBO
11	CAFETERIA BY KITCHEN		12V 144W
	GYM ENTRANCE		COMBO
23	GYM BY OFFICE		12V 144W
	GYM EXIT		COMBO
	GYM EXIT		COMBO
16	GYM		12V 144W
30	STAIRS NEAR ROOM 228		12V 144W
	MECH ROOM 202		12V 144W
27	MECH ROOM 248		12V 144W
	LIBRARY EXIT		COMBO
10	CAFETERIA EXIT		COMBO

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

PANEL BREAKER FOR EMERGENCY LIGHTS: 1) KITCHEN, PANEL 6, CCT#10, 2) BY RM 160, PANEL 3, CCT#30,
--

3) BY RM 150, PANEL A, CCT#16, 4) BY RM 240, PANEL I, CCT#14, 5) RM 202, PANEL 10, CCT#6, GYM, PANEL 2, CCT#10

Fire Door Number or Location	
BOTTOM OF STAIR 1	
TOP OF STAIR 1	
BOTTOM OF STAIR 2	
TOP OF STAIR 2	
BOTTOM OF STAIR 3	
TOP OF STAIR 3	
BOTTOM OF STAIR 4	
TOP OF STAIR 4	
LOBBY ENTRY TO REAR CORRIDOR	

	LOCATION: Harold T. Barrett	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards QS4		
1	MAIN ENTRY	M	ZN 1
2	CENTER HALL BY 107	M	ZN 1
3	WEST EXIT BY HOME EC	M	ZN 1
4	FURNACE ROOM	M	ZN 1
5	CAFETERIA EXIT	M	ZN 1
6	GYM HALL TO CAFETERIA	M	ZN 1
7	GYM FRONT EXIT	M	ZN 1
8	GYM REAR EXIT	M	ZN 1
9	WOODSHOP	M	ZN 1
10	PAINTSHOP	M	ZN 1
11	NORTH EXIT REAR BY LEARNING CTR	M	ZN 2
12	SOUTH EXIT BY ROOM 105	M	ZN 2
13	2ND FLOOR BY ROOM 204	M	ZN 3
14	2ND FLOOR BY ROOM 206	M	ZN 3
15	ELECTRICAL ROOM	SI	ZN 1
16	ELEVATOR SHAFT	SI	ZN 6
17	WEST STAIRWELL	SI	ZN 4
18	EAST STAIRWELL	SI	ZN 5
19	GYM FAN ROOM SUPPLY	DS	ZN 8
20	GYM FAN ROOM RETURN	DS	ZN 8
21	NORTH FAN ROOM SUPPLY	DS	ZN 9
22	NORTH FAN ROOM RETURN	DS	ZN 9
23	SOUTH FAN ROOM SUPPLY	DS	ZN 7
24	SOUTH FAN ROOM RETURN	DS	ZN 7
25	FURNACE ROOM	FSP	ZN 10
26	FURNACE ROOM	FSP	ZN 11
27	FURNACE ROOM #1 SUPERVISORY	SV	ZN 15
28	FURNACE ROOM #2 SUPERVISORY	SV	ZN 15
29	FURNACE ROOM #3 SUPERVISORY	SV	ZN 15

30	FURNACE ROOM #4 SUPERVISORY	SV	ZN 15
31	KITCHEN Range Sprinkler Valve	AD	ZN 16
32	BOY'S WASHROOM 2ND FLOOR	SV	ZN 17
33	Kitchen Range Suppression System	AD	ZN 18
	AHU SHUT DOWN	FYL	
	GATE VALVE	SUP	14
	TANK #1 LOW WATER	SUP	13
	TANK #2 LOW WATER	SUP	12
	BOOSTER PANEL	SUP	3
34	NOTIFYING DEVICES		
35	GYM	B	SIG 1
36	GYM	B	SIG 1
37	SOUTH CORRIDOR	B	SIG 1
38	SHOWER ROOM	B	SIG 1
39	2ND FLOOR CORRIDOR BY 202	B	SIG 1
40	2ND FLOOR CORRIDOR	B	SIG 1
41	NORTH CORRIDOR	B	SIG 1
42	CENTER HALL	B	SIG 1
43	CENTER HALL BY OFFICE	B	SIG 1
44	NORTH CORRIDOR	B	SIG 1
45	WOODSHOP	V	SIG 1

Fire Door Number or Location
1ST FLR BY ROOM 107
RIGHT REAR STAIR, BOTTOM
RIGHT FRONT STAIR, BOTTOM
RIGHT REAR STAIR, TOP
RIGHT FRONT STAIR , TOP

EMERGENCY LIGHTING INSPECTION REPORT			
Line #	EL UNIT Location	Remote Head	Cab. Head
	PANEL "E", CCT #14		
1	1ST FL BY MAIN ENTRANCE		
2	1ST FL BY MUSIC ROOM		
3	1ST FL BY CONFERENCE RM		
4	BY STAFF ROOM		EMER-LITE
5	BOY'S LOCKER ROOM		
6	GIRL'S LOCKER ROOM		
	KITCHEN STORAGE CCT#26		

7	STAGE STAIRS		AIM-LITE
8	GYM HALL EXIT		AIM-LITE
9	GYM EXIT TO CAFETERIA		EXIT
10	GYM BY GIRLS WASHROOM		
11	GYM REAR EXIT		
ELEC RM PANEL "A", CCT #25			
12	1ST FL CAFETERIA ENTRANCE		
13	CAFETERIA		
14	MECHANICAL ROOM		
15	1ST FL BY WOODSHOP		
16	WOODSHOP		
17	ELECTRICAL ROOM		
PANEL "F", CCT #20			
18	1ST FLR BY LEARNING CTR		
19	1ST FL RIGHT FRONT EXIT		
20	1ST FL BY ROOM 102		
21	1ST FL BY ROOM 105		
22	1ST FL RIGHT REAR EXIT		
23	BOYS WASHROOM		AIM-LITE
24	GIRLS WASHROOM		DUAL LITE
PANEL "G", CCT#10			
25	2ND FLR REAR RIGHT STAIRS		
26	2ND FLOOR BY ROOM 204		
27	2ND FLOOR BY ROOM 206		
28	2ND FLOOR BY ROOM 202		
29	2ND FLR FRONT RIGHT STAIRS		LUMACELL
30	2ND FL. BY RM. 204		
31	2ND FL. BY RM. 206		
32	2ND FL. BY RM. 202		
33	2ND FL. BY FRONT RT. STAIRS		
34			
EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS			
1	PANEL "E", CCT 14		
2	KITCHEN STORAGE ROOM (CORRIDOR BETWEEN CAFETERIA & GYM),CCT #26		
3	ELECTRICAL ROOM , PANEL "A", CCT#25		
4	PANEL "F" BY CONFERENCE ROOM ,CCT#20		
5	PANEL "G" 2ND FLOOR CORRIDOR, CCT#10		

	LOCATION: Holland Rd.	Device	Device address or circuit number

FIRE ALARM PANEL:EDWARDS QS

MANUAL PULL STATIONS			
1	WEST WING EXIT BY RM 131	M	D 131
2	WEST WING BY RM 164	M	D 131
3	EAST WING EXIT BY RM 128	M	D 133
4	EAST WING BY RM 171	M	D 133
5	MAIN ENTRANCE	M	D 128
6	FRONT LOBBY	M	D 128
7	LOWER HALL	M	D 129
8	GYM RIGHT OFF STAGE	M	D 129
9	GYM BY GIRLS WASHROOM	M	D 129
SMOKE DETECTORS			
1	STAIRWELL	SI	D 126
DUCT SMOKE DETECTORS			
1	LIBRARY HATCH (AHU)	DS	D134
SPRINKLER DEVICES			
1	SPRINKLER RM (MAIN GATE VALVE)	SV	D130
2	SPRINKLER RM (TANK # 1 GATE VALV	SV	D130
3	SPRINKLER RM (TANK # 2 GATE VALV	SV	D130
4	SPRINKLER RM FLOW	FSP	D132
5	SPRINKLER RM (LOW WATER #2)	PS	
6	SPRINKLER RM (LOW AIR)	PS	
7	SPRINKLER RM (LOW WATER #1)	PS	
8	ELEVATOR GATE VALVE	SV	D140
9	MUSIC RM STORAGE (GLYCOL VALVE	SV	D136
NOTIFYING DEVICES			
1	SOUTH HALL	B	SIG 1
2	SOUTH HALL	B	SIG 1
3	SOUTH HALL	B	SIG 1
4	NORTH HALL	B	SIG 1
5	NORTH HALL	B	SIG 1
6	NORTH HALL	B	SIG 1
7	FRONT LOBBY	B	SIG 1
8	LOWER HALL	B	SIG 1
9	GYM	B	SIG 1

RELAY

	DOOR HOLDER	CR	D142
	AHU SHUTT DOWN		

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Remarks
1	GYM		Y	
	GYMNASIUM REMOTE	Y		
2	ELECTRICAL RM		Y	
	BASE HALL	Y		
3	BOYS CHANGE RM (GYM)	Y		
	GIRLS CHANGE RM (GYM)	Y		
4	OUTDOOR MECH RM INNER		Y	exit combo
5	OUTDOOR MECH RM OUTER		Y	
6	BY OFFICE		Y	
	TOP OF STAIRS		Y	
7	MECH. RM		Y	
8	SPRINKLER RM		Y	
	GIRLS WASHROOM	Y		
	BOYS WASHROOM	Y		
9	BY RM 119		Y	
#	BY RM 126		Y	
#	BY RM 127	Y		
#	BY RM 123	Y		
#	BY RM 171		Y	
#	BY RM 132		Y	
#	BY RM 130	Y		
#	BY RM 133	Y		
#	BY RM 164		Y	
#	BOTTOM RAMP TO STAGE		Y	

GYM EXIT LIGHTS (3 UNITS)		
GYM ABOVE ENTRY DOOR		UNIT
BASEMENT NEAR ELEVATOR		EXIT
BASEMENT NEAR		EXIT

BASEMENT NEAR ELEVATOR		EXIT
TOP OF STAIRS		EXIT
MAIN ENTRANCE		EXIT
NEAR 131		EXIT
BY 128		EXIT
BY 173		EXIT

	LOCATION: Oldfield	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 1527		

MANUAL PULL STATIONS

1	GYM WEST EXIT	M	ZONE 1
2	GYM EAST EXIT	M	ZONE 1
3	NORTH HALL	M	ZONE 1
4	REAR EXIT	M	ZONE 1
5	MAIN ENTRANCE	M	ZONE 1
5	FURNACE RM	M	ZONE 1

HEAT DETECTORS

1	FURNACE RM	HT	ZONE 1
2	STAFF RM/ KITCHEN	HT	ZONE 1
3	WORK ROOM	HT	ZONE 1
4	NORTH HALL	EOL	ZONE 1

NOTIFYING DEVICES

1	NORTH HALL	B	SIG 1
2	SOUTH HALL	B	SIG 1
3	CENTER HALL / GYM	B	SIG 1
4	FURNACE RM	B	SIG 1
	NORTH HALL	EOL	SIG 1

EMERGENCY LIGHTING INSPECTION REPORT

Line #	EL UNIT Location	Remote Head	Cab. Head
1	SOUTH HALL BY CLASSROOM 4		Y

2	NORTH HALL BY CLASSROOM 20		Y
3	CENTER HALL / GYM		Y

	LOCATION: Waverley Memorial	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards EST3		

MANUAL PULL STATIONS

1	LEV 2 BY ELEVATOR	MA	103126
2	LEV 2 BY STAIR 2	MA	103127
3	CAFETERIA EXIT	MA	103128
4	LEVEL 2 BY STAIR 1	MA	103131
5	EXIT BY RM 115	MA	103132
6	BY RM 114	MA	103133
7	MAIN ENTRANCE	MA	103134
8	GYM EXIT ,EAST	MA	103135
9	GYM EXIT, SOUTH	MA	103136
10	LEVEL 1 SOUTH EXIT STAIR 2	MA	103137
11	BOILER ROOM 224	MA	103138
12	LEV 2 MECH RM 223	MA	103139
13	LEV 1 ADMIN ROOM 101	MA	103140
14	BY ROOM 107	MA	103157
15	STAIRWELL 1 EXIT	MA	103158

SMOKE DETECTORS

1	LEV 2 CORR BY STAIR 2	SA	103001
2	LEV 2 ROOM 201.1 STORAGE	SA	103002
3	LEV 2 COMM RM 219	SA	103003
4	LEV 2 TOP OF STAIR 2	SA	103004
5	LEV 2 CORR BY COMM RM 219	SA	103005
6	LEV 2 BY ELEVATOR, LEFT SIDE	SA	103006
7	LEV 2 BY ELEVATOR, RIGHT SIDE	SA	103007
8	LEV 2 STORAGE ROOM 221	SA	103008
9	LEV 2 IN FRONT OF STAIR 1	SA	103009
10	LEV 2 TOP OF STAIR 1	SA	103010
11	LEV 2 CORR BY ROOM 208	SA	103011
12	ELEVATOR SHAFT	SA	103012
13	LEV 1 CORR BY WOMAN'S WASH RM	SA	103013
14	LEV 1 CORR BY SPRINKLER RM 107	SA	103014
15	LEV 1 BOTTOM OF STAIR 2	SA	103015
16	LEV 1 STORAGE ROOM 115	SA	103016
16	LEV 1 CORR BY ROOM 114	SA	103017

17	LEV 1 ELECTRICAL RM 122	SA	103018
18	LEV 1 OUTSIDE GYM STORAGE RM 12	SA	103019
19	LEV 1 GYM STORAGE ROOM 104.4	SA	103020
20	LEV 1 CORR BY ROOM 109	SA	103021
21	LEV CORR BY ROOM 115	SA	103022
22	LEV 1 BOTTOM OF STAIR 1	SA	103023
23	LEV 1 CORR BY MEN'S W/R 117	SA	103024
24	LEV 1 SERVER RM 118	SA	103029
25	LEV 1 STORE RM OFF STAGE 103.2	SA	103030
26	LEV 1 GYM STORAGE 104.1	SA	103031
27	LEV 1 KITCHEN ROOM 102.2	SA	103032
28	LEV 1 ELEVATOR MACHINE RM 123	SA	103033
HEAT DETECTORS			
1	BOILER ROOM 224	HTA	103025
2	MECH ROOM 223(VENTILATION)	HTA	103026
3	LEV 1 RECYCLE ROOM 102.3	HTA	103027
4	LEV 1 SPRINKLER RM 107	HTA	103028
5	LEV 2 STORAGE RM 212.1	HTA	103036
DUCT SMOKE DETECTORS			
1	LEV MECH RM 222 AHU#3	DSA	103034
2	LEV 2 MECH RM 222 AHU #1	DSA	103035
SPRINKLER DEVICES			
1	ELEVATOR PIT VALVE	SV	103141
2	KITCHEN HOOD SYSTEM	AD	103156
3	VALVE FOR LEV 2	SV	103150
4	LEV 2 SPRINKLER WATER FLOW	FSV	103151
5	LEV 1 VALVE	SV	1031148
6	LEV SPRINKLER WATER FLOW	FSV	103149
7	BACK FLOW PREVENTER #2	SV	103147
8	BACK FLOW PREVENTER #1	SV	1031146
RELAY'S ETC			
	STOVE SHUNT	RLY	103153
	CONNECTING	RLY	103152
	DOOR LEVEL RELAY LEVEL 2 STAIR 2	RLY	103129
	DOOR LEVEL RELAY STAIR 1	RLY	103130
	WEST DOOR HOLDER LEVEL 1	RLY	103145
NOTIFYING DEVICES			
1	LEV 1 BY CLASS 114	A/V	SIG
2	LEV 1 BY W/R 114.1	A/V	SIG
3	LEV 1 BY CAFETERIA	A/V	SIG
4	LEV 1 BY KITCHEN	A/V	SIG
5	LEV 1 GYM	A/V	SIG
6	LEV 1 GYM	A/V	SIG

7	LEV 1 GYM	A/V	SIG
8	LEV 1 ADMIN OFFICE	A/V	SIG
9	LEV 1 BY MECH ROOM 107	A/V	SIG
10	LEV 1 BY STAIR 2	A/V	SIG
11	LEV 1 STAFF W/R	A/V	SIG
12	LEV 1 GIRLS WASHROOM	A/V	SIG
13	LEV 1 BOYS WASHROOM	A/V	SIG
14	LEV 1 CORR BY ELEC. ROOM 122	A/V	SIG
15	LEV 2 TOP STAIR 2	A/V	SIG
16	LEV 2 BY STORAGE ROOM 221	A/V	SIG
17	LEV 2 BY 220 MECHANICAL RM	A/V	SIG
18	LEV 2 MECHANICAL RM 220	A/V	SIG
19	LEV 2 IN ROOM 201	A/V	SIG
20	LEV 2 BOYS WASHROOM	A/V	SIG
21	LEV 2 IN ROOM 208.1A	A/V	SIG
22	LEV 2 STAFF W/R	A/V	SIG
	LEV 2 BY 209		
	LEV 2 BY 205		
	LEV 2 GIRLS WASHROOM		
	LEV 2 BOILER RM		
	LEV 2 MECH RM		

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
1	BY MAIN OFFICE		Y
2	LEV 1 STAIR 2,EXIT		Y
3	LEV 1 BOTTOM STAIR 1	Y	
4	LEV 2 STAIR 2 ,TOP		Y
5	LEV 2 STAIR 2, CENTER	Y	
6	LEV 2 BY ROOM 205	Y	
7	LEV 2 BY ROOM 209		Y
8	LEV 2 BY ROOM 206	Y	
9	LEV 2 BY STAIR 1	Y	
#	LEV 2 STAIR 1,TOP		Y
#	LEV 2 STAIR 1, CENTER	Y	
#	LEV 2 CENTER STAIRS, TOP		Y
#	LEV 2 MALE W/R		Y
#	LEV 2 WASHROOM 213		Y
#	LEV 2 BY COMM RM 219		Y
#	LEV 2 BY ROOM 202	Y	
#	LEV 1 BY LIBRARY RM 105A		Y
#	LEV 1 STAIR 1 ,BOTTOM BY 116		Y

#	LEV 1 STAIR 1 EXIT		Y
#	LEV 1 STAIR 1, REMOTE	Y	
#	LEV CUSTODIAN RM 118.1		Y
#	LEV 1 BOYS W/R ,ENTRY	Y	
#	LEV 1 BOYS W/R	Y	
#	LEV 1 BY ROOM 123		Y
#	LEV 1 BY ELEC RM 122		Y
#	LEV 1 IN ROOM 121	Y	
#	CAFETERIA ENTRY		Y
#	CAFETERIA ENTRY	Y	
#	CAFETERIA EXIT		Y
#	MUSIC ROOM	Y	
#	GYM FRONT		Y
#	GYM BY STORAGE ROOM	Y	
#	GYM BY STORAGE ROOM	Y	
#	GYM REAR		Y
#	GYM REAR EXIT	Y	
#	GYM LEFT SIDE	Y	
#	COMM ROOM 101		
#	WORK ROOM BY ADMIN		

BY ROOM 107		UNIT
IN ELECTRICAL ROOM 122		
MECH. ROOM O/S UP BANK 220		UNIT
BOILER ROOM O/S UP BANK		UNIT
WASHROOM BY ELECT. RM 122		REMOTE
WASHROOM 2 BY ELECT. RM 122		REMOTE
LEVEL 2 WASHROOM 214		REMOTE
IN ROOM 201		UNIT
LEV 2 COMM RM 219		
LEVEL 11, IN RM 114		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1	ELECTRICAL PANEL 3101, ROOM 122 ,CONTROLS MOST EMERGENCY LIGHTS EXCEPT FOR CAFETERIA & GYM
---	--

Fire Door Number or Location
STAIR 1 , BOTTOM
STAIR 1, TOP
STAIR 2, BOTTOM
STAIR 2, TOP

	LOCATION: Clayton Park Jr,	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
6	BOILER ROOM	M	ZONE 1
7	BOILER ROOM	HT	ZONE 1
8	BOILER ROOM	HT	ZONE 1
9	BOILER ROOM	EOL	ZONE 1
11	TEACHERS ROOM 134	HT	ZONE 2
12	ART ROOM 018	M	ZONE 2
13	ART ROOM 018	EOL	ZONE 2
15	BY BAND ROOM	HT	ZONE 3
16	BY ROOM 003	HT	ZONE 3
17	BY ROOM 012	M	ZONE 3
18	IN ROOM 014	HT	ZONE 3
19	BY ROOM 144	HT	ZONE 3
20	STORAGE ROOM BY ROOM 014	HT	ZONE 3
21	BY ROOM 003 BY MUSIC ROOM	M	ZONE 3
22	BY BAND ROOM STORAGE	M	ZONE 3
23	BY ROOM 144 EXIT	M	ZONE 3
24	IN ROOM 023	M	ZONE 3
25	BY ROOM 003 EXIT	M	ZONE 3
26	BAND ROOM STORAGE	HT	ZONE 3
27	CUSTODIANS ROOM	HT	ZONE 3
28	STORAGE IN ROOM 025	HT	ZONE 3
29	GYM STORAGE	HT	ZONE 4
30	STAGE	HT	ZONE 4
31	GYM OUTSIDE EXIT	M	ZONE 4
32	GYM MAIN ENTRANCE EXIT	M	ZONE 4
33	STAGE	EOL	ZONE 4
35	BOYS CHANGE ROOM	HT	ZONE 5
36	GYM EXIT BY STAGE	M	ZONE 5
37	GIRLS CHANGE ROOM	HT	ZONE 5
38	BY ROOM 121 OFFICE	HT	ZONE 5
39	BY ROOM 108	HT	ZONE 5
40	BY ROOM 147	HT	ZONE 5
41	BY ROOM 114	HT	ZONE 5
42	BY ROOM 115	HT	ZONE 5
43	BY ROOM 118	HT	ZONE 5

44	BY ROOM 118	HT	ZONE 5
45	BY ROOM 115	HT	ZONE 5
46	IN ROOM 118	HT	ZONE 5
47	MAIN ENTRANCE	M	ZONE 5
48	MAIN LOBBY	HT	ZONE 5
49	BY ROOM 118	HT	ZONE 5
51	BY ROOM 117 OR MAIN OFFICE	HT	ZONE 6
52	BY ROOM 111	HT	ZONE 6
53	BY ROOM 112	HT	ZONE 6
54	BY ROOM 104	HT	ZONE 6
55	BY ROOM 109	HT	ZONE 6
56	BY ROOM 146	HT	ZONE 6
57	HOME EC	HT	ZONE 6
58	HOME EC	HT	ZONE 6
59	BY ROOM 105	M	ZONE 6
60	BY ROOM 146	M	ZONE 6
61	HOME EC BACK HALL	M	ZONE 6
62	HOME EC	M	ZONE 6
63	BY ROOM 105	HT	ZONE 6
65	LIBRARY	M	ZONE 7
66	LIBRARY	HT	ZONE 7
67	LIBRARY	HT	ZONE 7
68	LIBRARY	HT	ZONE 7
69	BY ROOM 205	HT	ZONE 7
70	BY ROOM 214	HT	ZONE 7
71	BY ROOM 211	HT	ZONE 7
72	3RD FLOOR JANITORS ROOM	HT	ZONE 7
73	BY ROOM 209	HT	ZONE 7
74	BY ROOM 200	HT	ZONE 7
75	3RD FLOOR LIBRARY STAIRWELL	EOL	ZONE 7
76	BY ROOM 205	M	ZONE 7
77	BY ROOM 208	HT	ZONE 7
78	BY ROOM 220	M	ZONE 7
79	BY ROOM 220	EOL	ZONE 7
81	MAIN ENTRANCE STAIRWELL	S	ZONE 8
82	MAIN ENTRANCE STAIRWELL	EOL	ZONE 8
83	INSIDE LIBRARY	S	ZONE 9
84	LIBRARY STAIRWELL	S	ZONE 9
85	LIBRARY STAIRWELL	EOL	ZONE 9
87	CENTRE STAIRWELL OUTSIDE ROOM 204	S	ZONE 10
88	CENTRE STAIRWELL	EOL	ZONE 10

90	BY ROOM 220 STAIRWELL	S	ZONE 11
91	BY ROOM 220 STAIRWELL	EOL	ZONE 11
93	Signals		
94	BASEMENT HALL	B	SIG 1
95	ART ROOM 018	B	SIG 1
96	MUSIC ROOM	B	SIG 1
97	BY ROOM 025	B	SIG 1
98	BOILER ROOM	B	SIG 1
99	BY MUSIC ROOM	EOL	SIG 1
101	BY ROOM 121 OFFICE	B	SIG 2
102	BY ROOM 104	B	SIG 2
103	BY ROOM 108	B	SIG 2
104	IN ROOM 145 HOME EC	B	SIG 2
105	BY ROOM 112	B	SIG 2
106	BY ROOM 114	B	SIG 2
107	GYM	B	SIG 2
108	IN ROOM 143 HOME EC	B	SIG 2
109	LIBRARY	B	SIG 2
110	IN ROOM 023	B	SIG 2
111	IN ROOM 025	B	SIG 2
112	BY ROOM 220	B	SIG 2
113	BY ROOM 210	B	SIG 2
114	BY ROOM 220	EOL	SIG 2
EMERGENCY LIGHTING			

Unit #	Location	# of Heads	Model
	MAIN LOBBY	2	EXIT COMBO
2	STAIRS MAIN LOBBY		
3	OUTSIDE BOYS WASHROOM		
4	HALL BY OFFICE		
5	HALL BY ROOM 114		
6	GYM BACK HALL		
7	GYM BACK HALL EXIT		
8	GYM		

9	GYM		
	2ND FLOOR BY ROOM 146		
12	2ND FLOOR BY ROOM 112		
13	BY ROOM 112 STAIRS		
14	STAIRWELL BY ROOM 112		
15	HOME EC ROOM		
16	IN ROOM 146		
17	HOME EC STAIRWELL MID FLOOR		
18	HOME EC STAIRWELL BOTTOM		
19	ROOM 003		
	BY ROOM 003		
20	MUSIC ROOM		
21	EXIT BY MUSIC & WOOD ROOM		
22	LIBRARY		
23	LIBRARY STAIRS		
24	ADJ 205		
25	BY ROOM 220		
26	BY ROOM 204		
27	WOODSHOP EXIT BY ROOM 023		
	COMPUTER ROOM 025		
1	BOILER ROOM		

2	ART ROOM 018		
33	WOODSHOP HALL		
4	IN ROOM 023		
5	IN ROOM 025		
6	IN ROOM 003		EXIT 2H COMBO
7	OUTSIDE ROOM 003		
8	BY ROOM 105 STAIRWELL		
9	NEAR ROOM 200		
30	BOTTOM LIBRARY STAIR		COMBO
	REMOTE IN WOODSHOP 023		
	REMOTE IN 025		
33	BY ROOM 023		

	LOCATION: Duc D'Anville	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex 400		
DEVICES			

Location Description	Device	Model
----------------------	--------	-------

MANUAL PULL STATIONS

LOCKER ROOM HALLWAY	PULL	
GYM FOYER	PULL	
BY ROOM 215	PULL	
ENTRANCE BY FIRE PANEL	PULL	
BOILER ROOM	PULL	
BY OFFICE	PULL	
BY 266	PULL	

HEAT DETECTORS

BOILER ROOM	HEAT	
-------------	------	--

SPRINKLER DEVICES

SPRINKLER PRESSURE ALARM	FSP	
MAIN CONTROL VALVE	TS	

BELLS

BY ROOM 125	BELL	6"
BY ROOM 215	BELL	6"
BY ROOM 240	BELL	6"
BY OFFICE	BELL	6"
GYM LOBBY	BELL	8"

GYM	BELL	5"
-----	------	----

DOOR RELEASE	RLY	
STAIR BY 265	SMK	
BACK STAIR	SMK	

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	ENTRANCE BY FIRE PANEL		LUMACELL RG36-LMC
	OUTSIDE BOILER RM/SPRINKLER		EMERGI-LITE 6JML36 S7
	BY BOYS WASHRM		REMOTE
	BOILER RM		EMERGI-LITE 6JML36
	BY RM 160		LUMACELL RG36-LMC
	BY RM 310		LUMACELL RG36-LMC
	IN RM 310		LUMACELL RG36-LMC
	RM 305		LUMACELL RG36-LMC
	GYM HALL		LUMACELL RG36-LMC
	GYM FOYER		EMERGI-LITE 6JML36
	GYM		LUMACELL EX10W-PXM36
	GYM CTR		LUMACELL 3LMCEU2M TBW
	GYM		LUMACELL RG36-LMC

	2ND FL BY RM 265		LUMACELL COMBO
	2ND FL BY BOYS WASHRM		6JML36 S7
	BY RM 218		REMOTE
	2ND FL BY RM 215		COMBO RG38-LMC
	TOP SOUTH STAIR		UNIT
	HALL ADJ CHANGE RMS		COMBO
	CLASS RM 160		COMBO
	STAGE LEFT		STANPRO
	STAGE CENTRE		AIMLITE
	STAGE RIGHT		STANRPO
	ENTRANCE BY OFFICE		COMBO

Fire Door Number or Location
BY ROOM 125
GYM FOYER
GYM FOYER
TOP OF MAIN STAIRWELL
BY ROOM 215

	LOCATION: Fairview Heights	Device	Device address or circuit number
--	-----------------------------------	---------------	---

	FIRE ALARM PANEL: Edwards 6500
--	---------------------------------------

1	Devices		
2	MAIN ENTRANCE	M	ZONE 1
3	HALL BY ROOM P2	M	ZONE 1
4	HALL BY ROOM P2	EOL	ZONE 1
5	GYM WEST EXIT	M	ZONE 2
6	GYM EAST EXIT	M	ZONE 2
7	GYM EAST EXIT	EOL	ZONE 2
8	1ST FLOOR BY GIRLS WASHROOM	M	ZONE 3
9	1ST FLOOR BY ROOM 2	M	ZONE 3
10	1ST FLOOR BY ROOM 2	EOL	ZONE 3
11	TOP OF CENTER STAIRWELL	S	ZONE 4
12	TOP OF EAST STAIRWELL	S	ZONE 4
13	2ND FLOOR BY ROOM 11	M	ZONE 4
14	2ND FLOOR BY ROOM 8	M	ZONE 4
15	2ND FLOOR BY ROOM 8	EOL	ZONE 4
16	BOILER ROOM	HT	ZONE 5
17	BOILER ROOM	M	ZONE 5
18	BOILER ROOM	EOL	ZONE 5
19	CLASSROOM P1	S	1

	Signals		
19	MAIN ENTRANCE	B	SIG 1
20	WEST END HALL	B	SIG 1
21	GYM	B	SIG 2
22	1ST FLOOR EAST	B	SIG 2
23	1ST FLOOR WEST	B	SIG 2
24	2ND FLOOR EAST	B	SIG 2
25	2ND FLOOR WEST	B	SIG 2
26	BOILER ROOM	B	SIG 2
27	BOILER ROOM	EOL	SIG 2

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
--------	------------------	-------------	-----------

1	West Entrance		
2	Main Entrance		
3	Main Gym Entrance		
4	Gym East Exit		
5	Gym Outside Exit		
6	East Hall		
7	South Stairwell		
8	East Hall Near Stairs		
9	East Stairwell		
10	Bsmt East Hall Exit		
11	Bsmt East Hall Stairs		
12	BY ROOM 11 EXIT		
13	BY ROOM 5 EXIT		
14	Gym Left of Stage		COMBO
15	Gym Right of Stage		COMBO
16	Basement by Fire Doors		EXIT
17	Hallway by Fire Doors		EXIT

	LOCATION: Fairview Jr.	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
1	Devices		
2	2ND FLOOR BY ROOM 226	M	ZONE 1
3	2ND FLOOR BY ROOM 205	M	ZONE 1
4	2ND FLOOR BY ROOM 221	M	ZONE 1
6	2ND FLOOR BY ROOM 247	M	ZONE 2
7	2ND FLR CTR EAST BY ROOM 227 FAM. ST	M	ZONE 2
8	2ND FLOOR BY ART ROOM 236	M	ZONE 2
9	2ND FLOOR BY ROOM 248	EOL	ZONE 2
11	MAIN ENTRANCE	M	ZONE 3
12	BY OFFICE STEPS	M	ZONE 3
13	NURSES ROOM 149	DS	ZONE 3
14	UNDER STAIRS BY MAIN OFFICE	HT	ZONE 3
15	MAIN OFFICE HALL BY WATER FOUNTAIN	DS	ZONE 3
16	UNDER STAIRS BY MAIN ENTRANCE	HT	ZONE 3
18	BOILER ROOM EXIT	M	ZONE 4
19	BASEMENT AIR HANDLING UNIT (BOILER R	DS	ZONE 4
20	SWITCH ROOM 017	HT	ZONE 4
22	1ST FLOOR BY ROOM 110	M	ZONE 5
23	1ST FLOOR BY ROOM 107	M	ZONE 5
24	1ST FLOOR BY ROOM 103	M	ZONE 5
25	UNDER STAIRS BY ROOM 110	HT	ZONE 5
26	UNDER STAIRS BY ROOM 103	HT	ZONE 5
27	1ST FLOOR BY ROOM 103	EOL	ZONE 5
29	GYM EAST EXIT TO HALLWAY	M	ZONE 6
30	GYM WEST EXIT TO REAR EXIT	M	ZONE 6
31	GYM NORTH EXIT TO MAIN ENTRANCE	M	ZONE 6
32	GYM SOUTH EXIT TO BACK STAIRWELL	M	ZONE 6
33	GYM SOUTH EXIT	EOL	ZONE 6
35	SPRINKLER MAIN GATE VALVE	TS	ZONE 7
36	SPRINKLER WATER FLOW ALARM	FSP	ZONE 7

37	ALARM LINE TAMPER SWITCH	TS	ZONE 7
38	SPRINKLER ROOM	EOL	ZONE 7
40	INDUSTRIAL ARTS HALLWAY EXIT 1	M	ZONE 8
41	INDUSTRIAL ARTS HALLWAY EXIT 2	M	ZONE 8
42	SPRINKLER ROOM	HT	ZONE 8
43	INDUSTRIAL ARTS HALLWAY	EOL	ZONE 8
45	ELEVATOR GATE VALVE	GV	ZONE 9
46	2ND FLOOR ROOM 226	EOL	ZONE 9
48	Signals		
49	MAIN ENTRANCE	B	SIG 1
50	BY RM 208	B	SIG 1
51	BY RM 234	B	SIG 1
52	BY RM 204	B	SIG 1
53	BY RM 222	B	SIG 1
54	BY RM 110	B	SIG 1
55	BY OFFICE STEPS	B	SIG 1
56	BY RM 107	B	SIG 1
57	BY RM 103	B	SIG 1
58	GYM	B	SIG 1
59	GYM	B	SIG 1
60	BOILER RM	B	SIG 1
61	MUSIC RM BY 248	B	SIG 1
62	BY RM 018	B	SIG 1
63	WOOD SHOP	B	SIG 1
64	METAL SHOP	B	SIG 1
65	BY RM 103	EOL	SIG 1
66	DOOR RELEASE	R	
67	TROUBLE LIGHT	Visual	
78	BOILER ROOM		

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
1	Main Hall By Office	Y	
2	Main Hallway By Lunch Room		
3	Main Entrance Above Door		
4	Main Hall By Room 104		
5	Main Hall By Room 105		
6	By Room 108		
7	Main Electrical Room		
8	**Outside Electrical Room		
9	Across From Room 112		
10	Stairwell By Room 221		

11	2nd Floor East Entrance		
12	2nd Floor West Entrance		
13	East Stairwell		
14	West Stairwell		
15	Stairwell By Room 201		
16	2nd Floor By Room 224		
17	2nd Floor By Room 222		
18	2nd Floor Electrical Room		
19	**Outside Electrical Room		
20	**By Room 223		
21	Electrical Switch Room 017		
22	Boiler Room 014		
23	**Outside Boiler Room		
24	Boiler Room Back Entrance		
25	Basement Woodshop		
26	Woodshop Entrance		
27	Basement Janitors Storage		
28	**Outside Storage Room		
1	**Hall By Boys Washroom		
2	Boys Change Room		
3	Girls Change Room		
4	Computer Room		
5	Gym Stairwell		
6	Gym Main Hall Entrance		
7	Gym Exit To Washrooms		
8	Gym By Scoreboard		
9	Gym 2nd Hall Entrance		
10	2nd Floor Hall (NEW)		
11	2nd Floor Hall (NEW)		
12	158 Guidance		
13	Handicap Washroom		
14	Office Main		
15	Boys Washroom		
16	Girls Washroom		

ADJ 102		
BOILER ROOM		UNIT
GYM STAGE		EXIT COMBO
GYM STAGE		EXIT COMBO
STAIRWELL		REMOTE
STAIRWELL		REMOTE

STAIRWELL		REMOTE
COMPUTER LAB		UNIT
JANITOR ROOM		UNIT
BASEMENT BY WOODSHOP		

		Device	Device address or circuit number
	LOCATION: Halifax West		
	FIRE ALARM PANEL: Edwards EST 3		

MANUAL PULL STATIONS			
LEVEL 1			
	PUMP RM C132	MA	102126
	LEV 1 CORR BY STAIRWELL A	MA	102127
	LEV 1 BY SERVER RM C151	MA	102128
	LEV 1 CORR BY STAIRWELL 3 ADJ C103	MA	102129
LEVEL 2			
	GYM EXIT NORTH WEST	MA	102379
	GYM South West EXIT	MA	102378
	CORR BY C227	MA	376
	CORR BY RM C245	MA	102377
	RECEPTION A274 exit	MA	380
	BY RM 242A A WING	MA	381
	CAFETERIA EXIT	MA	382
	CORR BY B206	MA	383
	KITCHEN	MA	102384
	PRODUCTION TECH B214	MA	385
	CAFETERIA	MA	386
	BY RM A234	MA	102387
	CORR BY RM C220	MA	102388
	STORAGE RM C260 (OUTDOOR)	MA	102389
	LEV 2 BY STAIRWELL # 5	MA	406
	EAST END CORR A201 BY RM A286	MA	102411
	MAIN ENTRANCE A200	MA	412
LEVEL 3			
	LEVEL 3 CORR BY B318	MA	103127
	CORR BY RM A344	MA	103130
	CORR BY RM C327	MA	103131
	CORR BY C345	MA	103132
	MECH RM A341 inside A-342	MA	103133
	LEV 3 RIGHT THEATRE BALCONY	MA	103048
	CORR BY A310	MA	103142
	LEV ADJ WASHROOM A313	MA	103149
	LEV 3 ADJ OPEN STAIR	MA	103152
	PENTHOUSE 2	MA	103377
	PENTHOUSE 1	MA	103378
SMOKE DETECTORS			

LEVEL 1			
	PUMP STORAGE RM 134	SA	102001
	ELECTRICAL RM C174	SA	102002
	COMM RM C173	SA	102003
	SERVER RM C151	SA	102004
	ELEVATOR MACHINE RM	SA	102005
	LEV 1 ELEVATOR LOBBY C WING	SA	102006
LEVEL 2			
	CORR BY RM A-291	SA	264
	CORR BY RM A-233	SA	102269
	CORR BY RM A-220	SA	102266
	A224 STORAGE RM	SA	102253
	A231 STORAGE RM	SA	102252
	A232 COMM CLOSET	SA	102270
	Inside Balcony Right side and Left side, 3rd floor	SA	
	CORR BY RM A-234	SA	102268
	A241 STORAGE RM	SA	102258
	A242 OFFICE STORAGE	SA	102257
	A250 STORAGE RM	SA	102276
	A259 GYM STORAGE	SA	102260
	A259 GYM STORAGE(STEEL CAGE)	SA	259
	A277 STORAGE RM	SA	251
	CORR BY RM A-286	SA	102265
	A291 STORAGE RM	SA	102256
	B205, STORAGE RM / Kitchen Storage	SA	102267
	B221 STORAGE RM / Music room	SA	102262
	WING C BY ELEVATOR	SA	102254
	C219 CORRIDOR BY	SA	102263
	C219 COMM RM	SA	102274
	C220 CORR BY STORAGE RM	SA	102255
	C220 STORAGE RM	SA	102261
LEVEL 3			
	STAIRWELL 1	SA	103027
	STAIRWELL 2	SA	103007
	WING A STAIRS 5	SA	103019
	STAIRWELL 3	SA	103023
	STAIRWELL 4	SA	103021
	LEV 3 ADJ OPEN STAIR	SA	103034
	CORR BY A-310	SA	103025
	CORR BY A-312	SA	26
	CORR BY A-311	SA	103032
	A311, ELEVATOR LOBBY BY RM	SA	103024
	CORR BY A-312	SA	103025

	CORR BY A-313 Washroom	SA	103031
	A322, COMM RM	SA	103011
	Comm Rm C-319	SA	28
	,CORR BY A-327	SA	103012
	A331, STORAGE RM(INSIDE A333)	SA	15
	CORR BY RM A-344	SA	103017
	A353 ,BY RM	SA	103035
	A345, STORAGE(INSIDE A344)	SA	103014
	LEV 3 ADJ RIGHT ENTRY THEATRE BALCONY	SA	103030
	LEV 3 RIGHT ENTRY THEATRE BALCONY	SA	103033
	B328, STORAGE (INSIDE B327)	SA	103013
	B303, STORAGE RM	SA	103018
	Inside C-319	SA	103028
	, CORR BY B-320	SA	103006
	CORR BY B-318	SA	103005
	CATWALK stage / Also 2 on the Center Catwalk	SA	
	C351, STORAGE RM	SA	10320
	ELEVATOR SHAFT	SA	16
	STUDENT GOVERNMENT	SA	103020
	Level 3 A WING A301 BY 312	SA	10325
	BALCONY #1	S	103039
	BALCONY #2	S	103042

HEAT DETECTORS

	C132, BOILER RM	HTA	140
	A220, JANITOR'S RM	HTA	102275
	A233, JANITOR'S RM	HTA	102272
	B204, SPRINKLER RM(IN CAFETERIA)	HTA	102271
	C260, STORAGE RM(OUTDOOR)	HTA	102273
	SOUTH STAGE (AUDITORIUM)	HTA	103003
	NORTH STAGE (AUDITORIUM)	HTA	4
	B314, MECH RM	HTA	1
	B314, MECH RM	HTA	2
	A311, JANITOR'S RM	HTA	10
	A324, JANITOR'S RM	HTA	29
	A342,EAST MECH RM	HTA	8
	A342,EAST MECH RM	HTA	9
	PENTHOUSE 1(NORTH)	HTA	103251
	PENTHOUSE 1(SOUTH)	HTA	103253
	PENTHOUSE 2	HTA	103252
	PENTHOUSE 2(NORTH)	HTA	103254
	MECH. RM. LEVEL 3 AWING		103009

SPRINKLER DEVICES

1	SUPV VALVE ELEV WING A & B STAIR 3	SV	126
2	ELEVATOR TAMPER SWITCH 3RD FLOOR	SV	129
3	SPRINKLER VALVE ELEVATOR PIT	FSV	132
4	NORTH GATE VALVE RM C320	FS	134
5	NORTH SPRINKLER ALARM RM C320	FS	135
6	PENT WEST SPRK FLOW ALARM BY C340	FS	137
7	SPRINKLER FLOW ALARM	FSV	138
8	SPRK. FLOW SOUTH SWITCH STAIR 2	FS	143
9	SPRINKLER VALVE NORTH RM C220	FS	395
10	SPRINKLER NORTH C220	FS	396
11	TAMPER SWITCH 2	SV	397
12	TAMPER VALVE 1	SV	398
13	TAMPER SWITCH 3	SV	399
14	SPRK FLOW LEV 1,2,3 & PENTHOUSE	FS	400
15	TAMPER SWITCH 4	SV	401
16	SPRINKLER RM. FLOW PER-ACTION	FS	402
17	TAMPER SWITCH 11 SPRK. RM. LEV 2	SV	403
18	SPRK RM FLOW SW-10	FS	404
19	LOW PRESSURE SWITCH 26 SPRK RM	PS	407
20	LOW PRESSURE SWITCH 27 SPRK RM	PS	408
21	TAMPER SWITCH 5 DELUGE SPRK RM	SV	409
22	SPRINKLER LEV 1 & 2 WING	TS	410
23	SPRK SOLENOID PER-ACTION 2 OF 2	FS	413

DOOR HOLDERS

1	STAIRWELL 4	DH	130
2	STAIRWELL 3	DH	131
3	CORR A203 DOOR RELEASE	DH	390
4	DOOR RELEASE A202 S/E	DH	391
5	DOOR RELEASE A208 WEST	DH	392
6	CORR A204 DOOR HOLDERS	DH	394
7	STAIRS 2 LEV 2 DOOR RELEASE	DH	414
8	STAIRS 2 LEV 3 DOOR RELEASE	DH	415
9	STAIRS 2 LEV 4 DOOR RELEASE	DH	316
10	DOOR RELAY BY TEEN HEALTH	DH	417
11	RELAY DOOR BY TEEN HEALTH	DH	418
12	DOOR HOLDER	DH	419
13	SOUTH DOOR RELEASE	DH	128
14	DOOR RELEASE CORR A303	DH	140
15	DOOR RELEASE CORR A301	DH	141
16	STAIRS 4 LEV 3 DOOR RELEASE	DH	144
17	STAIRS 3 LEV 3 DOOR RELEASE	DH	145
18	RELAY REAR STAIR 3RD FL	DH	146
19	RELAY DOOR RELEASE CORR A305	DH	147

AUXILIARIES			
1	ELEVATOR RECALL	RLY	133
2	KITCHEN SHUNT TRIP	RLY	393
3	SPRK RM SOLENOID PER-ACTION RELAY	RLY	405
4	KITCHEN HOOD	RLY	420
NOTIFYING DEVICES			
1ST FLOOR / BASEMENT			
1	CORR C104	MH	SIG 1
2	MENS WASHROOM C172	MH	SIG 1
3	FEMALES WASHROOM C171	MH	SIG 1
4	WASHROOM C152	MH	SIG 1
5	EXIT AREA	MH	SIG 1
6	FEMALE WASHROOM C162	MH	SIG 1
7	MENS WASHROOM C161	MH	SIG 1
8	CORR BY C127	MH	SIG 1
9	CORR BY C121	MH	SIG 1
10	PUMP RM	MH	SIG 1
11	CORR BY C141	MH	SIG 1
12	PUMP RM	EOL	SIG 1
2ND FLOOR			
13	CORR BY A214	MH	SIG 2
14	FEMALES WASHROOM	MH	SIG 2
15	MENS WASHROOM	MH	SIG 2
16	CHANGE RM A262	MH	SIG 2
17	CHANGE RM A263	MH	SIG 2
18	GYM (OUTSIDE WALL)	MH	SIG 2
19	GYM (OUTSIDE WALL)	MH	SIG 2
20	GYM	MH	SIG 2
21	GYM	MH	SIG 2
22	CHANGE RM A270	MH	SIG 2
23	CHANGE RM A271	MH	SIG 2
24	CLASSROOM BY ALCOVE	MH	SIG 2
25	CORR BY STAIRS 5	MH	SIG 2
26	RECEPTION A274	MH	SIG 2
27	CORR BY A244	MH	SIG 2
28	OUTSIDE LIBRARY	MH	SIG 2
29	LIBRARY	MH	SIG 2
30	LIBRARY	MH	SIG 2
31	LOWER EXTERIOR COURTYARD	MH	SIG 2
32	WASHROOM A290	MH	SIG 2
33	ENTRANCE	MH	SIG 2
34	RECEPTION A274	MH	SIG 2
35	ACROSS FROM ALCOVE 211	MH	SIG 2

36	WASHROOM A221	MH	SIG 2
37	WASHROOM A222	MH	SIG 2
38	AUDITORIUM B210	MH	SIG 2
39	AUDITORIUM B210	MH	SIG 2
40	CORR BY WASHROOM B203	MH	SIG 2
41	MUSIC RM	MH	SIG 2
42	MUSIC PRACTICE B218	MH	SIG 2
43	MUSIC PRACTICE B219	MH	SIG 2
44	MUSIC PRACTICE B220	MH	SIG 2
45	ROOM BEHIND PRACTICE B219	MH	SIG 2
46	PRODUCTION TECH B214	MH	SIG 2
47	PRODUCTION TECH B214	MH	SIG 2
48	CORR BY STAIRS 2	MH	SIG 2
49	KITCHEN	MH	SIG 2
50	CAFETERIA	MH	SIG 2
51	CAFETERIA	MH	SIG 2
52	ENTRANCE BY MAIN STAIRS	MH	SIG 2
53	CORR BY STAIRWELL 4	MH	SIG 2
54	CORR BY C247	MH	SIG 2
55	CORR BY C249	MH	SIG 2
56	CORR BY C249	MH	SIG 2
57	ACROSS FROM C251	MH	SIG 2
58	CORR BY A225	MH	SIG 2
59	CORR BY C227	MH	SIG 2
60	CORR BY C229	MH	SIG 2
61	CORR BY C222A	MH	SIG 2
62	CORR BY C220	MH	SIG 2
3RD FLOOR			
63	WASHROOM A325	MH	SIG 3
64	WASHROOM A326	MH	SIG 3
65	MECH RM A341	MH	SIG 3
66	CORR BY A343	MH	SIG 3
67	STORAGE A344	MH	SIG 3
68	CORR BY A344	MH	SIG 3
69	CORR BY A328	MH	SIG 3
70	CORR BY A330	MH	SIG 3
71	STORAGE A333	MH	SIG 3
72	PREP A330	MH	SIG 3
73	NUTRITION/TEXTILES A353	MH	SIG 3
74	ACROSS FROM MAIN STAIRS	MH	SIG 3
75	WASHROOM A312	MH	SIG 3
76	WASHROOM A313	MH	SIG 3
77	CORR BY A312	MH	SIG 3

78	BIOLOGY A318	MH	SIG 3
79	CORR BY B327	MH	SIG 3
80	STORAGE B327	MH	SIG 3
81	SOUND STUDIO B321	MH	SIG 3
82	CORR BY B320	MH	SIG 3
83	CORR BY STAIRS 2	MH	SIG 3
84	STAFF RM B315	MH	SIG 3
85	MECH RM B312	MH	SIG 3
86	ACROSS FROM B314	MH	SIG 3
87	CORR BY STAIRS 4	MH	SIG 3
88	CORR BY C340	MH	SIG 3
89	CORR BY C347	MH	SIG 3
90	CORR BY C342A	MH	SIG 3
91	ACROSS FROM STORAGE C351	MH	SIG 3
92	CORR BY C329	MH	SIG 3
93	WASHROOM 315	MH	SIG 3
94	CORR BY C322	MH	SIG 3
95	CORR BY C327	MH	SIG 3
96	CORR BY C323	MH	SIG 3
97	CORR BY B319	MH	SIG 3
98	STORAGE B327	EOL	SIG 3

PENTHOUSE

99	PENTHOUSE 1	MH	SIG 4
100	PENTHOUSE 2	MH	SIG 4
101	PENTHOUSE 2	EOL	SIG 4

1ST FLOOR (LOOP 1 - 0102)

2ND FLOOR

	BELL CCT. LEV 2 POWER SUPPLY RM A241		421
	BELL CCT. LEV 2 POWER SUPPLY RM A241		422
	PRODUCTION TECH B214 EXTINGUISHING PANEL		423

3RD FLOOR (LOOP 1 - 0103)

	PENTHOUSE 2 TEST VALVE OUTSIDE C340		136
	SPRINKLER VALVE EAST PENTHOUSE 2 BY C329		138
	SPRINKLER VALVE EAST PENTHOUSE 2 BY C329		139

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
	1ST FLOOR		Y
	C174		
	COMM RM C173	Y	
	OUTSIDE C173		Y
	OUTSIDE C142	Y	

	OUTSIDE C146		Y
	CORR BY C148	Y	
	STAFF WASHROOM C170		Y
	BOY'S C171	Y	
	GIRLS C172	Y	
	CORR BY C151	Y	
	CORR BY C152	Y	
	STAFF WASHROOM C160		Y
	BOY'S C161	Y	
	BY ELEVATOR		Y
	OUTSIDE PUMP RM	Y	
	BY C128		Y
	BY C124 and C126	Y	
21	PUMP RM		Y
22	STAIRWELL A		Y
23	STAIRWELL C		Y
2ND FLOOR			
	BY C245		Y
	BY C242B	Y	
	BY C242B	Y	
	Gymnasium West Exit Cab Head BY C242A	Y	Y
	BY C242A exit lobby	Y	
	CORR BY C240		Y
	BY A230	Y	
	BY A228		Y
	BY A227 and A230	Y	
	BY ELEVATOR. LEV 2 Front		Y
	BY C222A	Y	
	BY C222A	Y	
	BY C226 Back by exit		Y
	BY C224		
	BY C227		
	BY B210		Y
	BY C219	Y	
	BY B222	Y	
	BY B216		Y
	BY B205 and Inside Rm 205	Y	
	STAIRWELL BY B205		Y
	CAFETERIA		Y
	KITCHEN	Y	
	KITCHEN	Y	

	CAFETERIA	Y	
	CAFETERIA	Y	
	BY JANITOR ROOM A220		Y
	AUDITORIUM HALLWAY	Y	
	A221, WASHROOM	Y	
	A222, WASHROOM	Y	
	THEATER SOUND ROOM		Y
	AUDITORIUM UPPER LEFT	Y	
	AUDITORIUM UPPER RIGHT	Y	
	AUDITORIUM LOWER LEFT	Y	
	AUDITORIUM LOWER RIGHT	Y	
	MAIN ENTRANCE		Y
	MAIN ENTRANCE	Y	
	MAIN ENTRANCE	Y	
	LIBRARY A241, STORAGE		Y
	LIBRARY, ABOVE MAIN DESK	Y	
	LIBRARY		Y
	A244 ,STUDY ROOM		Y
	A244 ,STUDY ROOM	Y	
	OFFICE A286		Y
	BY A285	Y	
	BY A284		Y
	BY A247 / 285	Y	
	BY A272 / 283	Y	
	A274, STUDENT SERVICES/ A278 WASHROOM		Y
	STAIRWELL BY A272		Y
	BY A247	Y	
	BY A260	Y	
	EXIT ACROSS FROM GYM TO COURTYARD		Y
	BY 233, ALSO BY 250	Y	
	BY 260	Y	
	GYM RIGHT SIDE		Y
	GYM FAR LEFT		Y
	GYM LEFT		Y
	GYM FAR RIGHT		Y
	GYM OFFICE AREA		Y
	WASHROOM 269	Y	
	WASHROOM 268 AND RM 267	Y / Y	
	WASHROOM 265 AND RM 264	Y / Y	
3RD FLOOR			
	STAIRWELL A		Y
	BY C345		Y

	BY 342B	Y	
	BY 342B	Y	
	CORR BY C342		Y
	BY 342A	Y	
	BY 342A	Y	
	BY A318		Y
	BY A321	Y	
	BY A317	Y	
	BY ELEVATOR ,LEVEL 3		Y
	BY C322A	Y	
	BY C322A	Y	
	BY C326		Y
	BY C322B	Y	
	BY C322B	Y	
	CORR BY B329		Y
	BY C319	Y	
	BY B324	Y	
	BY B323		Y
	BY B320	Y	
	STAIRWELL BY B318		Y
	CORR BY B315		Y
	BY B318	Y	
	BY B303	Y	
	BY A316		Y
	BY A313	Y	
	BY A312	Y	
	BY A310	Y	
	BY A310	Y	
	TOP OF MAIN STAIRS		Y
	BY A352		Y
	BY A334	Y	
	BY A328	Y	
	STAIRWELL BY A332		Y
	STAIRWELL BY A332		Y
	BY A332	Y	
	A324, JANITOR RM		Y
	A326, MALE WASHROOM	Y	
	A325, FEMALE WASHROOM	Y	
	RM A343		Y
	RM A343 ENTRY	Y	
	PENTHOUSE 1		Y
	PENTHOUSE 1	Y	

	PENTHOUSE 1	Y	
	PENTHOUSE 2		Y
	PENTHOUSE 2	Y	
	PENTHOUSE 2	Y	

A 324 JAN ROOM		UNIT
CORR. ADJ. C326		UNIT
STAIR ADJ C326		UNIT
2ND FLOOR EXIT		UNIT
TO FOYER ADJ CAFE		UNIT
BY A352		UNIT
BY A343		UNIT
FOYER BY CAFETERIA TO COURTYARD		LUMACELL
IT ROOM A232		
STAFF W/RM A225		REMOTE
STAGE GANTRY LEFT		UNIT
STAGE GANTRY RIGHT		UNIT
C319 COMM RM	2	UNIT AIMLITE
CHANGE RM A263	2	UNIT REMOTE
CHANGE RM A262	2	UNIT REMOTE
BY ELEVATOR LEVEL 3		RG12S144

	FOYER MAIN ENT. UNIT		UNIT 144/30
--	-------------------------	--	-------------

NOTE:

STAGE AREA HAS PRE-ACTION SYSTEM.

DOOR RELEASE BUTTONS ON CEILING TILE.

	LOCATION: Rockingham Ele.	Device	Device address or circuit number
--	----------------------------------	---------------	---

FIRE ALARM PANEL:Edwards 6500

MANUAL PULL STATIONS

1	EXIT BY EXCEL ROOM	M	ZN 1
2	EXIT BY MUSIC ROOM	M	ZN 1
3	GYM ENTRANCE	M	ZN 2
4	GYM ENTRANCE BY STAGE	M	ZN 2
5	GYM EXIT TO EXTERIOR	M	ZN 2
6	EXIT BY ROOM 26	M	ZN 3
7	EXIT BY ROOM 33	M	ZN 3
8	BREEZWAY CENTER	M	ZN 4
9	BREEZWAY EXIT	M	ZN 4
10	EXIT BY ROOM 37	M	ZN 5
11	EXIT BY ROOM 44	M	ZN 5
12	IN ROOM 36	M	ZN5
13	OFFICE HALL EXIT BY ROOM 8	M	ZN 6
14	MAIN ENTRANCE	M	ZN 6
15	LIBRARY EXIT	M	ZN 6
16	BASEMENT HALL EXIT BY ROOM 20	M	ZN 7
17	BOILER ROOM	M	ZN 7

HEAT DETECTORS

1	ELECTRICAL ROOM	HT	ZN 1
---	-----------------	----	------

DUCT SMOKE DETECTORS

1	CEILING HATCH BY ROOM 26(CLOSED DUCT)	DS	ZN 3
2	CEILING HATCH BY ROOM 26(OPEN DUCT)	DS	ZN 3

NOTIFYING DEVICES

1	BASEMENT HALL BY ROOM 21	B	SIG 1
2	BY ROOM 9	B	SIG 1
3	LIBRARY	B	SIG 1
4	MUSIC HALL	B	SIG 1
5	MUSIC ROOM	B	SIG 1
6	ROOM 59	B	SIG 1
7	ROOM 55	B	SIG 1
8	BY ROOM 55	B	SIG 1
9	OUTSIDE GYM	B	SIG 2

10	GYM	B	SIG2
11	GYM	B	SIG 2
12	BREEZWAY	B	SIG 2
13	BY ROOM 25	B	SIG 2
14	BY ROOM 35	B	SIG 2

END OF LINE RESISTORS

1	GYM	EOL	ZN 2
2	EXIT BY ROOM 26	EOL	ZN 3
3	BREEZWAY EXIT	EOL	ZN 4
4	EXIT BY ROOM 37	EOL	ZN 5
5	OFFICE HALL EXIT BY ROOM 8	EOL	ZN 6
6	BASEMENT HALL EXIT BY ROOM 20	EOL	ZN 7
7	GYM	EOL	SIG 2
8	EXIT BY ROOM 58	EOL	ZN 1
9	BY ROOM 58	EOL	SIG 1

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
1	Basement By Room 17		Y
2	Basement By Room 18		Y
3	Basement By Room 20		Y
	**Stairwell By Room 20	Y	
5	Boiler Room		Y
6	Stairwell By Main Office		
7	Main Office Stairs Entrance		Y
8	Stairwell By Room 8		Y
9	Hall By Room 8		Y
10	Hall By Office		Y
11	Outside Music Room 60		Y
12	In Music Room 60		Y
13	In Room 59		Y
14	In Room 55		Y
15	In Room 55		Y
16	In Room 58		Y
	**Hall By Room 53	Y	
18	Storage Room On Stage PACK		Y
	**Hall By Snack Bar	Y	
	**Gym	Y	
21	Gym Storage Room		Y
	**Hall By Entrance To Stage	Y	
23	Gym Storage Room #2		Y
	**Gym	Y	

25	Female Washroom 48		Y
	**Outside Female Washroom	Y	
	**Breezeway	Y	
28	Boys Washroom 30		Y
	**Outside Boys Washroom	Y	
	**Stairwell By Room 24	Y	
31	Stairwell By Room 27		Y
	**Bottom Stairs	Y	
33	In Room 44		Y
	**Hall By Room 38	Y	
34	GYM, REAR EXIT		Y

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

	THESE LIGHTS CONTROLLED BY PANEL BY RM 18, CCT# 5
	THESE LIGHTS CONTROLLED BY PANEL BY RM 6, CCT# 13
	THESE LIGHTS CONTROLLED BY PANEL IN MUSIC RM, CCT# 25
	THESE LIGHTS CONTROLLED BY PANEL IN RM 55, CCT# 20
	THESE LIGHTS CONTROLLED BY PANEL "A" ,ROOM 58, CCT# 24
	THESE LIGHTS CONTROLLED BY PANEL "C" ,GYM STORAGE RM, CCT# 21
	THESE LIGHTS CONTROLLED BY PANEL "C",GYM STORAGE RM, CCT# 34

	LOCATION: Fairview Heights Annex	Device	Device address or circuit number
--	---	---------------	---

	FIRE ALARM PANEL: Edwards 2280		
--	---------------------------------------	--	--

Devices			
---------	--	--	--

	BY FIRE ALARM PANEL	M	ZONE 1
	MAIN HALL CENTER	M	ZONE 1
	MAIN HALL EAST	M	ZONE 1
	MAIN HALL EAST	EOL	ZONE 1
	GYM SOUTH EXIT	M	ZONE 2
	GYM EAST EXIT	M	ZONE 2
	GYM WEST EXIT	M	ZONE 2
	BY RESOURCE ROOM	M	ZONE 2
	BY RESOURCE ROOM	EOL	ZONE 2
	SPRINKLER	FS	3

NOTIFYING DEVICES			
-------------------	--	--	--

	MAIN HALL EAST	B	SIG 1
	MAIN HALL EAST	B	SIG 1
	GYM	B	SIG 1
	RESOURCE ROOM	B	SIG 1
	RESOURCE ROOM	EOL	SIG 1

EMERGENCY LIGHTING			
--------------------	--	--	--

t	Location	# of Heads	Model
	BY ROOM 5		UNIT
	BY BOYS WASHROOM		UNIT
	BY GIRLS		UNIT

WASHROOM		
BY ROOM 4		UNIT
FAR ENTERANCE		UNIT COMBO
GYM LEFT		UNIT
GYM RIGHT		UNIT
GYM EXIT THROUGH CLASS		UNIT COMBO

Fire Alarm System Information - Lockview High

1 of 11

FIRE ALARM DEVICES - System Manufacturer EDWARDS IO 1000

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
ELEVATOR SHAFT	HEAT	SIGA-HFS	1		✓			✓	✓						
STAIRWELL 4	SMOKE	SIGA-IS	2		✓			✓	✓						
STAIRWELL 5	SMOKE	SIGA-IS	3		✓			✓	✓						
STAIRWELL 1	SMOKE	SIGA-IS	4		✓			✓	✓						
STAIRWELL 2	SMOKE	SIGA-IS	5		✓			✓	✓						
STAIRWELL 3	SMOKE	SIGA-IS	6		✓			✓	✓						
HEADER EF VALVE SPRK RM	GV	SIGA-CT2	146		✓				✓	✓					
SUPPLY 3 MECH B212 SHUTDOWN	RLY	SIGA-CR	147		✓			✓							
SUPPLY 5 MECH B201 SHUTDOWN	RLY	SIGA-CR	148		✓			✓							
SUPPLY 2 MECH B212 SHUTDOWN	RLY	SIGA-CR	149		✓			✓							
SUPPLU 7 MECH B201 SHUTDOWN	RLY	SIGA-CR	150		✓			✓							
SUPPLY 1 MECH B212 SHUTDOWN	RLY	SIGA-CR	151		✓			✓							
SUPPLY 6 MECH B201 SHUTDOWN	RLY	SIGA-CR	152		✓			✓							
SUPPLY 4 MECH B201 SHUTDOWN	RLY	SIGA-CR	153		✓			✓							
ELEVATOR RELAY	RLY	SIGA-CR	154		✓			✓							
KITCHEN SHUNT TRIP	RLY	SIGA-CR	155		✓			✓							
BOOSTER PANEL 2	RLY	SIGA-CR	156		✓			✓							
BOOSTER PANEL 1	RLY	SIGA-CR	157		✓			✓							
PROPANE SOLENOID	RLY	SIGA-CR	158		✓			✓							
FIRE PUMP RUNNING	SUPV	SIGA-CT2	164		✓				✓	✓					C1
FIRE PUMP TROUBLE	SUPV	SIGA-CT2	165		✓				✓	✓					C1
KITCHEN HOOD FLOW	ALARM	SIGA-CT2	166		✓			✓	✓						C1
KITCHEN HOOD VALVE	GV	SIGA-CT2	167		✓				✓	✓					C1
2ND FL EFF RM F120 SPRK WATERFLOW	FS	SIGA-CT2	168		✓			✓	✓						C1
2ND FL EFF RM F120 SPRK VALVE	GV	SIGA-CT2	169		✓				✓	✓					C1
1ST FL ABD RM C137 SPRK WATERFLOW	FS	SIGA-CT2	170		✓			✓	✓						C1
1ST FL ABD RM C137 SPRK VALVE	GV	SIGA-CT2	171		✓				✓	✓					C1
1ST FL C KITCHEN STORAGE SPRK FLOW	FS	SIGA-CT2	172		✓			✓	✓						C1
1ST FL C KITCHEN STORAGE SPRK VALVE	GV	SIGA-CT2	173		✓				✓	✓					C1
1ST FL EFF RM F120 SPRK WATERFLOW	FS	SIGA-CT2	174		✓			✓	✓						C1
1ST FL EFF RM F120 SPRK VALVE	GV	SIGA-CT2	175		✓				✓	✓					C1
BACKFLOW VALVE 1 SPRK RM	TS	SIGA-CT2	176		✓				✓	✓					C1

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
GATE VALVE HEADER SPRK RM	GV	SIGA-CT2	177		✓				✓	✓					
2ND FL ABCD RM C137 SPRK WATERFLOW	FS	SIGA-CT2	178		✓			✓	✓						
2ND FL ABCD RM C137 SPRK VALVE	GS	SIGA-CT2	179		✓				✓	✓					
BOOSTER PANEL 2 SUPV (RM F121)	SUPV	SIGA-CT2	180		✓				✓	✓					
BOOSTER PANEL 1 SUPV (RM F121)	SUPV	SIGA-CT2	181		✓				✓	✓					
HEADER ABCD FLOW SPRK RM	FS	SIGA-CT2	182		✓			✓	✓	✓					
HEADER ABCD VALVE SPRK RM	SUPV	SIGA-CT2	183		✓				✓	✓					
HEADER EF FLOW SPRK RM	FS	SIGA-CT2	184		✓			✓	✓						
GYM SOUTHWEST	M	SIGC270B	185		✓			✓	✓						
GYM NORTHWEST	M	SIGC270B	186		✓			✓	✓						
ALCOVE @ D106	M	SIGC270B	187		✓			✓	✓						
OUTSIDE STORAGE	M	SIGC270B	188		✓			✓	✓						
CORR A114 @ STAIR 3	M	SIGC270B	189		✓			✓	✓						
CORR D133	M	SIGC270B	190		✓			✓	✓						
CORR A211 @ STAIR 3	M	SIGC270B	191		✓			✓	✓						
CORR E118	M	SIGC270B	192		✓			✓	✓						
MECHANICAL RM F120	M	SIGC270B	193		✓			✓	✓						
MUSIC RM F122	M	SIGC270B	194		✓			✓	✓						
CORR F115	M	SIGC270B	195		✓			✓	✓						
CORR C211 @ STAIR 2	M	SIGC270B	196		✓			✓	✓						
CORR D202 @ STAIR 4	M	SIGC270B	197		✓			✓	✓						
DUCT COLLECTOR	M	SIGC270B	198		✓			✓	✓						
CORR D130 @ VESTIBULE	M	SIGC270B	199		✓			✓	✓						
CORR B215 @ STAIR 5	M	SIGC270B	200		✓			✓	✓						
CORR F134 @ STAIR 2	M	SIGC270B	201		✓			✓	✓						
CORR E116	M	SIGC270B	202		✓			✓	✓						
ALCOVE @ B104/B106	M	SIGC270B	203		✓			✓	✓						
CORR C211 @ STAIR 1	M	SIGC270B	204		✓			✓	✓						
CORR D102 @ STAIR 4	M	SIGC270B	205		✓			✓	✓						
ELEVATOR PIT VALVE	TS	SIGA-CT1	206		✓				✓	✓					
BACKFLOW VALVE 2 SPRK RM	TS	SIGA-CT1	207		✓				✓	✓					
FIRE PUMP SWITCH OFF SPRK RM	TS	SIGA-CT1	208		✓				✓	✓					
TEST HEADER VALVE	TS	SIGA-CT1	209		✓				✓	✓					

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
----------------------	--------	-------	---------	---------------------	------	-----	------	-----	-----	-----	-----	----	-----	------	---------

SIGNAL CIRCUIT C1 (AUD. 1 - 163)

MAIN ENTRANCE VESIBULE	H/S	757-7A-T		1	✓			✓							
LIBRARY C116 FRONT	H/S			1	✓			✓							
CENTRE CORRIDOR A101	H/S			1	✓			✓							
CORRIDOR C134	H/S			1	✓			✓							
CAFETERIA F103	H/S			1	✓			✓							
CORRIDOR C134	EOL			1	✓										
LIBRARY REAR WALL	H/S				✓			✓							

SIGNAL CIRCUIT C2 (AUD. 2 - 160)

CORRIDOR D102 AT STAIR 4	H/S			2	✓			✓							
LEARNING SUPPORT D109	H/S			2	✓			✓							
STUDENT SERVICES C129	H/S			2	✓			✓							
WASHROOM C119	STR			2	✓			✓							
WASHROOM 135	STR			2	✓			✓							
COMMON LAB B114 REAR	H/S			2	✓			✓							
COMMON LAB B114 FRONT	H/S			2	✓			✓							
COMMON LAB B114 FRONT	EOL			2	✓										

SIGNAL CIRCUIT C3 (AUD. 3 - 162)

CORRIDOR D133 AT C122	H/S			3	✓			✓							
STUDENT SERVICES C129	H/S			3	✓			✓							
OFFICE CORRIDOR D122	H/S			3	✓			✓							
CORRIDOR B115 AT C136	H/S			3	✓			✓							
CORRIDOR B115 AT C103	H/S			3	✓			✓							
CORRIDOR A114 AT A106	H/S	757-7A-T		3	✓			✓							
WORK AREA A113	H/S			3	✓			✓							
WORK AREA A113	EOL			3	✓										

SIGNAL CIRCUIT C4 (AUD. 4 - 159)

CLASSROOM D106 W/R	S			4	✓			✓							
WORK AREA D113	H/S			4	✓			✓							
WASHROOM D112	S			4	✓			✓							
WELLNESS C122	H/S			4	✓			✓							
LIBRARY C116 REAR	H/S			4	✓			✓							

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
WASHROOM C104	S			4	✓			✓							
WASHROOM C104	EOL			4	✓										

SIGNAL CIRCUIT 5 - BOOSTER PANEL #1 (AUD. 5)

MECHANICAL ROOM F120	H/S			5	✓			✓							
MUSIC ROOM F122	H/S			5	✓			✓							
ROOM E106 WASHROOM	H/S			5	✓			✓							
GYM E102 AT 3110	H/S			5	✓			✓							
OUTDOOR STORAGE E-104	H/S			5	✓			✓							
WASHROOM F127	STROBE			5	✓			✓							

SIGNAL CIRCUIT 6 - BOOSTER PANEL #1 (AUD. 6)

CORRIDOR AT DRAMA/DANCE F106	H/S			6	✓			✓							
EXERCISE E108	H/S			6	✓			✓							
WASHROOM E107	H/S			6	✓			✓							
GYM E107 NEAR OUTDOOR STORAGE	H/S			6	✓			✓							
GYM E 102 BY GYM STORAGE E103	H/S			6	✓			✓							
WASHROOM F128	H/S			6	✓			✓							

SIGNAL CIRCUIT 7 - BOOSTER PANEL #2 (AUD. 7)

CORRIDOR AT F113 NUTRITION	H/S			7	✓			✓							
LOCKROOM E114	H/S			7	✓			✓							
WASHROOM E112	H/S			7	✓			✓							
LOCKER ROOM E110	H/S			7	✓			✓							
STAGE F106	H/S			7	✓			✓							
CORRIDOR AT F126 GROUP WORK	H/S			7	✓			✓							

SIGNAL CIRCUIT 8 - BOOSTER PANEL #2 (AUD. 8)

GROUP WORK F114	H/S			8	✓			✓							
LOCKER ROOM E111	H/S			8	✓			✓							
WASHROOM E113	S			8	✓			✓							
LOCKER ROOM E115	H/S			8	✓			✓							
PRODUCTION F131	H/S			8	✓			✓							
CORRIDOR AT D113 W/R	H/S			8	✓			✓							

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
----------------------	--------	-------	---------	---------------------	------	-----	------	-----	-----	-----	-----	----	-----	------	---------

SIGNAL CIRCUIT C9 - (AUD. 9 - F.P. CCT #1)

[illegible]

SIGNAL CIRCUIT C10 (AUD. 10 - 161)

[illegible]

SIGNAL CIRCUIT C11 (AUD. 11 - F.P. CCT #2)

[illegible]

Fire Alarm System Information - Marine Drive Academy

System Manufacturer: Notifier NFS2-640

Location	Device	Circuit #						
Top Of Elevator Shaft	S	D001						
3rd Floor Mechancial Room	M	M029	✓		✓	✓		
Corridor By Elevator 300C	S	D017	✓		✓	✓		
Corridor 300C BY 310	S	D015	✓		✓	✓		
Corridor 300A BY Stair 1	M	M024	✓		✓	✓		
Corridor 300A BY 307	S	D023	✓		✓	✓		
Stairwell 2	S	D047	✓		✓	✓		
Corridor 300F	M	M046	✓		✓	✓		
Communications Room 311	S	D021	✓		✓	✓		
Mechancial Room 305	M	M029	✓		✓	✓		
Elevator Shaft Valve	TS	M042	✓		✓	✓		
Stairwell 1-3	S	D025	✓		✓	✓		
Stairwell 1-2	S	D074	✓		✓	✓		
Stairwell 1-2	M	M077	✓		✓	✓		
Vestibule 200F Main Entry	M	M070	✓		✓	✓		
Room 207 Admin Exit	M	M062	✓		✓	✓		
Kitchen	M	M071	✓		✓	✓		
Kitchen Storage 206A	S	D072	✓		✓	✓		
2nd Floor Elevator Lobby	S	D066	✓		✓	✓		
Elevator Pit	TS	M122	✓		✓	✓		
Washroom Corridor 111	S	D119	✓		✓	✓		
1st Floor Elevator Lobby	S	D121	✓		✓	✓		
1st Floor Stair 2	M	M109	✓		✓	✓		
1st Floor Corridor 100G	M	M106	✓		✓	✓		
Fire Pump Room	M	M134	✓		✓	✓		
Fire Pump Discharge	TS	M136	✓		✓	✓		
Level 1 Shut Off	TS	M137	✓		✓	✓		
2nd/3rd Floor Shutoff	TS	M139	✓		✓	✓		
Test Header Valve	TS	M135	✓		✓	✓		
Fire Pump Running	IM	M141	✓		✓	✓		
Fire Pump Trouble	IM	M145	✓		✓	✓		
Fire Pump AC Fail	IM	M142	✓		✓	✓		
Fire Pump Phase Reversal	IM	M143	✓		✓	✓		
1st Floor Flow	FS	M138	✓		✓	✓		
2nd / 3rd Floor Flow	FS	M140	✓		✓	✓		
3rd Floor Valve	TS	M044	✓		✓	✓		
3rd Floor Flow	FS	M045	✓		✓	✓		
Outside Electrical Room	M	M149	✓		✓	✓		
Outside Electrical Room	S	D150	✓		✓	✓		
Boiler Room	HT	D157	✓		✓	✓		
Boiler Room	HT	D154	✓		✓	✓		

Boiler Room	M	M155	✓		✓	✓		
Boiler Room Corridor	HT	D153	✓		✓	✓		
Outside Storage Room	M	M147	✓		✓	✓		
Outside Storage Room	S	D148	✓		✓	✓		
Outside Water Treatment Room	M	M133	✓		✓	✓		
Floor 1 Rear Exit	M	M131	✓		✓	✓		
2nd Floor Gate Valve	TS	M070	✓		✓	✓		
2ND Floor Flow	FS	M076	✓		✓	✓		
Corridor 100E #3	S	D112	✓		✓	✓		
Corridor 100E #2	S	D111	✓		✓	✓		
Corridor 100E #1	S	D110	✓		✓	✓		
Corridor 100D	S	D113	✓		✓	✓		
Corridor 100D	S	D114	✓		✓	✓		
Corridor 100D	S	D115	✓		✓	✓		
Recycling Room	HT	D130	✓		✓	✓		
Custodian Room	HT	D125	✓		✓	✓		
Staff Washroom 110A	S	D120	✓		✓	✓		
Boiler Room	HT	D118	✓		✓	✓		
Gym from Café	M	M089	✓		✓	✓		
201D Change Room	S	D094	✓		✓	✓		
201D Change Room	S	D095	✓		✓	✓		
201D Change Room	S	D096	✓		✓	✓		
201D Change Room	S	D097	✓		✓	✓		
Gym Comm Room	S	D093	✓		✓	✓		
Gym #5	M	M093	✓		✓	✓		
Gym #4	M	M092	✓		✓	✓		
Gym #3	M	M091	✓		✓	✓		
Gym #2	M	M090	✓		✓	✓		
Gym #1	M	M089	✓		✓	✓		
Room 207 E	S	D061	✓		✓	✓		
Room 207 D	S	D060	✓		✓	✓		
Room 217 B	S	D059	✓		✓	✓		
Northwest Standpipe	TS	M127	✓		✓	✓		
Northeast Standpipe	TS	M126	✓		✓	✓		
Comm Room 211	TS	D064	✓		✓	✓		
Washroom Hallway 213	S	D065	✓		✓	✓		
Kitchen Hood System	IM	M001	✓		✓	✓		
Stairwell 3	S	D068	✓		✓	✓		
Washroom 220A	S	D058	✓		✓	✓		
Com Library 200K	S	D055	✓		✓	✓		
Corridor 200K	M	M053	✓		✓	✓		
Washroom 221A	S	D057	✓		✓	✓		
Custodian 210	HT	D067	✓		✓	✓		
Corridor 200E	S	D069	✓		✓	✓		

Room 224	S	D051	✓		✓	✓		
Staff Washroom 223B	HT	D056	✓		✓	✓		
Chair Storage #8	S	D087	✓		✓	✓		
Chair Storage #7	S	D086	✓		✓	✓		
Chair Storage #6	S	D085	✓		✓	✓		
Chair Storage #5	S	D084	✓		✓	✓		
Chair Storage #4	S	D083	✓		✓	✓		
Chair Storage #3	S	D082	✓		✓	✓		
Chair Storage #2	S	D081	✓		✓	✓		
Chair Storage #1	S	D080	✓		✓	✓		
Gym Storage 201A	S	D003	✓		✓	✓		
Gym Storage 201B	S	D002	✓		✓	✓		
Storage Room 317A	S	D018	✓		✓	✓		
Storage Room 317A	S	D019	✓		✓	✓		
Corridor 300E	S	D007	✓		✓	✓		
Electrical Panel By 300E	S	D009	✓		✓	✓		
Corridor 300F By Stair 2	S	D005	✓		✓	✓		
Learn Library 300F	S	D006	✓		✓	✓		
305 Mechanical Room East	S	D030	✓		✓	✓		
305 Mechanical Room West	S	D031	✓		✓	✓		
AHU-1 Fitness	DS	D038	✓		✓	✓		
AHU-2 Mechanical Room	DS	D039	✓		✓	✓		
AHU-3 Mechanical Room	DS	D041	✓		✓	✓		
Room 308 Custodial	HT	D020	✓		✓	✓		
Room 307A Workroom	S	D022	✓		✓	✓		
Room 319 Washroom	HT	D008	✓		✓	✓		
Corridor 300D Maker Space	S	D010	✓		✓	✓		
Art Storage 316A	S	D011	✓		✓	✓		
Room 310A Nutrition Pantry	S	D013	✓		✓	✓		
Room 310 Nutrition Lab	S	D012	✓		✓	✓		
Washroom 313 Corridor	S	D016	✓		✓	✓		
Room 312 Staff Washroom	S	D012	✓		✓	✓		
Room 109A Main Communication	S	D024	✓		✓	✓		
Room 102 Storage	S	D132	✓		✓	✓		
Room 115 Printer	S	D117	✓		✓	✓		
Room 114	M	M128	✓		✓	✓		
Room 118A Electrical Closet	S	D116	✓		✓	✓		
Fire Doors	R		✓		✓	✓		
3rd Floor Window By Stairwell Shutter	R		✓		✓	✓		
3rd Floor Main Stairwell Shutter	R		✓		✓	✓		
3rd Floor Rear Wing Ceiling Shutter	R		✓		✓	✓		
Stair 2 3rd Floor	R		✓		✓	✓		

Stair 2 2nd Floor	R		✓		✓	✓		
Stair 2 1st Floor	R		✓		✓	✓		
Stair 1 3rd Floor	R		✓		✓	✓		
Stair 1 2nd Floor	R		✓		✓	✓		
Stair 1 1st Floor	R		✓		✓	✓		
Main Elevator Recall	R	M098	✓		✓	✓		
Alternate Elevator Recall	R	M104	✓		✓	✓		
Elevator Fire Hat	R	M100	✓		✓	✓		
3RD Floor								
Multi purpose science 317	HS		✓		✓	✓	✓	
By Classroom 324	HS		✓		✓	✓	✓	
By Learning Center 318	HS		✓		✓	✓	✓	
By Nutrition Lab 310	HS		✓		✓	✓	✓	
Nutrition Lab 310	HS		✓		✓	✓	✓	
By Maintenance Office 309	HS		✓		✓	✓	✓	
Youth Health 307	HS		✓		✓	✓	✓	
Mechanical Room 305A	HS		✓		✓	✓	✓	
Main Floor								
Music Room	HS		✓		✓	✓	✓	
By Gym 201	HS		✓		✓	✓	✓	
Café	HS		✓		✓	✓	✓	
Gymnasium	HS		✓		✓	✓	✓	
Gymnasium	HS		✓		✓	✓	✓	
Unisex Change Room	HS		✓		✓	✓	✓	
By Communication Room 211	HS		✓		✓	✓	✓	
Washrooms 213	HS		✓		✓	✓	✓	
Classroom 218	HS		✓		✓	✓	✓	
Classroom 220	HS		✓		✓	✓	✓	
By Assisted Care Washroom 224	HS		✓		✓	✓	✓	
Learning Center 226	HS		✓		✓	✓	✓	
Staff Room 223	HS		✓		✓	✓	✓	
Classroom 221	HS		✓		✓	✓	✓	
Guidance 217	HS		✓		✓	✓	✓	
By Vice Principal Office 207C	HS		✓		✓	✓	✓	
Outside By Gym Exit	HS		✓		✓	✓	✓	
Outside By Flag Pole	HS		✓		✓	✓	✓	
Outside By Pre Primary	HS		✓		✓	✓	✓	
Kitchen	HS		✓		✓	✓	✓	
Kitchen	HS		✓		✓	✓	✓	

1st Floor								
Main Communication Room 109	HS		✓		✓	✓	✓	
By Custodian 103	HS		✓		✓	✓	✓	
Profuction 114	HS		✓		✓	✓	✓	
Washrooms 111	HS		✓		✓	✓	✓	
By Classroom 118	HS		✓		✓	✓	✓	
By Classroom 126	HS		✓		✓	✓	✓	
Water Tratment Room	HS		✓		✓	✓	✓	
Outside By Water Treatment Room	HS		✓		✓	✓	✓	
Outside By Generator	HS		✓		✓	✓	✓	
Boiler Room	HS		✓		✓	✓	✓	
Main Electrical Room	HS		✓		✓	✓	✓	
Sprinkler Room	HS		✓		✓	✓	✓	
Outside Stroage	HS		✓		✓	✓	✓	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

Emergency Light & Exit Sign Inspection List - EASTERN SHORE CONSOLIDATED SCHOOL EL

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	West Wing	/												No	Yes	0.2	6.4			30 min	Pass	
	By East Exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 150	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 147	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Locker 517	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 143	Ready-Lite/FL2									Yes	Yes		No	Yes	0.2	6.4			30 min	Pass	
	By Room 142	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 139	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 137	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 138	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	By EL.CL8 100D.1	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Locker 389	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Locker 375	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 131	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 109.1	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 113	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 114	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 115	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	Center Wing	/												No	Yes	0.2	6.4			30 min	Pass	
	By Room 109	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	By Room 109	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 109	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Bathroom stall #5	Ready-Lite/RH												No	Yes	0.2	6.4			30 min	Pass	
	Corridor by 107	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By room 105	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By main entry vestibule	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Main entry vestibule#1	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Main entry vestibule#2	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Main entry vestibule	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Above reception desk	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	Above reception desk	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By reception 101 back exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Main entry reception 101	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Alternate Main Entry/Student Services	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By room 105.6	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By room 105.4	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	By 105.3 / 105 back exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	In room 105 bathroom	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Trades classrooms lobby	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Trades classrooms lobby	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	By room 102 common area	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Room 104 production	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Room 106 skill trades	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Production back exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Production Main entry	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Production back exit	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Skill trades side wall	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Skill trades back exit	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Skill trades back exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Gym and Cafeteria	/												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	Outside Gym Entry	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	Gym Main Entry	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Gym Office room 111.2	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	Storage 112.6	Ready-Lite/PACK												No	Yes	0.2	6.4			30 min	Pass	
	Storage South	Ready-Lite/PACK												No	Yes	0.2	6.4			30 min	Pass	
	West Wall	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Rear Gym Entry	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	North Wall by Gym Entry	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	Above Change room windows	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	Above room 112.6	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By Gym east Bathroom	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By Gym west Bathroom	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	By Gym east Exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Corridor outside Gym east exit	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Southeast Gym Exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Southeast Gym Exit corridor	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Southeast Gym Exit corridor	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Southeast Gym Exit corridor	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By room 112.4 south wall #2	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	By south wall	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By room 112.3 south wall	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	West Wall	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	Stage Stair exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Rear Stage	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Rear Stage exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By room 119	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	Room 119	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	119 bathroom	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	North Cafeteria Wall	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	North Cafeteria Wall	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	West Cafeteria Wall	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	West Center Cafeteria	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	West Center Cafeteria Exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	West Cafeteria By kitchen	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	West Cafeteria By kitchen	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Kitchen Entry	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Kitchen	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Kitchen	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Kitchen Office	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	Kitchen	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Center South Bathroom area	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Center South Bathroom area	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Center South Bathroom area	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	In Room 128	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 129	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	In Room 122	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	In Room 122	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Storage in room 122	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Storage in room 122	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	East Wing	/												No	Yes	0.2	6.4			30 min	Pass	
	Corridor Entry	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By Room 153.4	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By Room 153	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	In room 153 Storage #1	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	In room 153 Storage #2	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	In room 153 Storage #3	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	In Room 154 Bathroom	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	In Room 154 Storage	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	In Room 154	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	In Room 155	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	By Room ER153	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 158	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 160	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 159	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 161	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Fail	1 of 2 flood lights did not come on
	By Room 163	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room EL-CL10	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 167	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	By Room 169	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By Room 170	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	East Corridor Exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	East Corridor Gym Exit ES	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Room 160	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	East Corridor to Main Corridor	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Boiler Room	/												No	Yes	0.2	6.4			30 min	Pass	
	By east exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	West Wall	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	East Wall	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	By eletrical room	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Inside eletrical room	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Main Eletrical Room	Ready-Lite/												No	Yes	0.2	6.4			30 min	Pass	
	In Main Eletrical	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Ladder to penthouse	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	East corridor exit	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	East corridor exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Water Treatment Corridor	/												No	Yes	0.2	6.4			30 min	Pass	
	Main exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	North exit to corridor	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	North exit to corridor	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Penthouse#1	/												No	Yes	0.2	6.4			30 min	Pass	
	By ladder to roof	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	By ladder to water room	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By ladder to water room	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By AHU#5	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	By AHU#1	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By AHU#1	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	Exit to Penthouse corridor	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Penthouse Corridor	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	Penthouse Corridor	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	Penthouse Corridor	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Penthouse Corridor to Penthouse #1	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Penthouse Corridor to Penthouse #2	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Penthouse#2	/												No	Yes	0.2	6.4			30 min	Pass	
	Main entry	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By AHU#2 supply	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By AHU#3 supply	Ready-Lite/2RH												No	Yes	0.2	6.4			30 min	Pass	
	By AHU#2 return	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By AHU#3 return	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	

Report of Inspection / Test

Annual Exit Signs



04-29-2026

Conducted by: Mark Holloway

Property

Eastern Shore Consolidated School
210 Motts Dr
East Chezzetcook NS B3E 1J1
Print Date: 05-13-2026

D & L Engineering
58 McQuade Lake Crescent
Beechville NS B3S 1G8
902-429-3790
servicescheduler@dl-eng.com

ID#	Location	MFG/Type	Barcode	Battery Type	Height	Make	Model	Size	Input Power	Style	Main Unit	Remote Head	Battery Part	Was 90 min load test completed?	Did the push button test operate?	Current(A)	Voltage(V)	Test Start Time	Test End Time	Load Test	Pass/Fail	Notes
	By AHU#4	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Near roof top access	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	
	West ladder exit	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Fire Pump Room	/												No	Yes	0.2	6.4			30 min	Pass	
	Main Entry	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	By Fire pump controller	Ready-Lite/FL2												No	Yes	0.2	6.4			30 min	Pass	
	Storage beside fire pump room	/												No	Yes	0.2	6.4			30 min	Pass	
	Main Entry	Ready-Lite/ES												No	Yes	0.2	6.4			30 min	Pass	
	Inside room	Ready-Lite/2R H												No	Yes	0.2	6.4			30 min	Pass	