

RFP # 4290
Fire Alarm & Emergency Lighting Inspections

Appendix F – Fire Alarm and Emergency
Lighting System Information

Region 1

	LOCATION: Atlantic Memorial
	FIRE ALARM PANEL: Siemens XLS

Location Description	Device	Address
BY MUSIC ROOM	M	1-31
IT ROOM 132B REAR	S	1-30
BY LEARNING RESOURCE	M	1-29
BY LEARNING RESOURCE	S	1-28
BY MULTI-PURPOSE ROOM	M	1-27
BY MULTI-PURPOSE ROOM	S	1-26
BY 102	M	1-22
STORAGE ROOM 110	S	1-21
IN CLASSRM 106	S	1-20
STAFF WASHROOM	S	1-19
STORAGE ROOM 117B	S	1-18
IN CLASSRM 105	S	1-17
FEMALE WASHROOM 115	S	1-16
STORAGE ROOM 117A	S	1-15
PHOTOCOPY ROOM	S	1-14
BY JANITORS ROOM 114A	S	1-13
JANITORS ROOM 114A	HT	1-12
MALE WASHROOM 114	S	1-11
DUCT SMOKE AH-1	D	1-10
STORAGE 103B	S	1-9
FILE AREA 105	S	1-8
BY MAIN OFFICE	S	1-7
WASHROOM 103A	S	1-6
BY 108	M	1-5
BY 112	M	1-4
BY 108	S	1-3

BY 107	S	1-2
MAIN ENTRANCE	M	1-1
ELECTRICAL ROOM CORRIDOR 125	S	1-63
ELECTRICAL ROOM BY 118	S	1-62
DUCT SMOKE GYM AHU	D	1-61
UNDER STAGE STORAGE	S	1-60
BY MALE WASHROOM 114	M	1-49
GYM STORAGE WEST	S	1-48
GYM WEST EXIT	M	1-47
OUTSIDE STORAGE ROOM	M	1-46
OUTSIDE STORAGE ROOM	S	1-45
OIL STORAGE ROOM	HT	1-44
BOILER ROOM	M	1-43
BOILER ROOM	HT	1-42
ELECTRICAL ROOM	S	1-41
BOILER ROOM STORAGE	S	1-40
MECHANICAL ROOM	S	1-39
LEARNING RESOURCE WASHROOM	S	1-38
GYM BOYS CLANGE ROOM	HT	1-37
GYM GIRLS CHANGE ROOM	HT	1-36
MUSIC/SCIENCE STORAGE	S	1-35
ART STORAGE	S	1-34
RAMP TO GYM STAGE	S	1-33
BY MUSCI RM	S	1-32
ELECTRICAL ROOM BY 119	S	1-64

BELLS

BY ROOM 112	H/S
BY ROOM 103	H/S
MAIN HALL LEFT	H/S

GYM	H/S
BY CARETAKERS OFFICE	H/S
BOILER ROOM	H/S
BY CARETAKERS OFFICE WEST	H/S
MUSIC ROOM	H/S
STAFF ROOM	H/S
MALE WASHROOM BY OFFICE	H/S
FEMALE WASHROOM BY OFFICE	H/S
MECHANICAL ROOM	H/S
BOYS CHANGE ROOM	H/S
GIRLS CHANGE ROOM	H/S
RESOURCE ROOM	H/S
ROOM 105	H/S
ROOM 106	H/S
STAGE	H/S

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	BY ROOM 110	2H	UNIT
	BY RM 108	2R	LED REMOTE
	MAIN LOBBY	2H 2R	REMOTE
	BY RM 105	2H	LED REMOTE
	BY RM 102	2R	LED REMOTE
	FRONT VESTIBULE	2R	REMOTE
	HALL BY OFFICE	2R	LED REMOTE
	NORTH EXIT		EXIT LED
	SOUTH EXIT		EXIT LED
	HALL BY GIRLS WASHRM	2R	REMOTE
	HALL BY BOYS		EXIT

	WASHRM		
	WEST SIDE EXIT		RG72QB LUMACELL
	BY CARETAKERS BACK RM		RG72QB LUMACELL
	GIRLS CHANGE RM	2H	LUMACELL
	BOYS CHANGE RM	2H	LUMACELL
	MECHANICAL RM		6JML36 EMERGI- LITE
	ELECTRICAL RM		
	GYM BY OFFICE		LUMACELL
	BOILER RM		RG72QB LUMACELL
	OFFICE	2H	6MJL36 EMERGI- LITE
	WEST SIDE EXIT		EXIT
	WEST FIRE DOOR BY SIDE EXIT		EXIT
	GIRLS CHANGE RM		EXIT
	SIDE EXIT GYM		EXIT
	GYM		EXIT
	EXIT ADJ ENTR. TO MECH. AHU RM		EXIT
	HALL BY PHOTOCOPY RM	2 H	LUMACELL UNIT

Fire Door Number or Location
CENTER HALL LEFT SIDE
CENTER HALL RIGHT SIDE

	LOCATION: Brookside Jr.	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards QS4		
MANUAL PULL STATIONS			
	CAFETERIA	M	101001
	FIRE DOORS NEAR 106	M	101001
	BOILER ROOM	M	101002
	TOP OF MAIN STAIRS	M	101003
	AT END OF HALLWAY EAST 2nd	M	101003
	GYM ENTRANCE	M	101004
	GYM	M	101001
	1ST FLOOR WEST CORRIDOR	M	101004
	CAFETERIA EXIT	M	101004
	2nd FLOOR NEAR FIRE DOORS	M	101005
	2nd FLOOR END OF WEST HALLWAY	M	101005
	MAIN ENTRANCE	M	101006
	MAIN ENTRANCE STAIRS	M	101006
	MAIN HALL OFFICE	M	101006
	END OF MAIN HALL EAST	M	101006
SMOKE DETECTORS			
	MID 2nd FLOOR HALLWAY WEST	SI	101003
	FIRST FLOOR EAST	SI	101006
	ELEVATOR SHAFT	SI	
HEAT DETECTORS			
1	CAFETERIA KITCHEN	HT	101004
2	BOILER ROOM	HT	101002
3	BOILER ROOM	HT	101002
4	MAIN STAIRWELL	HT	
5	COOKING ROOM 215 ON 2nd FLOOR	HT	101003
6	COOKING ROOM 215 ON 2nd FLOOR	HT	101003
7	EAST HALLWAY STAIRWELL	HT	
8	GYM STAGE, LEFT	HT	
9	GYM STAGE, CENTER	HT	
10	GYM STAGE, RIGHT	HT	
11	REAR STAIRWELL	HT	
12	2nd FLOOR MECHANICAL ROOM	HT	101005
13	JANITOR'S CLOSET 2nd FLOOR	HT	101005

14	ELEVATOR MECHANICAL ROOM	HT	101007
15	PAINT STORAGE	HT	101006
16	KITCHEN STORAGE	RHT	101004
17	JANITORS CLOSET 1st FLOOR	RHT	101006
18	1st FLOOR WEST STORAGE	RHT	101004
19	BOILER ROOM STORAGE	RHT	101002
20	CHIEF CARETAKERS OFFICE	RHT	101002
21	STORAGE 100	RHT	101002
22	2nd FLOOR EAST END STORAGE	RHT	101003
23	COMPUTER REPAIR / RECYCLING	RHT	101005
24	TEACHERS RESOURCE RM 2ND FLOOR	RHT	101005
25	STORAGE IN MUSIC ROOM 2ND FLOOR	RHT	101005
26	WEST END STORAGE 2ND FLOOR	RHT	101005
27	WOOD WORKING SHOP STORAGE	RHT	101006
28	EAST ELECTRICAL ROOM	RHT	101006

AUXILIARIES

	1ST FLOOR	DH	
	2ND FLOOR	DH	
	FAN SHUTDOWN	AUX	

NOTIFYING DEVICES

	2nd FLOOR HALLWAY	B	SIG1
	2nd FLOOR HALLWAY WEST	B	SIG1
	BESIDE CLASS 210 ON 2nd FLOOR	B	SIG1
	BOILER ROOM	B1	SIG1
	CAFETERIA	B	SIG1
	EAST HALLWAY	B	SIG1
	GYM	B	SIG1
	GYM	B	SIG1
	HALLWAY WEST	B1	SIG1
	MAIN ENTRANCE STAIRS	B	SIG1
	MAIN HALL OFFICE	B	SIG1
	STAFF LUNCH ROOM ON 2nd FLOOR	B	SIG1
	WOOD WORKING SHOP	B	SIG1

END OF LINE RESISTORS

	SIGNAL CCT# 1	EOL	SIG1
	ZONE 1	EOL	1
	ZONE 2	EOL	2
	ZONE 3	EOL	3
	ZONE 4	EOL	4
	ZONE 5	EOL	5
	ZONE 6	EOL	6
	ZONE 7	EOL	7
	ZONE 8	EOL	8

Fire Door Number or Location
1ST FLOOR BY ROOM 106
2ND FLOOR BY ROOM 207

EMERGENCY LIGHTING			
Line #	EL UNIT Location	Remote Head	MODEL
1	1st FLOOR JANITOR ROOM	Y	
2	BY OFFICE		EMERGI-LITE
3	BOTTOM CENTER STAIRS		EMERGI-LITE
4	MAIN ENTRY		BATT. PACK
5	GYM	Y	
6	GYM	Y	
7	1st FLOOR WEST END STORAGE	Y	
8	WEST END HALL	Y	
9	WEST STAIRS	Y	
10	2nd FLOOR BY WEST STAIRS	Y	
11	AV ROOM		EMERGI-LITE
12	ELECTRICAL ROOM		BATT. PACK
13	EAST EXIT	Y	
14	EAST STAIRS	Y	
15	2nd FLOOR BY EAST STAIRS	Y	
16	TOP CENTER STAIRS		BATT. PACK
17	CENTER STAIRS	Y	
18	BY CENTER STAIRS 2nd FLOOR	Y	AIMLITE
19	BOILER ROOM		EMERGI-LITE
20	IN KITCHEN		EMERGI-LITE
21	CAFETERIA NORTH ADJ 102		EMERGI-LITE
22	HALL BY GYM		EMERGI-LITE
23	GYM EXIT		EMERGI-LITE

24	GYM ENTRY ON OUTSIDE WALL		EMERGI-LITE
25	GYM		EMERGI-LITE
26	CAFETERIA SOUTH		EMERGI-LITE
27	STORAGE ADJ 101		BATT. PACK
28	ADJ 204		UNIT

NOTES:

EMERGENCY LIGHTING

NOTE: #1 PNL AA CCT.16, 24

#2 PNL A CCT 4, 24, 33

#3 PNL P CCT. 28

	LOCATION: Prospect Rd. Ele.	Device	Device address or circuit number
--	------------------------------------	---------------	---

	FIRE ALARM PANEL: Edwards FS 100		
--	---	--	--

1	MAIN ENTRANCE - A	M	ZONE 1
2	EXIT BY ROOM108 - B	M	ZONE 1
3	MID HALL BY GYM ENTRANCE - C	M	ZONE 1
4	BACK HALL EXIT - D	M	ZONE 1
5	BOILER ROOM EXIT - E	M	ZONE 1
6	GYM BACK EXIT - F	M	ZONE 1
7	EXIT BY ROOM 122 - G	M	ZONE 1
1	ELECTRICAL ROOM	RHT	ZONE 2
1	MAIN SYSTEM PRESSURE	FSP	ZONE 3
2	MAIN SPRINKLER CONTROL VALVE	TS	ZONE 6
3	SYSTEM #1 CONTROL VALVE	TS	ZONE 6
4	SYSTEM #2 CONTROL VALVE	TS	ZONE 6
5	TANK #1 LOW WATER		7
6	TANK #2 LOW WATER		5
7	SPRINKLER LOW AIR		4

NOTIFYING APPLIANCES

1	BY ROOM 120	B	SIG 1
2	BY ROOM 125	B	SIG 1
3	GYM ENTRANCE	B	SIG 1
4	GYM	B	SIG 1
5	BY ROOM 106	B	SIG 1
6	MAIN ENTRANCE	B	SIG 1
7	OUTSIDE BOYS WASHROOM	B	SIG 1

EMERGENCY LIGHTING						
Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH	MOD #	Manuf.
1	WEST WING BY ROOM 103		Y			
2	WEST WING BY ROOM 106		Y			
3	EAST WING BY LIBRARY		Y			
4	HALL BY OFFICE		Y	6V 7.2A	RG72QB	Lumacell
5	GYM ENTRANCE		Y			
6	GYM BACK EXIT		Y			
7	STAIRS BY GYM		Y			
8	EAST WING BY BOILER ROOM		Y			
9	EAST WING BY MUSIC ROOM	Y	Y			
10	*EAST WING HALL		Y			
11	BOILER ROOM		Y			
12	RAMP BY BOILER ROOM		Y			
13	*ELECTRICAL ROOM	Y	Y			
14	BOYS CHANGE ROOM		Y	6V 7.2A	RG72QB	Lumacell
15	GIRL CHANGE ROOM		Y	6V 7.2A	RG72QB	Lumacell
16	BOILER RM.	Y				

BREAKERS FOR LIGHTING

GYM STAGE PANEL
PANEL IN ROOM 110

	LOCATION:Terence Bay	Device	Device address or circuit	NOTES
	FIRE ALARM PANEL:Fireshield FS 302			
MANUAL PULL STATIONS				
1	BY LIBRARY	M	ZN 1	
2	BY MAIN ENTRANCE	M	ZN 1	
3	GYM	M	ZN 1	
4	LEFT EXIT	M	ZN 1	
5	BY TEACHER'S WORK ROOM	M	ZN 1	
6	BOILER ROOM	M	ZN 1	
7	C@P ROOM EXIT	M	ZN 1	
HEAT DETECTORS				
1	JANITOR'S ROOM	HT	ZN 1	
2	CLOSET ADJ ROOM 3	RHT	ZN 1	CR135
3	CLOSET ADJ ROOM 4	RHT	ZN 1	CR135
4	TEACHER'S WORK ROOM	RHT	ZN 1	CR135
5	BOILER ROOM	HT	ZN 1	CR200
NOTIFYING DEVICES				
1	BY LIBRARY	K	SIG 1	
2	BY MAIN ENTRANCE	K	SIG 1	
3	BY TEACHER'S WORK ROOM	K	SIG 1	
4	GYM	K	SIG 1	
5	LEFT EXIT	K	SIG 1	
6	BOILER ROOM	K	SIG 1	

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Notes
	BY TEACHERS WORK ROOM		AIMLITE	
	RESOUCE OPP CENTRE EXIT		LUMACELL	COMBO UNIT. REPLACED 6V 7AH BATTERY
	BY ROOM 03			
	MAIN ENTRANCE		AIMLITE	
	GYM ABOVE HALLWAY		EMERGILITE	
	GYM WEST EXIT		AIMLITE	COMBO UNIT. REPLACED 6V 7AH BATTERY
	GYM EAST EXIT		AIMLITE	COMBO UNIT

	OTHER EXIT		EMERIGLIT E	
	BY ROOM 07			
	EXIT NEAR WASHROOM		EXIT	WORK ON AC ONLY
	EXIT BY ROOM 9		EXIT	WORK ON AC ONLY
	EXIT BY ROOM 8		EXIT	WORK ON AC ONLY
	EXIT BY GIRLS BATHROOM		EXIT	WORK ON AC ONLY
	EXIT BY MUSIC ROOM		EXIT	WORK ON AC ONLY
	EXIT OFF READING CENTER		EXIT	WORK ON AC ONLY

	LOCATION: Central Spryfield	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards EST 3X		
1	Devices		

WEST STAIRWELL	EOL	1
WEST ENTRANCE	EOL	2
FLOW ALARM WET	FSP	5
FLOW ALARM DRY	FSP	6
SPRINKLER ROOM	EOL	3
BY ROOM 126 (GYM ENTRANCE)	M	3
GYM	M	3
GYM	M	3
BY MAIN OFFICE 105	M	3
BY ROOM 126 (GYM ENTRANCE)	EOL	5
BY ROOM 209	EOL	6
AIR HANDLING ROOM 202	DS	9
JANITOR ROOM 212	EOL	7
SPRINKLER LOW PRESSURE	PS	11
BY MAIN OFFICE	B	
BY ROOM 100A	B	
GYM	B	
GYM	B	
GIRLS LOCKER ROOM	B	
BOYS LOCKER ROOM	B	
BY ROOM 113	B	
BY ROOM 200	B	
BY ROOM 205	B	
BY ROOM 209	B	

BY ROOM 200	B	
2ND FLOOR BOYS WASHROOM	B	
2ND FLOOR GIRLS WASHROOM	B	
BY ROOM 209	EOL	
AHU SHUTDOWN	R	
DOOR RELEASE	R	
BOILER ROOM	B	8
BOILER ROOM	M	1
BY ROOM 218	M	4
BY ROOM 200D	M	2
STAIRWELL BY 100C	M	1
EXIT BY FURNACE RM	M	1
TOP STAIR #3	S	7
TOP STAIR #4	S	8
BY MAIN ELEC. RM	S	1
IN MAIN ELEC. RM	S	1
IN RM 100D	S	1
JANITOR RM BY 100B	HT	
IN RM 103	M	3
TOP OF STAIR 2	S	10

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	C
	BOILER ROOM		REMOTE	
	EAST STAIRWELL	2	REMOTE	
	BY ROOM 200A	2	REMOTE	
	BY ROOM 200E	2	REMOTE	
	STAIRWELL BY 200A	2	REMOTE	
	JANITOR ROOM 212 BATTERY PACK		UNIT/REMOTE	
	ROOM 212		REMOTE	
	BY ROOM 215		REMOTE	
	NORTH STAIRWELL		REMOTE	

	BY ROOM 218		
	BOYS WASHROOM 214		UNIT/REMOTE
	GIRLS WASHROOM 215		UNIT/REMOTE
	BY ART ROOM 113		REMOTE
	MECH ROOM 202 BATTERY PACK		REMOTE
	CARETAKERS OFFICE BY BOILER ROOM		REMOTE
	FURNACE ROOM		REMOTE
	BY ROOM 202		REMOTE
	IN ROOM 202		REMOTE
	ACROSS FROM LIBRARY		REMOTE
	GYM STORAGE BATTERY PACK		
	GYM		REMOTE
	GYM		REMOTE
	GYM		REMOTE
	GYM		REMOTE
	OUTSIDE GYM ENTRANCE		REMOTE
	GYM LEFT		COMBO
	GYM RIGHT		COMBO
	GYM ENTRANCE		COMBO
	STAIRWELL BY 200D		
	BOYS LOCKER ROOM		UNIT
	GIRLS LOCKER ROOM		UNIT
	SPRINKLER ROOM		UNIT/REMOTE
	MAIN ELEC. ROOM		EXIT COMBO
	ROOM 103		EXIT COMBO

EMERGENCY LIGHTS

Unit	Location	# of	Model	to
------	----------	------	-------	----

#	Location	# of Heads	Notes
	BOILER ROOM		REMOTE
	EAST STAIRWELL	2	REMOTE
	BY ROOM 200A	2	REMOTE
	BY ROOM 200E	2	REMOTE
	STAIRWELL BY 200A	2	REMOTE
	JANITOR ROOM 212 BATTERY PACK		UNIT/REMOTE
	ROOM 212		REMOTE
	BY ROOM 215		REMOTE
	NORTH STAIRWELL BY ROOM 218		REMOTE
	BOYS WASHROOM 214		UNIT/REMOTE
	GIRLS WASHROOM 215		UNIT/REMOTE
	BY ART ROOM 113		REMOTE
	MECH ROOM 202 BATTERY PACK		REMOTE
	CARETAKERS OFFICE BY BOILER ROOM		REMOTE
	FURNACE ROOM		REMOTE
	BY ROOM 202		REMOTE
	IN ROOM 202		REMOTE
	ACROSS FROM LIBRARY		REMOTE
	GYM STORAGE BATTERY PACK		
	GYM		REMOTE
	GYM		REMOTE
	GYM		REMOTE
	GYM		REMOTE
	OUTSIDE GYM ENTRANCE		REMOTE
	GYM LEFT		COMBO
	GYM RIGHT		COMBO

	GYM ENTRANCE		COMBO
	STAIRWELL BY 200D		
	BOYS LOCKER ROOM		UNIT
	GIRLS LOCKER ROOM		UNIT
	SPRINKLER ROOM		UNIT/REMOTE
	MAIN ELEC. ROOM		EXIT COMBO
	ROOM 103		EXIT COMBO

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1	There are only two breakers for emergency lights. One is in the Boiler room and One is in the Mechanical room # 202			
	The rest of the lights are on the Three Battery Packs or stand alone			

LOCATION: Chebucto Heights	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards 6500		

DEVICES

BY ROOM # 213	M	ZONE # 1
BY ROOM # 216	M	ZONE # 1
BY ROOM # 225	M	ZONE # 1
MAIN ENTRANCE	M	ZONE # 2
NORTH ENTRANCE	M	ZONE # 2
SOUTHWEST ENTRANCE	M	ZONE # 2
BY ROOM # 126	M	ZONE # 2
BY STAIRS # 2	M	ZONE # 2
ENTRANCE BY GYM	M	ZONE # 3
GYM	M	ZONE # 3
GYM	M	ZONE # 3
GYM	M	ZONE # 3
COURTYARD EXIT BY DR 163 STORAGE	M	ZONE # 3
BOILER ROOM	M	ZONE # 4
BY ELECTRICAL ROOM	M	ZONE # 4
ELECTRICAL ROOM/SWITCH RM	HT	ZONE # 4

BASEMENT AHU	DS	ZONE # 9
GYM AHU	DS	ZONE#1 0
1ST FLOOR BY STAIR #2	PS	ZONE # 5
2ND FLOOR BY STAIR #2	PS	ZONE # 6
SPRINKLER ROOM	PS	ZONE # 7
SPRINKLER ROOM	PS	ZONE # 8

GYM	B	SIG # 1
BY BOYS LOCKER ROOM	B	SIG # 1
LIBRARY HALL	B	SIG # 1
BY ELECTRICAL ROOM	B	SIG # 1
MAIN ENTRANCE	B	SIG # 1
BY ROOM # 116	B	SIG # 1
BY ROOM # 126	B	SIG # 1
BY ROOM # 136	B	SIG # 1
BY ROOM # 207	B	SIG # 1
BY ROOM # 225	B	SIG # 1
RELAYS		
AHU SHUT DOWN	R	
DOOR RELEASE	R	
ANN.PNL		Main Ent.

Fire Door Number or Location

BOTTOM STAIR 1
TOP STAIR 1
BOTTOM STAIR 2 BY BOYS WASHROOM
BOTTOM STAIR 2 BY EXIT
TOP STAIR 2 BY STAIRS
TOP STAIR 2 BY BOYS WASHROOM
BOTTOM STAIR 3
TOP STAIR 3

EMERGENCY LIGHTING				
EL UNIT Location	Remote	Cab.	MOD #	Manuf.
Breaker is in room 113, panel C1, CCT#11				
Storage Room 113		Y	6 JML 36	Emergi-Lite

**Across from Room 105	Y			
**By Room 116	Y			
MAIN ENTRY BY 112		Y		
Plumbing Closet Battery Pak		Y	CDL-36	Dual-Lite
**Gym Hall	Y			
**Gym Hall	Y			
BREAKER IN ROOM 130, PANEL"B", CCT# 6				
GYM WASHROOM ,GIRLS		Y		
GYM WASHROOM ,BOYS		Y		
Storage Room 226		Y	SLB/108	Dual-Lite
**Top Stairs 1	Y			REMOTE
**By Room 225	Y			
BREAKER IN JANITOR CLOSET BETWEEN RMS 152 & 158, CCT #14				
Gym Back Hall		Y	6 ESL 72 P1	Emergi-Lite
**Gym Back Hall	Y			
**Gym Rear Exit Door 160	Y			
Gym Hall Back		Y	ESX6-36-LRU	Luxnet
Gym Hall Back		Y	ESX6-36-LRU	Luxnet
Gym Hall By Entry		combo	ESX6-36-LRU	Luxnet
Gym BACK DOOR LEFT	Y		ESX6-36-LRU	Luxnet
Gym		combo	ESX6-36-LRU	Luxnet
Gym		combo	ESX6-36-LRU	Luxnet
Gym		combo	ESX6-36-LRU	Luxnet
BREAKER IN ROOM 210, PANEL"F", CCT #13				
Storage Room 210		Y	SLB/108	Dual-Lite
**By Room 210	Y			
**By Room 210	Y			
**Top Stairs 3	Y			
BREAKER IN ROOM 210, PANEL"F", CCT #7				
Art Room 216		Y	SLB/108	Dual-Lite
**Hallway By 216	Y			
**Top Stairs 2	Y			
Stairs 2 North Exit		Y	PXE36	Emergi-Lite
BREAKER IN ROOM 226, PANEL"D", CCT #27				
Storage Room 130		Y	SLB/108	Dual-Lite
**Bottom Stairs 1	Y			
**By Room 126	Y			
BREAKER IS IN MECHANICAL ROOM ,PANEL"A", CCT#42				
Electrical Room		Y		LITHONIA
Mechanical room By Electric rm		Y		
BREAKER IS IN MECHANICAL ROOM ,PANEL"A", CCT#7				
Mechanical room by storage		Y		

BREAKER IS IN MECHANICAL ROOM ,PANEL"A", CCT#3				
Sprinkler Room By Entry		Y		
Sprinkler Room By Exit		Y		
BREAKER IS IN ROOM 113, PANEL"C1", CCT#5				
Main Entry		Y		
BREAKER IS IN ROOM 113, PANEL"C", CCT#17				
Main Office		Y		
BREAKER IS IN ROOM 113, PANEL"C1", CCT#13				
AV Room 112 by rm 112		Y		
AV Room entry by main corridor		Y		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1 BREAKER FOR EMERGENCY LIGHTS NEAR OFFICE

	LOCATION: Cunard	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
1	Devices		
2	STAIRWAY 2ND FLOOR EAST BY 207	M	1
3	STAIRWAY 2ND FLOOR WEST	M	1
4	LIBRARY	M	1
5	ELEVATOR LOBBY 1ST FL	S	1
7	GYM BY STAGE	M	2
8	GYM	M	2
9	GYM	M	2
10	GYM	EOL	2
12	WOODSHOP	M	3
13	WOODSHOP	EOL	3
15	SCIENCE ROOM	M	4
16	SCIENCE ROOM	EOL	4
18	BY SCIENCE ROOM	M	5
19	BY FACP	M	5
20	BY MAIN ENTRANCE	M	5
21	BY ROOM 104	M	1
22	ELEVATOR LOBBY 2ND FL	S	5
24	BOILER ROOM	M	7
25	BOILER ROOM	EOL	7
30	ELEVATOR MACHINE ROOM (OUTDOORS)	M	9
31	ELEVATOR MACHINE ROOM (OUTDOORS)	S	9
32	ELEVATOR MACHINE ROOM (OUTDOORS)	EOL	9
34	BY SCIENCE ROOM	B	SIG 1
35	WOODSHOP	B	SIG 1
36	GYM	B	SIG 1
37	GYM EXIT TO HALLWAY	B	SIG 1
38	BOILER ROOM	B	SIG 1
39	BY MAIN ENTRANCE	B	SIG 1
40	BY ROOM 102	B	SIG 1

41	BY ROOM 104	B	SIG 1
42	STAIRWAY 2ND FLOOR EAST	B	SIG 1
43	STAIRWAY 2ND FLOOR WEST	B	SIG 1
44	BY ROOM 208	B	SIG 1
45	BY ROOM 212	B	SIG 1
46	LIBRARY	B	SIG 1
47	OUTSIDE FRONT ENTRANCE	B	SIG 1
48	ELEVATOR MACHINE ROOM	B	SIG 1

EMERGENCY LIGHTING

Location	# of Heads	Model
ACROSS FROM CANTEEN PNL C CCT 29	2	LITHONITE
BY LIBRARY PNL C CCT 29	2	LUMACELL
BY RM 203 PNL C CCT 29	2	LITHONITE
BY RM 207 PNL C CCT 29	2	EMERGILITE
WEST STAIRWELL	2	EMERGILITE
BY RM 105 PNL AA CCT 7	2	LITHONITE
BY RM 102 PNL AA CCT 7	2	LITHONITE
MAIN ENTR PNL AA CCT 7	2	EMERGILITE
WOODSHOP HALLWAY PNL AA CCT 7	2	LUMACELL COMBO
OFFICE		LITHONITE
GIRLS LOCKERS	2	LUMACELL
BOYS LOCKERS	2	LUMACELL
GYM PNL C CCT 16 OUTSIDE EXIT	2	EXIT COMBO
GYM PNL C CCT 16	2	EXIT

OUTSIDE EXIT		COMBO
GYM PNL C CCT 16 EXIT BY OFFICE	2	EXIT COMBO
GYM DOOR TO HALL PNL C CCT 16 BY RM 111	2	EXIT COMBO
EAST STAIRWELL	2	EMERGILIT E
AREA OF REFUGE 2ND FL PNL CCT 29	2	EMERGILIT E
AREA OF REFUGS 1ST FL PNL AA CCT 7	2	EMERGILIT E
ELEV MACH RM		

TECH NOTE:

1. FUSE FOR PANEL IN BOILER ROOM.
2. THERE IS A SET UP IN THE PANEL FOR ELEVATOR CONTROL. ANY ALARM BRINGS ELEVATOR TO GROUND FLOOR. SMOKE DETECTOR ACTIVATION ON FLOOR BY ELEVATOR SENDS ELEVATOR TO SECOND FLOOR. SMOKE DETECTOR ACTIVATION ON 2ND FLOOR SENDS ELEVATOR TO 1ST FLOOR. YOU HAVE TO RESET PANEL AND THEN RESET ELEVATOR WITH FIREMAN'S KEY.

	LOCATION: Elizabeth Sutherland	Device	Device address or circuit number
	FIRE ALARM PANEL: Ewards 6500		
MANUAL PULL STATIONS			
1	BY ROOM #1	M	Zone #1
2	BY ROOM #7	M	Zone #1
3	BY ROOM #8	M	Zone #1
5	BY PANEL	M	Zone #1
6	BY STORAGE ROOM	M	Zone #1
7	BY ART ROOM	M	Zone #2
8	BY SCIENCE ROOM	M	Zone #2
9	BY ROOM 20	M	Zone #2
10	GYM	M	Zone #2
11	MAIN ENTRANCE	M	Zone #2
12	FOODLAB	M	Zone #2
13	BOILER ROOM	M	Zone #3
DUCT SMOKE DETECTORS			
1	BY ROOM #3 CEILING	DS	Zone #1
HEAT DETECTORS			
1	ELECTRICAL ROOM	HT	Zone #1
2	BY ROOM #14 STORAGE	HT	Zone #1
NOTIFYING DEVICES			
1	BY ROOM #4	B	Sig #2
2	BY ROOM #11	B	Sig #2
3	NEAR FACP	B	Sig #2
4	BY STAFF ROOM	B	Sig #2
5	BY ROOM #15	B	Sig #2
6	BY ROOM 20	B	Sig #2
7	GYM	B	Sig #2
8	BY LIBRARY	B	Sig #2
9	BOYS LOCKER ROOM	B	Sig #2
10	GIRLS LOCKER ROOM	B	Sig #2
11	BY ROOM #16	B	Sig #2
12	MAIN ENTRANCE	B	Sig #2
13	MUSIC ROOM	B	Sig #2
14	BOILER ROOM	B	Sig #2
15	BY STORAGE ROOM	B	Sig #2

END OF LINE RESISTORS			
	SPRINKLER ROOM	EOL	Zone #4
	BY ROOM #7	EOL	Zone #1
	BY SCIENCE ROOM	EOL	Zone #2
	BOILER ROOM	EOL	Zone #3
EMERGENCY LIGHTING			
Line #	EL UNIT Location	MOD #	Manuf.
1	Administration Office	M636 120 CS	Lithonia
2	Outside of Office	M636 120 CS	Lithonia
3	Janitor Room Battery Pak		Lumacell
4	**Outside of Gym	REMOTE	REMOTE
5	**Gym	REMOTE	REMOTE
6	**Gym	REMOTE	REMOTE
7	**Gym	REMOTE	REMOTE
8	**Gym	REMOTE	REMOTE
9	**Back of Stage	REMOTE	REMOTE
10	**Hallway by Janitor's Room	REMOTE	REMOTE
11	By Library	HX5W3R120	Lithonia
12	By Room #15	M636120CS	Lithonia
13	By Science Room	HX5W3R120	Lithonia
14	By Room #17	M636120CS	Lithonia
15	By Room #19	06JML36/2M	Emergi-Lite
16	By Room #21	RG36	Lithonia
17	Boys Locker Room	06JML36/2M	Emergi-Lite
18	Girls Locker Room	06JML36/2M	Emergi-Lite
19	By Janitor's Office	M636120CS	Lithonia
20	By FACP	HX5W3R120	Lithonia
21	In Caretaker Office	RG36	Lumacell
22	**Boiler Room	REMOTE	REMOTE
23	**Electrical Room	REMOTE	REMOTE
24	Boiler Room	HX5W3R120	Lithonia
25	Electrical Room	M636120CS	Lithonia
26	By Art Room	HX5W3R120	Lithonia
27	By Storage Room	HX5W3R120	Lithonia
28	By Room #1	HX5W3R120	Lithonia
29	By Room #4	HX5W3R120	Lithonia
30	By Room #7	HX5W3R120	Lithonia
31	Common area		
32	food lab		
33	By room 16		
34	By Room #9	HX5W3R120	Lithonia

35	Room #20-30	UNIT	
36	Girls Washroom	UNIT	
37	Boys Washroom	UNIT	

Fire Door Number or Location
BY LIBRARY
BY GUIDANCE OFFICE

	LOCATION: Harrietsfield Ele.	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards 6500			
MANUAL PULL STATIONS			
1	FRONT ENTRANCE	M	ZONE #1
2	WEST END 1ST FLOOR BY OFFIC	M	ZONE #1
3	1ST FLOOR EAST	M	ZONE #1
4	GYM	M	ZONE #1
5	GYM	M	ZONE #1
6	FURNACE ROOM	M	ZONE #2
7	2ND FLOOR WEST	M	ZONE #2
8	2ND FLOOR EAST	M	ZONE #2
9	CENTER HALL 2ND FLOOR	M	ZONE #2
SMOKE DETECTORS			
1	EAST STAIRS	S	ZONE #2
2	WEST STAIRS	S	ZONE #2
DUCT SMOKE DETECTORS			
1	BOILER ROOM	DS	ZONE #4
2	BOILER ROOM	DS	ZONE #4
HEAT DETECTORS			
1	ELECTRICAL ROOM	RHT	ZONE #1
2	STORAGE ROOM #4	RHT	ZONE #2
3	BOILER ROOM	HT	ZONE #7
NOTIFYING DEVICES			
1	FURNACE ROOM	B	SIG #1
2	FRONT ENTRANCE	B	SIG #1
3	1ST FLOOR HALL	B	SIG #1
4	GYM	B	SIG #1
5	2ND FLOOR HALL	B	SIG #1
6	2ND FLOOR HALL	B	SIG #1
7	2ND FLOOR HALL	B	SIG #1
8	1ST FLOOR HALL	B	SIG #1
END OF LINE RESISTORS			
1	1ST FLOOR WEST	EOL	ZONE #1
2	2ND FLOOR WEST	EOL	ZONE #2
3	BOILER ROOM	EOL	ZONE #3
4	BOILER ROOM	EOL	ZONE #4

5	BOILER ROOM	EOL	ZONE #5
6	BOILER ROOM	EOL	ZONE #6
7	BOILER ROOM	EOL	ZONE #7

RELAYS

	AHU SHUT DOWN	R	
	DOOR HOLDERS	R	
	LOW AIR	SUP	6
	SPRINKLER	GU	3

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
1	Front Entrance(#1)		Y
2	**Front Entrance(#1)	Y	
3	Centre Hall 1ST FLOOR(#2)		Y
4	Gym, FRONT(#12)		Y
5	Gym, REAR(#13)		Y
6	East Hall 1ST FLOOR(#3)		Y
7	**East Hall 1ST FLOOR(#3)	Y	
8	East Stairs(#4)		Y
9	**East Stairs 2nd Floor(#4)	Y	
10	**East Stairs 1st Floor(#4)	Y	
11	East Hall 2nd Floor(#5)		Y
12	**East Hall 2nd Floor(#5)	Y	
13	Centre Hall 2nd Floor(#6)		Y
14	West Hall 2nd Floor(#7)		Y
15	**West Hall 2nd Floor(#7)	Y	
16	Boys Washroom 2nd Floor(#8)		Y
17	**Girls Washroom 2nd Floor(#8)	Y	
18	West Stairs(#9)		Y
19	**West Stairs 2nd Floor(#9)	Y	
20	**West Stairs 1st Floor(#9)	Y	
21	Boys Washroom 1st Floor(#10)		Y
22	**Girls Washroom 1st Floor(#10)	Y	
23	Boiler Room(#11)		Y
24	Main Doors		EXIT
25	By 206	Y	
26	In Office	Y	

Fire Door Number or Location
TOP OF WEST STAIRS
BOTTOM OF WEST STAIRS
TOP OF EAST STAIRS
BOTTOM OF EAST STAIRS

	LOCATION: Herring Cove Jr.	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards EST 3		

MANUAL PULL STATIONS

SMOKE DETECTORS

1	HALL 1ST FLOOR ACROSS FROM 101	M	Zone 1
2	HALL 1ST FLOOR	M	Zone 1
3	ART ROOM	M	Zone 1
4	HALL 2ND FLOOR	M	Zone 2
5	MAIN ENTRANCE	M	Zone 2
6	GYM EXIT	M	Zone 2
7	HALL 3RD FLOOR	M	Zone 3
8	HALL 3RD FLOOR BY ROOM 313	M	Zone 3
1	REAR STAIRWELL	S	Zone 9
2	SUPPLY STORAGE BY PRICIPAL OFFICE	S	ZONE 2
3	PAPER STORAGE BY PRINCIPAL STORAGE	S	ZONE 2
4	ELEVATOR MACHINE ROOM 108	S	ZONE 14
5	FRONT STAIRWELL	S	Zone 10

DUCT SMOKE DETECTORS

1	FAN ROOM 3RD FLOOR	DS	Zone #5
2	GYM STORAGE	DS	Zone #6

HEAT DETECTORS

1	JANITOR ROOM 131	RHT	ZONE 1
2	AV CLOSET ROOM 113	RHT	ZONE 1
3	AV SUPPLY ROOM	RHT	ZONE 1
4	STORAGE ACROSS ROOM 114	RHT	ZONE 1

5	CHEMISTRY STORAGE ROOM 119	RHT	ZONE 1
6	ART STORAGE ROOM	RHT	ZONE 1
7	WOOD VENT ROOM 121	RHT	ZONE 1
8	THEATER STORAGE ROOM 118	RHT	ZONE 1
9	SCIENCE STORAGE ROOM 120	RHT	ZONE 1
10	JANITOR OFFICE ROOM 110	RHT	ZONE 1
11	STORAGE ROOM 232	RHT	ZONE 2
12	UNDER STAGE	RHT	ZONE 2
13	JANITOR ROOM 224	RHT	ZONE 2
14	ROOM 235	RHT	ZONE 2
15	ELECTRICAL/STORAGE ROOM 228	RHT	ZONE 2
16	STORAGE ROOM 324	RHT	Zone 3
17	STORAGE ROOM 321	RHT	Zone 3
18	BOILER ROOM	HT	Zone #7

NOTIFYING DEVICES

1	HALL 1ST FLOOR	B	Sig #1
2	HALL 1ST FLOOR	B	Sig #1
3	HALL 2ND FLOOR	B	Sig #1
4	HALL 2ND FLOOR	B	Sig #1
5	HALL 3RD FLOOR	B	Sig #1
6	HALL 3RD FLOOR	B	Sig #1
7	WOOD SHOP	B	Sig #1
8	METAL SHOP	B	Sig #1
9	CAFETERIA	B	Sig #1
10	HOME EC	B	Sig #1
11	GYM	B	Sig #1

END OF LINE RESISTORS

1	WOODSHOP	EOL	Zone #1
2	GYM EXIT	EOL	Zone #2

3	WOOD STORAGE	EOL	Zone #4
4	FAN ROOM 3RD FLOOR	EOL	Zone #5
5	GYM STORAGE	EOL	Zone #6
6	BOILER ROOM	EOL	Zone #7
7	SUPPLY ROOM 108	EOL	Zone #8
8	REAR STAIRWELL	EOL	Zone #9
9	FRONT STAIRWELL	EOL	Zone #10

ELECTRICAL ROOM	S	13
ELEVATOR SHAFT.	S	15
NEW ELECT RM	B	
AHU SHUTDOWN	RLY	
KITCHEN HOOD	FS	11
PRINCIPAL STORAGE	S	2
OUTSIDE ELEC ROOM	M	

EMERGENCY LIGHTING

Location	# of Heads	Model
1ST FL FRONT STAIRS		EMERGI-LITE
1ST FL HALL BY 131		EMERGI-LITE
RM 118		LUMACELL
BY COOKING RM 114		EMERGI-LITE
RM 118		EMERGI-LITE
RM 122		EMERGI-LITE
AV RM		LUMACELL
BOILER RM		EMERGI-LITE
1ST FL ADJ 101		COMBO UNIT

ELEV LOBBY 1ST FLOOR		UNITS
2ND FL		
2ND FL FRONT STAIRS		EMERGI-LITE
BY CAFETERIA IN GYM		EMERGI-LITE
2ND FL HALL BY 232		EMERGI-LITE
2ND FL REAR STAIRS		EMERGI-LITE
GYM SIDE EXIT		EMERGI-LITE
GYM STAGE HALL BATTERY PAK		EMERGI-LITE
2ND FL ADJ KITCHEN		UNIT
CAFETERIA TO GYM		UNIT
3RD FL		
3RD FL FRONT STAIRS		EMERGI-LITE
3RD FL REAR STAIRS		AIM-LITE
3RD FL HALL BY 324		EMERGI-LITE
NEW ELECT RM		UNIT

	LOCATION: J.L. ILsley	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards EST 2			
MANUAL PULL STATIONS			
1	STAGE HALL EXIT	MA	D-0220
2	CAFETERIA HALL	MA	D-0221
3	MAIN ENTRANCE	MA	D-0214
4	BOILER ROOM EXIT	MA	D-0204
5	BY ROOM 100	MA	D-0215
6	BY ROOM 153	MA	D-0203
7	BY ROOM 116	MA	D-0222
8	EXIT NEAREST TO RM 128 (IND ARTS)	MA	D-0224
9	BY ROOM 137	MA	D-0223
10	QUAD EXIT	MA	D-0206
11	CAFETERIA	MA	D-0216
12	BY GYM OFFICE RM 117	MA	D-0217
13	GYM HALL ENTRANCE	MA	D-0218
14	BY ROOM 200	MA	D-0212
15	BY ROOM 211	MA	D-0210
16	BY ROOM 216	MA	D-0209
17	BY ROOM 217	MA	D-0211
18	BY ROOM 233	MA	D-0207
19	BY ROOM 236	MA	D-0208
20	GYM BY PARKING EXIT	MA	D-0219
21	BY ROOM 300	MA	D-0213
22	BY ROOM 309	MA	D-0225
23	BY ROOM 316	MA	D-0226
24	BY ROOM 319	MA	D-0227
25	BY ROOM 330	MA	D-0231
SMOKE DETECTORS			
1	TOP STAIRS ROOM 319	SA	D-0103
2	TOP STAIRS ROOM 330	SA	D-0104
3	TOP MAIN STAIRS	SA	D-0105
4	TOP STAIRS ROOM 300	SA	D-0106
5	LIBRARY STAIRS 217	SA	D-0107
6	ELEVATOR MACHINE ROOM 1st Floor	SA	D-0108
7	ELEVATOR SHAFT	SA	D-0109
8	2ND FLOOR ELEVATOR LOBBY	SA	D-0110

9	3RD FLOOR ELEVATOR LOBBY	SA	D-0111
HEAT DETECTORS			
1	ELECTRICAL VAULT	RHTA	D-0100
2	PENTHOUSE 1 access through room 327	RHTA	D-0101
3	PENTHOUSE 2 access through room 327	RHTA	D-0102
4	ELECTRICAL ROOM	HTA	D-0230
SPRINKLER DEVICES			
1	SPRINKLER, MAIN GATE	SV	D-0232
2	SPRINKLER, RISER 1 COMM. WING	SV	D-0232
3	SPRINKLER, RISER 3 ACADEMIC	SV	D-0232
4	SPRINKLER, GYM ZONE 2	SV	D-0232
5	SPRINKLER, GYM ZONE 2	FSV	D-0233
6	SPRINKLER, COMM. WING ZONE 1	FSV	D-0234
7	SPRINKLER, ACADEMIC ZONE 3	FSV	D-0235
8	SPRINKLER, FLOW	FSP	D-0236
9	ELEVATOR MACHINE RM SPRINKLER VAL	SV	D-0238
10	ELEVATOR PIT SPRINKLER VALVE	SV	D-0239
11	ELEVATOR 3RD FLOOR	SV	D-0242
DUCT SMOKE DETECTORS			
1	PENTHOUSE 1	DS	
2	PENTHOUSE 2	DS	
3	NURSE ROOM	DS	
4	AV ROOM	DS	
5	AV ROOM	DS	
NOTIFYING DEVICES			
1	INDUSTRIAL ARTS 130	B	SIG 1
2	ROOM 151 WOODSHOP	B	SIG 1
3	BACK CAFETERIA HALL	B	SIG 1
4	CAFETERIA	B	SIG 1
5	MAIN ENTRANCE	B	SIG 1
6	BY ROOM 117	B	SIG 1
7	GYM	B	SIG 1
8	STAGE	B	SIG 1
9	BY BOILER ROOM ENTRANCE	B	SIG 1
10	BOILER ROOM	B	SIG 1
11	BY ROOM 141	B	SIG 1
12	BY ROOM 118	B	SIG 1
13	BY OFFICE	B	SIG 1
14	BY ROOM 104	B	SIG 1
15	WOODWORKING 145	B	SIG 1
16	BY ROOM 204	B	SIG 1
17	BY ROOM 211	B	SIG 1
18	BY ROOM 219	B	SIG 1

19	LIBRARY 219	B	SIG 1
20	BY ROOM 231	B	SIG 1
21	BY ROOM 237A	B	SIG 1
22	BY ROOM 241	B	SIG 1
23	BY ROOM 329	B	SIG 1
24	BY ROOM 323	B	SIG 1
25	BY ROOM 315	B	SIG 1
26	BY ROOM 309	B	SIG 1
27	BY ROOM 304	B	SIG 1

TECH NOTES:

1. PNL G #29 RM 127
2. PNLN CCT #8, KITCHEN CCT #9
3. PNL 2 GYM CCT #33, 35
4. PNL A CCT #22, CCT #21
5. PNL AA CCT #8 SPRK RM
6. SPRK RM PNL M CCT #13, CCT #35
7. DD CCT #36 BOILER RM
8. PNL E CCT #6 ADJ RM 237, PNL F CCT #35
9. PNL R CCT #19, CCT #21
10. PNL BB CCT #8

EMERGENCY LIGHTING			
Line #	EL UNIT Location	Remote Head	Cab. Head
1	Office		Y
2	By Office		Y
3	By Sprinkler Room		COMBO
4	In Room 105		Y
5	By Room 106		Y
6	By Room 101		COMBO
7	By Room 116 Double Doors		Y
8	By Elevator		Y
9	By Room 141		Y
10	By Room 141 Double Doors		Y
11	By Room 145		Y
12	By Room 151		Y
13	By Room 153		Y
14	By Room 128 Exit		COMBO
15	Boiler Room		Y
16	Boiler Room Exit		Y

17	Main Lobby		Y
18	Gym Hall from Lobby		Y
19	Exit by Gym Office		Y
20	Gym Hall Exit		Y
21	Gym Exit by Electrical Panel		Y
22	Gym Exit to Outside		Y
23	Gym Exit to Stage Hall		Y
24	Stage Hall Exit to Gym		Y
25	Exit to Outside Stage Left Corr		Y
26	Stage		Y
27	Gym Exit by Room 123		Y
28	Cafeteria		COMBO
29	Cafeteria		COMBO
30	Outside Exit in Cafeteria Hall		COMBO
1	Stairs by Room 217		Y
2	Library (Rear Entrance)		Y
3	Library		Y
4	Library Hall		Y
5	By Main Stairs #1		Y
6	By Room 205		Y
7	By Room 200		Y
8	By Room 209 Double Doors		Y
9	By Room 216 Double Doors		Y
10	By Room 218		Y
11	By Room 235		Y
12	By Room 222 Double Doors		Y
13	By Room 237		COMBO
14	By Room 241		Y
15	In Room 221		Y
16	In Room 221		Y
17	1ST FL MAIN CORR TO GYM		Y
18	1ST FL BY ROOM 117		Y
1	By Room 329		
2	Stairs by Room 329 Battery Pak		Y
3	**3rd Floor Stairs	Y	
4	**3rd Floor Stairs	Y	
5	**2nd Floor Stairs	Y	
6	**1st Floor Stairs	Y	
7	By Room 325		Y
8	By Room 321 Double Doors		Y
9	By Room 319		Y
10	Stairs by Room 319 Battery Pak		Y
11	**3rd Floor Stairs	Y	

12	**3rd Floor Stairs	Y	
13	**2nd Floor Stairs	Y	
14	**1st Floor Stairs	Y	
15	By Room 316 Double Doors		Y
16	By Room 309 Double Doors		Y
17	By Room 304		Y
18	By Room 301		Y
19	Stairs by Room 301 Battery Pak		Y
20	**3rd Floor Stairs	Y	
21	**3rd Floor Stairs	Y	
22	**2nd Floor Stairs	Y	
23	**1st Floor Stairs	Y	
24	By Room 318		Y
25	Top Main Stairs		Y
26	Main Stairs Battery Pak		Y
27	**3rd Floor Stairs	Y	
28	**3rd Floor Stairs	Y	
29	**2nd Floor Stairs	Y	
	Kitchen		Y
	Weight Rm.		
	Weight Rm.		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

	BREAKER FOR EMERGENCY LIGHTS:
	1) SPRINKLER ROOM, PNL "A", CCT#28, PNL"AA:, CCT#8, 2) GYM PANEL, CCT#35, 3) KITCHEN, CCT#9, 4) INDUSTRIAL
	ARTS OFFICE, CCT#31, 5) BY ROOM 206, CCT#8, 6) JANITOR ROOM BY 207, CCT#8, 7) JANITOR ROOM BY 215, CCT#19.21
	8) BIOLOGY STORAGE, CCT#30, 9) CLOSET B Y 237, CCT#5, 15, 10) BY ROOM 325, PNL"F", CCT#19,

		Device	Device address or circuit number
	LOCATION: John W. MacLeod		
	FIRE ALARM PANEL: Edwards 6500		

MANUAL PULL STATIONS

1	MAIN ENTRY BY STAFF ROOM	M	ZONE 1
2	BY ROOM 16	M	ZONE 1
3	BY ROOM 12	M	ZONE 1
4	GYM BY STAGE	M	ZONE 1
5	BEHIND GYM BY ROOM 37	M	ZONE 1
6	BY ROOM 19	M	ZONE 1
7	GYM BACK EXIT	M	ZONE 1
8	MUSIC ROOM 201	M	ZONE 9
9	ROOM 203	M	ZONE 9
10	BY ROOM 30	M	ZONE 2
11	BY SPRINKLER ROOM	M	ZONE 2
12	BY ROOM 26	M	ZONE 2
13	BASEMENT BY ROOM 36	M	ZONE 2
14	BY ROOM 20	M	ZONE 2

SMOKE DETECTORS

1	GYM RAMP	S	ZONE 5
2	TOP OF STAIRS BY MUSIC ROOM	S	ZONE 8

SPRINKLER DEVICES

1	DRY SYSTEM #2 FLOW ALARM	FSP-1	ZONE 3
2	DRY SYSTEM #2 MAIN CONTROL VAL	SV	ZONE 3
3	DRY SYSTEM #1 FLOW ALARM	FSP	ZONE 4
4	DRY SYSTEM #1 MAIN CONTROL VAL	SV	ZONE 4

DUCT SMOKE DETECTORS

1	FAN ROOM 48 FRONT	DS	ZONE 6
2	FAN ROOM 48 REAR	DS	ZONE 7

NOTIFYING DEVICES

1	MUSIC ROOM 201	B	SIG 2
2	BY LIBRARY	B	SIG 2
3	BY ROOM 16	B	SIG 2
4	BY ROOM 19	B	SIG 2
5	BY ROOM 12	B	SIG 2
6	GYM	B	SIG 2

7	BY ROOM 36	B	SIG 2
8	BY ROOM 30	B	SIG 2
9	BY ROOM 26	B	SIG 2
10	BY ROOM 20	B	SIG 2
11	OUTSIDE MAIN ENTRANCE	B	SIG 2

END OF LINE RESISTORS

1	BY ROOM 20	EOL	ZONE 2
2	SPRINKLER ROOM	EOL	ZONE 4
3	SPRINKLER ROOM	EOL	ZONE 3
4	MUSIC ROOM 201	EOL	ZONE 9
5	TOP OF STAIRS BY MUSIC ROOM	EOL	ZONE 8
6	BY ROOM 19	EOL	ZONE 1
7	BY ROOM 20	EOL	SIG 2
8	FAN ROOM 48	EOL	ZONE 7
9	FAN ROOM 48	EOL	ZONE 6
10	GYM RAMP	EOL	ZONE 5

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
1	BY LIBRARY		
2	BY ROOM 17		
3	GYM STAIRWELL		
4	GYM STORAGE #4		Y
5	GYM	Y	
6	GYM RAMP BY GIRLS W/R	Y	
7	GYM RAMP BY BOYS W/R	Y	
8	GYM RAMP BY 123	Y	
9	HALL BY MUSIC RM STAIRS	Y	
10	BOTT RM 46 STAIRS	Y	
12	BOILER ROOM BATT PACK		Y
13	BY BOILER ROOM	Y	
14	IN BOILER ROOM	Y	
15	BY ROOM 30	Y	
16	BOTT GYM RAM	Y	
17	BY ROOM 25	Y	
18	BY ROOM 21		Y
19	BY ROOM 35		Y
20	BOOK STORAGE RM 37		Y
21	OUTSIDE BOOK STO ROOM	Y	
22	STAIRWELL BY BOOK STORE	Y	
23	MUSIC RM STORAGE 47		Y

24	MUSIC ROOM	Y	
25	ROOM 46	Y	
26	OUTSIDE RM 46	Y	
27	ELECTRICAL RM IN ART RM		Y
28	GYM REAR(HIGH)		Y
29	BY STAIRS 102	Y	
30	BY PS#12 GYM	Y	
31	SOUTHWEST Gym		Y
32	Stairs to Gym		Y
33	Left of Stage		Y
34	Northwest Gym		Y
35	Boiler Rm.		Y

	LOCATION: Rockingstone Heights	Device	Device address or circuit number
--	---------------------------------------	---------------	---

FIRE ALARM PANEL:Edwards 6500

MANUAL PULL STATIONS

1	BOILER ROOM	M	ZONE # 2
2	BY ROOM 105	M	ZONE # 3
3	BY LIBRARY	M	ZONE #4
4	BY ROOM 204	M	ZONE # 4
5	MAIN ENTRANCE BY LOBBY	M	ZONE #3
6	BY SPRINKLER ROOM	M	ZONE # 3
7	BY 301	M	ZONE # 5
8	BY 304	M	ZONE # 5
9	GYM	M	ZONE # 6
10	GYM	M	ZONE # 6

SMOKE DETECTORS

1	ELECTRICAL ROOM	S	ZONE # 2
2	SOUTHSTAIRWELL	S	ZONE # 9
3	NORTHSTAIRWELL	S	ZONE#1 0

DUCT SMOKE DTECTORs

1	MECHANICAL RM ABOVE GYM STAGE	DS	ZONE # 7
---	----------------------------------	----	-------------

NOTIFYING DEVICES

1	BOILER ROOM	B	SIG #1
2	GYM	B	SIG #1
3	GYM	B	SIG #1

4	MAIN ENTRANCE	B	SIG #1
5	MAIN OFFICE	B	SIG #1
6	BY ROOM #104	B	SIG #1
7	BY ROOM#200	B	SIG #1
8	BY ROOM # 203	B	SIG #1
9	BY ROOM # 302	B	SIG #1
10	BY ROOM # 305	B	SIG #1
11	2ND FLOOR TEACHERS ROOM	B	SIG #1
SPRINKLER DEVICES			
1	SPRINKLER	FS	1
2	SPRINKLER	G/V	1
RELAY			
	AHU SHUT DOWN	RLY	

Fire Door Number or Location
BY MAIN ENTRANCE
1ST FLOOR BY GIRLS W/ROOM
2ND FLOOR BY ROOM 204
2ND FLOOR NEAR STAFF ROOM
2ND FLOOR NEAR STAFF ROOM
3RD FLOOR BY ED ROOM
3RD FLOOR NEAR GUIDANCE ROOM
3RD FLOOR NEAR ROOM 308

EMERGENCY LIGHTING

Location	# of Heads	Model
GYM BY MAIN LOBBY		
GYM BY STAGE EXIT		COMBO
BY RM 36		
BOYS SHOWER		UNIT
GIRLS SHOWER		UNIT
BOILER RM		COMBO
BY RM 106		
EXIT BY SPRINKLER RM		
DOUBLE DOORS BY GIRLS WASHRM		COMBO
1ST FL JANITOR'S RM		UNIT
2ND FL BY LIBRARY		COMBO

		UNIT
2ND FL BY 208		COMBO UNIT
3RD FL BY 308		COMBO UNIT
3RD FL HALLWAY @ FIRE DOORS		COMBO UNIT
ELECTRICAL RM		
MAIN ENTR		
1ST FL BY OFFICE		
2ND FL HALLWAY @ DOUBLE DOORS		COMBO
3RD FL @ FIRE DOOR		REMOTE
3RD FL @ FIRE DOOR		REMOTE
3RD FL @ 309		COMBO
STAIR #1 TOP		REMOTE
STAIR #1 2ND FL		REMOTE
STAIR #1 1ST FL		REMOTE
2ND FL @ FIRE DOORS		UNIT
2ND FL @ FIRE DOORS		UNIT
2ND FL @ AV MUSIC 209		UNIT
STAIR 2 TOP		REMOTE
STAIR 2 2ND FL		REMOTE
STAIR 2 1ST FL		REMOTE
SPRINKLER RM		UNIT
JAN RM		UNIT
3RD FLOOR BY 309		REMOTE
BY 103		UNIT
GYM OFFICE		UNIT

		Device	Device address or circuit number
	LOCATION: Sambro Ele.		
FIRE ALARM PANEL: Mircom FX100			
MANUAL PULL STATIONS			
1	MAIN ENTRANCE	M	ZN 6
2	MAIN ENTRANCE HALL	M	ZN 6
3	1ST FLOOR REAR EXIT	M	ZN 6
4	2ND FLOOR REAR EXIT	M	ZN 5
5	2ND FLOOR ABOVE MAIN ENTRANCE	M	ZN 5
6	MAIN HALL OLD SECTION	M	ZN 3
7	GYM ENTRY	M	ZN 3
8	BASEMENT EXT.		
9	BY ROOM 103		
SMOKE DETECTORS			
1	STAIRWELL FRONT	SI	ZN 1
2	STAIRWELL REAR	SI	ZN 2
3	BASEMENT Rt.	SI	1
4	BASEMENT LEFT	SI	6
HEAT DETECTORS			
1	ROOM FRONT OF GYM BY STAGE	HT	ZN 3
2	RM FRONT OF GYM LEFT OF EXIT DOOR	HT	ZN 3
3	ROOM FRONT OF GYM 100 B / Gym Office	RHT	ZN 3
4	GYM EQUIPMENT ROOM	HT	ZN 3
5	BOILER ROOM	HT	ZN 4
6	CUSTODIAN ROOM	HT	ZN 6
7	KITCHEN	HT	ZN 5
8	CARETAKER OFFICE 106	RHT	ZN 6
9	RM 113 STORAGE	HT	ZN 6
10	RM 116 ELECTRICAL RM IN LIBRARY	HT	ZN 6
NOTIFYING DEVICES			
1	1ST FLOOR FRONT BY RM 110	B	SIG 1
2	1ST FLOOR REAR	B	SIG 1
3	2ND FLOOR FRONT	B	SIG 1
4	2ND FLOOR REAR BY 207	B	SIG 1
5	MAIN HALL OLD SECTION	B	SIG 1

6	MAIN ENTRANCE	B	SIG 1
7	GYM ENTRANCE	B	SIG 1

END OF LINE RESISTORS

1	STAIRWELL FRONT	EOL	ZN 1
2	STAIRWELL REAR	EOL	ZN 2
3	GYM ENTRY	EOL	ZN 3
4	2ND FLOOR ABOVE MAIN ENTRANCE	EOL	ZN 5
5	MAIN ENTRANCE	EOL	ZN 6
6	GYM ENTRANCE	EOL	SIG 1

FIRE DOORS

MAIN ENTRY

FOYER BY FACP

MAIN LEVEL CORRIDOR
FRONT

MAIN LEVEL CORRIDOR
REAR

CENTRE

LEVEL 2 BY KITCHEN

LEVEL 2 REAR CORRIDOR

EMERGENCY LIGHTS

Location	# of Heads	Model
FRONT ENTRANCE HALL (#2)		
1ST FLOOR WEST (#7)		
1ST FLOOR EAST (#8)		
GYM (#3)		
WEST STAIR (#6)		
EAST STAIR (#4)		
2ND FLOOR (#5)		
EXIT ADJ 114		EMERGI LITE
GIRLS WASHROOM		UNIT

BOYS WASHROOM		UNIT
---------------	--	------

Fire Door Number or Location
MAIN ENTRY
FOYER BY FACP
MAIN LEVEL CORRIDOR FRONT
MAIN LEVEL CORRIDOR REAR
INTERMEDIATE LEVEL BY LEARN CTR
LEVEL 2 BY KITCHEN
LEVEL 2 REAR CORRIDOR

	LOCATION: William King	Device	Device address or circuit number

FIRE ALARM PANEL: Notifier AFP 400

MANUAL PULL-STATIONS			
1	MAIN ENTRY	M	Zone 1
2	WEST EXIT	M	Zone 2
3	EAST EXIT	M	Zone 1
4	CAFETERIA	M	Zone 2
5	GYM EXIT	M	Zone 1
6	SPRINKLER ROOM 163	M	Zone 1
DUCT SMOKE DETECTORS			
	FAN #1 ROOM 154	DS	Zone 3
BELLS			
24	FAN ROOM	B	
25	WEST HALLWAY	B	
26	EAST HALLWAY	B	
27	GYM	B	
28	CAFETERIA	B	
29	MAIN ENTRY	B	
30	WEST HALLWAY	B	
SPRINKLER DEVICES			

SPRINKLER NORTH	FLOW	13
SPRINKLER SOUTH	FLOW	14
MAIN TAMPER	TS	10
SPRINKLER SOUTH	PSA	11
SPRINKLER NORTH	PSA	12
SPRINKLER SOUTH	TS	11
SPRINKLER NORTH	TS	12
BACKFLOW #1	TS	9
SPARE	TS	15

BACKFLOW #2	TS	9
SPRINKLER LOW PRESSURE TANK 1 & 2	LW	10

EMERGENCY LIGHTS

Location	# of Heads	Model
GYM BY MAIN ENTRANCE		EMERG-LITE
GYM BY BELL		REMOTE
MAIN ENTRANCE		REMOTE
GYM BY STAGE RIGHT		EMERG-LITE
GYM BY STAGE LEFT		REMOTE
GYM BY TEACHERS OFFICE		REMOTE
GYM GIRLS CHANGE RM		REMOTE
GYM BOYS CHANGE RM		EMERG-LITE
BY FAN RM 154		EMERG-LITE
IN RM 154 TOP STAIRS		REMOTE
IN RM 163		
IN BOYS WASHRM 153		REMOTE
IN GIRLS WASHRM 155		REMOTE
BY RM 156		REMOTE
SPRINKLER RM 145		EMERG-LITE
ELECTRICAL RM 147		REMOTE
BY RM 120		EMERG-LITE
GIRLS WASHRM 117		REMOTE
BOYS WASHRM 115		REMOTE
BY RM 112		REMOTE
CASPERIA		EMERG-LITE

CAFETERIA		EMERG- LITE
OUTSIDE CAFETERIA		REMOTE
ADJ OFFICE		REMOTE
IN RM 116 (CARETAKER CLOSET)		REMOTE
ELECTRICAL RM 147		EMERG- LITE
OFF SPRINKLER RM		REMOTE

	LOCATION: Burton Ettinger	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards 6500			
MANUAL PULL STATIONS			
1	BY ROOM 228	M	ZONE 1
2	BY ROOM 229	M	ZONE 1
3	BY ROOM 234	M	ZONE 1
4	EXIT BY FIRE ALARM PANEL	M	ZONE 1
5	BY ROOM 111	M	ZONE 2
6	BY ROOM 110	M	ZONE 2
7	BY ROOM 115	M	ZONE 2
8	BY ROOM 218	M	ZONE 5
9	LIBRARY HALL	M	ZONE 5
10	BY ROOM 221	M	ZONE 5
11	BY ROOM 103	M	ZONE 7
12	BY ROOM 106	M	ZONE 7
13	BY LIBRARY	M	ZONE 8
14	MAIN ENTRANCE	M	ZONE 8
15	GYM	M	ZONE 8
16	102 MECHANICAL ROOM	M	ZONE 8
SMOKE DETECTORS			

1	ELEVATOR SHAFT	SI	ZONE 3
2	STAIRWELL BY ROOM 218	SI	ZONE 9
3	STAIRWELL BY ROOM 230	SI	ZONE 10
4	STAIRWELL BY ELEVATOR	SI	ZONE 11
5	STAIRWELL BY ROOM 221	SI	ZONE 14
6	STAIRWELL BY FIRE ALARM PANEL	SI	ZONE 15
DUCT SMOKE DETECTORS			
1	ABOVE GYM STORAGE ROOM	DS	ZONE 13
HEAT DETECTORS			
1	ELECTRICAL ROOM	RHT	ZONE 8
2	BOILER ROOM	HT	ZONE 8
3	JANITORS ROOM	RHT	ZONE 8
SPRINKLER DEVICES			
1	SRINKLER FLOW ALARM	FSP	ZONE 4
4	MAIN CONTROL VALVE	SV	ZONE 6
NOTIFYING DEVICES			
1	1ST FLOOR BY CENTRE STAIRS	H/S	SIG 1
2	BY ROOM 115	H/S	SIG 1
3	BY ROOM 234	H/S	SIG 1
4	BY ROOM 106	H/S	SIG 1
5	2ND FLOOR BY BOYS WASHROOM	H/S	SIG 1
6	BY BOILER ROOM	H/S	SIG 2
7	LIBRARY HALL	H/S	SIG 2
8	BY ROOM 221	H/S	SIG 2
9	BY ROOM 103	H/S	SIG 2
10	BY ROOM 218	H/S	SIG 2
11	GYM	H/S	SIG 2
12	STROBE BY FIRE ALARM PANEL	V	
END OF LINE RESISTORS			
1	BY ROOM 228	EOL	ZONE 1

2	BY ROOM 110	EOL	ZONE 2
3	ELEVATOR SHAFT	EOL	ZONE 3
4	SRINKLER ROOM 109	EOL	ZONE 4
5	LIBRARY HALL	EOL	ZONE 5
6	SRINKLER ROOM IN TEACHERS ROOM	EOL	ZONE 6
7	BY ROOM 103	EOL	ZONE 7
8	BOILER ROOM	EOL	ZONE 8
9	BY ROOM 218	EOL	ZONE 9
10	BY ROOM 231	EOL	ZONE 10
11	2ND FLOOR BY ELEVATOR	EOL	ZONE 11
12	ABOVE GYM STORAGE ROOM	EOL	ZONE 13
13	BY ROOM 221	EOL	ZONE 14
14	STAIRWELL BY FIRE ALARM PANEL	EOL	ZONE 15

RELAYS

AHU SHUTDOWN		
DOOR RELEASE		

EMERGENCY LIGHTING

Location	# of Heads	Model
STAIRS BY ROOM 221 1ST FLOOR		JML 36 EMERGI- LITE
BY LIBRARY ENTRANCE		RG36A LUMACELL
BY ROOM 110		JML 36 EMERGI- LITE
BY ROOM 112		JML 36 EMERGI- LITE
BY ROOM 109		06JML 36 EMERGI- LITE
STAIRS BY ROOM 218		JML 36 EMERGI-

		LITE
1ST FLOOR BY ELEVATOR		RG36A LUMACELL
EXIT BY ROOM 228		JML 36 EMERGI-LITE
STAIRS BY ROOM 229		JML 36 EMERGI-LITE
BY ROOM 233		RG36MT9W EMERGI-LITE
BY OFFICE		RG36A EMERGI-LITE
GYM EXIT		UNIT
GYM ENTRY		CS38
BY ROOM 218		RG36A LUMACELL
BY ROOM 229 2ND FLOOR		JML 36 EMERGI-LITE
GYM STAGE		UNIT
2ND FLOOR BY ELEVATOR		RG36A EMERGI-LITE
BY ROOM 114		JML36 EMERGI-LITE
EXIT BY FIRE ALARM PANEL		JML36 EMERGI-LITE
GIRLS CHANGE ROOM		UNIT
BOYS CHANGE ROOM		UNIT
IN SPRINKLER ROOM		UNIT
MAIN ELECTRICAL ROOM		UNIT
BY 221		EXIT COMBO
MECH RM 102		UNIT/COMBO
BY 224		UNIT
BOYS WSHRM BY STAFF RM		UNIT
GIRLS WSHRM BY STAFF RM		UNIT
MECH ROOM 102 BACK		UNIT
GYM RAMP		UNIT

	LOCATION: Springvale	Device	Device address or circuit number
--	-----------------------------	---------------	---

FIRE ALARM PANEL:Edwards 6500

MANUAL PULL STATIONS

1	1ST FLOOR BY ROOM 101	M	ZONE 1
5	1ST FLOOR BY ROOM 109	M	ZONE 3
2	ROOM 102 / Inside Rm 102	M	ZONE 1
3	1ST FLOOR BOTTOM CENTRE STAIRS	M	ZONE 1
4	BOILER ROOM	M	ZONE 2
6	2ND FLOOR BY ROOM 201	M	ZONE 5
7	2ND FLOOR CENTRE	M	ZONE 5
8	2ND FLOOR BY ROOM 211	M	ZONE 6
9	GYM	M	ZONE 7
10	GYM RIGHT OF STAGE	M	ZONE 7
11	GYM LEFT OF STAGE	M	ZONE 7
12	3RD FLOOR BY 301	M	ZONE 8
13	3RD FLOOR BY CENTRE STAIRS	M	ZONE 8
14	3RD FLOOR BY ROOM 313	M	ZONE 9

SMOKE DETECTORS

1	TOP OF STAIRS BY ROOM 301	S	ZONE 8
2	TOP OF CENTRE STAIRS	S	ZONE 8

3	TOP OF STAIRS BY ROOM 313	S	ZONE 9
HEAT DETECTORS			
1	BOILER ROOM	HT	ZONE 2
2	ELECTRICAL ROOM	RHT	ZONE 2
3	ROOM 101	RHT	ZONE 1
4	ROOM 102 BY RAMP	RHT	ZONE 1
5	ROOM 102	RHT	ZONE 1
6	ROOM 103	RHT	ZONE 1
7	ROOM 103 BY SINK	RHT	ZONE 1
8	1ST FLOOR HALL BY ROOM 103	HT	ZONE 1
9	ROOM 104 BAND ROOM BY OFFICE	RHT	ZONE 3
10	ROOM 104 BAND ROOM	RHT	ZONE 3
11	STORAGE #1 LEV 1(#1)	RHT	ZONE 3
12	STORAGE #1 LEV 1(#2)	RHT	ZONE 3
13	STORAGE #1 LEV 1(#3)	RHT	ZONE 3
14	HEADQUARTER STORAGE BY ENTRY	RHT	ZONE 3
15	HEADQUARTER STORAGE	RHT	ZONE 3
16	ROOM 105	RHT	ZONE 3
17	ROOM 107	HT	ZONE 3
18	1ST FLOOR HALL BY ROOM 107	HT	ZONE 3
19	ROOM 109	RHT	ZONE 3
20	ROOM 106 BY ENTRY	RHT	ZONE 4

21	ROOM 106	RHT	ZONE 4
22	ROOM 201	RHT	ZONE 5
23	ROOM 202	RHT	ZONE 5
24	ROOM 203	RHT	ZONE 5
25	ROOM 204	RHT	ZONE 5
26	2ND FLOOR HALL BY ROOM 204	HT	ZONE 5
27	ROOM 205	RHT	ZONE 5
28a	PRINCIPALS OFFICE WAIT ROOM CLST	RHT	ZONE 5
28	PRINCIPALS OFFICE	HT	ZONE 6
29	CORRIDOR BETWEEN OFFICES	RHT	ZONE 6
30	PRINCIPALS WAITING ROOM	RHT	ZONE 6
31	SECRETARY'S OFFICE	RHT	ZONE 6
32	ROOM 209	RHT	ZONE 6
33	2ND FLOOR JANITORS ROOM	RHT	ZONE 6
34	2ND FLOOR HALL BY 209	RHT	ZONE 6
35	ROOM 211	RHT	ZONE 6
36	GYM CEILING	HT	ZONE 7
37	GYM CEILING	HT	ZONE 7
38	GYM CEILING	HT	ZONE 7
39	GYM CEILING	HT	ZONE 7
40	GYM STORAGE - RIGHT/OFFICE	RHT	ZONE 7
41	GYM STORAGE - LEFT	RHT	ZONE 7

43	GYM BALCONY	RHT	ZONE 7
44	BALCONY STORAGE	RHT	ZONE 7
45	BALCONY STORAGE	RHT	ZONE 7
46	ROOM 301	RHT	ZONE 8
47	3RD FLOOR LIBRARY, LEFT SIDE	RHT	ZONE 8
48	3RD FLOOR LIBRARY, RIGHT SIDE	RHT	ZONE 8
49	ROOM 304	RHT	ZONE 8
50	ROOM 305	RHT	ZONE 8
51	3RD FLOOR HALL BY ROOM 305	HT	ZONE 8
52	3RD FLR UTILITY RM BY STAFF WASHRM	RHT	ZONE 8
53	3RD FLOOR BOOK ROOM STORAGE	RHT	ZONE 8
54	ROOM 308 CARETAKERS OFFICE	RHT	ZONE 9
55	ROOM 309 OFFICE	RHT	ZONE 9
56	ROOM 309 OFFICE FOYER	RHT	ZONE 9
57	3RD FLOOR HALL BY ROOM 311	HT	ZONE 9
58	ROOM 311	RHT	ZONE 9
59	ROOM 313	RHT	ZONE 9
60	BY ROOM 314/SM	RHT	ZONE 9
61	ROOM 314 STORAGE	RHT	ZONE 9
62	ROOM 314 LEARNING CENTER	RHT	ZONE 9
NOTIFYING DEVICES			
1	ROOM 104 BAND ROOM	B	SIG 1
2	1ST FLOOR HALL BY ROOM 107	B	SIG 1
3	LIBRARY STORAGE	B	SIG 1

4	2ND FLOOR BY OFFICE	B	SIG 1
5	GYM	B	SIG 1
6	3RD FLOOR HALL BY ROOM 311	B	SIG 1
7	1ST FLOOR HALL BY ROOM 103	B	SIG 2
8	ROOM 102	B	SIG 2
9	2ND FLOOR HALL BY ROOM 203	B	SIG 2
10	3RD FLOOR HALL BY 305	B	SIG 2

END OF LINE RESISTORS

1	1ST FLOOR BY ROOM 101	EOL	ZONE 1
2	1ST FLOOR BY ROOM 109	EOL	ZONE 3
3	BOILER ROOM	EOL	ZONE 2
4	2ND FLOOR BY ROOM 201	EOL	ZONE 5
5	2ND FLOOR BY ROOM 211	EOL	ZONE 6
6	GYM	EOL	ZONE 7
7	3RD FLOOR BY 301	EOL	ZONE 8
8	HALL BY ROOM 106	EOL	ZONE 4
9	3RD FLOOR BY ROOM 313	EOL	ZONE 9
10	SPRINKLER ROOM	EOL	ZONE 10
	SPRINKLER	FLOW	10
	SPRINKLER	G/V	10

Fire Door Number or Location

BY ROOM 106
BY ROOM 104
BY ROOM 103
BY ROOM 101
BY ROOM 211
BY ROOM 204
BY ROOM 203
BY ROOM 201
BY ROOM 313
BY ROOM 308
BY ROOM 301
BY STAFF WASHROOM

EMERGENCY LIGHTING

Unit #	Location	# of Heads	Model	C
	BY ROOM 103			
	INSIDE ROOM 102			
	BY ROOM 109			
	BY ROOM 211			
	GYM BY PULL STATION #7			
	GYM BY PULL STATION #8			
	GYM BY PULL STATION #9			
	MAIN ENTRANCE			
	BY ROOM 203			
	BY ROOM 303			
	BY ROOM 313			
	INSIDE RM 102 #2			
	BY ROOM 103			
	BY ROOM 102			
	BY ROOM 104			
	IN ROOM 104			
	ELECTRICAL RM			
	BOILER RM			
	ADJ. RM 107			
	EAST STAIR LEVEL 1			
	WEST STAIR LEVEL 1			
	IN ROOM 104		UNIT	
	IN ROOM 104		UNIT	
	ON STAGE		UNIT	
	GYM CORNER		UNIT	
	ADJ 309		UNIT	
	CTR STAIR LANDING		UNIT	
	TOP CTR STAIR RIGHT		UNIT	
	TOP CTR STAIR LEFT		UNIT	
	ADJ 305		UNIT	
	EAST STAIR LANDING		UNIT	

	WEST STAIR LANDING		UNIT
	ADJ 204		UNIT
	STORAGE UNDER GYM (BASEMENT) IN CAFETERIA		EXIT COMBO
	STORAGE UNDER GYM (BASEMENT) IN CAFETERIA		UNIT

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS	
---	--

1	EML ON PANEL F CCT 18 & 19
2	EML PANEL G CCT 15

	LOCATION: Joseph Howe	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards			
MANUAL PULL STATIONS			
1	LOWER CORR SOUTH EXIT BY GYM + EOL	M	ZONE#6
2	DAYCARE CORR NORTH	M	ZONE#7
3	DAYCARE CORR SOUTH +EOL	M	ZONE#7
4	HALIFAX COMM LIVING RM 127 SIDE EXIT+e	M	ZONE#8
5	GYM SIDE WALL	M	ZONE#9
6	GYM	M	ZONE#9
7	MAIN ENTRANCE	M	ZONE#10
8	MAIN ENTRANCE LOWER +EOL	M	ZONE#10
9	LOWER OFFICE HALL NEAR EXIT BY 104+ec	M	ZONE#11
10	UPPER HALL LIBRARY AREA BY 204 + EOL	M	ZONE#12
11	UPPER HALL LIBRARY AREA BY 220 STAFF	M	ZONE#12
12	BOILER ROOM + EOL	M	ZONE#13
SMOKE DETECTORS			
1	STAIR 1 BY ROOM 210(pre school area) + EOL	SI	ZONE#1
2	STAIR 2 BY LADIES W/RM(pre school area)+e	SI	ZONE#2
3	STAIR 3 BY MAIN ENTRANCE	SI	ZONE#3
4	STAIR 4 BY STAFF ROOM	SI	ZONE#4
5	STAIR 5 BY ROOM 202	SI	ZONE#5
HEAT DETECTORS			
2	BOILER ROOM	HT	ZONE#15
SPRINKLER DEVICES			
1	SPRINKLER	PS	ZONE#14
3	SPRINKLER	TS	ZONE#17
NOTIFYING APPLIANCES			
1	PRIMARY/GRADE ONE	B	SIG#1
2	2ND FLOOR NORTH HALL (UPPER)	B	SIG#1
3	2ND FLOOR NORTH HALL (LOWER)	B	SIG#1
4	MAIN LOWER	B	SIG#1
5	MAIN UPPER	B	SIG#1
6	1ST FLOOR BY GYM	B	SIG#1
7	GYM	B	SIG#1
8	2ND FLOOR BY GYM	B	SIG#1
9	2ND FLOOR BY GYM	B	SIG#1
10	BOILER ROOM	B	SIG#1

EMERGENCY LIGHTING

Location	# of Heads	Model	C
MAIN LOBBY			
BY ADMIN OFFICE			
CORRIDOR BY GIRL'S WASHROOM			
WALL BY ROOM 114			
CORRIDOR BY ROOM 104			
PANEL "B" CCT. 24			
GYM SIDE WALL 1 CLOSET TO STAGE			
GYM BACK EXIT			
GYM SIDE WALL 2 BY CORNER			
GYM CORRIDOR BY ROOM 128			
GYM CORRIDOR BY ROOM 145			
CORRIDOR BY ELO ROOM		REMOTE	
MAIN FLOOR/CENTRE STAIRS			
HALIFAX COMM. LIVING ROOM 127 SIDE EXIT			
PANEL "D" CCT 11			
DAYCARE CORRIDOR BY 224 WASHROOM			
DAYCARE CORRIDOR BY PLAY ROOM			
PANEL "C" CCT. 34			
2ND FLOOR LOWER BY 203			
2ND FLOOR UPPER BY 220			
BOILER ROOM BACK			
BOILER ROOM BOTTOM STAIR			
PANEL "E" CCT 24/18			
GYM RIGHT STAIR TO STAGE			

LUNCH ROOM EXIT TO LOBBY		
LEFT STAGE STAIR		
STAIRS TO DAYCARE		
CORRIDOR BY RM 128	2	COMBO
BOILER ROOM		COMBO
STORAGE BY GYM		EXIT
STAGE		COMBO

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

The Breaker for the Main Lobby Emergency Light is located in Panel " A" and is breaker # 30. There are other plugs on this breaker as well.

	LOCATION: Oxford	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards EST 2		
1	Gym back exit	M	214
2	West stairwell Willow Street	M	220
3	Basement Hall by Washroom	M	205
4	North East entry North Street	M	217
5	2nd Floor hall by Washroom	M	206
6	Gym East Side	M	213
7	Gym West Side	M	212
8	Community Main Entry	M	221
9	2nd Floor East Hall	M	218
10	2nd Floor Center Hall	M	207
11	2nd Floor West Hall	M	208
12	3rd Floor East Hall	M	219
13	3rd Floor Hall by Washroom	M	211
14	3rd Floor Center Hall	M	210
15	3rd Floor West Hall	M	209
	SMOKE DETECTORS		
16	3rd Floor East Stairwell	SA	102
17	3rd Floor Center Stairwell	SA	105
18	3rd Floor West Stairwell	SA	104
19	2nd Floor West Stairwell	SA	101
20	2nd Floor Community Stairwell	SA	103
BELLS			
21	By Room # 110	B	SIG
22	By Room # 206	B	SIG
23	By Room # 213	B	SIG
24	By Room # 309	B	SIG
25	By Room # 313	B	SIG
	Gym	B	SIG
	By ROOM 302	B	SIG
EMERGENCY LIGHTING			

Location	# of Heads	Model	Ci
BSMT ADJ 102	2	COMBO	

AT BOILER ROOM	2	EMERGI LITE
BSMT AT CTR STAIR	2	COMBO
BSMT AT CTR STAIR	2	COMBO
BSMT AT 105	2	COMBO
BSMT AT 110	2	UNIT
BOYS WR BSMT	2	LUMACELL
ADJ RM 114	2	COMBO
FEMALE WR	2	LUMACELL
1ST FLOOR ADJ 205	2	COMBO
1ST FLOOR ADJ 207	2	COMBO
1ST BOYS WR	2	UNIT
1ST GIRLS WR	2	UNIT
1ST DOOR AT 207	2	COMBO
1ST ADJ F/A	2	COMBO
1ST ADJ STAIR W F/A	2	UNIT
3RD FLR AT NORTH STAIR	2	COMBO
BOYS WR	2	EMERGI LITE
ADJ BOYS WR	2	
GIRLS WR	2	
CTR AT 313	2	
CTR AT 312	2	
CTR AT 305	2	
GIRLS WR	2	

BOYS WVR	2	
EXIT ADJ 301	2	
BASEMENT AT 115		
TOP 3RD STAIR ADJ F/A		REMOTE
1ST ADJ ROOM 219	2	COMBO
1ST BOYS WVR	2	UNIT
1ST GIRLS WVR	2	UNIT
1ST ADJ BOYS WVR	2	UNIT
1ST ADJ BOYS WVR	2	UNIT
1ST ADJ OFFICE	2	COMBO
1ST ADJ 210	2	COMBO
1ST ADJ GUIDANCE	2	COMBO
1ST TEACHERS WVR	2	UNIT
GYM AT FAR DOOR	2	COMBO
GYM AT OFFICE HALL	2	COMBO
STAGE	2	UNIT
GYM DOOR AT SIDE STAFF	2	COMBO
2ND FLR EXIT ADJ 219		COMBO
ADJ BOYS WVR		EMERGI- LITE
NORTH ST EXIT		COMBO
EXIT ADJ 201		COMBO

	LOCATION: St. Agnes	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards 6500			
MANUAL PULL STATIONS			
1	BY RM 18	M	1
2	3RD LEVEL BY RM 16	M	1
3	ENTRANCE TO FOOD TECH LABS	M	1
4	3RD LEVEL SOUTH BY RM 27	M	2
5	MAIN ENTRANCE	M	3
6	GYM	M	4
7	GYM	M	4
8	GYM BY LIBRARY	M	4
9	GYM ENTRANCE	M	4
10	LIBRARY	M	5
11	AT BOTTOM OF RAMP	M	6
13	BY ROOM 9	M	6
14	BY RM 1	M	7
15	FURNACE RM	M	9
HEAT DETECTORS			
16	ELECTRICAL RM	RHT	8
NOTIFYING DEVICES			
19	BY RM 25	B	SIG 1
20	BY RM 18	B	SIG 1
21	BY TECH ED	B	SIG 1
22	FOOD LAB	B	SIG 1
23	FOOD LAB	B	SIG 1
24	GYM	B	SIG 2
25	GYM HALL	B	SIG 2
26	MAIN ENTRANCE	B	SIG 2
27	LIBRARY	B	SIG 2
28	HALL BY ART RM	B	SIG 2
29	HALL BY STAFF RM	B	SIG 2
30	HALL BY RM 9	B	SIG 2
31	BOILER RM	B	SIG 2
SPRINKLER			
	MAIN (non-latching)	GV	10

	PRESSURE SWITHCH	PS	10
	Fire Door Number or Location		
	LEV 1 BY ELECTRICAL ROOM		
	LEV 1 BY GIRLS WASHROOM		
	LEV 2 BY ROOM #22		

EMERGENCY LIGHTING			
Line #	EL UNIT Location	Remote Head	Manuf.
1	Computer Lab #1(#6)		EMERGI-LITE
2	Computer Lab #2(#8)		EMERGI-LITE
3	Wood Working Shop(#9)		EMERGI-LITE
4	ENTRY TO Tech Ed Rm(#7)		EMERGI-LITE
5	Home Ed Rm #1(#10)		EMERGI-LITE
6	Home Ed Rm #2(#11)		EMERGI-LITE
7	2nd flr by ROOM 18(#2)		EMERGI-LITE
8	2nd Flr Female washroom(#6)		EMERGI-LITE
9	2nd Flr Male washroom(#4)		EMERGI-LITE
10	**2nd floor staff female	Y	
11	**2nd floor staff male	Y	
12	3rd flr by Rm 25(#5)		EMERGI-LITE
13	Male Lockers(#13)		EMERGI-LITE
14	Female Lockers(#12)		EMERGI-LITE
15	**female locker room	Y	
16	Main Entry(#21)		EMERGI-LITE
17	Gym Bleacher Side(#14)		LITHONIA
18	**Outside Male Lockers		REMOTE
19	1st Flr by Rm 3(#21)		EMERGI-LITE
20	1st Flr by Washrooms(#16)		EMERGI-LITE

21	1st Flr Female washroom(#18)		LUMACELL
22	1st Flr Male washroom(#17)		LUMACELL
23	**1st floor staff female	Y	
24	**1st floor staff male	Y	
25	1st Flr by Rm 10(#20)		LITHONIA
26	1st Flr by Rm 9(#19)		CLORIDE
27	Gym Kitchen Side(#15)		LITHONIA
28	2nd Floor By Rm 19(#1)		EMERGI-LITE
29	ELECTRICAL ROOM		REMOTE
	ELECTRICAL ROOM		LUMACELL
	ELECTRICAL ROOM		COMBO

	LOCATION: St.Catherines	Device	Device address or circuit number
--	--------------------------------	---------------	---

FIRE ALARM PANEL: Edwards QS4

MANUAL PULL STATIONS

1	BY MAIN OFFICE	M	PP5
2	ADJ ROOM 219	M	5
3	ADJ ROOM 226	M	5
4	ADJ ROOM 225	M	5
5	ADJ ROOM 232	M	5
6	ADJ ROOM 125	M	2
7	ADJ ROOM 113	M	2
8	ACROSS FROM 113	M	2
9	ACROSS FROM 108	M	2
10	ADJ ROOM 103	M	2
11	ADJ 210	M	6
12	ADJ GYM ENTRANCE	M	6
13	GYM EXIT	M	4
14	BOILER ROOM	M	3

SMOKE DETECTORS

1	STAIR ABOVE FIRE PANEL MAIN ENTRY	SI	9
2	STAIR ADJ ROOM 219	SI	11
3	CENTER STAIR NORTH WING ADJ ROOM 235	SI	7
4	NORTHEAST STAIR ADJ ROOM 226	SI	8
5	NORTHWEST STAIR ADJ ROOM 225	SI	10
6	GYM STORAGE ROOM	SI	4
7	ROOM 228	SI	5
8	STORAGE ROOM 103	SI	2
9	STORAGE ROOM 105	SI	2
10	STORAGE ROOM 118	SI	2
11	STORAGE ROOM 115	SI	2
12	STORAGE ROOM 128	SI	2

HEAT DETECTORS

1	ROOM 214 STAFF ROOM	HT	5
2	ROOM 210 KITCHEN	HT	5

3	ROOM 102 CARETAKER'S OFFICE	HT	2
4	BOILER ROOM	HT	3
5	ROOM 209(OLD STAFFROOM)	HT	6
SPRINKLER DEVICES			
1	MAIN VALVE TAMPER	SV	3
2	SPRINKLER MAIN FLOW	FSP	3
NOTIFYING DEVICES			
1	BY RM 222 NORTH HALL	B	
2	BY RM 226 NORTH HALL	B	
3	BY RM 230 NORTH HALL	B	
4	BY RM 203 EAST HALL	B	
5	BY RM 207 EAST HALL	B	
6	GYM	B	
7	BY RM 103 NORTH HALL	B	
8	BY RM 124 NORTH HALL	B	
9	BY RM 116 NORTH HALL	B	
10	BOILER RM	B	
EMERGENCY LIGHTING			

Location	# of Heads	Model
BY UNIT 101		EMERGI LITE
BY ROOM 107	2	AIMLITE
BOTTOM OF STAIRS		REMOTE
BY ROOM 125		EMERGI LITE
BOTTOM OF STAIRS		EMERGI LITE
BY ROOM 235	2	UNIT
BY ROOM 225		EMERGI LITE
TOP OF REAR STAIRS		REMOTE
BY ROOM 201		EMERGI LITE
BY ROOM 210		EMERGI LITE
GYM ENTRY		AIM LITE
BY ROOM 117		LHS
BOTTOM OF STAIRS		REMOTE

GYM		EMERGILIT E
BY ROOM 116		
BY RM 121	2	AIMLITE
BY RM 111	2	AIMLITE
BY RM 110	2	AIMLITE
GYM		AIMLITE
GYM BY STAGE		AIMLITE
GYM ON STAGE		AIMLITE
STAGE LEFT STAIRS		AIMLITE
STAGE RIGHT STAIRS		AIMLITE

	LOCATION: Westmount	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
1	BOILER ROOM	M	Zone #2
2	BOILER ROOM	HT	Zone #2
4	WEST WING NORTH EXIT	M	Zone #3
5	WEST WING CENTER EXIT	M	Zone #3
6	WEST WING RESOURCE ROOM	M	Zone #3
7	WEST WING SOUTH EXIT	M	Zone #3
9	GYM STORAGE	S	Zone #4
10	GYM	M	Zone #4
11	GYM HALL	M	Zone #4
12	MAIN ENTRANCE	M	Zone #5
13	MAIN HALL SOUTH EXIT	M	Zone #5
14	READING ROOM	S	Zone #5
15	PHOTO COPY ROOM	S	Zone #5
16	KITCHEN/STAFF ROOM	HT	Zone #5
17	EAST WING CENTER EXIT	M	Zone #6
18	EAST WING SOUTH EXIT	M	Zone #6
19	EAST WING NORTH EXIT	M	Zone #6

20	LEARNING CENTER ROOM	M	Zone #6
21	MAIN HALL BY BOILER ROOM	M	Zone #6

BELLS

MAIN ENTRANCE	B
GYM	B
BY LIBRARY	B
BY ROOM 20	B
BY ROOM 13	B
BY MUSIC ROOM	B
BY ROOM 2	B
BY ROOM 5	B
BY ROOM 10	B
O/S MAIN ENTRANCE	B

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	ENTRANCE BY BOILER ROOM		
	ENTRANCE BY ROOM 4		
	ENTRANCE BY ROOM 5		
	ENTRANCE BY FACP		
	MAIN GYM EXIT/MAIN SCHOOL ENTRANCE		
	SIDE GYM EXIT		
	GYM HALL ENTRANCE		
	ENTRANCE BY ROOM 12		
	ENTRANCE BY ROOM 21		
	ENTRANCE BY ROOM 15		
	ENTRANCE BY ROOM 16		
	ENTRANCE BY ROOM 20		
	ENTRANCE BY LEARNING CENTER		
	BOILER ROOM		
	MALE WASHROOM		

	MALE WASHROOM BY ROOM 10		
	FEMALE WASHROOM BY ROOM 3		
	MALE WASHROOM BY ROOM 17		
	FEMALE WASHROOM BY ROOM 18		
	EXIT BY RM 9		COMBO
	EXIT BY RM 10		COMBO
	BY RM 5		COMBO
	BOYS WASHROOM BY RM 6		EMERGILIT E
	ELECTRICAL RM		
	EXIT BY RM 4		
	BY RM 1		
	EXIT BY RM 1		COMBO
	BY GYM		COMBO
	EXIT BY FIRE ALARM		COMBO
	HALL BY PANEL E		AIMLITE
	BY MUSIC RM		AIMLITE
	GYM HALL		AIMLITE
	GYM HALL EXIT		COMBO
	HALL BY LIBRARY		COMBO
	EXIT BY LIBRARY		COMBO
	HALL BY RM 21		COMBO
	EXIT BY RM 20		COMBO
	HALL BY RM 18		COMBO
	HALL BY RM 17		COMBO
	EXIT BY RM 18		COMBO
	EXIT BY RM 15		COMBO
	BOYS WSHRM BY RM 17		EMERGILIT E
	BOILER RM		COMBO
	GIRLS WSHRM BY RM 5		
	HALL BY RM 5		AIMLITE
	HALL BY RM 11		AIMLITE
	BY RM 1		
	BY OFFICE		
	BY GYM STORAGE		COMBO
	GIRLS WSHRM BY RM 18		
	GYM		
	GYM		

GYM		
GYM		
GYM		
GYM		
STORAGE RIGHT		
BEHIND STORGAE		
REAR STORAGE		

	LOCATION: Halifax Central	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
2	BOILER ROOM	M	ZONE # 1
3	BOILER ROOM STAIRWELL	S	3
4	BOILER ROOM	HT	ZONE # 1
5	BOILER ROOM	HT	ZONE # 1
6	BOILER ROOM STORAGE	HT	ZONE # 1
7	ELECTRICAL ROOM	RHT	ZONE # 1
8	SPRINKLER ROOM	RHT	ZONE # 1
9	SPRINKLER ROOM	RHT	ZONE # 1
12	GYM - Left of stage	M	ZONE # 2
13	GYM - Back by outside exit	M	ZONE # 2
14	GYM - By Fire Extinguisher	M	ZONE # 2
15	GYM STORAGE - By Office	RHT	ZONE # 2
16	GYM STORAGE - By Double Doors	RHT	ZONE # 2
17	BOYS LOCKER ROOM	RHT	ZONE # 2
18	BOYS LOCKER ROOM	RHT	ZONE # 2
19	OFFICE OFF GYM	RHT	ZONE # 2
20	ROOM # 25 / PAPER ROOM	RHT	ZONE # 2
21	INDUSTRIAL ARTS OFFICE BY # 25	RHT	ZONE # 2

22	GIRLS LOCKER ROOM	RHT	ZONE # 2
23	GIRLS LOCKER ROOM	RHT	ZONE # 2
24	JANITORS ROOM	RHT	ZONE # 2
25	CUSTODIANS OFFICE	RHT	ZONE # 2
27	EXIT NEAR BOILER ROOM DR. (1ST FL)	M	ZONE #3
28	1ST FLOOR BY ROOM # 25	M	ZONE #3
29	WOOD SHOP STORAGE / EXPLOSION PROOF	HT	ZONE #3
30	HALL BY ROOM # 7	HT	ZONE #3
31	HALL BY MAIN OFFICE	RHT	ZONE #3
32	IN ROOM # 5	RHT	ZONE #3
33	IN ROOM # 6	RHT	ZONE #3
34	IN ROOM # 7	RHT	ZONE #3
35	STORAGE ROOM # 7	RHT	ZONE #3
36	PHOTOCOPY ROOM	RHT	ZONE #3
37	JANITORS ROOM STORAGE	RHT	ZONE #3
38	WOOD SHOP STORAGE	RHT	ZONE #3
39	WOOD SHOP	RHT	ZONE #3
40	WOOD SHOP	RHT	ZONE #3
41	IN HALL BY WOOD SHOP	RHT	ZONE #3
42	PRINCIPALS OFFICE	RHT	ZONE #3
43	SECRETARY'S OFFICE	RHT	ZONE #3
44	BY PRINCIPAL'S OFFICE WASHROOM	RHT	ZONE #3

45	IN HALL BY WOOD SHOP	EOL	ZONE #3
47	MAIN ENTRANCE	M	ZONE # 4
48	1ST FLOOR BY ROOM # 2	M	ZONE # 4
49	HALL BY TEACHERS ROOM	RHT	ZONE # 4
50	HALL BY ROOM # 2	RHT	ZONE # 4
51	IN FITNESS ROOM # 1	RHT	ZONE # 4
52	IN FITNESS ROOM # 1	RHT	ZONE # 4
53	IN ROOM # 1 STORAGE	RHT	ZONE # 4
54	IN ROOM # 2 LIBRARY BY MAIN DOOR	RHT	ZONE # 4
55	IN ROOM # 2 BY LIBRARY BY MAIN DOOR	RHT	ZONE # 4
56	IN ROOM # 3	RHT	ZONE # 4
57	IN ROOM # 4	RHT	ZONE # 4
58	HALL BY ROOM # 1 AND STAGE	RHT	ZONE # 4
59	HALL BY JANITORS ROOM	RHT	ZONE # 4
60	FITNESS ROOM	RHT	ZONE # 4
61	GYM STAGE EXIT ROOM	RHT	ZONE # 4
62	IN TEACHERS ROOM	RHT	ZONE # 4
63	JANITORS ROOM	RHT	ZONE # 4
65	2ND FLOOR BY ROOM # 17	M	ZONE # 5
66	NORTH STAIRWELL	S	ZONE # 5
67	HALL BY ROOM # 18	RHT	ZONE # 5
68	HALL BY AV ROOM	HT	ZONE # 5

69	ROOM # 15	RHT	ZONE # 5
70	ROOM # 17	RHT	ZONE # 5
71	ROOM # 17	RHT	ZONE # 5
72	ROOM # 17 STORAGE	RHT	ZONE # 5
73	ROOM # 18	RHT	ZONE # 5
74	ROOM # 18 CHEM STORAGE	RHT	ZONE # 5
75	ROOM # 18 STORAGE	RHT	ZONE # 5
76	ROOM # 19	RHT	ZONE # 5
77	ROOM # 20	RHT	ZONE # 5
78	JANITORS ROOM 2ND FLOOR	RHT	ZONE # 5
79	AV ROOM	RHT	ZONE # 5
80	PICTURE ROOM	RHT	ZONE # 5
81	ROOM # 14	RHT	ZONE # 5
82	VICE PRINCIPAL OFFICE	RHT	ZONE # 5
84	BY ROOM # 9 2ND FLOOR	M	ZONE # 6
85	SOUTH STAIRWELL	S	ZONE # 6
86	IN ROOM # 24	S	ZONE # 6
87	COOKING ROOM	RHT	ZONE # 6
88	COOKING ROOM	RHT	ZONE # 6
89	HALL BY ROOM # 10	RHT	ZONE # 6
90	HALL BY ROOM # 22	RHT	ZONE # 6
91	COOKING ROOM STORAGE A	RHT	ZONE # 6

92	COOKING ROOM STORAGE B	RHT	ZONE # 6
93	BY ROOM # 9 2ND FLOOR / BOOK ROOM	RHT	ZONE # 6
94	BY ROOM # 10	RHT	ZONE # 6
95	IN ROOM # 10	RHT	ZONE # 6
96	GUIDANCE OFFICE WAITING ROOM	RHT	ZONE # 6
97	IN ROOM # 11	RHT	ZONE # 6
98	IN ROOM # 12	RHT	ZONE # 6
99	IN ROOM # 13	RHT	ZONE # 6
100	IN ROOM # 22	RHT	ZONE # 6
101	GUIDANCE OFFICE	RHT	ZONE # 6
102	COOKING ROOM STORAGE B	EOL	ZONE # 6
108	COOK ROOM # 9	B	SIG # 1
109	BY ROOM # 10	B	SIG # 1
110	BY ROOM # 14	B	SIG # 1
111	METAL SHOP ROOM # 17	B	SIG # 1
112	BY ROOM # 18	B	SIG # 1
115	GYM	B	SIG # 2
116	GYM	B	SIG # 2
117	BOILER ROOM	B	SIG # 2
118	WOOD SHOP	B	SIG # 2
119	MUSIC ROOM # 1	B	SIG # 2
120	BY ROOM # 2	B	SIG # 2
121	BY ROOM # 7	B	SIG # 2

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	1ST FLOOR		
	BY ROOM 2		EMERGI-LITE JML 26
	LIBRARY		EMERGI-LITE

	STREET EXTERIOR ROOM		LITE PRO 2
	BOYS LOCKER ROOM		EMERGI- LITE PRO 2
	STAIRS TOP ADJ ROOM 9		EMERGI- LITE JML 36
	BY WOOD SHOP		EMERGI- LITE JML 36
	BY BACK EXIT (GYM)		EMERGI- LITE 6 PXM 36
	BY STAGE (GYM)		EMERGI- LITE 6 PXM 36
	BY FIRE HOSE (GYM)		EMERGI- LITE 6 PXM 36
	BY BREAKER PANEL (GYM)		LITHONIA- HX SW 3 R 120
	BELOW BALCONY (GYM)		LITHONIA- HX SW 3 R 120
	2ND FLOOR		
	ADJ STAIR TO BSMT		EMERGI- LITE JML 36
	AV ROOM		LUMACELL 3LMCEU2M 19W
	BY ROOM 10		EMERGI- LITE JML 36
	BY ROOM 13		EMERGI- LITE JML 36
	BY ROOM 18		EMERGI- LITE JML 36
	BOILER ROOM		EMERGI-

	UPPER LEVEL ENTRANCE		EMERGI-LITE JML 36
	SPRINKLER ROOM		EMERGI-LITE JML 36
	BOILER ROOM STAIRS		EMERGI-LITE JML 36
	ADJ MAIN ENT		UNIT
	2ND FL BY 20A		AIMLITE
	TOP OF STAIRS BY 17		AIMLITE
	TOP OF STAIRS BY 9		AIMLITE
	GYM STAGE LOBBY		COMBO
	BY STAFF RM		AIMLITE
	STAGE RHS		AIMLITE
	STAGE LHS		AIMLITE
	REAR GYM STAGE		COMBO

	LOCATION: Ecole Beaufort School
	FIRE ALARM PANEL: Notifier NFP 320
	FIRE ALARM DEVICES

Location Description	Device	Model	Address
----------------------	--------	-------	---------

MAIN SCHOOL

MAIN ENTRANCE	M	IM025	
BOTTOM OF STAIR BY 129	S		D13
IN RM 116	S		ID 027
IN RM 117	S		ID 028
IN RM 118	S		ID 029
BOTTOM SOUTH STAIRS	M		IM030
TOP OF STAIR 4	S		ID 012
TOP OF SOUTH STAIRS	M		IM 011
TOP OF SOUTH STAIRS	S		ID 008
TOP OF NORTH STAIRS	S		ID 002
TOP OF CENTRE STAIRS	S		ID 006
VESTIBULE 107	S		ID 013
CORRIDOR 102	S		ID 014
CORRIDOR 202	S		ID 016
TOP OF NORTH STAIRS	M		IM 001
TOP OF CENTRE STAIR	M		IM 005
NORTH STAIR 1ST FL	M		IM 016

HORNS

BY 106	H		
BY MAIN OFFICE	H		
BY 118	H		
IN 2ND FLR MUSIC RM	H		
BY 225	H		
BY 212	H		
IN 212	H		
BY 205	H		

ANNEX			
BY MAIN STAIRS	M		IM 040

BY 204	S		IM 040
BY ANNUNCIATOR	M		IM 040
IN ROOM B205	S		IM 040
BY REAR STAIRS	M		IM 040
OIL TANK ROOM	HT		OM 040
LOBBY 201	S		ID015

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	C
	MAIN AREA EXIT		UNIT	
	MAIN AREA ENTRANCE		REMOTE X 2	
	STAIR BY MAIN ENTRANCE		UNIT + REMOTE	
	BY 103		REMOTE	
	GIRLS WASHROOM		REMOTE	
	BY 106		UNIT	
	BY 108		REMOTE	
	BY 108 EXIT		REMOTE	
	BY 110		UNIT	
	STAIR TO ANNEX		UNIT + REMOTE	
	TOP OF ANNEX STAIR		REMOTE	
	BY B203		REMOTE	
	BY REAR STAIR		REMOTE	
	BY B201		UNIT	
	ANNEX SERVER ROOM		UNIT	
	IN STAIRS BY ANNUNCIATOR		REMOTE	
	STAIRS TO LOWER LEVEL		UNIT	
	BY R102		REMOTE	

	BY B102		REMOTE
	BY BACK DOOR		UNIT
	BY BOYS WSHRM AND REMOTE		UNIT
	BY B103		REMOTE
	MAIN OFFICE		UNIT + REMOTE
	BY 125		REMOTE
	BY 122		REMOTE
	BY PANEL B		REMOTE
	BOTTOM OF STAIRS		REMOTE
	TOP OF STAIRS		UNIT
	BY 218		REMOTE
	MUSIC ROOM		UNIT
	BY 225		UNIT
	BY 227		REMOTE
	BY RAMP		UNIT
	BY RAMP		REMOTE
	TOP CENTRE STAIRS		REMOTE
	BY 211		REMOTE
	BY 205		UNIT
	BY 208		REMOTE
	REAR STAIRS		UNIT IN CEILING
	TOP OF STAIRS BY LUNCH RM		UNIT

	LOCATION:Gorsbrook
	FIRE ALARM PANEL:Edwards 6500
MANUAL PULL STATIONS	
1	GYM(#1)
2	GYM(#2)
3	GYM(#3)
4	GYM(#4)
5	BY ARTROOM 3(#5)
6	OUTSIDE BOILER ROOM(#6)
7	BY CLASS 10(#7)
8	MAIN NORTH EXIT BY ROOM 13(#8)
9	CENTER BACK EXIT BY ROOM 18(#9)
10	BY ELEVATOR MAIN FLOOR (#10)
11	EXIT BY CLASS 46(#11)
12	BASEMENT BY ROOM 36(#12)
13	BASEMENT NORTH EXIT (#13)
14	BASEMENT MIDDLE (#14)
15	BOILER ROOM(#15)
16	ENTRANCE BY OFFICE
SMOKE DETECTORS	
1	STORAGE BY OFFICE
2	PENTHOUSE
3	ELEVATOR ROOM
4	SOUTH STAIRS
5	WEST STAIRS
6	BOILER ROOM STAIRS
7	GYM STORAGE STAIRS
8	ELECTRICAL ROOM
DUCT SMOKE DETECTORS	
1	PENTHOUSE DUCT DETECTOR
HEAT DETECTORS	
1	BASEMENT STORAGE ROOM
2	BOILER ROOM
3	BOILER ROOM
4	JANITORS RM NEAR FIRE PANEL
NOTIFYING DEVICES	
CIRCUIT #1	

BY GUIDANCE OFFICE #19	B	6"
CORRIDOR BY GIRL'S WASHROOM	B	6"
CORRIDOR BY RESOURCE RM #11	B	6"
CORRIDOR BY STAFF/ CUSTODIAN RM	B	6"
HALL NEAR MUSIC ROOM	B	6"
GYM	B	6"
BOILER ROOM	B	6"
BOILER ROOM	EOL	6"

CIRCUIT #2

FOODS ROOM BASEMENT RM 38	B	6"
CORRIDOR BY FOODS ROOM 38	B	10"
CORRIDOR BY WOOD WORKING RM 30	B	10"
WOOD WORKING ROOM 30	B	6"
CORRIDOR BY WOOD WORKING	EOL	

CIRCUIT #3

CORRIDOR BY LIBRARY RM 25	B	6"
---------------------------	---	----

Fire Door Number or Location
BY PENTHOUSE ACCESS
BY ROOM 41
BASEMENT FRONT CORRIDOR
BASEMENT CENTER CORRIDOR
BASEMENT REAR CORRIDOR

Line #	EL UNIT Location	MOD #	Manuf.
1	Stairwell Exit by Room 40, #17	RG12-144QB	Lumacell
2	By Room 37 #18	RG12-144QB	Lumacell

3	By Room 36 #19	RG362MT9W	Lumacell
4	By Room 20 #20	RG12-144QB	Lumacell
5	BY Fire alarm panel	REMOTE	REMOTE
6	By Elevator #21	RG12144QB212	Lumacell
7	Elevator Room	RG12-144QB	Lumacell
8	Stairwell By Elevator #23	RG12-144QB	Lumacell
9	2nd Floor By Boys Washroom	RG12-144QB	Lumacell
10	**Top Elevator Stairwell	REMOTE	REMOTE
11	**Top Elevator	REMOTE	REMOTE
12	**Boys Washroom	REMOTE	REMOTE
13	**Girls Washroom	REMOTE	REMOTE
14	By Room 18 #12	RG12-144QB	Lumacell
15	By Room 10 #13	RG12-144QB	Lumacell
16	By Room 16 #11	RG12-144QB	Lumacell
17	By Room 11 #9	RG12-144QB	Lumacell
18	**Exit By Room 9 #8	REMOTE	REMOTE
19	**By Administration Office	REMOTE	REMOTE
20	Hallway By Admin(#8)	RG12-144QB	Lumacell
21	**Washroom By Room 3	REMOTE	REMOTE
22	**Hall By Gym Entrance	REMOTE	REMOTE
23	By Boiler Room in Hall	RG12-144QB	Lumacell
24	Boiler Room Top Stairs(#7)	RG12-144QB	Lumacell
25	**Boiler Room	REMOTE	REMOTE
26	**Boiler Room Bottom Stairs	REMOTE	REMOTE
27	By Room 22(LOCKERS)	RG12-144QB	Lumacell
28	By Library	RG12-144QB	Lumacell
29	Lobby By Room 46	RG12-144QB	Lumacell
30	Gym Entrance Lobby(#41/2)	RG12-144QB	Lumacell
31	**Girls Locker Room	REMOTE	REMOTE
32	**Girls Locker Room Wash.	REMOTE	REMOTE
33	**Boys Locker Room	REMOTE	REMOTE
34	**Boys Locker Room Wash	REMOTE	REMOTE
35	Gym	PXM 36	Emergi-Lite
36	Gym	PXM 36	Emergi-Lite
37	Gym BY PULL STATION 2	PXM 36	Emergi-Lite
38	Gym	PXM 36	Emergi-Lite
39	South Stairs	PXM 36	Emergi-Lite
40	EXIT TO SOUTH STAIRS #15		Lumacell

	LOCATION: Highland Park	Device	Device address or circuit number
	FIRE ALARM PANEL: NOTIFIER		
MANUAL PULLSTATIONS			
1	MAIN ENTRANCE	M	M9
2	ROOM # 400	M	M20
3	ROOM # 404	M	M10
4	ROOM # 410	M	M14
5	ROOM # 411	M	M16
6	BY ROOM # 410	M	M15
7	STAIRS BY BOYS WASHROOM	M	M24
8	BY OFFICE ENTRANCE	M	M07
9	RESOURCE ROOM	M	M05
10	BY ROOM # 204 ENTRANCE	M	M04
11	RESOURCE ROOM	M	M30
12	LEARNING CENTER	M	M28
13	HALL ESOURCE ROOM	M	M34
14	GYM	M	M46
15	GYM SIDE ENTRANCE	M	M47
16	GYM STAGE	M	M44
17	FAN ROOM HALL	M	M48
18	BOILER ROOM	M	M54
HEAT DETECTORS			
19	CLOSET IN RM 407	HT	19
20	ROOM # 400	HT	22
21	CLOSET IN RM 406	HT	11
22	ROOM # 400 STORAGE	HT	21
23	ROOM 400 CLOSET	HT	23
24	PAINT BOOTH	HT	27
25	JANITORS ROOM BY #403	HT	2
26	GYM STORAGE	HT	49
27	PAPER STORAGE BY JANITORS RM	HT	
28	FAN ROOM	HT	51
29	BOILER ROOM	HT	53
30	BOILER ROOM	HT	52
31	STORAGE ADJ.GYM	HT	45
	PAPER RM. UNDERSTAIRS	HT	3

	ROOM 408	HT	12
	ROOM 410	HT	13
	ROOM 411	HT	17
	ROOM 409	HT	18

SMOKE DETECTORS

	OFFICE HALL	S	D54
32	GYM HALL	S	D50
33	LIBRARY	S	D41
34	LIBRARY	S	D40
35	STAIRS BY BOYS WASHROOM	S	D26
36	STAIRS BY BOYS WASHROOM	S	D25
37	STAIRS BY BOYS WASHROOM	S	D26
38	RESOURCE/LEARNING HALL	S	D29
39	RESOURCE ROOM	S	D31
40	RESOURCE ROOM	S	D32
41	HALL BEHIND ROOM RESOURCE	S	D35
42	MAIN ENTRANCE	S	D42
	MAIN ELECTRICAL ROOM	S	1

NOTIFYING DEVICES

43	BY OFFICE	B	SIG # 1
44	BY ROOM # 400	B	SIG # 1
45	BY ROOM # 404	B	SIG # 1
46	BY ROOM # 410	B	SIG # 1
47	GYM ENTRY	B	SIG # 1
48	BOILER ROOM	B	SIG # 1
49	BY SPRINKLER ROOM	B	SIG # 1
50	MUSIC ROOM	B	SIG # 1
51	LEARNING CENTRE	B	SIG # 1
52	BEHIND WOODSHOP	B	SIG # 1
53	GYM	B	SIG # 1
54	GYM	B	SIG # 1

	DOOR RELEASE	RLY	
	MAIN CONTROL #1	G/V	60
	MAIN CONTROL #2	G/V	60

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	BY RM 411		
	BY OFFICE		AIMLITE

	HALL @ STAIRS		
	RESOURCE 301		
	RESOURCE 301		
	BY BOYS WASHRM UPPER HALL		LUMACELL
	MAIN ENTRANCE		
	MAIN ENTR HALL		
	BY 405		
	BY 409		
	STAIRS BY BOYS WASHRM		COMBO
	ART RM 300		COMBO
	BACK WALL OF ART RM 300		COMBO
	STAIRS BY OFFICE		COMBO
	GYM HALL @ RM 102		EMERGI- LITE
	BOILER RM		
	STAIRS BOTTOM		REMOTE
	EXIT BY CARETAKERS OFFICE		LUMACELL
	IN RM 410		COMBO UNIT
	IN RM 404		COMBO UNIT
	IN RM 411		
	GYM FOYER		
	IN GYM REAR		COMBO
	IN GYM TO SIDE DOOR		COMBO
	GYM MAIN ENTR		COMBO

	GYM SIDE DOOR		COMBO
	HALL BEHIND ART RM #10		
	BY COMMUNITY RM 204		
	MAIN STAIR LANDING		
	BY RM 204		
	JANITOR'S RM		AIMLITE
	ELECTRICAL RM OFF JANITOR'S RM		
	STAIRS BY OFFICE		COMBO
	FAN RM BY GYM		AIMLITE
	GYM REAR EXIT		
	STAGE BY BREAKER PANEL		COMBO

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS		
---	--	--

1	PANEL 'A' IN ELECTRICAL ROOM CCT 2,4,5,6,7 (CUSTODIAN ROOM)	
---	---	--

	LOCATION: Inglis Street Ele.	Device	Device address or circuit number

	FIRE ALARM PANEL: MIRCON FA-300		
--	--	--	--

MANUAL PULL-STATIONS

1	BOILER ROOM	M	5
2	BY ELECTRICAL ROOM	M	2
3	BY SPRINKLER ROOM # 105	M	2
4	BY ROOM # 114 (CARETAKER'S OFFICE)	M	2
5	GYM ENTRANCE	M	6
6	BY ROOM # 206	M	6
7	BY ROOM # 212	M	6
8	GYM EXIT	M	3
9	GYM EXIT	M	3
10	BY ROOM # 308	M	7
11	BY ROOM # 315	M	7

HEAT DETECTORS

12	ELECTRICAL ROOM	HT	2
13	ELECTRICAL ROOM / PUMP ROOM	HT	2
14	ROOM # 107 / FAN ROOM	HT	2
15	ROOM # 108 / 109	HT	2
16	ROOM # 204	HT	6
17	BOILER ROOM	HT	5
18	ROOM # 311	HT	7

SMOKE DETECTORS

19	ROOM # 106	S	2
20	ROOM # 110	S	2
21	SOUTH STAIRS/By Room#315	S	4
22	NORTH STAIRS/By Room#308	S	8

EOL

25	ROOM # 204	EOL	6
26	GYM EXIT	EOL	3
27	BY SPRINKLER ROOM # 105	EOL	2
28	BY ROOM # 308	EOL	7
29	SOUTH STAIRS	EOL	4
30	NORTH STAIRS	EOL	8

31	BOILER ROOM	EOL	5
----	-------------	-----	---

NOTIFYING DEVICES

32	BY ROOM # 107	B	1
33	BY ROOM # 111	B	1
34	BY ROOM # 206	B	1
35	BY ROOM # 212	B	1
36	BY ROOM # 306	B	1
37	BY ROOM # 315	B	1
38	BOILER ROOM	B	1
39	GYM	B	1

SPRINKLER

	MAIN SPRINKLER RM. G/V	SUPV	1
	SPRINKLER RM. G/V	SUPV	1
	SPRINKLER ROOM FLOW	FLOW	1

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head
1	Main Entrance		
2	By Room 212		
3	2nd Floor Boys Washroom		
4	Lobby to Gym		
5	Outside Lobby to Gym		
6	By Room 210		
7	By Room 208		
8	2nd Floor Back Lobby Entrance		
9	2nd Floor Back Lobby Exit		
10	2nd Floor Back Lobby Stairwell		
11	2nd Floor Girls Washroom		
12	Outside Sprinkler Room		
13	1st Floor Back Lobby Entrance		
14	By Room 104		
15	1st Floor Girls Washroom		
16	By Room 110		
17	By Room 102		
18	1st Floor Hall By Front Lobby		
19	1st Floor Front Lobby		
20	1st Floor Front Lobby Stairwell		
21	1st Floor Front Lobby Back Exit		
22	Electrical Room		
23	3rd Floor Front Stairs		
24	By Room 315		

25	3rd Floor Boys Washroom		
26	By Room 313		
27	By Room 310		
28	3rd Floor Back Lobby Entrance		
1	3rd Floor Back Lobby Stairwell		
2	3rd Floor Girls Washroom		
3	Gym		
4	Gym		
5	Gym		
6	Girls Change Room		
7	Girls Change Room Lower		
8	Boys Change Room		
9	Boys Change Room Lower		
	EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS		
	Emergency light panel for most of EM lights in Panel "J" CCT#2 and 4, first Floor corridor by room 113		

	LOCATION: Sir Charles Tupper	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards 6500			
MANUAL PULL-STATIONS			
1	GYM	M	ZONE 4
2	GYM	M	ZONE 4
3	BY GYM BALCONY	M	ZONE 5
4	BY STAFF WASHROOM	M	ZONE 6
5	BY ROOM # 8	M	ZONE 6
6	BY ROOM # 1	M	ZONE 6
7	BY ROOM # 5	M	ZONE 6
8	BY ROOM # 3	M	ZONE 5
9	BY ROOM # 2	M	ZONE 5
10	BY ROOM # 11	M	ZONE 5
11	MUSIC ROOM	M	ZONE 2
12	BOTTOM OF CENTRE STAIRWELL	M	ZONE 5
13	FRONT ENTRANCE	M	ZONE 5
14	BY GRADE PRIMARY ROOM	M	ZONE 5
15	BOILER ROOM	M	ZONE 3
16	ART ROOM	M	ZONE 2
17	BY TEACHERS ROOM BASEMENT	M	ZONE 2
HEAT DETECTORS			
18	TEACHERS STR NEXT SPRINKLER RM	HT	ZONE # 6
19	BOILER ROOM	HT	ZONE # 3
20	KITCHEN IN GYM	HT	ZONE # 4
21	2ND FLOOR KITCHEN	HT	ZONE # 6
SMOKE DETECTORS			
22	NORTH STAIRWELL	S	ZONE #1
23	NORTHEAST STAIRWELL	S	ZONE #7
24	SOUTHEAST STAIRWELL	S	ZONE # 8

25	SOUTHWEST STAIRWELL	S	ZONE # 9
----	---------------------	---	-------------

EOL

26	ROOM # 204	EOL	ZONE # 4
27	GYM EXIT	EOL	ZONE # 5
28	BY SPRINKLER ROOM # 105	EOL	ZONE # 3
29	BY ROOM # 308	EOL	ZONE # 6
30	SOUTH STAIRS	EOL	ZONE # 7
31	NORTH STAIRS	EOL	ZONE # 8
32	BOILER ROOM	EOL	ZONE # 2

NOTIFYING DEVICES

33	HALLWAY BY ROOM 2	B	SIG # 1
34	HALLWAY BY ROOM 9	B	SIG # 1
35	HALLWAY BY ROOM 12	B	SIG # 1
36	2ND FLOOR HALLWAY BY ROOM 6	B	SIG # 1
37	GYM	B	SIG # 1
38	BOILER ROOM	B	SIG # 1
39	BASEMENT NEAR CUSTODIAN OFFICE	B	SIG # 1
40	NEXT TO SPRINKLER ROOM	B	SIG # 1

SPRINKLER

	SPRINKLER RM.	TAMPER	1
	SPRINKLER RM.	TAMPER	1
	SPRINKLER RM.	FLOW	1
	SPRINKLER RM.	EOL	1

EMERGENCY LIGHTING

Location	# of Heads	Model
MAIN ENT TO GYM	2	LUMACELL
GYM LEFT #10	2	EMERGI-LITE
GYM RIGHT #11	2	EMERGI-LITE

		TYPE
GYM MAIN ENT #12	2	EMERGI-LITE
FOYER ADJ TO GYM FR HALL	2	LITHONIA
3RD FL RESOURCE RM	2	EMERGI-LITE
ADJ RESOURCE RM	2	REMOTE
3RD FL HALL ADJ RM 7	2	REMOTE
FOYER BY BOILER RM	2	LITHONIA
ART ROOM	2	LUMACELL COMBO
ENT BY BALCONY	2	EMERGI-LITE COMBO
BY OFFICE NEAR STAIRS	2	REMOTE
HALL BY RM 2 (1)	2	LUMACELL
HALL BY RM 2 (2)	2	REMOTE
BSMT ADJ MAINT OFF	2	COMBO UNIT
BSMT STAIR ADJ SPK RM	2	COMBO UNIT
MUSIC ROOM	2	
ON STAGE	2	AIMLITE
NEAR GYM STAGE EXIT	2	COMBO
OUTSIDE	2	AIMLITE

OUTSIDE CUSTODIAN ROOM	2	AIMLITE
OUTSIDE CUSTODIAN RM BOTTOM STAIR	2	COMBO
BASEMENT BOYS WASHROOM	2	AIMLITE
BASEMENT GIRLS WASHROOM	2	AIMLITE
ABOVE GYM ENTRANCE NEAR MAIN ENTRANCE	2	AIMLITE
BOILER ROOM	2	AIMLITE
OUTSIDE OFFICE	2	COMBO
OUTSIDE OFFICE	2	REMOTE
2ND FLOOR BY STAIR	2	REMOTE
2ND FLOOR BY STAIR	2	REMOTE
2ND FLOOR BY ROOM 4	2	REMOTE
3RD FLOOR BY STAIR	2	REMOTE
3RD FLOOR BY STAIR	2	REMOTE
3.5 FLOOR ABOVE RM 12	2	AIMLITE
3RD FLR CENTRAL CORRIDOR	2	AIMLITE

	LOCATION: Saint Mary's	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
MANUAL PULL STATIONS			
1	GYM	M	Zone #3
2	By Gym Office	M	Zone #3
3	BASEMENT BY SIDE STAIRS	M	Zone #5
4	BASEMENT BY SIDE EXIT	M	Zone #5
5	BASEMENT BY BACK STAIRS	M	Zone #5
6	SIDE EXIT LEFT	M	Zone #6
7	MAIN ENTRANCE	M	Zone #7
8	TOP OF STAIRS BY OFFICE	M	Zone #7
9	TOP OF STAIRS BACK	M	Zone #7
10	RM 208	M	6
11	RM 206	M	6
12	RM 205	M	6
12	RM	M	6
SMOKE DETECTORS			
1	GYM Electrical Room	S	Zone #3
2	BACK TOP OF STAIRS	S	Zone #8
3	TOP OF SIDE STAIRS	S	Zone #8
HEAT DETECTORS			
1	BOILER ROOM	HT	Zone #4
NOTIFYING DEVICES			
1	BY OFFICE	B	Sig #1

2	SIDE HALL UPPER FLOOR	B	Sig #1
3	BACK HALL UPPER FLOOR	B	Sig #1
4	BASEMENT	B	Sig #2
5	BASEMENT	B	Sig #2
6	GYM	B	Sig #2

END OF LINE RESISTORS

1	SPRINKLER	EOL	Zone #1
2	SPRINKLER	EOL	Zone #2
3	GYM	EOL	Zone #3
4	BOILER ROOM	EOL	Zone #4
5	BASEMENT BY BACK STAIRS	EOL	Zone #5
6	SIDE EXIT LEFT	EOL	Zone #6
7	TOP OF STAIRS BACK	EOL	Zone #7

EMERGENCY LIGHTING

Location	# of Heads	Model	Circuit #
MAIN ENTRANCE		PXM 18 EMERGI LITE	STANPRO
SIDE HALL BY ROOM 205		PXM 18 EMERGI LITE	
TOP BACK STAIRS BY ROOM 203		6 PXM 36 EMERGI - LITE	STANPRO
BOTTOM BACK STAIRS BY ROOM 113		6 PXM 36 EMERGI - LITE	
BOTTOM SIDE STAIRS BY REAR EXIT		6 PXM 36 EMERGI - LITE	
GYM FRONT		6 PXM 36 EMERGI - LITE	
TOP BACK CORRIDOR		6 PXM 36 EMERGI - LITE	
GYM SIDE		6 PXM 36 EMERGI - LITE	

GYM BACK		PXM 36 EMERGI LITE	
PORTABLE		UNIT	
PORTABLE		UNIT	
PORTABLE		EXIT	
PORTABLE		EXIT	
CLASS RM 206		UNIT	
CLASS RM 205		UNIT LUMACELL	
BOILER RM		UNIT	
BOTTOM STAIRS BY GIRLS WASHROOM			STANPRO
MIDDLE SIDE STAIRS			STANPRO

	LOCATION: St. Stevens	Device	Device address or circuit number
	FIRE ALARM PANELS: Edwards 6500		
MANUAL PULL STATIONS			
1	BY MAIN OFFICE	M	ZONE 1
2	BY TEACHER'S ROOM	M	ZONE 1
3	BY PHYS ED	M	ZONE 1
4	BY ROOM 18 and EOL	M	ZONE 1
5	BY ROOM 15	M	ZONE 1
6	GYM MAIN ENTRY	M	ZONE 2
7	GYM LEFT SIDE	M	ZONE 2
8	GYM REAR and EOL	M	ZONE 2
9	BOILER ROOM and EOL	M	ZONE 3
10	BY ROOM 4 and EOL	M	ZONE 5
12	BY ROOM 2	M	ZONE 5
13	BY ROOM 8	M	ZONE 5
SMOKE DETECTORS			
1	GYM STAGE STORAGE	SI	ZONE 2
2	GYM EXIT LEFT	SI	ZONE 2
HEAT DETECTORS			
1	TEACHERS ROOM	HT	ZONE 5
2	BOILER ROOM	HT	ZONE 3

SPRINKLER DEVICES

1	SPRINKLER ROOM	PS	ZONE 4
2	SPRINKLER ROOM MAIN GATE VALVE	SV	ZONE 4
3	SPRINKLER ROOM ALARM LINE	SV	ZONE 4

NOTIFYING DEVICES

1	BY ROOM 6	B	SIG. 1
2	BY ROOM 10	B	SIG. 1
3	GYM	B	SIG. 1
4	BY ROOM 21	B	SIG. 1
5	BOILER ROOM	B	SIG. 1
6	BY ROOM 10	B	SIG. 1

END OF LINE RESISTORS

1	BY ROOM 4	EOL	ZONE 5
2	BOILER ROOM	EOL	ZONE 3
3	GYM REAR	EOL	ZONE 2
4	BY ROOM 18	EOL	ZONE 1

Location	# of Heads	Model	C
BY OFFICE		EMERGI-LITE	
IN OFFICE		AIMLITE	
PANEL "E" CCT 1			
BY CLASSRM 12		EMERGI-LITE	
PANEL "F" CCT 1			
BY CLASSRM 18		EMERGI-LITE	

PANEL "E" OCT 7		
NORTH HALL BY RM 13		EMERGI-LITE
NORTH HALL BY RM 15		EMERGI-LITE
BETWEEN RM 13 & 14		COMBO
PANEL "A" OCT 14		
SOUTH HALL BY RM 4		EMERGI-LITE
PANEL "B" OCT 4		
SOUTH HALL BY RM 10		EMERGI-LITE
SOUTH HALL BY RM 4		AIMLITE
PANEL "B" RM 8		
SOUTH HALL BY RM 8		COMBO
BOILER RM		EMERGI-LITE
GYM FRONT		EMERGI-LITE
GYM SIDE		EMERGI-LITE
BRKR PNL IN GYM		
STORAGE LEFT OF STAGE OCT 9		
GYM BY STAGE		EMERGI-LITE
STAGE WING		EMERGI-LITE

STAGE WING		EMERGENCY-LITE
STORAGE RM RIGHT STAGE	AIMLIGHT	
BY RM 17	AIMLITE	
BY RM 21	AIMLITE	
BY RM 14	AIMLITE	
HALL BY GIRL'S LOCKER RM	AIMLITE	
HALL BY STAFF RM	COMBO	
BY RM 3	AIMLITE	

	LOCATION: Citadel High
	FIRE ALARM PANEL: Edwards QS4
	FIRE ALARM DEVICES

Location Description	Device	Model	Address
----------------------	--------	-------	---------

DETECTORS FOR PANEL 1 CARD 1

TOP OF STAIRS #6	SMK	SIGA-PS	1
2ND FLOOR CHORAL ROOM 2075	SMK	SIGA-PS	2
CORRIDOR 2076 ADJ. TEAM ROOM 2077	SMK	SIGA-PS	3
2ND FLOOR ELECTRICAL ROOM 2060	SMK	SIGA-PS	4
2ND FLOOR TEAM ROOM 2077 EAST	SMK	SIGA-PS	5
2ND FLOOR TEAM ROOM 2077 WEST	SMK	SIGA-PS	6
2ND FLOOR CORRIDOR ADJ. TEAM ROOM NORTH	SMK	SIGA-PS	7
TOP OF STAIR #5 LIBRARY	SMK	SIGA-PS	8

MODULES FOR PANEL 1 CARD 1

1ST FLOOR MAIN ENTRANCE	PULL	SIGC-270B	126
1ST FLOOR STAIR #5 EXIT	PULL	SIGC-270B	127
SCHOOL GYM EXIT	PULL	SIGC-270B	128
1ST FLOOR EXIT BY RECYCLING	PULL	SIGC-270B	129
1ST FLOOR NE STAIR #6 EXIT	PULL	SIGC-270B	130
CIVIC GYM EXIT	PULL	SIGC-270B	131
1ST FLOOR NORTH EXIT	PULL	SIGC-270B	132
2ND FLOOR N SPRINKLER GATE VALVE MECHANICAL ROOM 2078	SUPV	SIGA-CT2	133
2ND FLOOR NORTH SPRINKLER FLOW	FLOW	SIGA-CT2	134
1ST FLOOR GYM AREA GATE VALVE MECHANICAL ROOM 2078	SUPV	SIGA-CT2	135
1ST FLOOR GYM AREA SPRINKLER FLOW	FLOW	SIGA-CT2	136
1ST FLOOR N SPRINKLER GATE VALVE MECHANICAL ROOM 2078	SUPV	SIGA-CT2	137
1ST FLOOR NORTH SPRINKLER FLOW	FLOW	SIGA-CT2	138
AHU #2 EXHAUST FAN RELAY MECHANICAL ROOM 2078	RLY	SIGA-CR	139
AHU #2 SUPPLY FAN	RLY	SIGA-CR	140

AHU #2 SUPPLY FAN RELAY MECHANICAL 2078	RLY	SIGA-CR	140
AHU #1 EXHAUST FAN RELAY MECHANICAL ROOM 2078	RLY	SIGA-CR	141
AHU #1 SUPPLY FAN RELAY MECHANICAL ROOM 2078	RLY	SIGA-CR	142

Location Description	Device	Model	Address
2ND FLOOR NE STAIR #6	PULL	SIGC-270B	143
2ND FLOOR M/L RELAY CORRIDOR 2075	RLY	SIGA-CR	144
DOORS STAIR #5 LIBRARY	RLY	SIGA-CR	145
2ND FLOOR LIBRARY STAIR 2067	PULL	SIGC-270B	146
1ST FLOOR LIBRARY STAIR EXIT DOOR HOLDER	RLY	SIGA-CR	147
AUDITORIUM EXIT STAGE	PULL	SIGC-270B	148
1ST FLOOR MAG HOLDER AT 1084	RLY	SIGA-CR	149
2ND FLOOR CORRIDOR LIBRARY STAIR 2068	PULL	SIGC-270B	150

DETECTORS FOR PANEL 1 CARD 2

MECHANICAL SPINE DETECTOR 1 OF 15	SMK	SIGA-PS	1
MECHANICAL SPINE DETECTOR 2 OF 15	SMK	SIGA-PS	2
MECHANICAL SPINE DETECTOR 3 OF 15	SMK	SIGA-PS	3
MECHANICAL SPINE DETECTOR 4 OF 15	SMK	SIGA-PS	4
MECHANICAL SPINE DETECTOR 5 OF 15	SMK	SIGA-PS	5
MECHANICAL SPINE DETECTOR 6 OF 15	SMK	SIGA-PS	6
MECHANICAL SPINE DETECTOR 7 OF 15	SMK	SIGA-PS	7
MECHANICAL SPINE DETECTOR 8 OF 15	SMK	SIGA-PS	8
MECHANICAL SPINE DETECTOR 9 OF 15	SMK	SIGA-PS	9
MECHANICAL SPINE DETECTOR 10 OF 15	SMK	SIGA-PS	10
MECHANICAL SPINE DETECTOR 11 OF 15	SMK	SIGA-PS	11
MECHANICAL SPINE DETECTOR 12 OF 15	SMK	SIGA-PS	12
MECHANICAL SPINE DETECTOR 13 OF 15	SMK	SIGA-PS	13
MECHANICAL SPINE DETECTOR 14 OF 15	SMK	SIGA-PS	14

DETECTOR 14 OF 15			
MECHANICAL SPINE DETECTOR 15 OF 15	SMK	SIGA-PS	15
TOP OF STAIR #1	SMK	SIGA-PS	16
TOP OF STAIR #2	SMK	SIGA-PS	17
TOP OF STAIR #3	SMK	SIGA-PS	18
3RD FLOOR STORAGE/KILN ROOM 3051	SMK	SIGA-PS	19
TOP OF ELEVATOR SHAFT	SMK	SIGA-PS	20

Location Description	Device	Model	Address	2 C
2ND FLOOR ELECTRICAL ROOM 2029	SMK	SIGA-PS	21	
IM BASEMENT MECHANICAL ROOM B001 (IN)	IM	SIGA-IM	22	
IM BASEMENT MECHANICAL ROOM B001 (OUT)	IM	SIGA-IM	23	
1ST FLOOR MAIN LOBBY	SMK	SIGA-PS	24	
3RD FLOOR BY STAIR #3 CORRIDOR	SMK	SIGA-PS	25	
3RD FLOOR BY ROOM 3043 CORRIDOR	SMK	SIGA-PS	26	
3RD FLOOR BY ROOM 3038 CORRIDOR	SMK	SIGA-PS	27	
3RD FLOOR BY ROOM 3035 CORRIDOR	SMK	SIGA-PS	28	
3RD FLOOR BY ROOM 3029 CORRIDOR	SMK	SIGA-PS	29	
3RD FLOOR BY STAIR #2 CORRIDOR	SMK	SIGA-PS	30	
3RD FLOOR BY ROOM 3017 CORRIDOR	SMK	SIGA-PS	31	
3RD FLOOR BY ROOM 3016 CORRIDOR	SMK	SIGA-PS	32	
3RD FLOOR BY ROOM 3011 CORRIDOR	SMK	SIGA-PS	33	
3RD FLOOR BY ROOM 3009 CORRIDOR	SMK	SIGA-PS	34	
3RD FLOOR BY STAIR #1 CORRIDOR	SMK	SIGA-PS	35	
2ND FLOOR BY STAIR #3 CORRIDOR	SMK	SIGA-PS	36	
2ND FLOOR BY ROOM 2040 CORRIDOR	SMK	SIGA-PS	37	
2ND FLOOR BY ROOM 2035 CORRIDOR	SMK	SIGA-PS	38	
2ND FLOOR BY ROOM 2034 CORRIDOR	SMK	SIGA-PS	39	
2ND FLOOR BY ROOM 2028 CORRIDOR	SMK	SIGA-PS	40	
2ND FLOOR BY STAIR #2	SMK	SIGA-PS	41	

CORRIDOR			
2ND FLOOR BY ROOM 2017 CORRIDOR	SMK	SIGA-PS	42
2ND FLOOR BY ROOM 2016 CORRIDOR	SMK	SIGA-PS	43
2ND FLOOR BY ROOM 2015 CORRIDOR	SMK	SIGA-PS	44
2ND FLOOR BY ROOM 2009 CORRIDOR	SMK	SIGA-PS	45
2ND FLOOR BY STAIR #1 CORRIDOR	SMK	SIGA-PS	46
1ST FLOOR BY ROOM 1035 CORRIDOR	SMK	SIGA-PS	47
1ST FLOOR BY ROOM 1032 CORRIDOR	SMK	SIGA-PS	48

Location Description	Device	Model	Address
1ST FLOOR BY ROOM 1030 CORRIDOR	SMK	SIGA-PS	49
1ST FLOOR BY ROOM 1026 CORRIDOR	SMK	SIGA-PS	50
1ST FLOOR BY ROOM 1025 CORRIDOR	SMK	SIGA-PS	51
1ST FLOOR BY STAIR #2 CORRIDOR	SMK	SIGA-PS	52
1ST FLOOR BY ROOM 1013 CORRIDOR	SMK	SIGA-PS	53
1ST FLOOR BY ROOM 1011 CORRIDOR	SMK	SIGA-PS	54
1ST FLOOR BY ROOM 1007 CORRIDOR	SMK	SIGA-PS	55
1ST FLOOR BY STAIR #1 CORRIDOR	SMK	SIGA-PS	56

MODULES FOR PANEL 1 CARD 2

LIBRARY MEZZANINE	PULL	SIGC-270B	126
2RD FLOOR MECHANICAL ROOM 3056	PULL	SIGC-270B	127
3RD FLOOR SE STAIR #1 EXIT	PULL	SIGC-270B	128
AHU #3 EXHAUST FAN RELAY ROOM 3056	RLY	SIGA-CR	129
AHU #3 SUPPLY FAN RELAY ROOM 3056	RLY	SIGA-CR	130
AHU #4 EXHAUST FAN RELAY ROOM 3056	RLY	SIGA-CR	131
AHU #4 SUPPLY FAN RELAY ROOM 3056	RLY	SIGA-CR	132
3RD FLOOR D/H RELAY STAIR #1	RLY	SIGA-CR	133
3RD FLOOR STAFF KITCHEN STAIR	PULL	SIGC-270B	134
3RD FLOOR E STAIR #2 EXIT	PULL	SIGC-270B	135

EX11			
3RD FLOOR D/H RELAY STAIR #2	RLY	SIGA-CR	136
3RD FLOOR CORRIDOR D/H RELAY & MAG 3001 S	RLY	SIGA-CR	137
STAIR #3 3RD FLOOR	RLY	SIGA-CR	138
3RD FLOOR ELEVATOR LOBBY	PULL	SIGC-270B	139
3RD FLOOR ELEVATOR MACHINE ROOM GATE VALVE	SUPV	SIGA-CT2	140
ELEVATOR GATE VALVE #141	SUPV	SIGA-CT2	141
2ND FLOOR PEDWAY EXIT	PULL	SIGC-270B	142
2ND FLOOR ELEVATOR LOBBY	PULL	SIGC-270B	143
2ND FLOOR AT STAIR #3 M/L RELAY	RLY	SIGA-CR	144

Location Description	Device	Model	Address
2ND FLOOR D/H RELAY & MAG BY STUDENT SERVICE	RLY	SIGA-CR	145
2ND FLOOR HOSE CABINET GATE VALVE	SUPV	SIGA-CT2	146
2ND FLOOR HOSE CABINET GATE VALVE 147 (SPARE)	MON	SIGA-CT2	147
2ND FLOOR IN STAIR D/H RELAY STAIR #2	RLY	SIGA-CR	148
2ND FLOOR SE STAIR #1 EXIT	PULL	SIGC-270B	149
2ND FLOOR IN STAIR D/H RELAY STAIR #1	RLY	SIGA-CR	150
MECHANICAL ROOM B001 AHU SUPPLY FAN SHUTDOWN	RLY	SIGA-CR	151
MECHANICAL ROOM B001 AHU RETURN FAN SHUTDOWN	RLY	SIGA-CR	152
3RD FLOOR SOUTH GATE VALVE ROOM B001	SUPV	SIGA-CT2	153
3RD FLOOR SOUTH SPRINKLER WATERFLOW	FLOW	SIGA-CT2	154
2ND FLOOR SOUTH GATE VALVE ROOM B001	SUPV	SIGA-CT2	155
2ND FLOOR SOUTH SPRINKLER WATERFLOW	FLOW	SIGA-CT2	156
1ST FLOOR SOUTH GATE VALVE ROOM B001	SUPV	SIGA-CT2	157
1ST FLOOR SOUTH SPRINKLER WATERFLOW	FLOW	SIGA-CT2	158
BASEMENT LEVEL SOUTH GATE VALVE ROOM B001	SUPV	SIGA-CT2	159
BASEMENT LEVEL SOUTH SPRINKLER WATERFLOW	FLOW	SIGA-CT2	160

SPRINKLER ROOM BACKFLOW GATE VALVE #2	SUPV	SIGA-CT2	161
SPRINKLER ROOM BACKFLOW GATE VALVE #1	SUPV	SIGA-CT2	162
AUDITORIUM SPRINKLER ROOM GATE VALVE	SUPV	SIGA-CT2	163
AUDITORIUM WATERFLOW	FLOW	SIGA-CT2	164
LEVEL 2 REMOTE HEADER GATE VALVE	SUPV	SIGA-CT2	165
LEVEL 2 REMOTE HEADER WATERFLOW	FLOW	SIGA-CT2	166
LEVEL 1 REMOTE HEADER GATE VALVE	SUPV	SIGA-CT2	167
LEVEL 1 REMOTE HEADER WATERFLOW	FLOW	SIGA-CT2	168
1ST FLOOR SOUTH EXIT	PULL	SIGC-270B	169
RELAY WATER MOTOR GONG SPRINKLER	RLY	SIGA-CR	170
1ST FLOOR SOUTH EXIT STORAGE 1003	PULL	SIGC-270B	171

Location Description	Device	Model	Address
1ST FLOOR D/H RELAY STAIR #1	RLY	SIGA-CR	172
1ST FLOOR SE STAIR #1 EXIT	PULL	SIGC-270B	173
PRODUCTION ROOM GATE VALVE	SUPV	SIGA-CT1	174
DUST COLLECTOR	ALRM	SIGA-CT1	175
PRODUCTION ROOM 1024 EXIT	PULL	SIGC-270B	176
1ST FLOOR D/H RELAY STAIR #2	RLY	SIGA-CR	177
1ST FLOOR ADJ. STAIR #2	PULL	SIGC-270B	178
KITCHEN 1046 EXIT	PULL	SIGC-270B	179
D/H RELAY & MAG ADJ. ROOM 1037	RLY	SIGA-CR	180
1ST FLOOR CENTRE SECTION GATE VALVE UNDER STAIR #3	SUPV	SIGA-CT2	181
1ST FLOOR CENTRE SECTION SPRINKLER FLOW	FLOW	SIGA-CT2	182
2ND FLOOR CENTRE SECTION GATE VALVE UNDER STAIR #3	SUPV	SIGA-CT2	183
2ND FLOOR CENTRE SECTION SPRINKLER FLOW	FLOW	SIGA-CT2	184
3RD FLOOR NORTH GATE VALVE UNDER STAIR #3	SUPV	SIGA-CT2	185

3RD FLOOR NORTH SPRINKLER FLOW	FLOW	SIGA-CT2	186
1ST FLOOR ELEVATOR PIT GATE VALVE	SUPV	SIGA-CT2	187
1ST FLOOR D/H RELAY STAIR #3	RLY	SIG-ACR	188
1ST FLOOR EXIT BY CAFETERIA	PULL	SIGC-270B	189
HOSE CABINET 3RD FLOOR	SUPV	SIGA-CT2	190
SPARE	SUPV	SIGA-CT2	191
HOSE CABINET GATE VALVE BY 1028	SUPV	SIGA-CT2	192
SPARE	MON	SIGA-CT2	193
BOOSTER PANEL RISER	AUD	SIGA-CC1	194
2ND FLOOR STAIR #2 EXIT	PULL	SIGC-270B	195
KITCHEN CO2 HOOD SYSTEM #1 NORTH	SUPV		196
SPARE KITCHEN CO2 HOOD SYSTEM #1 NORTH	SUPV		197
KITCHEN CO2 HOOD SYSTEM #2 SOUTH	SUPV		198
SPARE KITCHEN HOOD CO2 SYSTEM #2 SOUTH	SUPV		199

Location Description	Device	Model	Address	Zone / Circuit #
1ST FLOOR CAFETERIA SIDE EXIT	PULL	SIGC-270B	200	
KITCHEN HOOD RELAY SHUTDOWN #1	RLY	SIGA-CR	201	
KITCHEN HOOD RELAY SHUTDOWN #2	RLY	SIGA-CR	203	

SIGNAL CCT. #3 - NAC CCT. #1 BOOSTER - 2ND FLOOR NORTH

CATWALK OVERLOOKING CAFETERIA	H/S			1
CORRIDOR ADJ. LIBRARY 2065	H/S			1
LIBRARY 2065	H/S			1
CAFETERIA SOUTH	H/S			1
CORRIDOR ADJ. PRACTICE ROOM 2073	H/S			1
INSTRUMENTAL MUSIC ROOM 2074	H/S			1
CHORAL MUSIC ROOM 2075	H/S			1
CORRIDOR 2076 ADJ. MECHANICAL ROOM 2078	H/S			1
MECHANICAL ROOM 2072	H/S			1
POTENTIAL SPACE	H/S			1

POTENTIAL SPACE	H/S			1
POTENTIAL SPACE	H/S			1
AUDITORIUM BALCONY WEST	H/S			1
AUDITORIUM BALCONY EAST	H/S			1

SIGNAL CCT. #4 - NAC CCT. #2 BOOSTER - 2ND FLOOR SOUTH

CORRIDOR 2043 ADJ. STORAGE ROOM 2062	H/S			2
TEEN HEALTH ROOM 2050	H/S			2
STUDENT SERVICES	H/S			2
ROOM 2040	H/S			2
SERVER ROOM 2039	H/S			2
CORRIDOR 2001 ADJ. CLASSROOM 2036	H/S			2
CORRIDOR 2001 ADJ. SMALL GROUP ROOM 2034	H/S			2
CORRIDOR 2001 ADJ. CLASSROOM 2026	H/S			2
VESTIBULE 2019 ADJ. STAFF WORKROOM 2022	H/S			2
STAFF WORK ROOM 2022	H/S			2
CORRIDOR 2001 ADJ. CLASSROOM 2017	H/S			2

Location Description	Device	Model	Address	Zone / Circuit
PHYSICS LAB 2013	H/S			2
CORRIDOR 2001 ADJ. SMALL GROUP ROOM 2015	H/S			2
CORRIDOR 2001 ADJ. CLASSROOM 2009	H/S			2
CENTRE SCIENCE LAB 2004	H/S			2
BIOLOGY LAB 2002	H/S			2

SIGNAL CCT. #5 - NAC CCT. #3 BOOSTER - 3RD FLOOR NORTH

MECHANICAL ROOM 3056	H/S			3
UPPER MECHANICAL ROOM 3058	H/S			3
ELECTRICAL ROOM 3059	H/S			3
ELECTRICAL ROOM 3059	EOL			3

SIGNAL CCT. #6 - NAC CCT. #4 BOOSTER - 3RD FLOOR SOUTH

CORRIDOR 3047 ADJ. ART ROOM 3050	H/S			4
ART ROOM 3050	H/S			4
GREEN ROOF	H/S			4
CORRIDOR 3047 ADJ. CLASSROOM 3039	H/S			4
NUTRITION/TEXTILES 3041	H/S			4
CORRIDOR 3011 ADJ. SMALL GROUP ROOM 3035	H/S			4
CORRIDOR 3001 ADJ. CLASSROOM 3027	H/S			4
STAFF KITCHEN 3022	H/S			4
CORRIDOR 3001 ADJ. CLASSROOM 3017	H/S			4
CHEMISTRY LAB 3014	H/S	-		4
CORRIDOR 3001 ADJ. SMALL GROUP ROOM 3011	H/S			4
CORRIDOR 3001 ADJ. CLASSROOM 3009	H/S			4
CENTRAL SCIENCE LAB 3004	H/S			4
BIOLOGY LAB 3002	H/S			4
BIOLOGY LAB 3002	H/S			4
MECHANICAL SPINE	H/S			4
MECHANICAL SPINE	H/S			4
MECHANICAL SPINE	H/S			4
MECHANICAL SPINE	H/S			4

Location Description	Device	Model	Address	Zone / Circuit #
----------------------	--------	-------	---------	------------------

BELL CCT. #1 - NAC CCT. 01 01 270 - 1ST FLOOR NORTH

CORRIDOR 1058 ADJ. ADMIN.	H/S			1
CORRIDOR 1058 ADJ. DRAMA 1063	H/S			1
AUDITORIUM EAST	H/S			1
AUDITORIUM WEST	H/S			1
AUDITORIUM STAGE	H/S			1
CORRIDOR 1049 ADJ. CAFETERIA	H/S			1
CORRIDOR 1074 ADJ. VICE-PRINCIPAL 1075	H/S			1
SCHOOL GYM 1007 SE	H/S			1
SCHOOL GYM 1007 SW	H/S			1
SCHOOL GYM 1007 NE	H/S			1

SCHOOL GYM 1007 NW	H/S			1
SHOWER 1100	H/S			1
SHOWERS 1090	H/S			1
CORRIDOR 1083 ADJ. OFFICE 1096	H/S			1
CORRIDOR 1112 ADJ. JANTIRO 1117	H/S			1
LOCKER ROOM 1115 MALE	H/S			1
LOCKER ROOM 1123 FEMALE	H/S			1
MULTI-PURPOSE ROOM 1128	H/S			1
CORRIDOR 1112 ADJ. RECEPTION 1125	H/S			1
CIVIC GYM	H/S			1
CIVIC GYM	H/S			1
CIVIC GYM	H/S			1
CIVIC GYM	H/S			1
MULTI-PURPOSE ROOM 1128	EOL			1

SIGNAL CCT. #2 - NAC #01 02 270 - 1ST FLOOR SOUTH

CORRIDOR 1040 ADJ. CENTRE STAIR	H/S			2
KITCHEN 1045	H/S			2
CORRIDOR 1040 ADJ. YEARBOOK ROOM 1035	H/S			2
YEARBOOK ROOM 1035	H/S			2
COMM. TECH. LAB 1033	H/S			2
CORRIDOR 1002 ADJ. SMALL GROUP ROOM 1028	H/S			2

Location Description	Device	Model	Address	Zone / Circuit #
CORRIDOR 1002 ADJ. CLASSROOM 1025	H/S			2
CORRIDOR 1002 ADJ. CLASSROOM 1014	H/S			2
CORRIDOR 1002 ADJ. SMALL GROUP ROOM 1011	H/S			2
CORRIDOR 1002 ADJ. GLASSROOM 1007	H/S			2
CLASSROOM 1004	H/S			2
EXTERIOR STORAGE 1003	H/S			2
EXTERIOR STORAGE 1003	EOL			2

BASEMENT MECHANICAL ROOM B001	H/S			2
-------------------------------	-----	--	--	---

PANEL 1- CARD 1

AUDITORIUM RIGHT VESTIBULE	S		18	
AUDITORIUM LEFT VESTIBULE	S		19	
1ST FLOOR EXIT ADJ STAGE	S		23	
AUDITORIUM SERVICE CORRIDOR LEFT	HT		24	
AUDITORIUM SERVICE CORRIDOR RIGHT	HT		25	
AUDITORIUM SOUND MIXING ROOM	RLY		151	
AUDITORIUM LIGHTS IN ROOM 2060	RLY		152	
1ST FLOOR EXIT ADJ RECYCLING	M		153	
2ND FLOOR AUDITORIUM CORR RIGHT	S		57	
2ND FLOOR AUDITORIUM CORR CENTRE	S		58	
2ND FLOOR AUDITORIUM CORRIDOR LEFT	S		59	
2ND FLOOR CORRIDOR ADJ ELEVATOR LOBBY	S		60	
1ST FLOOR AUDITORIUM CORR RIGHT	S		61	
1ST FLOOR AUDITORIUM CORR LEFT	S		62	
1ST FLOOR CORRIDOR ADJ ELEVATOR LOBBY	S		63	

Location Description	Device	Model	Address	Zone / Circuit #
AUDITORIUM BALCONY RIGHT	H/S			
AUDITORIUM BALCONY LEFT	H/S			

FIRE ALARM PANEL

HORN/STROBE CCT #1-1ST FLOOR NORTH (01270)

AUDITORIUM RIGHT	HS			
AUDITORIUM LEFT	HS			

STAGE	HS			
BEHIND STAGE	HS			

EMERGENCY LIGHTING

t	Location	# of Heads	Model	Circuit #	S
	1ST FLOOR				1
	CORRIDOR BY ROOM 1111				
	CORRIDOR BY ROOM 1095				
	CORRIDOR BY ROOM 1096				
	WOMENS LOCKER ROOM				
	WOMENS LOCKER ROOM				
	WOMENS LOCKER ROOM				
	MAIN WILSON GYM CENTRE MAIN ENTRY				
	MAIN GYM BY ELEC OUTLET				
	MAIN GYM BY COURT NET 2				
	MAIN GYM OPP COURT NET 2				
	MAIN GYM BY COURT NET 1				
	MAIN GYM AREA 4				
	MAIN GYM FAR EXIT				
	CORRIDOR BY ROOM 1094 GYM				
	MENS LOCKER ROOM 1092				
	MENS LOCKER				

MENS LOCKER ROOM			
MENS LOCKER ROOM			
CORRIDOR BY ROOM 1105			
CORRIDOR BY ROOM 1084			
CORR/ BY DOUBLE DOORS TO GYM			
CORRIDOR BY ROOM 1081			
ROOM 1056 OH DOOR			
ROOM 1056			
ROOM 1056			
EXIT BY ROOM 1056			
CORRIDOR BY PAY PHONE			
CORRIDOR BY ROOM 1063			
MENS WASHROOM		UNIT	
MENS WASHROOM		REMOTE	
WOMENS WASHROOM			
WOMENS WASHROOM			
MAIN OFFICE BY COURIER			

Location	# of Heads	Model	Circuit #
MAIN OFFICE BY ROOM 1076			
ABOVE STAGE ON GANTRY	UNIT		
ABOVE STAGE ON GANTRY	REMOTE		
ABOVE STAGE ON GANTRY	REMOTE		
STAGE REAR TO CORR	UNIT		
STAGE REAR CORR	REMOTE		
STAGE REAR CORR	REMOTE		

STAGE REAR CORN	REMO TE		
STAGE RHS TO SEATING	UNIT		
STAGE RHS BY STEPS TO GANTRY	UNIT		
STAGE LHS	REMO TE		
CORRIDOR BY MAIN OFFICE			
CORR BY ROOM 1037 (STUD. COUNCIL)			
CORRIDOR BY CAFETERIA			
CAFETERIA PEDWAY WALL			
CAFETERIA EXIT			
CAFETERIA PEDWAY WALL			
CAFETERIA BY TRAY RETURN WINDOW		REMOTE	
CORR. BY ROOM 1061 JANITORS ROOM		UNIT	
MEN'S WASHROOM BY 1061		REMOTE	
MENS WASHROOM BY 1061		UNIT	
MENS WASHROOM BY 1061		UNIT	
CORRIDOR BY ROOM 1033			
CORRIDOR BY ROOM 1032			
CORRIDOR BY ROOM 1028			
CORRIDOR BY ROOM 1026			
CORRIDOR BY ROOM 1020			
CORRIDOR BY ROOM 1014			
CORRIDOR BY ROOM 1011			
CORRIDOR BY ROOM 1009			
CORRIDOR BY ROOM		REMOTE	

CORRIDOR BY ROOM B001		REMOTE	
2ND FLOOR			
Location	# of Heads	Model	Circuit #
ROOM 2078 ELECTRICAL /SPRK		UNIT	
ROOM 2078 ELECTRICAL/SPRK		REMOTE	
CORRIDOR BY ROOM 2077		REMOTE	
CORRIDOR BY ROOM 2078		REMOTE	
ROOM 2075		REMOTE	
CORRIDOR BY ROOM 2075		UNIT	
CORRIDOR BY ROOM 2074		REMOTE	
ROOM 2060 ELECTRICAL		UNIT	
CORRIDOR BY ROOM 2060		REMOTE	
CORRIDOR BY ROOM 2069			
CORRIDOR BY ROOM 2063		REMOTE	
UNIT IN KITCHEN			
DRAMA CLASS RM 122		UNIT	
ROOM 2065 LIBRARY ENTRANCE			
ROOM 2065 LIBRARY BY RM 2067			
ROOM 2065 LIBRARY BY RM 2063			
ROOM 2065 LIBRARY BY RM 2068			
ROOM 2065 LIBRARY MEZZ BY RM 3055			
ROOM 2065 LIBRARY BEYOND STAIRS			
PEDWAY TROPPOPE ST END		LUMACELL	
PEDWAY ALFARO		REMOTE	

PEDWAY AHEARD ST. END		REMOTE	
PEDWAY AHEARN ST. END STAIRS		LUMACELL	
CORRIDOR BY ELEVATOR		REMOTE	
CORRIDOR BY ROOM 2050		UNIT	
ROOM 2042 WASHROOM		REMOTE	
CORRIDOR BY ROOM 2040		REMOTE	
CORRIDOR BY ROOM 2036		UNIT	
CORRIDOR BY ROOM 2034		REMOTE	
CORRIDOR BY ROOM 2026		UNIT	
CORRIDOR BY ROOM 2022		REMOTE	
WOMENS WASHROOM BY RM 2022		REMOTE	

Location	# of Heads	Model	Circuit #
WOMENS WASHROOM BY RM 2022		REMOTE	
ROOM 2022		REMOTE	
ROOM 2022		REMOTE	
MENS WASHROOM BY RM 2022		UNIT	
MENS WASHROOM BY RM 2022		REMOTE	
CORRIDOR BY ROOM 2017		REMOTE	
CORRIDOR BY ROOM 2010		REMOTE	
CORRIDOR BY ROOM 2002		REMOTE	
3RD FLOOR			
ROOM 3059 ELECTRICAL		UNIT	

ROOM 3056		REMOTE	
RM 2014		UNIT	
IN RM 2039 (IN 2039A)		UNIT	
IN RM 2064			
RM 2045 GUIDANCE RM			
CORRIDOR BY ROOM 3053		REMOTE	
CORRIDOR BY ELEVATOR		REMOTE	
ROOM 3044		REMOTE	
CORRIDOR BY ROOM 3049		UNIT	
CORRIDOR BY 3043		REMOTE	
CORRIDOR BY ROOM 3038		UNIT	
CORRIDOR BY ROOM 3035		REMOTE	
MENS WASHROOM		UNIT	
MENS WASHROOM		REMOTE	
ROOM 3022		REMOTE	
ROOM 3022		REMOTE	
WOMENS WASHROOM		REMOTE	
WOMENS WASHROOM		REMOTE	
CORRIDOR BY ROOM 3027		UNIT	
CORRIDOR BY ROOM 3022		REMOTE	
CORRIDOR BY ROOM 3017		REMOTE	
CORRIDOR BY ROOM 3011		REMOTE	
CORRIDOR BY ROOM 3008		UNIT	

Location	# of Heads	Model	Circuit #
----------	---------------	-------	-----------

	HEADS		
CORRIDOR BY ROOM 3004		REMOTE	
PENTHOUSE			
REMOTE HEAD #1			
REMOTE HEAD #2			
REMOTE HEAD #3			
REMOTE HEAD #4			
REMOTE HEAD #5			
REMOTE HEAD #6			
REMOTE HEAD #7			
REMOTE HEAD #8			
CABINET HEAD #A			
CABINET HEAD #B			
CABINET HEAD #C			
STAIR #1			
1ST FLOOR BOTTOM OF STAIRS BY 100		UNIT	
1ST FLOOR EXIT		REMOTE	
1ST TO 2ND			
2ND FLOOR			
2ND TO 3RD			
3RD FLOOR			
STAIRS #2 BY 1020			
1ST FLOOR		UNIT	
1ST TO 2ND		REMOTE	
2ND FLOOR		REMOTE	
RM 300 MECH RM 3RD FLR		UNIT	
RM 3052		REMOTE HEAD	
RM 3040 (FAMILY STUDIES)		UNIT	

2ND FLR MUSIC RM LEFT		UNIT	
2ND FLR MUSIC RM RIGHT		UNIT	
2ND TO 3RD		REMOTE	
3RD FL MECH RM REAR DOOR		EXIT COMBO	
3RD FLOOR		REMOTE	
STAIR #3			
1ST FLOOR		UNIT	
1ST TO 2ND			
2ND FLOOR			
2ND TO 3RD			

Location	# of Heads	Model	Circuit #
3RD FLOOR			
STAIR #4 SEE LIBRARY			
STAIR #5			
BOTTOM OF STAIRS EXIT			
MID-STAIRS			
TOP OF STAIRS			
STAIR #6			
2ND FLOOR VESTIBULE			
TOP OF STAIR			
MIDDLE OF STAIR			
EXIT			
BOTTOM OF STAIR			
COMMUNITY CENTRE			
COMMUNITY CENTRE ENTRANCE			
CORR. BY GIRLS			

LOCKER ROOM			
CORRIDOR BY ROOM 1124			
BOYS LOCKER ROOM VESTIBULE			
BOYS WASHROOM			
BOYS LOCKER ROOM			
BOYS SHOWER			
GIRLS LOCK RM VESTIBULE			
GIRLS WASHROOM			
GIRLS LOCKER ROOM			
GIRLS SHOWER			
CIVIC GYM ENTRY NEAR SCHOOL			
CIVIC GYM OUTSIDE WALL NEAR SCHOOL			
CIVIC GYM OUTSIDE WALL CENTRE			
CIVIC GYM FAR OUTSIDE WALL			
CIVIC GYM EXIT BY REC DESK			
CIVIC GYM ABOVE BLEACHERS			
2ND CIVIC STAIRS LANDING			
CIVIC CENTRE 2ND FLR 2077	UNIT		
CIVIC CENTRE 2ND FLR RM 2077	UNIT		
CIVIC CENTRE 2ND FLR STORE RM	UNIT		

Location	# of Heads	Model	Circuit #
CIVIC CENTRE 2ND FLR STORE RM	UNIT		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS		
--	--	--

1	DOOR 2060, PANEL "3201", CCT# 12	
---	----------------------------------	--

2	DOOR 2029, PANEL "3202", CCT#30-2ND FLR HALL; CCT#32-3RD FLR HALL; CCT#28-1ST FLR HALL; CCT#26-STAIR	
3	#1; CCT#36-STAFF ROOMS; CCT#24-2ND FLR WASHROOMS	
4	ELECTRICAL ROOM 2060, PNL 3201 HAS MORE CIRCUITS, MARKED ON PANEL.	
5	RM 3059, PANEL "3301", CCT# 8-MAIN GYM, CCT#10-CIVIC GYM (reach 3509 via Rm 2078)	

FIRE ALARM NOTES AND RECOMMENDATIONS	
1	ACCESS TO PENTHOUSE THROUGH SCIENCE LAB RM 3004, THEN THROUGH STORAGE RM 3005
2	3RD FL STOR/KILN RM 3051 IS ACCESSED THROUGH RM 3050
3	PRODUCTION RM GATE VALVE PROTECTS ACTUATOR RM
4	TOP OF ELEVATOR SHAFT SMOKE DETECTOR REQUIRES ELEVATOR TECH TO PROVIDE ACCESS.
Fire Door Number or Location	
1st Floor Stairs # 1	
2nd Floor Stairs # 1	
3rd Floor Stairs # 1	
1st Floor Stairs # 2	
2nd Floor Stairs # 2	
3rd Floor Stairs # 2	
1st Floor Stairs # 3 (Main Lobby)	
2nd Floor Stairs # 3	
3rd Floor Stairs # 3	
1st Floor Hall by Elevator	
2nd Floor Hall by Elevator	
3rd Floor Hall by Elevator	
2nd Floor Stairs # 5	

	LOCATION: Fleming Tower	Device	Device address or circuit number
	FIRE ALARM Panel: Edwards 6604		
	MAIN ENTRY(SOUTH WING)	M	ZN2
	LEFT ENTRY	M	ZN2
	RIGHT ENTRY(NORTH WING)	M	ZN3
	BOILER ROOM	M	ZN3
	LEFT CORRIDOR	SI	ZN2
	MAIN ENTRY(SOUTH WING)	SI	ZN3
	LEFT CORRIDOR	SI	2
	RIGHT CORRIDOR ,FAR END	SI	ZN3
	BOILER ROOM	HT	ZN3
	LEFT CORRIDOR	B	SIG 1
	CORRIDOR BY BOILER ROOM	B	SIG 1
	RIGHT CORRIDOR	B	SIG 1
	Fire Door Location		
	LEFT CORRIDOR		
	MAIN ENTRY TO GYM		
	CENTER CORRIDOR		
	RIGHT EXIT		

EMERGENCY LIGHTING	
#	EL UNIT Location
1	RIGHT EXIT
2	MAIN ENTRY
3	MAIN ENTRY TO GYM
4	GYM LEFT
5	GYM RIGHT
6	LEFT EXIT

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
----------------------	--------	-------	---------	------------------	------	-----	------	-----	-----	-----	-----	----	-----	------	---------

SIMPLEX 4100ES PANEL

1ST FLOOR LOOP (01-01)

UNDER STAGE 1 (01-01-95)	SMOKE	4098-9754	M1-95-1		✓			✓	✓						
UNDER STAGE 1 (01-01-95)	HEAT	4098-9754	M1-95-2		✓			✓	✓						
UNDER STAGE 2 (01-01-96)	SMOKE	4098-9754	M1-96-1		✓			✓	✓						
UNDER STAGE 2 (01-01-96)	HEAT	4098-9754	M1-96-2		✓			✓	✓						
UNDER STAGE 3 (01-01-97)	SMOKE	4098-9754	M1-97-1		✓			✓	✓						
UNDER STAGE 3 (01-01-97)	HEAT	4098-9754	M1-97-2		✓			✓	✓						
UNDER STAGE 4 (01-01-98)	SMOKE	4098-9754	M1-98-1		✓			✓	✓						
UNDER STAGE 4 (01-01-98)	HEAT	4098-9754	M1-98-2		✓			✓	✓						
UNDER STAGE 5 (01-01-99)	SMOKE	4098-9754	M1-99-1		✓			✓	✓						
UNDER STAGE 5 (01-01-99)	HEAT	4098-9754	M1-99-2		✓			✓	✓						
UNDER STAGE 6 (01-01-100)	SMOKE	4098-9754	M1-100-1		✓			✓	✓						
UNDER STAGE 6 (01-01-100)	HEAT	4098-9754	M1-100-2		✓			✓	✓						
1ST FL ADMIN RM 102 (01-01-101)	RIAM	4090-9002	M1-101		✓			✓							
1ST FL ADMIN RM 102 (01-01-102)	PULL	4099-9004CB	M1-102		✓			✓	✓						
1ST FL MAIN ENTRY 100A (01-01-103)	PULL	4099-9004CB	M1-103		✓			✓	✓						
1ST FL CORR 100B BY RM 115 (01-01-105)	SMOKE	4098-9754	M1-105-1		✓			✓	✓						
1ST FL CORR 100B BY RM 115 (01-01-105)	HEAT	4098-9754	M1-105-2		✓			✓	✓						
1ST FL CORR 100B BY CAFE (01-01-106)	SMOKE	4098-9754	M1-106-1		✓			✓	✓						
1ST FL CORR 100B BY CAFE (01-01-106)	HEAT	4098-9754	M1-106-2		✓			✓	✓						
1ST FL BY STAIR ST1-1 (01-01-107)	SMOKE	4098-9754	M1-107-1		✓			✓	✓						
1ST FL BY STAIR ST1-1 (01-01-107)	HEAT	4098-9754	M1-107-2		✓			✓	✓						
1ST FL BY STAIR ST1-1 (01-01-108)	PULL	4099-9004CB	M1-108		✓			✓	✓						
1ST FL BY STAIR ST1-1 (01-01-109)	RIAM	4090-9002	M1-109		✓			✓							
1ST FL SUMP PUMP RM 104B (01-01-110)	HEAT	4098-9733	M1-110		✓			✓	✓						
1ST FL ELEVATOR LOBBY (01-01-111)	SMOKE	4098-9754	M1-111-1		✓			✓	✓						
1ST FL ELEVATOR LOBBY (01-01-111)	HEAT	4098-9754	M1-111-2		✓			✓	✓						
1ST FL ELEVATOR GV (01-01-112)	LATSUPV	4090-9001	M1-112		✓			✓							
1ST FL LIBRARY 108 WEST (01-01-113)	SMOKE	4098-9754	M1-113-1		✓			✓	✓						

[illegible]

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
LEV 3 STORAGE GV (01-01-141)	LATSUPV	4090-9001	M1-141		✓			✓							
LEV 3 STORAGE FLOW (01-01-142)	FS	4090-9001	M1-142		✓										
TEST HEADER GV (01-01-143)	LATSUPV	4090-9001	M1-143		✓										
1ST FL SPRINKLER RM E101 (01-01-144)	PULL	4099-9004CB	M1-144		✓			✓	✓						
1ST FL KITCHEN RM 107 (01-01-145)	PULL	4099-9004CB	M1-145		✓			✓	✓						
1ST FL CAFETERIA RM 105 (01-01-146)	PULL	4099-9004CB	M1-146		✓			✓	✓						
1ST FL BY STAIR ST2-1 (01-01-147)	PULL	4099-9004CB	M1-147		✓			✓	✓						
1ST FL CLASS RM 125A (01-01-148)	SMOKE	4098-9754	M1-148-1		✓			✓	✓						
1ST FL CLASS RM 125A (01-01-148)	HEAT	4098-9754	M1-148-2		✓			✓	✓						
1ST FL CLASS RM 126A (01-01-149)	SMOKE	4098-9754	M1-149-1		✓			✓	✓						
1ST FL CLASS RM 126A (01-01-149)	HEAT	4098-9754	M1-149-2		✓			✓	✓						
1ST FL CLASS RM 124A (01-01-150)	SMOKE	4098-9754	M1-150-1		✓			✓	✓						
1ST FL CLASS RM 124A (01-01-150)	HEAT	4098-9754	M1-150-2		✓			✓	✓						
1ST FL SUB COMM RM E123 (01-01-151)	SMOKE	4098-9754	M1-151-1		✓			✓	✓						
1ST FL SUB COMM RM E123 (01-01-151)	HEAT	4098-9754	M1-151-2		✓			✓	✓						
1ST FL SUB COMM RM E102 (01-01-152)	RIAM	4090-9002	M1-152		✓			✓							
1ST FL BY STAIR ST2-1 (01-01-153)	SMOKE	4098-9754	M1-153-1		✓			✓	✓						
1ST FL BY STAIR ST2-1 (01-01-153)	HEAT	4098-9754	M1-153-2		✓			✓	✓						
1ST FL BY STAIR ST2-1 (01-01-154)	RIAM	4090-9002	M1-154		✓										
1ST FL MAIN ELECTRICAL E102 (01-01-155)	SMOKE	4098-9754	M1-155-1		✓			✓	✓						
1ST FL MAIN ELECTRICAL E102 (01-01-155)	HEAT	4098-9754	M1-155-2		✓			✓	✓						
1ST FL MAIN ELECTRICAL E102 (01-01-156)	PULL	4099-9004CB	M1-156		✓			✓	✓						
1ST FL ELECTRICAL RM 113A (01-01-157)	RIAM	4090-9002	M1-157		✓										
1ST FL ELECTRICAL RM 113A (01-01-158)	RIAM	4090-9002	M1-158		✓										
1ST FL GYM STORAGE RM 190D (01-01-159)	SMOKE	4098-9754	M1-159-1		✓			✓	✓						
1ST FL GYM STORAGE RM 190D (01-01-159)	HEAT	4098-9754	M1-159-2		✓			✓	✓						
BUILDING AUTOMATION (01-01-161)	RIAM	4090-9002	M1-161		✓										
1ST FL BOILER RM E104 (01-01-162)	PULL	4099-9004CB	M1-162		✓			✓	✓						

[illegible]

2ND FL A (COMM RM 212) (01-02-01)	ISO	4090-9116	M2-1		✓								
2ND FL B (COMM RM 212) (01-02-02)	ISO	4090-9116	M2-2		✓								

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
3RD FL B (COMM RM 212) (01-01-03)	ISO	4090-9116	M2-3		✓										
3RD FL A (COMM RM 212) (01-02-04)	ISO	4090-9116	M2-4		✓										
3RD FL A (COMM RM 310) (01-02-05)	ISO	4090-9116	M2-5		✓										
3RD FL B (COMM RM 310) (01-02-06)	ISO	4090-9116	M2-6		✓										
2ND FL BY WASHROOMS 211 (01-02-35)	SMOKE	4098-9754	M2-35-1		✓			✓	✓						
2ND FL BY WASHROOMS 211 (01-02-35)	HEAT	4098-9754	M2-35-2		✓			✓	✓						
2ND FL JANITORS RM 209 (01-02-36)	HEAT	4098-9733	M2-36		✓			✓	✓						
2ND FL SKYLIGHT 200A N (01-02-37)	SMOKE	4098-9754	M2-37-1		✓			✓	✓						
2ND FL SKYLIGHT 200A N (01-02-37)	HEAT	4098-9754	M2-37-2		✓			✓	✓						
2ND FL SKYLIGHT 200A W (01-02-38)	SMOKE	4098-9754	M2-38-1		✓			✓	✓						
2ND FL SKYLIGHT 200A W (01-02-38)	HEAT	4098-9754	M2-38-2		✓			✓	✓						
2ND FL ELEVATOR LOBBY 200A (01-02-39)	SMOKE	4098-9754	M2-39-1		✓			✓	✓						
2ND FL ELEVATOR LOBBY 200A (01-02-39)	HEAT	4098-9754	M2-39-2		✓			✓	✓						
2ND FL SKYLIGHT 200A S (01-02-40)	SMOKE	4098-9754	M2-40-1		✓			✓	✓						
2ND FL SKYLIGHT 200A S (01-02-40)	HEAT	4098-9754	M2-40-2		✓			✓	✓						
2ND FL BY STAIR ST1-2 (01-02-41)	PULL	4099-9004CB	M2-41		✓			✓	✓						
2ND FL BY STAIR ST1-2 RELAY (01-02-42)	RIAM	4090-9002	M2-42		✓			✓							
2ND FL BY STAIR ST1-2 (01-02-43)	SMOKE	4098-9754	M2-43-1		✓			✓	✓						
2ND FL BY STAIR ST1-2 (01-02-43)	HEAT	4098-9754	M2-43-2		✓			✓	✓						
2ND FL SKYLIGHT 200B S (01-02-44)	SMOKE	4098-9754	M2-44-1		✓			✓	✓						
2ND FL SKYLIGHT 200B S (01-02-44)	HEAT	4098-9754	M2-44-2		✓			✓	✓						
2ND FL SKYLIGHT 200B W (01-02-45)	SMOKE	4098-9754	M2-45-1		✓			✓	✓						
2ND FL SKYLIGHT 200B W (01-02-45)	HEAT	4098-9754	M2-45-2		✓			✓	✓						
2ND FL SKYLIGHT 200B N (01-02-46)	SMOKE	4098-9754	M2-46-1		✓			✓	✓						
2ND FL SKYLIGHT 200B N (01-02-46)	HEAT	4098-9754	M2-46-2		✓			✓	✓						
2ND FL SKYLIGHT 200C S (01-02-47)	SMOKE	4098-9754	M2-47-1		✓			✓	✓						
2ND FL SKYLIGHT 200C S (01-02-47)	HEAT	4098-9754	M2-47-2		✓			✓	✓						
2ND FL SKYLIGHT 200C W (01-02-48)	SMOKE	4098-9754	M2-48-1		✓			✓	✓						

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
2ND FL SKYLIGHT 200C W (01-02-48)	HEAT	4098-9754	M2-48-2		✓			✓	✓						
2ND FL SKYLIGHT 200C N (01-02-49)	SMOKE	4098-9754	M2-49-1		✓			✓	✓						
2ND FL SKYLIGHT 200C N (01-02-49)	HEAT	4098-9754	M2-49-2		✓			✓	✓						
2ND FL BY STAIR ST2-2 (01-02-50)	SMOKE	4098-9754	M2-50-1		✓			✓	✓						
2ND FL BY STAIR ST2-2 (01-02-50)	HEAT	4098-9754	M2-50-2		✓			✓	✓						
2ND FL BY STAIR ST2-2 RELAY (01-02-51)	RIAM	4090-9002	M2-51		✓			✓							
2ND FL BY STAIR ST2-2 (01-02-52)	PULL	4099-9004CB	M2-52		✓			✓	✓						
2ND FL MECH RM AHU 2 (01-02-55)	RIAM	4090-9002	M2-55		✓			✓							
2ND FL MECH RM AHU 1 (01-02-56)	RIAM	4090-9002	M2-56		✓			✓							
2ND FL RM 223 SUPPLY FAN (01-02-57)	RIAM	4090-9002	M2-57		✓			✓							
2ND FL COMM RM 212 (01-02-58)	SMOKE	4098-9754	M2-58-1		✓			✓	✓						
2ND FL COMM RM 212 (01-02-58)	HEAT	4098-9754	M2-58-2		✓			✓	✓						
2ND FL RM 212 SUPPLY FAN (01-02-59)	RIAM	4090-9002	M2-59		✓			✓							
2ND FL LIBRARY RM 210 WEST (01-02-60)	SMOKE	4098-9754	M2-60-1		✓			✓	✓						
2ND FL LIBRARY RM 210 WEST (01-02-60)	HEAT	4098-9754	M2-60-2		✓			✓	✓						
2ND FL LIBRARY RM 210 EAST (01-02-61)	SMOKE	4098-9754	M2-61-1		✓			✓	✓						
2ND FL LIBRARY RM 210 EAST (01-02-61)	HEAT	4098-9754	M2-61-2		✓			✓	✓						
2ND FL BY RM 221 SUPPLY FAN 2 (01-02-62)	DUCT	4098-9755	M2-62		✓			✓	✓						
2ND FL RM 221 SUPPLY FAN 2 (01-02-63)	DUCT	4098-9755	M2-63		✓			✓	✓						
2ND FL RM 221 SUPPLY FAN 1 (01-02-64)	DUCT	4098-9755	M2-64		✓			✓	✓						
2ND FL RM 223 (01-02-65)	SMOKE	4098-9754	M2-65-1		✓			✓	✓						
2ND FL RM 223 (01-02-65)	HEAT	4098-9754	M2-65-2		✓			✓	✓						

3RD FLOOR LOOP (01-03)

3RD FL COMM RM 320 (01-03-66)	SMOKE	4098-9754	M2-66-1		✓			✓	✓						
3RD FL COMM RM 320 (01-03-66)	HEAT	4098-9754	M2-66-2		✓			✓	✓						
3RD FL RELAY ROOM 320 (01-03-67)	RIAM	4090-9002	M2-67		✓										
3RD FL CORR BY ROOM 320 (01-03-68)	SMOKE	4098-9754	M2-68-1		✓			✓	✓						
3RD FL CORR BY ROOM 320 (01-03-68)	HEAT	4098-9754	M2-68-2		✓			✓	✓						

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
3RD FL BY STAIR ST2-3 (01-03-69)	SMOKE	4098-9754	M2-69-1		✓			✓	✓						
3RD FL BY STAIR ST2-3 (01-03-69)	HEAT	4098-9754	M2-69-2		✓			✓	✓						
TOP OF STAIR ST2-3 (01-03-70)	SMOKE	4098-9754	M2-70-1		✓			✓	✓						
TOP OF STAIR ST2-3 (01-03-70)	HEAT	4098-9754	M2-70-2		✓			✓	✓						
3RD FL RELAY STAIR ST2-3 (01-03-71)	RIAM	4090-9002	M2-71		✓										
3RD FL BY STAIR ST2-3 (01-03-72)	PULL	4099-9004CB	M2-72		✓			✓	✓						
TOP OF STAIR ST1-3 (01-03-73)	SMOKE	4098-9754	M2-73-1		✓			✓	✓						
TOP OF STAIR ST1-3 (01-03-73)	HEAT	4098-9754	M2-73-2		✓			✓	✓						
3RD FL ELEVATOR SHAFT GV (01-03-74)	LATSUPV	4090-9001	M2-74		✓				✓						
3RD FL ELEVATOR MACH GV (01-03-75)	LATSUPV	4090-9001	M2-75		✓				✓						
ELEVATOR SHAFT (01-03-76)	SMOKE	4098-9754	M2-76-1		✓			✓	✓						
ELEVATOR SHAFT (01-03-76)	HEAT	4098-9754	M2-76-2		✓			✓	✓						
ELEVATOR MACHINE RM (01-03-77)	SMOKE	4098-9754	M2-77-1		✓			✓	✓						
ELEVATOR MACHINE RM (01-03-77)	HEAT	4098-9754	M2-77-2		✓			✓	✓						
3RD FL BY STAIR ST1-3 (01-03-78)	SMOKE	4098-9754	M2-78-1		✓			✓	✓						
3RD FL BY STAIR ST1-3 (01-03-78)	HEAT	4098-9754	M2-78-2		✓			✓	✓						
3RD FL RELAY BY STAIR ST1-3 (01-03-79)	RIAM	4090-9002	M2-79		✓			✓	✓						
3RD FL BY STAIR ST1-3 (01-03-80)	PULL	4099-9004CB	M2-80		✓			✓	✓						
3RD FL ELEVATOR LOBBY (01-03-81)	SMOKE	4098-9754	M2-81-1		✓			✓	✓						
3RD FL ELEVATOR LOBBY (01-03-81)	HEAT	4098-9754	M2-81-2		✓			✓	✓						
3RD FL COMM ROOM 310 (01-03-82)	SMOKE		M2-82-1		✓			✓	✓						
3RD FL COMM ROOM 310 (01-03-82)	HEAT		M2-82-2		✓			✓	✓						
3RD FL RELAY COMM ROOM 310 (01-03-83)	RIAM	4090-9002	M2-83		✓			✓	✓						
3RD FL BY WASHROOMS (01-03-84)	SMOKE	4098-9754	M2-84-1		✓			✓	✓						
3RD FL BY WASHROOMS (01-03-84)	HEAT	4098-9754	M2-84-2		✓			✓	✓						
3RD FL JANITORS RM 303 (01-03-85)	HEAT	4098-9733	M2-85		✓			✓	✓						
3RD FL RELAY MECH RM 305A (01-03-86)	RIAM	4090-9002	M2-86		✓			✓	✓						
3RD FL RELAY MECH RM 305A (01-03-87)	RIAM	4090-9002	M2-87		✓			✓	✓						

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
3RD FL MECH RM 305A (01-03-90)	SMOKE	4098-9754	M2-90-1		✓			✓	✓						
3RD FL MECH RM 305A (01-03-90)	HEAT	4098-9754	M2-90-2		✓			✓	✓						
3RD FL STORAGE 305 (01-03-91)	SMOKE	4098-9754	M2-91-1		✓			✓	✓						
3RD FL STORAGE 305 (01-03-91)	HEAT	4098-9754	M2-91-2		✓			✓	✓						
TOP OF STAIR ST3-3 (01-03-92)	SMOKE	4098-9754	M2-92-1		✓			✓	✓						
TOP OF STAIR ST3-3 (01-03-92)	HEAT	4098-9754	M2-92-2		✓			✓	✓						
2ND FL MACH RM 221 (01-03-130)	PULL	4099-9004CB	M2-130		✓			✓	✓						
3RD FL STORAGE RM 302 (01-03-131)	PULL	4099-9004CB	M2-131		✓			✓	✓						
3RD FL MECH RM 305A (01-03-131)	PULL	4099-9004CB	M2-132		✓			✓	✓						
2ND FL MECH RM 221 (01-03-133)	SMOKE	4098-9754	M2-133-1		✓			✓	✓						
2ND FL MECH RM 221 (01-03-133)	HEAT	4098-9754	M2-133-2		✓			✓	✓						
3RD FL RM 305A SUPPLY FAN 4 (01-03-182)	DUCT	4098-9755	M2-182		✓			✓	✓						
3RD FL RM 305A SUPPLY FAN 4 (01-03-183)	DUCT	4098-9755	M2-183		✓			✓	✓						
3RD FL RM 305A SUPPLY FAN 4 (01-03-184)	DUCT	4098-9755	M2-184		✓			✓	✓						
BLDNG STOR 305 SUPPLY FAN 3 (01-03-185)	DUCT	4098-9755	M2-185		✓			✓	✓						
ELEVATOR HAT (01-03-186)	RIAM	4090-9002	M1-186		✓			✓							
ALT FLOOR RELAY (01-03-187)	RIAM	4090-9002	M1-187		✓			✓							
ELEVATOR RECALL (01-03-188)	RIAM	4090-9002	M1-188		✓			✓							
2ND FL RM 221 SUPPLY FAN 1 (01-03-189)	DUCT	4098-9755	M2-189		✓			✓	✓						

1ST FL NORTH & SOUTH - WEST CLASS A --

1ST FL BOOSTER COMM RM 110A

1ST FL OFFICE ADMIN AREA	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL BY STAIR ST1-1	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL RM 104 CLASSRM	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL BY WASHRM	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL COMM RM 110A	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL CLASSRM 114	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL ASSISTIVE CARE WASHRM	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL CLASSRM 116	H/S	4906-9129	M1-169-1		✓			✓							
1ST FL BY CLASSRM 118	H/S	4906-9129	M1-169-1		✓			✓							

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
----------------------	--------	-------	---------	---------------------	------	-----	------	-----	-----	-----	-----	----	-----	------	---------

1ST FL NORTH & SOUTH - EAST CLASS A --**1ST FL BOOSTER COMM RM 119A**

1ST FL CLASSRM 122	H/S	4906-9129	M1-175-1		✓			✓							
1ST FL CLASSRM 124	H/S	4906-9129	M1-175-1		✓			✓							
1ST FL CLASSRM 126	H/S	4906-9129	M1-175-1		✓			✓							
1ST FL BY CLASSRM 124	H/S	4906-9129	M1-175-1		✓			✓							
1ST FL CLASSRM 125	H/S	4906-9129	M1-175-1		✓			✓							
1ST FL GYM NORTH	H/S	4906-9129	M1-175-1		✓			✓							
1ST FL GYM VESTIBULE 112	H/S	4906-9129	M1-175-1		✓			✓							
1ST FL GYM CHANGE RM 119D	H/S	4906-9129	M1-175-2		✓			✓							
GYM SOUTH	H/S	4906-9129	M1-175-1		✓			✓							
COMM RM 119A	H/S	4906-9129	M1-175-2		✓			✓							
BOILER RM E107	H/S	4906-9129	M1-175-2		✓			✓							
OUTSIDE STORAGE E103	H/S	4906-9129	M1-175-2		✓			✓							
MAIN ELECT RM E112	H/S	4906-9129	M1-175-2		✓			✓							
1ST FL WATER/SPRK 111	H/S	4906-9129	M1-175-2		✓			✓							
1ST FL KITCHEN 107	H/S	4906-9129	M1-175-2		✓			✓							
CAFETERIA 105	H/S	4906-9129	M1-175-2		✓			✓							
MUSIC RM 111	H/S	4906-9129	M1-175-2		✓			✓							
GYM STORAGE	H/S	4906-9129	M1-175-2		✓			✓							

2ND FL NORTH --**2ND FL BOOSTER RM 212 SUB COMM RM**

2ND FL BY CLASSRM 225	H/S	4906-9129	M2-54-2		✓			✓							
CLASSRM 225	H/S	4906-9129	M2-54-2		✓			✓							
MECH RM 221	H/S	4906-9129	M2-54-2		✓			✓							
BY CLASSRM 216	H/S	4906-9129	M2-54-2		✓			✓							
BY CLASSRM 220	H/S	4906-9129	M2-54-2		✓			✓							
CLASSRM 226	H/S	4906-9129	M2-54-2		✓			✓							

2ND FL SOUTH --**2ND FL BOOSTER RM 212 SUB COMM RM**

2ND FL ASSISTIVE CARE WASHRM	H/S	4906-9129	M2-54-1		✓			✓							
BY WASHRM	H/S	4906-9129	M2-54-1		✓			✓							

Inst - Correctly Installed **Smk** - Smoke Sensitivity **Miss** - Missing **Alm** - Alarm Operation Confirmed
Ann - Annunciation Indication **Sup** - Supervisory Circuit Confirmed **Dec** - Decibel Level
FS - Sprinkler Flow Delay **Grd** - Ground **Serv** - Requires Service

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
BY CLASSRM 208	H/S	4906-9129	M2-54-1		✓			✓							
CLASSRM 206	H/S	4906-9129	M2-54-1		✓			✓							

3RD FL CARD 1 CLASS A --

3RD FL CLASSRM 302	H/S	4906-9129		SIG 3	✓			✓							
BY RM 304	H/S	4906-9129		SIG 3	✓			✓							
CLASSRM 304	H/S	4906-9129		SIG 3	✓			✓							
WASHRM	H/S	4906-9129		SIG 3	✓			✓							
RM 305 STORAGE	H/S	4906-9129		SIG 3	✓			✓							
MECH RM	H/S	4906-9129		SIG 3	✓			✓							
BY RM 314	H/S	4906-9129		SIG 3	✓			✓							
ASSISTIVE CARE WASHRM	H/S	4906-9129		SIG 3	✓			✓							
BY CLASSRM 318	H/S	4906-9129		SIG 3	✓			✓							
BY CLASSRM 327	H/S	4906-9129		SIG 3	✓			✓							
CLASSRM 326	H/S	4906-9129		SIG 3	✓			✓							

[illegible]

[illegible]

[illegible]

FIRE ALARM DEVICES - System Manufacturer EDWARDS IO 1000

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
PENTHOUSE A 2ND FROM STAIR	S	SIGA-PS	1		✓										
2ND FL SOUTH STAIR	S	SIGA-PS	2		✓			✓	✓						
PENTHOUSE A 4TH FROM STAIR	S	SIGA-PS	3		✓			✓	✓						
PENTHOUSE A 1ST FROM STAIR	S	SIGA-PS	4		✓										
STAIR 1	S	SIGA-PS	5		✓			✓	✓						
PENTHOUSE A 3RD FROM STAIR	S	SIGA-PS	6		✓										
PENTHOUSE B	S	SIGA-IPHS	7		✓			✓	✓						40
ELEVATOR SHAFT	S	SIGA-IPHS	8		✓										
NORTH STAIR	S	SIGA-IPHS	9		✓			✓	✓						
AHU #4 SHUTDOWN PENTHOUSE A	RLY	SIGA-CR	126		✓			✓							
AHU #1 SHUTDOWN PENTHOUSE A	RLY	SIGA-CR	127		✓			✓							
AHU #3 SHUTDOWN PENTHOUSE A	RLY	SIGA-CR	128		✓			✓							
AHU #2 SHUTDOWN PENTHOUSE B	RLY	SIGA-CR	129		✓			✓							
DOOR RELEASE PANEL	RLY	SIGA-CR	130		✓			✓							
KITCHEN SOLENOID SHUTDOWN	RLY	SIGA-CR	131		✓										
BOOSTER PANEL PENTHOUSE A BELLS	RLY	SIGA-CR	132		✓			✓							
CC1 #2 H/S CCT		CC1	133		✓			✓							
CC1 #1 H/S CCT		CC1	134		✓			✓							
GATE VALVE MAIN BOILER RM	GV	SIGA-CT2	135		✓				✓	✓					
GATE VALVE MAIN BOILER RM	GV	SIGA-CT2	136		✓				✓	✓					
PENTHOUSE SPRK TAMPER TOP STAIR 3 ADJ 2029	TS	SIGA-CT2	137		✓										
PENTHOUSE SPRK FLOW TOP STAIR 3 ADJ 2029	FS	SIGA-CT2	138		✓			✓	✓						
2ND FL SPRK VALVE TOP STAIR 3	TS	SIGA-CT2	139		✓										
2ND FL SPRK FLOW TOP STAIR 3	FS	SIGA-CT2	140		✓			✓	✓						
1ST FL SPRK VALVE BOILER RM	TS	SIGA-CT2	141		✓										
1ST FL SPRK FLOW BOILER RM	FS	SIGA-CT2	142		✓			✓	✓						
KITCHEN HOOD SYSTEM IN ALARM	ALARM	SIGA-CT2	143		✓			✓	✓						
KITCHEN HOOD SYSTEM IN ALARM	ALARM	SIGA-CT2	144		✓			✓	✓						
GYM STORAGE	M	SIGA-270	145		✓			✓	✓						
TOP STAIR 4	M	SIGA-270	146		✓			✓	✓						

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
GYM S/W	M	SIGA-270	147		✓			✓	✓						
2ND FL ADJ STAIR 1	M	SIGA-270	148		✓			✓	✓						
1ST FL ADJ MUSIC RM	M	SIGA-270	149		✓			✓	✓						
GYM N/E	M	SIGA-270	150		✓			✓	✓						
2ND FL SOUTH PULL STATION 2005	M	SIGA-270	151		✓			✓	✓						
2ND FL NORTH PULL STATION 2002	M	SIGA-270	152		✓			✓	✓						
1ST FL NORTH PULL STATION 1003	M	SIGA-270	153		✓			✓	✓						
BOILER RM	M	SIGA-270	154		✓			✓	✓						
1ST FL MAIN LOBBY	M	SIGA-270	155		✓			✓	✓						
PENTHOUSE B	M	SIGA-270	156		✓			✓	✓						
1ST FL SOUTH PULL STATION 1010	M	SIGA-270	157		✓			✓	✓						
PENTHOUSE A	M	SIGA-270	158		✓			✓	✓						
2ND FL GATE VALVE NEAR ELEVATOR	GV	SIGA-CT1	159		✓										
SPRK GATE VALVE LEFT SIDE OF STAGE	GV	SIGA-CT1	160		✓										
1ST FL GATE VALVE NEAR ELEVATOR	GV	SIGA-CT1	161		✓										
SPRK FLOW MAIN BOILER RM	FS	SIGA-CT1	162		✓										
BOOSTER PANEL PENTHOUSE A	ALARM	SIGA-CT1	163		✓			✓	✓						

SIGNAL CIRCUITS**ZONE 1**

MUSIC ROOM	H/S			1	✓			✓							
B/W CLASSROOMS 1092/1094	B/S			1	✓			✓							
CORRIDOR TO SCIENCE CLASSROOMS (1082)	B/S			1	✓			✓							
WASHRM 1081 FOR KITCHEN NEAR SCIENCE RM	STRB			1	✓			✓							
GIRLS WASHROOM 1102	STRB			1	✓			✓							
ADJ. 1ST FLOOR ELEVATOR	B/S			1	✓			✓							
CAFETERIA ADJ. MEZZANINE 1ST FLOOR	B/S			1	✓			✓							
CORRIDOR 1003 ADJ. CAFETERIA	B/S			1	✓			✓							
B/W CLASSROOMS 2005/2057 CORRIDOR 2052	B/S			1	✓			✓							
GIRLS WASHROOM 2074	STRB			1	✓			✓							

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
TOP OF MAIN STAIRS	B/S			1	✓			✓							
2ND FL CORRIDOR 2002 ADJ. MEZZ.	B/S			1	✓			✓							
2ND FL CORRIDOR 2002	EOL			1	✓										

ZONE 2

MAIN LOBBY 1ST FLOOR	B/S			2	✓			✓							
CORRIDOR 1011	B/S			2	✓			✓							
B/W CLASSROOMS 1073/1075 CORR 1071	B/S			2	✓			✓							
MALE WASHROOM 1103	STRB			2	✓			✓							
UPPER LOBBY ADJ. CLASSROOM 2020	B/S			2	✓			✓							
MALE WASHROOM 2075	STRB			2	✓			✓							
CORRIDOR 2006 NEAR ROOM 2004/2064	B/S			2	✓			✓							
B/W CLASSROOMS 2047/2049 CORR, 2045	B/S			2	✓			✓							
PENTHOUSE B	B/S			2	✓			✓							
PENTHOUSE B	EOL			2	✓										
PENTHOUSE B	EOL			2	✓										

ZONE 3

BOILER ROOM	STRB			3	✓			✓							
WASHROOM 1037	STRB			BPS CIR	✓			✓							
WASHROOM 1036	STRB			BPS CIR	✓			✓							
CORRIDOR 1003 ADJ. WASHROOMS	B/S			3	✓			✓							
FEMALE CHANGE ROOM 1043	STRB			3	✓			✓							
FEMALE SHOWER 1045	STRB			3	✓			✓							
MALE CHANGE ROOM 1050	STRB			3	✓			✓							
MALE SHOWER 1052	STRB			3	✓			✓							
NORTH GYMNASIUM	B/S			BPS CIR	✓			✓							
NORTH GYMNASIUM	EOL			3	✓										
NORTH GYMNASIUM	EOL			3	✓										
NORTH GYMNASIUM	B/S			BPS CIR	✓			✓							
TECH. ED. PRODUCTION ROOM 2029	H/S			BPS CIR	✓			✓							
CORRIDOR 2002 OUTSIDE STAFF ROOM DOOR	B/S			3	✓			✓							
PENTHOUSE A	B/S			3	✓			✓							

Emergency Lighting - Ridgecliff Middle School

UNIT #	LOCATION	MAKE & MODEL #	COMBO UNIT (YES/NO)	# OF HEADS	CHARGER CIRCUIT CONFIRMED	VISUAL EXAM OF BATTERIES	BREAKER NUMBER	VOLT & WATT	347 VAC OR 120 VAC	HEIGHT IN FEET (ESTIMATE)	LIFT OR LADDER REQUIRED	MOUNTED ON: WALL, CEILING OR COLUMN	EXT SIGNS - BULB QTY/TYPE	HARDWIRED OR PLUG TYPE	PASSED ☒	FAILED ☐	NOTES
1	CORR ADJ OFFICE	DUAL-LITE	NO	2				12V72W		8FT	LADDER	WALL		HW	☒	☐	
2	CORR ADJ RM 1029	DUAL-LITE	NO	2				12V72W		8FT	LADDER	WALL		HW	☒	☐	
3	CORR ADJ RM 1036	DUAL-LITE	NO	2				12V72W		8FT	LADDER	WALL		HW	☒	☐	
4	CORR ADJ RECYCLE RM 1038	AIM-LITE						12V72W							☒	☐	
5	GYM NEAR ENTRANCE	STANRPO													☒	☐	
6	GYM NEAR STORAGE 1053	DUAL-LITE						12V72W							☒	☐	
7	GYM EMERG. EXIT NEAR STORAGE 1053	DUAL-LITE						12V72W							☒	☐	
8	GYM NEAR CHANGE RMS	DUAL-LITE	NO	2				12V72W		8FT	LADDER	WALL		HW	☒	☐	
9	BOYS CHANGE RM	DUAL-LITE	NO	2				12V72W		8FT	LADDER	WALL		HW	☒	☐	
10	STAGE	DUAL-LITE	NO	2				12V72W		12FT	LADDER	WALL		HW	☒	☐	
11	KITCHEN	DUAL-LITE	NO	2				12V72W		12FT	LADDER	WALL		HW	☒	☐	
12	CAFETERIA OFFICE SIDE	DUAL-LITE	NO	2				12V72W		12FT	LADDER	WALL		HW	☒	☐	
13	CAFETERIA NEAR DRAMA	DUAL-LITE	NO	2				12V72W		12FT	LADDER	WALL		HW	☒	☐	
14	CORR ADJ 1072	AIM-LITE	NO	2				6V36W		10FT					☒	☐	
15	ACROSS ELECTRICAL RM 1098	AIM-LITE	NO	2				12V32W		10FT	LADDER	WALL			☒	☐	
16	ELEC RM 1098	AIM-LITE	NO	2				6V36W		8FT	LADDER	WALL			☒	☐	
17	CORR ADJ RM 1086	DUAL-LITE						12V72W							☒	☐	

Emergency Lighting - Ridgecliff Middle School

[illegible]

	LOCATION: Kingswood	Device	Device address or circuit number	Annunciation
	FIRE ALARM PANEL: Simplex 4100U			

MANUAL PULL STATIONS

1	CAFETERIA EXIT	MA	M1-16	
2	CORRIDOR BY STAIRS # 1 LEVEL 1	MA	M1-17	
3	MAIN ENTRANCE LEVEL 1	MA	M1-20	
4	OUTDOOR STORAGE ROOM	MA	M1-21	
5	GYMNASIUM LEV 1 BY ROOM 154	MA	M1-22	
6	GYMNASIUM EXIT	MA	M1-23	
7	CORRIDOR BY STAIRS # 2 LEVEL 1	MA	M1-24	
8	CORRIDOR BY STAIRS # 3 LEVEL 1	MA	M1-28	
9	SPRINKLER ROOM LEVEL 1 OUTSIDE	MA	M1-31	
10	BOILER ROOM	MA	M1-38	
11	CORRIDOR BY STAIRS # 1 LEVEL 2	MA	M1-6	
12	CORRIDOR BY STAIRS # 2 LEVEL 2	MA	M1-7	
13	CORRIDOR BY STAIRS # 3 LEVEL 2	MA	M1-8	

SMOKE DETECTORS

1	ELECTRICAL ROOM	SMK	M1-40	
2	KITCHEN STORAGE ROOM	SMK	M1-41	
3	SERVER ROOM 143 LEVEL 1	SMK	M1-46	
4	STORAGE ROOM 149 LEVEL 1	SMK	M1-47	
5	STAIR # 1 TOP OF STAIR SMOKE DETECTOR	SMK	M1-48	
6	STAIR # 2 TOP OF STAIR SMOKE DETECTOR	SMK	M1-49	
7	STAIR # 3 TOP OF STAIR SMOKE DETECTOR	SMK	M1-50	
8	SMOKE DET. TOP OF ELEVATOR SHAFT	SMK	M1-9	

HEAT DETECTORS

1	BOILER ROOM	RHTA	M1-39	
---	-------------	------	-------	--

SPRINKLER DEVICES

1	LEFT RISER FLOW SWITCH	FSV	M1-32	
2	RIGHT RISER FLOW SWITCH	FSV	M1-33	
3	LEFT RISER SHUT OFF VALVE SUPERVISORY	SV	M1-34	
4	RIGHT RISER SHUT OFF VALVE SUPERVISORY	SV	M1-35	
5	LEFT BACK FLOW PREVENTER SUPERVISORY	SV	M1-36	
6	RIGHT BACK FLOW PREVENTER SUPERVISORY	SV	M1-37	
7	KITCHEN HOOD SUPPRESSION SYSTEM RELEASE	IAM	M1-45	

NOTIFYING DEVICES

1	LEVEL 1 ELECTRICAL ROOM	MH	SIG # 1	
---	-------------------------	----	---------	--

2	LEVEL 1 BOILER ROOM	MH	SIG # 1	
3	LEVEL 1 GYMNASIUM	MH	SIG # 1	
4	LEVEL 1 GYMNASIUM	MH	SIG # 1	
5	LEVEL 1 GYMNASIUM	MH	SIG # 1	
6	LEVEL 1 GYMNASIUM	MH	SIG # 1	
7	LEVEL 1 CAFETERIA	MH	SIG # 1	
8	LEVEL 1 KITCHEN	MH	SIG # 1	
9	LEVEL 1 CORR BY ROOM 143	MH	SIG # 2	
10	LEVEL 1 CORR BY ROOM 112	MH	SIG # 2	
11	LEVEL 1 CLASSROOM 112	MH	SIG # 2	
12	LEVEL 1 CLASSROOM 115	MH	SIG # 2	
13	LEVEL 1 CLASSROOM 120	MH	SIG # 2	
14	LEVEL 1 CLASSROOM 118	MH	SIG # 2	
15	LEVEL 1 CORR BY ROOM 118	MH	SIG # 2	
16	LEVEL 1 COMM ROOM 143	MH	SIG # 3	
17	MAIN RECEPTION ROOM 109	MH	SIG # 3	
18	LEVEL 1 MAIN ENTRANCE	MH	SIG # 3	
19	LEVEL 1 MUSIC ROOM	MH	SIG # 3	
20	LEVEL 1 CLASSROOM 103	MH	SIG # 3	
21	LEVEL 1 CLASSROOM 101	MH	SIG # 3	
22	LEVEL 1 CORRIDOR BY RM 103	MH	SIG # 3	
23	LEVEL 1 SPRINKLER ROOM	MH	SIG # 3	
24	BELL OUTSIDE MAIN ENTRANCE	HORN	SIG # 4	
25	LEVEL 2 MECHANICAL LEFT SIDE	MH	SIG # 5	
26	LEVEL 2 MECHANICAL RIGHT SIDE	MH	SIG # 5	
27	LEVEL 2 CORRIDOR BY MECH ROOM	MH	SIG # 5	
28	LEVEL 2 CLASSROOM 205	MH	SIG # 5	
29	LEVEL 2 CLASSROOM 204	MH	SIG # 5	
30	LEVEL 2 CLASSROOM 202	MH	SIG # 5	
31	LEVEL 2 CORRIDOR BY CLASSROOM 203	MH	SIG # 5	
32	LEVEL 2 CLASSROOM 208	MH	SIG # 6	
33	LEVEL 2 CLASSROOM 210	MH	SIG # 6	
34	LEVEL 2 CORRIDOR BY CENTER STAIRS	MH	SIG # 6	
35	LEVEL 2 CLASSROOM 212	H/S	SIG # 6	
36	LEVEL 2 CLASSROOM 215	H/S	SIG # 6	
37	LEVEL 2 CLASSROOM 218	H/S	SIG # 6	
38	LEVEL 2 CLASSROOM 220	H/S	SIG # 6	
39	LEVEL 2 CORRIDOR BY RM 218	H/S	SIG # 6	
RELAYS, ETC				
1	DOOR HOLDER BY STAIRS # 1 LEVEL 1	REL-IAM	M1-15	
2	DOOR HOLDER -CORR BY CLASS ROOM 175	REL-IAM	M1-18	
3	DOOR HOLDER -CORR BY CLASS ROOM 175	REL-IAM	M1-19	
4	DOOR HOLDER BY STAIRS # 2 LEVEL 1	REL-IAM	M1-25	

5	DOOR HOLDER BY ROOM 174 LEVEL 1	REL-IAM	M1-26	
6	DOOR HOLDER BY ROOM 174 LEVEL 1	REL-IAM	M1-27	
7	DOOR HOLDER BY STAIRS # 3 LEVEL 1	REL-IAM	M1-29	
8	DOOR HOLDER BY STAIRS # 3 LEVEL 1	REL-IAM	M1-30	
9	DOOR HOLDER BY STAIRS	REL-IAM	M1-42	
10	DOOR HOLDER BY STAIRS	REL-IAM	M1-43	
11	DOOR HOLDER BY STAIRS	REL-IAM	M1-44	
12	DOOR HOLDER BY STAIRS # 1 LEVEL 2	REL-IAM	M1-1	
13	DOOR HOLDER BY STAIRS # 1 LEVEL 2	REL-IAM	M1-2	
14	DOOR HOLDER BY STAIRS # 2 LEVEL 2	REL-IAM	M1-3	
15	DOOR HOLDER BY STAIRS # 3 LEVEL 2	REL-IAM	M1-4	
16	DOOR HOLDER BY STAIRS # 3 LEVEL 2	REL-IAM	M1-5	
17	AHU # 3 FAN SHUTDOWN	REL-IAM	M1-51	
18	AHU # 4 SUPPLY FAN SHUTDOWN	REL-IAM	M1-52	
19	AHU # 4 RETURN FAN SHUTDOWN	REL-IAM	M1-53	
20	AHU # 2 FAN SHUTDOWN	REL-IAM	M1-54	
21	AHU # 1 RETURN FAN SHUTDOWN	REL-IAM	M1-55	
22	AHU # 1 SUPPLY FAN SHUTDOWN	REL-IAM	M1-56	

END OF LINE RESISTORS

1	LEVEL 1 KITCHEN	EOL	SIG # 1	
2	LEVEL 1 CORR BY ROOM 118	EOL	SIG # 2	
3	LEVEL 1 SPRINKLER ROOM	EOL	SIG # 3	
4	SPRINKLER ROOM	EOL	SIG # 4	
5	LEVEL 2 CORRIDOR BY CLASSROOM 203	EOL	SIG # 5	
6	LEVEL 2 CORRIDOR BY RM 218	EOL	SIG # 6	

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Serial #	
1	BY Rm 106 Student services		Y		
	Main Lobby	Y			
	Boys and Girls W/R by music rm	Y			
2	Outside Room 152 MECH RM		Y		
	Outside Gym BY RM 148	Y			
	MECH Room 152	Y			
3	Outside Rooms 118/120		Y		
	Outside Closet 184	Y			
	Outside Closet 116	Y			
	Outside Room 114	Y			
	Bottom of Stairs to BBall Court	Y			
4	Reception		Y		
	Outside Reception	Y			
	Library	Y			

5	BY Primary Classroom 102		Y		
6	Exit to Playground		Y		
	Stairwell, LEFT MIDDLE	Y			
	Stairwell, LEFT UPPER	Y			
7	Outside Class 202		Y		
	End of Hallway, LEFT	Y			
	Boys and Girls W/R BY RM 225	Y			
8	Outside 207		Y		
	Outside Mechanical Room	Y			
	Outside Room 205	Y			
	2 in Mechanical Room	Y			
9	BY CENTER Stairwell. LEV 2		Y		
	In CENTER Stairwell	Y			
	In CENTER Stairwell	Y			
	Boys & Girls W/R BY RM 233	Y			
	Outside Room 210	Y			
10	Top of right Stairs Bball Crt		Y		
	RIGHT CENTER STAIR	Y			
	RIGHT UPPER STAIR	Y			
	BY Room 242	Y			
11	Electrical Room		Y		
12	Cafeteria		Y		
	Cafeteria	Y			
	Cafeteria	Y			
	Cafeteria	Y			
13	Gym Entrance		Y		
	Boys and Girls Change rooms	Y			
	Server Room	Y			
14	Gym		Y		
	GYM	Y			
	GYM	Y			
	GYM	Y			
15	BY RM 101		Y		
16	STAIR TO STAGE		Y		
	STAGE	Y			
	FOYER BETWEEN GYM & STAGE	Y			
17	GYM EXIT BY RM 153		Y		
18	BOT CTR STAIR REAR EXIT		Y		
19	BOT CTR STAIR		Y		
20	BOYS & GIRLS W/R LEV 1 BY ELEV		Y		

NOTES

Breaker 2nd floor mech. room will turn off hallway lights

Breaker 1st fl or O/S Electrical room.

	LOCATION: Basinview Dr.	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards QS4		

	MANUAL PULL STATIONS		
1	MAIN ENTRANCE	M	ZN 01
2	EAST HALL 1ST FL	M	ZN 01
3	ENTRANCE BY PARKING	M	ZN 01
4	WEST HALL 1ST FL	M	ZN 02
5	LIBRARY EXIT	M	ZN 02
6	GYM EXIT	M	ZN 03
7	CAFETERIA EXIT	M	ZN 03
8	BOILER RM	M	ZN 07
9	OIL TANK RM (IN BOILER RM)	M	ZN 08
10	OUTDOOR STORAGE AREA	M	ZN 09
11	EAST HALL BY 210	M	ZN 10
12	TOP OF CENTRE STAIRS	M	ZN 11
13	WEST HALL ,2ND FLOOR	M	ZN 11
	SMOKE DETECTORS		
1	ELECTRICAL RM	SI	ZN 06
2	EAST STAIRS	SI	ZN 13
3	WEST STAIRS	SI	ZN 14
4	CENTRE STAIRS	SI	ZN 15
5	ELEVATOR SHAFT	SI	ZN 16
	HEAT DETECTORS		
1	OFFICE STORAGE	HT	ZN 01
2	JANITORS RM (EAST HALL)	RHT	ZN 01
3	CARETAKERS OFFICE	RHT	ZN 01
4	1ST FL BOOK STORAGE	RHT	ZN 02
5	GYM STORAGE RIGHT SIDE	RHT	ZN 03
6	GYM STORAGE LEFT SIDE	RHT	ZN 03
7	ELEVATOR MECH. RM (IN OFFICE STORAGE)	RHT	ZN 05
8	BOILER RM	HT	ZN 07
9	OIL TANK RM (IN BOILER RM)	HT	ZN 08
10	GYM OUTDOOR STORAGE AREA	RHT	ZN 09
11	FAN RM # 2	RHT	ZN 10
12	STORAGE RM 2ND FLOOR	HT	ZN 11
13	BOOK STORAGE 2ND FLOOR	RHT	ZN 11
14	FAN RM # 1,NEAR ENTRY	RHT	ZN 10

15	FAN RM # 1	RHT	ZN 10
16	UPPER GYM STAGE	RHT	ZN 12
17	UPPER GYM STAGE RIGHT	RHT	ZN 12
	SPRINKLER DEVICES		
1	SPRINKLER FLOW(IN BOILER RM)	FSP	ZN 17
2	SPRINKLER FLOW(IN BOILER RM)	TS	ZN 17
3	ELEVATOR PIT TAMPER	TS	ZN 20
	NOTIFYING DEVICES		
1	ART RM	B	
2	BOILER RM	B	
3	BOILER RM	V	
4	BOYS LOCKER RM	B	
5	BY CARETAKER OFFICE	B	
6	BY CARETAKER OFFICE	V	
7	CAFETERIA	B	
8	CAFETERIA	B	
9	CAFETERIA	V	
10	CAFETERIA	V	
11	CAFETERIA	V	
12	EAST ENTRY BY PAY PHONE	B	
13	EAST HALL	B	
14	EAST HALL	B	
15	EAST HALL	V	
16	EAST HALL	V	
17	EAST HALL	B	
18	EAST HALL	B	
19	EAST HALL	V	
20	EAST HALL	V	
21	FAN RM 1	B	
22	FAN RM # 1	V	
23	FAN RM # 2	B	
24	FAN RM # 2	B	
25	FAN RM # 2	V	
26	FAN RM # 2	V	
27	GIRLS LOCKER RM	B	
28	GYM	B	
29	GYM	B	
30	GYM	V	
31	GYM	V	
32	GYM	V	
33	GYM	V	
34	GYM BACK EXIT	B	
35	GYM ENTRANCE	V	

36	LIBRARY	B	
37	LOBBY AREA	B	
38	LOBBY AREA	V	
39	MAIN EAST ENTRANCE	B	
40	MAIN EAST ENTRANCE	V	
41	MAIN OFFICE	B	
42	MUSIC RM	B	
43	OIL TANKER RM	B	
44	OUTDOOR STORAGE RM	B	
45	WEST HALL	B	
46	WEST HALL	B	
47	WEST HALL	B	
48	WEST HALL	B	
49	WEST HALL	B	
50	WEST HALL	V	
51	WEST HALL	V	
52	WEST HALL	V	
53	WEST HALL	V	
	END OF LINE RESISTORS		
1	JANITORS RM (EAST HALL)	EOL	ZN 01
2	WEST HALL 1ST FL	EOL	ZN 02
3	GYM EXIT	EOL	ZN 03
4	ELEVATOR MECH. RM (IN OFFICE STORAGE)	EOL	ZN 05
5	ELECTRICAL RM	EOL	ZN 06
6	BOILER RM	EOL	ZN 07
7	OIL TANK RM (IN BOILER RM)	EOL	ZN 08
8	OUTDOOR STORAGE AREA	EOL	ZN 09
9	STORAGE RM	EOL	ZN 10
10	WEST HALL	EOL	ZN 11
11	BOILER RM	EOL	ZN 17

Fire Door Number or Location
1ST FL LEFT INNER
1ST FL LEFT OUTER
1ST FL RIGHT INNER
1ST FL RIGHT OUTER
TOP OF MAIN STAIRS
2ND FL LEFT INNER
2ND FL LEFT OUTER
2ND FL RIGHT INNER
2ND FL RIGHT OUTER

EMERGENCY LIGHTING			
Line #	EL UNIT Location	MOD #	Serial #
REM #1			
1	East Vestibule	RG 12-72QB	
2	By Rm 131	RG 12-72QB	
3	Girls Washroom MAIN FLOOR	RG 12-72QB	
4	Boys Washroom MAIN FLOOR	RG 12-72QB	
5	By Trophy Case	RG 12-72QB	
6	By Trophy Case(re mote)	RG 12-72QB	
7	Cafeteria By Kitchen	RG 12-72QB	
8	Cafeteria Exit	RG 12-72QB	
9	Cafeteria, right side	RG 12-72QB	
10	Gym Emergency Exit by cafeteria	RG 12-72QB	
11	Caretakers Rm	RG 12-72QB	
12	Staff rm	RG 12-72QB	
13	By Rm 137	RG 12-72QB	
14	BY STAFF ROOM		
REM #2			
14	Above Main Office	RG 12-72QB	
15	Library	RG 12-72QB	
16	Outside Library	RG 12-72QB	
17	Main Office	RG 12-72QB	
18	Main Vestibule	RG 12-72QB	
19	Vestibule By Fire Panel	RG 12-72QB	
20	Library By Resource Room		
21	West Vestibule BY BOILER RM		
22	Gym Main Entry	RG 12-72QB	
23	Gym By Women's Washroom	RG 12-72QB	
24	Gym by Boy's Washroom	RG 12-72QB	
25	ELECTRICAL RM	RG 12-72QB	
26	Gym By Stage	RG 12-72QB	
27	Gym Stage By Exit	RG 12-72QB	
28	Gym Stage	RG 12-72QB	
29	Rear Gym Wall	RG 12-72QB	
30	Music Rm	RG 12-72QB	
31	Boy's Locker Rm	RG 12-72QB	
32	Girls Locker Rm	RG 12-72QB	
33	By Computer Rm	RG 12-72QB	
34	By Art Rm	RG 12-72QB	
35	Boiler Rm Exit Sign	RG 12-72QB	
36	Electrical Rm	RG 12-72QB	

REM #3			
37	By Resource Rm	RG 12-72QB	
38	Centre Stairs 2ND FLOOR	RG 12-72QB	
39	BY ROOM 201	RG 12-72QB	
40	By Rm 204	RG 12-72QB	
41	By Rm 206	RG 12-72QB	
42	By Rm 210	RG 12-72QB	
43	East Stairs 2ND FLOOR	RG 12-72QB	
44	Girls Washroom 2ND FLOOR	RG 12-72QB	
45	Boys Washroom 2ND FLOOR	RG 12-72QB	
REM #4			
46	By Rm 221	RG 12-72QB	
47	By Rm 223	RG 12-72QB	
48	By Rm 225	RG 12-72QB	
49	West Stairs 2ND FLOOR	RG 12-72QB	
50	Fan Rm Entry	RG 12-72QB	
51	Fan Rm Back Wall	RG 12-72QB	
52	MECH. RM. ENT. BY 225		
53	MECH. RM. BY 225		

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

- 1 BREAKER IN CARETAKER'S OFFICE, PANEL" 302", CCT # 18
- 2 BREAKER IN ELECTRICAL ROOM BY BOILER, PANEL"301, CCT # 1
- 3 BREAKER IN FAN ROOM #1, PANEL"303, CCT # 10
- 4 BREAKER IN MECH ROOM BY RM 210, PANEL"304, CCT # 10

	LOCATION: Rocky Lake	Device	Device address or circuit number	Annunciation
FIRE ALARM PANEL: Simplex 4100U				
MANUAL PULL STATIONS				
1	3RD FLOOR BY ROOM 311	M	6	
2	3RD FLOOR LOBBY	M	6	
3	3RD FLOOR BY ROOM 325	M	1	
4	3RD FLOOR BY ROOM 319	M	3	
5	2ND FLOOR LOBBY	M	3	
6	2ND FLOOR BY ROOM 216	M	3	
7	2ND FLOOR BY ROOM 209	M	3	
8	2ND FLOOR BY ROOM 217	M	3	
9	2ND FLOOR BY STAFF ROOM	M	3	
10	GYM MAIN ENTRANCE	M	3	
11	GYM, RIGHT OF STAGE	M	3	
12	BACK OF GYM	M	3	
13	GYM, UNDER SCORE CLOCK	M	3	
14	1ST FLOOR LOBBY	M	2	
15	1ST FLOOR BY ROOM 104	M	2	
16	1ST FLOOR BY ROOM 106	M	2	
17	KITCHEN	M	2	
18	CAFETERIA	M	2	
19	LIBRARY	M	2	
20	CARETAKER SUPPLY IN DANCE ROOM	M	3	
21	FURNACE ROOM	M	5	
SMOKE DETECTORS				
1	CARETAKER SUPPLY ROOM IN DANCE ROOM	SI	ZONE 3	
DUCT SMOKE DETECTORS				
1	3RD FLOOR LOBBY FAN ROOM RETURN	DS	ZONE 7	
2	3RD FLOOR LOBBY FAN ROOM	DS	ZONE 7	
HEAT DETECTORS				
1	ELECTRICAL ROOM	HT	ZONE 5	
SPRINKLER DEVICES				
1	KITCHEN	AD	1	
2	SPRINKLER ROOM GATE VALVE	GV	7	
3	SPRINKLER ROOM FLOW ALARM	FS	7	
NOTIFYING DEVICES				
1	1ST FLOOR LOBBY	B	SIG 1	

2	1ST FLOOR BY ROOM 102	B	SIG 1	
3	1ST FLOOR BY ROOM 107	B	SIG 1	
4	DANCE ROOM 106	B	SIG 1	
5	COMPUTER ROOM 105	B	SIG 1	
6	MUSIC ROOM	B	SIG 1	
7	CAFETERIA	B	SIG 1	
8	LIBRARY	B	SIG 1	
9	FURNACE ROOM	10" B	SIG 1	
10	SPORTS STORAGE ROOM (GREY DOOR)	B	SIG 1	
11	2ND FLOOR LOBBY	B	SIG 2	
12	2ND FLOOR BY GIRLS WASHROOM	B	SIG 2	
13	2ND FLOOR BY ROOM 205	B	SIG 2	
14	2ND FLOOR BY ROOM 208	B	SIG 2	
15	2ND FLOOR BY ROOM 211	B	SIG 2	
16	2ND FLOOR BY ROOM 215	B	SIG 2	
17	2ND FLOOR BY STAFF ROOM	B	SIG 2	
18	GYM (Corridor above Lockers)	B	SIG 2	
19	GYM	B	SIG 2	
20	3RD FLOOR LOBBY	B	Sig #3	
21	3RD FLOOR BY GIRLS WASHROOM	B	Sig #3	
22	3RD FLOOR BY ROOM 304	B	Sig #3	
23	3RD FLOOR BY ROOM 310	B	Sig #3	
24	3RD FLOOR BY ROOM 313	B	Sig #3	
25	3RD FLOOR BY ROOM 318	B	Sig #3	
26	3RD FLOOR BY ROOM 325	B	Sig #3	

END OF LINE RESISTORS

1	3RD FLOOR BY ROOM 319	EOL	ZONE 1	
2	LIBRARY	EOL	ZONE 3	
3	KITCHEN	EOL	ZONE 4	
4	FURNACE ROOM	EOL	ZONE 5	
5	SPRINKLER ROOM	EOL	ZONE 6	
6	3RD FLOOR LOBBY FAN ROOM	EOL	ZONE 7	
7	CAFETERIA	EOL	SIG 1	
8	2ND FLOOR BY ROOM 215	EOL	SIG 2	
9	3RD FLOOR BY ROOM 318	EOL	Sig #3	

LOOP

2ND FLR SERVER RM 204B	S		M1-2
2ND FLR 200A	HT		M1-3
2ND FLR ELEV. LOBBY	M		M1-7
2ND FLR ELEV. LOBBY	S		M1-9
3RD FLR STORAGE 301B	S		M1-12

ELEV ALT	R		M1-15
1ST FLR ELEV	GV		M1-18
1ST FLR MACH RM	HT		M1-5
1ST FLR STORAGE 101A	S		M1-8
3RD FLR ELEV. SHUT OFF	GV		M1-19
1ST FLOOR ELEV. SHUT OFF	GV		M1-18
3RD FLR ELEV. LOBBY	S		M1-1
ELEV. HAT	R		M1-16
ELEV. SHAFT	S		M1-13
ELEV. RECALL	R		M1-14
1ST ELEV. LOBBY	S		M1-17
3RD FLR STORAGE 300A	HT		M1-4
3RD FLR ELEV. LOBBY	M		M1-7
2ND FLR STORAGE 201B	S		M1-10

NOTES:

ZONE 4: 3RD FLR DEVICES

ZONE 3: 2ND FLR DEVICES

ZONE 1: KIT. SUPPRESSION

ZONE 2: 1ST FLR DEVICES

ZONE 5: BOILER RM

ZONE 6: DUCT DET,'S

ZONE 7: SPRINK. FLOW

EMERGENCY LIGHTING			
Line #	EL UNIT Location	Remote Head	
			Cab. Head
1	GYM EXIT		
2	GYM EXIT	REMOTE	
3	GYM EXIT		COMBO
4	GYM EXIT		COMBO
5	MUSIC ROOM 108A		COMBO

6	MUSIC ROOM 107B		COMBO
1	1ST FLR STORAGE BATT PACK		
2	North Stairs Floor 1 1/2	REMOTE	
3	Boiler Room	REMOTE	
4	Electrical Room	REMOTE	
5	By room 107	REMOTE	
6	By room 102	REMOTE	
7	By room 207	REMOTE	
8	Gym rear left	REMOTE	
9	Gym rear right	REMOTE	
10	By room 212	REMOTE	
11	North Stairs Floor 2 1/2	REMOTE	
12	By room 313	REMOTE	
13	By room 308	REMOTE	
14	2ND FLR JANITOR ROOM BATT PACK		
15	By room 202	REMOTE	
16	2nd floor lobby	REMOTE	
17	Main lobby	REMOTE	
18	Cafeteria hallway	REMOTE	
19	1st floor ramp	REMOTE	
20	Front stairs 1st to 2nd floor	REMOTE	
21	Front stairs 2nd to 3rd floor	REMOTE	
22	Front stairs top	REMOTE	
23	Boys washroom 1st floor	REMOTE	
24	Girls washroom 1st floor	REMOTE	
25	Boys washroom 2nd floor	REMOTE	
26	Girls washroom 2nd floor	REMOTE	
27	Boys change room 2nd floor	REMOTE	
28	Girls change room 2nd floor	REMOTE	
1	*Boys Washroom 3rd Floor	REMOTE	
2	*Girls Washroom 3rd Floor	REMOTE	
3	*3rd Floor Lobby	REMOTE	
4	*By Room 301	REMOTE	
5	*Kitchen	REMOTE	
6	Room 317 Battery Pack		
7	*By Room 324	REMOTE	
8	*Ramp 3rd Floor	REMOTE	
9	*Ramp 2nd to 3rd Floor #1	REMOTE	
10	*Ramp 2nd to 3rd Floor #2	REMOTE	
11	*Ramp 2nd to 1st Floor #1	REMOTE	
12	*Ramp 2nd to 1st Floor #2	REMOTE	
13	*Library	REMOTE	
14	*By Staff Room	REMOTE	

15	*By Room 217	REMOTE
16	*West Stairs 1st to 2nd Floor	REMOTE
17	*West Stairs 2nd to 3rd Floor	REMOTE
18	*Cafeteria - Right Wall	REMOTE
19	*Cafeteria - Left Side	REMOTE
20	*Gym Entry	REMOTE
21	*Gym	REMOTE
22	*Gym Wall By Stage	REMOTE
23	Cafeteria Front Post	UNIT
24	*Cafeteria Front	REMOTE
25	Cafeteria Centre Post	UNIT
26	*Cafeteria Centre	REMOTE
27	Cafeteria Rear Post	UNIT
28	*Cafeteria Rear	REMOTE

	LOCATION: Hammonds Plains	Device	Device address or circuit number	Annunciation
	FIRE ALARM PANEL: Notifier 2500			
MANUAL PULL STATIONS				
1	BACK ENTRANCE BY ROOM 257	M	ZONE 11	
2	FRONT ENTRANCE BY ROOM 245	M	ZONE1 1	
3	GYM EXIT	M	ZONE 2	
4	GYM ENTRANCE 1	M	ZONE 2	
5	GYM ENTRANCE 2	M	ZONE 2	
6	MAIN ENTRANCE	M	ZONE 3	
7	LIBRARY EXIT	M	ZONE 3	
8	STORAGE ROOM 221	M	ZONE 3	
9	EXIT BY ROOM 229	M	ZONE 3	
10	BY STAFF WASHROOM 228	M	ZONE 3	
11	ENTRANCE BY ROOM 207	M	ZONE 3	
12	CAFETERIA ENTRANCE BY ROOM 206	M	ZONE 4	
13	CAFETERIA LEFT	M	ZONE 4	
14	CAFETERIA RIGHT	M	ZONE 4	
15	BASEMENT ENTRANCE	M	ZONE 5	
16	MECHANICAL ROOM 300	M	ZONE 6	
SMOKE DETECTORS				
1	COMM ROOM 239	S	ZONE 3	
2	BOOK STORAGE ROOM 240	S	ZONE 3	
3	LIBRARY OFFICE 205B	S	ZONE 3	
4	ELECTRICAL ROOM 102	S	ZONE 5	
5	MECH RM ABOVE KITCHEN STAIRS	S	ZONE 6	
HEAT DETECTORS				
1	JANITORS ROOM 269	HT	ZONE 1	
2	GYM STORAGE 259	HT	ZONE 1	
3	GYM STORAGE 267	HT	ZONE 1	
4	MECHANICAL ROOM 273-Ventalation	HT	ZONE 3	
5	ROOM 237	HT	ZONE 3	

6	STORAGE ROOM 221	HT	ZONE 3	
7	JANITORS ROOM 226	HT	ZONE 3	
8	STORAGE ROOM 241	HT	ZONE 3	
9	STORAGE ROOM 238	HT	ZONE 3	
10	STORAGE ROOM 237A	HT	ZONE 3	
11	KITCHEN	HT	ZONE 4	
12	BOILER ROOM	HT	ZONE 5	
13	BOILER ROOM	HT	ZONE 5	
14	BOILER ROOM	HT	ZONE 5	
15	SPRINKLER ROOM 101	HT	ZONE 5	
16	MECHANICAL ROOM 2	HT	ZONE 6	
17	MECHANICAL ROOM 2	HT	ZONE 6	
18	OUTSIDE STORAGE	HT	ZONE 7	

NOTIFYING DEVICES

1	CAFETERIA LEFT	B	SIG 1	
2	HALL BY ROOM 216	B	SIG 1	
3	HALL BY ROOM 211	B	SIG 1	
4	HALL BY ROOM 237	B	SIG 1	
5	GYM FRONT	B	SIG 1	
6	GYM BACK	B	SIG 1	
7	HALL BY ROOM 273	B	SIG 1	
8	HALL BY BOYS WASHROOM 270	B	SIG 1	
9	HALL BY STAFF WASHROOM 264	B	SIG 1	
10	HALL BY ROOM 257	B	SIG 1	
11	MUSIC ROOM 257	B	SIG 1	
12	HALL BY ROOM 204	B	SIG 2	
13	CAFETERIA RIGHT	B	SIG 2	
14	LIBRARY	B	SIG 2	
15	HALL BY GIRLS WASHROOM 225	B	SIG 2	
16	HALL BY BOYS WASHROOM 227	B	SIG 2	
17	HALL BY ROOM 219	B	SIG 2	
18	MECHANICAL ROOM 2	B	SIG 2	
19	BASEMENT ENTRANCE	B	SIG 2	
20	STAFF ROOM 203	B	SIG 2	
21	LIBRARY	V	SIG 3	
22	CAFETERIA LEFT	V	SIG 3	
23	CAFETERIA RIGHT	V	SIG 3	
24	ROOM 219	V	SIG 3	
25	GYM FRONT	V	SIG 4	
26	GYM BACK	V	SIG 4	

END OF LINE RESISTORS

1	GYM BACK	EOL	SIG 1	
---	----------	-----	-------	--

2	HALL BY BOYS WASHROOM 227	EOL	SIG 2	
3	CAFETERIA RIGHT	EOL	SIG 3	
4	GYM BACK	EOL	SIG 4	
5	MECHANICAL ROOM 273	EOL	ZONE 1	
6	GYM EXIT	EOL	ZONE 2	
7		EOL	ZONE 3	
8	KITCHEN	EOL	ZONE 4	
9	BASEMENT ENTRANCE	EOL	ZONE 5	
10	MECHANICAL ROOM 2	EOL	ZONE 6	
11	OUTSIDE STORAGE	EOL	ZONE 7	
12	KITCHEN	EOL	ZONE 8	
13	SPRINKLER ROOM	EOL	ZONE 9	
14	SPRINKLER ROOM	EOL	ZONE 10	
15	SPRINKLER ROOM	EOL	ZONE 13	
16	SPRINKLER ROOM	EOL	ZONE 14	
17	SPRINKLER ROOM	EOL	ZONE 15	
18	KITCHEN	EOL	ZONE 16	

KITCHEN & SPRINKLER DEVICES

KITCHEN HOOD	ALARM	8
SPRINKLER ALARM	F	9
LOW WATER #2	ALARM	10
SPRINKLER LOW AIR	SUPERVI SORY	13
SPRINKLER LOW WATER	ALARM	14
SPRINKLER VALVES	SUPERVI SORY	15
KITCHEN HOOD VALVE	SUPERVI SORY	16

EMERGENCY LIGHTS

Location	# of Heads	Model
BY EXIT NEAR ROOM 229		REMOTE
EXIT NEAR ROOM 229		EXIT
BY ROOM 228		UNIT LUMACELL
CORRIDOR BY ROOM 226	2	REMOTE

226		
GIRLS WASHROOM	1	REMOTE
BOYS WASHROOM	1	REMOTE
CORRIDOR BY ROOM 232	2	REMOTE
CORRIDOR BY ROOM 232		EXIT
CORRIDOR BY ROOM 237		LUMACELL UNIT
CORRIDOR BY ROOM 235	2	REMOTE
CORRIDOR BY ROOM 273		UNIT LUMACELL
ROOM 273 MECH ROOM	1	REMOTE
CORRIDOR BY ROOM 245		LUMACELL UNIT
SIDE EXIT NEAR GYM ENTRANCE		EXIT
SIDE EXIT NEAR GYM ENTRANCE	1	REMOTE
NEAR ROOM 246	2	REMOTE
NEAR ROOM 246	EXIT	
BOYS WASHROOM 270	1	REMOTE
GIRLS WASHROOM	1	REMOTE
CORRIDOR BY ROOM 264		UNIT
CORRIDOR BY ROOM 257	2	REMOTE
INSIDE ROOM 256	2	REMOTE
SIDE EXIT BY PORTABLES		EXIT
SIDE EXIT BY PORTABLES	1	REMOTE
PORTABLE CLASSROOM EXIT 3		LUMACELL UNIT
PORTABLE CLASSROOM EXIT 3		LUMACELL UNIT
PORTABLE CLASSROOM 1		LUMACELL UNIT
PORTABLE CLASSROOM 1		EXIT COMBO LUMACELL
PORTABLE		EXIT

PORTABLE CLASSROOM 1		EXIT COMBO LUMACELL
PORTABLE CLASSROOM 3		EXIT COMBO LUMACELL
PORTABLE CLASSROOM 3		EXIT COMBO LUMACELL

GYM		UNIT
GYM	2	REMOTE
GYM EXIT	1	REMOTE
GYM	2	REMOTE
BOYS CHANGE ROOM 271	1	REMOTE
BOYS WASHROOM	1	REMOTE
GIRLS CHANGE ROOM 277	1	REMOTE
GIRLS WASHROOM	1	REMOTE
MECH ROOM ABOVE CAFETERIA	1	UNIT LUMACELL
ELECTRICAL ROOM		REMOTE
SPRINKLER ROOM	1	REMOTE
BOILER ROOM		UNIT LUMACELL ROOM 1440B
CORRIDOR BT ROOM 211		EXIT #1
CORRIDOR BY ROOM 211		EXIT #2
BY ROOM 211	2	REMOTE
BY ROOM 209	2	REMOTE
BY ROOM 204		EXIT SIGN
BY MAIN OFFICE		EXIT SIGN
BY FIRE ALARM PANEL	1	REMOTE
IN ROOM 203	2	REMOTE
ADJACENT TO ROOM 203	2	REMOTE
BY ROOM 208		UNIT

BY ROOM 206		UNIT LUMACELL
BY ROOM 207		UNIT LUMACELL
BY ROOM 216		EXIT SIGN
BY ROOM 207		EXIT SIGN
BY ROOM 207 EXIT DOOR	1	REMOTE
BY ROOM 210	2	REMOTE
BY ROOM 219	2	REMOTE
LIBRARY	2	REMOTE
EXIT SIGN #1		CORRIDOR NEAR WASHROO M 220
CORRIDOR NEAR WASHROOM		EXIT SIGN
CORRIDOR NEAR WASHROOM 220		EXIT SIGN
CAFETERIA		UNIT LUMACELL
CAFETERIA	2	REMOTE

CAFETERIA		EXIT SIGN
CAFETERIA		EXIT SIGN
CAFETERIA		UNIT LUMACELL
CAFETERIA		EXIT SIGN
BREAKERS CONTROLLING LIGHTS		
ROOM 226 PANEL 31 CIRCUIT 13		
FAN ROOM PANEL 32 CIRCUIT 13		
PORTABLE 13		COMBO UNIT
PORTABLE 13		COMBO UNIT
PORTABLE 14		COMBO UNIT
PORTABLE 14		COMBO UNIT
PORTABLE 14		UNIT

PORTABLE 15		EXIT
PORTABLE 16		EXIT
PORTABLE 16		EXIT

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS	
---	--

	BREAKERS IN JANITOR ROOM BEHIND DOOR AND IN ROOM 226 & ELECTRICAL ROOM
--	--

	LOCATION: Sunnyside Eagelwood	Device	Device address or circuit number
	FIRE ALARM PANEL: Mirtone 790		

MANUAL PULL STATIONS

1	GYM #1	M	ZONE 1
2	GYM #2	M	ZONE 1
3	GYM #3	M	ZONE 1
4	GYM #4	M	ZONE 1
5	FRONT ENTRANCE	M	ZONE 2
6	EXIT BY RM 105	M	ZONE 2
7	EXIT BY MUSIC ROOM	M	ZONE 2
8	BOILER ROOM	M	ZONE 3
9	2ND FLOOR BY 207	M	ZONE 5
10	2ND FLOOR TOP STAIR BY STAFF OFFICE	M	ZONE 5
11	2ND FLOOR BY 205	M	ZONE 5

SMOKE DETECTORS

1	NORTH STAIRS BY 205	S	ZONE 4
2	MAIN STAIRS	S	ZONE 6
3	SOUTH STAIRS BY 207	S	ZONE 10

HEAT DETECTORS

1	BOILER ROOM	HT	ZONE 3
---	-------------	----	--------

NOTIFYING DEVICES

1	MAIN LOBBY	B	SIG 1
2	GYM	B	SIG 1
3	SICK ROOM	B	SIG 1
4	PHOTOCOPY ROOM	B	SIG 1
5	1ST FLOOR HALL	B	SIG 1
6	1ST FLOOR HALL	B	SIG 1
7	1ST FLOOR HALL	B	SIG 1
8	2ND FLOOR HALL BY ROOM 207	B	SIG 2
9	2ND FLOOR HALL BY CARETAKERS OFFICE	B	SIG 2
10	BOILER ROOM	B	SIG 1
11	2ND FLOOR HALL	B	SIG 2

END OF LINE RESISTORS

1	GYM	EOL	ZONE 1
2	WEST EXIT BY MUSIC ROOM	EOL	ZONE 2
3	BOILER ROOM	EOL	ZONE 3
4	NORTH STAIRS	EOL	ZONE 4

5	2ND FLOOR SOUTH STAIR	EOL	ZONE 5
6	MAIN STAIRS	EOL	ZONE 6
7	SOUTH STAIRS	EOL	ZONE 8
8	2ND FLOOR HALL	EOL	SIG 1
8	2ND FLOOR HALL BY ROOM 207	EOL	SIG 2

Fire Door Number or Location
BY 102
BY STAFF WASHROOM
BY MUSIC ROOM
BY 105
BY 205
BY 202
BY 208

EMERGENCY LIGHTING

Line #	EL UNIT Location	Cab. Head	Cover	Bat. VAH
BREAKER IN 1ST FLOOR JANITOR CLOSET, PNL "A", CCT #14				
1	Main Entrance	Y		
2	By Room 103	Y		
3	West Exit By Music Room	Y		6V/7.2Ah
4	Gym,#1	Y		6V/4.5Ah
5	Gym,#2	Y		6V/4.5Ah
6	Gym,#3	Y		
7	Gym, #4	Y		
8	Gym,#5	Y		
9	BY Work Room	Y		
BREAKER IN 2ND FLOOR JANITOR RM , PANEL "B",. CCT#29				
10	By Room 201	Y		
11	By Room 203	Y		
12	Top of North Stairs	Y		
13	Top of Main Stairs	Y		
14	2nd Floor BY 207	Y		
15	Top of South Stairs	Y		
INDIVIDUAL LIGHTS				
16	by Room 105	Y		
17	2nd Floor BY 205	Y		
18	PORTABLE #1			
19	PORTABLE #1			
20	PORTABLE #2 marked as # 27			
21	PORTABLE #2			

22	PORTABLE #3 marked as # 28			
23	PORTABLE #3			

	LOCATION: Sunnyside Fort Sackville	Device	Device address or circuit number	Annunciation	NOTES
	FIRE ALARM PANEL: Edwards 1527				

MANUAL PULL STATIONS					
1	FRONT ENTRANCE	M	ZONE 1		
3	LEFT EXIT FROM GYM	M	ZONE 1		
4	RIGHT EXIT FROM GYM	M	ZONE 1		
5	REAR EXIT	M	ZONE 1		
2	HALL OUTSIDE GYM	M	ZONE 1		
6	BOILER ROOM	M	ZONE 1		
HEAT DETECTORS					
1	BOILER ROOM	HT	ZONE 1		
2	TEACHER'S WORK ROOM	RHT	ZONE 1		
3	STAFF ROOM	HT	ZONE 1		
NOTIFYING DEVICES					
1	BOILER ROOM	B	SIG 1		
2	HALLWAY	B	SIG 1		
3	GYM	B	SIG 1		
END OF LINE RESISTORS					
1	GYM	EOL	ZONE 1		
2	GYM	EOL	SIG 1		

EMERGENCY LIGHTING

Line #	EL UNIT Location	# of Head	Cab. Head	Re ma rks	Bat. VAH
1	Hallway	2	Y		
2	Gym Left	2	Y	CO M BO	
3	Gym Right	2	Y		
4	Portable, FRONT	2	Y		
5	Portable, REAR	2	Y		6V 7AH

	GYM BY PHOTOCOPY RM.	2			
	FRONT ENTRY	2		COMBO	
	BOILER ROOM				

LOCATION: Charles P. Allen

Fire Panel: Siemens

FIRE ALARM DEVICE

Location Description	Device	Model	Address	Zone / Circuit #
1ST FLOOR MAIN ENTRY	M			1-10
ADMINISTRATION ROOM 1042	M			1-11
WASHROOM 1048	S			1-12
WORK ROOM 1050	S			1-13
CLOSET 1052A	S			1-14
WATER ROOM 1046	H			1-15
MENS WASHROOM 1054	S			1-16
JANITORS ROOM 1057	H			1-17
WASHROOM 1056	S			1-18
WOMENS WASHROOM 1055	S			1-19
1ST FLOOR CORRIDOR BY STAIR 4	M			1-20
1ST FLOOR CORRIDOR BY STAIR 4	R			1-21
1ST FLOOR CORRIDOR BY STAIR 4	S			1-22
COMMUNICATIONS ROOM 1063	S			1-23
CORRIDOR BY COMMS ROOM 1063	M			1-24
CORRIDOR BY WATER ROOM 1064	M			1-25
SERVERY 1077	M			1-26
KITCHEN STORES 1076	S			1-27
SERVERY 1077 HOOD SYSTEM ALARM	R			1-28
WATER ROOM 1064	H			1-29
CUSTODIAL ROOM 1065	H			1-30
RECYCLING ROOM 1066	S			1-31

RECYCLING ROOM 1066	S			1-31
STORAGE ROOM 1067.1	S			1-32
STORAGE ROOM 1067.2	S			1-33
STORAGE ROOM 1067.30	S			1-34
1ST FLOOR CORRIDOR BY STAIR 5A	S			1-35
STORAGE ROOM 1066A	S			1-36
CORRIDOR 1071 NEAR DRAMA	M			1-37
PRACTICE ROOM 1069C	S			1-38
CAFETORIUM 1074	M			1-39
CAFETORIUM 1074	M			1-40
CAFETORIUM 1074	M			1-41
STUDENT EXCHANGE 106	M			1-42

Location Description	Device	Model	Address	Zone / Circuit #
1ST FLOOR CORRIDOR BY ELEVATOR 1	S			1-43
1ST FLOOR CORRIDOR BY ELEVATOR 1	S			1-44
1ST FLOOR CORRIDOR BY ELEVATOR 1	GV			1-45
CORRIDOR BY SUMP ROOM 1032	S			1-46
1ST FLOOR CORRIDOR BY STAIRS 1	S			1-47
1ST FLOOR CORRIDOR BY STAIR 1	M			1-48
1ST FLOOR CORRIDOR BY STAIR 1 DOOR RELEASE	R			1-49
WASHROOM 1005	S			1-50
1ST FLOOR CORRIDOR BY STAIR 2	S			1-51
1ST FLOOR CORRIDOR BY STAIR 2	M			1-52
1ST FLOOR CORRIDOR BY STAIR 2	M			1-53
SUMP ROOM 1032	HT			1-54
COMMUNICATIONS ROOM 1033	S			1-55
ELEVATOR MACHINE ROOM 1043	S			1-56
ELEVATOR MACHINE ROOM 1034 CAPTURE	R			1-57
ELEVATOR MACHINE ROOM 1034 ALTERNATE	R			1-58

FLOOR				
ELEVATOR MACHINE ROOM 1034 FF HAT	R			1-59
WASHROOM 1029 WOMENS	S			1-61
WASHROOM 1030	S			1-62
JANITORS ROOM 1031	H			1-63
WASHROOM 1028 MENS	S			1-64
PHOTOGRAPHY ROOM 1026	S			1-65
STORAGE ROOM 1025A	S			1-66
VISUAL ARTS 1025	M			1-67
1ST FLOOR CORRIDOR BY STAIR 3	S			1-68
1ST FLOOR CORRIDOR BY STAIR 3	M			1-69
1ST FLOOR CORRIDOR BY STAIR 3 DOOR RELEASE	R			1-70
1ST FLOOR STAIR 3	S			1-71

Location Description	Device	Model	Address	Zone / Circuit #
DUST COLLECTOR	D			1-72
DUST COLLECTOR	D			1-73
BACKFLOW CITY SIDE	SO			1-74A
BACKFLOW BUILDING SIDE	SO			1-74B
1ST FLOOR SPRINKLER FLOW	F			1-75A
1ST FLOOR SPRINKLER SHUTOFF	SO			1-75B
RISER 2 SPRINKLER FLOW	F			1-76A
RISER 2 SPRINKLER SHUT OFF	SO			1-76B
RISER 1 SPRINKLER FLOW	F			1-77A
RISER 1 SPRINKLER SHUT OFF	SO			1-77B
MAIN ELECTRICAL ROOM SPRINKLER FLOW	F			1-78A
MAIN ELECTRICAL ROOM SPRINKLER SHUT OFF	SO			1-79B
DRAMA/MUSIC EXIT	M			1-79
DRAMA/MUSIC EXIT	M			1-80
2ND FLOOR MAGNETIC DOOR HOLDER RELAY CORRIDOR BY STAIR 3,	R			1-101

2ND FLOOR				
2ND FLOOR CORRIDOR BY STAIR 3	M			1-102
2ND FLOOR CORRIDOR BY STAIR 3	S			1-103
MALE WASRHOOOM 2029	S			1-104
JANITORS ROOM 2032	H			1-105
WASHROOM 2031	S			1-106
FEMALE WASHROOM 2030	S			1-107
STORE ROOM 2030A	S			1-108
COMMUNICATION ROOM 2033	S			1-109
2ND FLOOR CORRIDOR BY STAIR 2	M			1-110
WASHROOM 2008A	S			1-111
RECORDS ROOM 2004C	S			1-112
2ND FLOOR CORRIDOR BY STAIR 1	S			1-113
2ND FLOOR CORRIDOR BY STAIR 1	M			1-114
2ND FLOOR MAGNETIC DOOR HOLDER RELAY CORRIDOR BY STAIR 1	R			1-115

Location Description	Device	Model	Address	Zone / Circuit #
2ND FLOOR ZONE 3 SPRINKLER FLOW	F			1-116A
2ND FLOOR ZONE 3 SPRINKLER SHUT OFF	SO			1-116B
2ND FLOOR ZONE 2 SPRINKLER FLOW	F			1-117A
2ND FLOOR ZONE 2 SPRINKLER SHUT OFF	SO			1-117B
2ND FLOOR ZONE 1 SPRINKLER FLOW	F			1-118A
2ND FLOOR ZONE 1 SPRINKLER SHUT OFF	SO			1-118B
WASHROOM 2044A	S			1-119
WASHROOM 2044B	S			1-120
MALE WASHROOM 2045	S			1-121
JANITORS ROOM 2048	H			1-122
WASHROOM 2047	S			1-123

FEMALE WASHROOM 2046	S			1-124
2ND FLOOR CORRIDOR BY STAIR 4	M			1-125
2ND FLOOR CORRIDOR BY STAIR 4	S			1-126
COMMUNICATIONS ROOM 2062	S			1-127
STORE ROOM 2060A	S			1-128
WASHROOM 2062A	S			1-129
VESTIBULE 2054	M			1-130
CORRIDOR BY ELECTRICAL ROOM 2055	M			1-131
COMMUNICATIONS ROOM 2077	S			1-132
STORE ROOM 2076A	S			1-133
2ND FLOOR PUBLIC STREET	S			1-135
2ND FLOOR PUBLIC STREET	S			1-136
2ND FLOOR STAIR 7	S			1-137
ELEVATOR 2 SPRINKLER	SO			1-138
CORRIDOR BY DAYCARE 214	M			1-139
DAYCARE 214	S			1-140
DAYCARE 214	S			1-141

Location Description	Device	Model	Address	Zone / Circuit #
OUTDOOR WASHROOM 2090	S			1-142
OUTDOOR WASHROOM 2091	S			1-143
STORE ROOM 2089B (IN DAYCARE)	S			1-144
STORE ROOM 2092A	S			1-145
STORE ROOM 2092B	S			1-146
2ND FLOOR PUBLIC ST	S			1-134
RECYCLING ROOM 2075	S			1-147
CHANGE ROOM 2078	S			1-148

CHANGE ROOM 2081	S			1-149
JANITOR ROOM 2084	H			1-150
WASHROOM 2079	S			1-151
WASHROOM 2080	S			1-152
STORE ROOM 2082	S			1-153
COMMUNITY GYM 2066	M			1-154
COMMUNITY GYM 2066	M			1-155
COMMUNITY GYM 2066	M			1-156
SCHOOL GYM 2063	M			1-157
SCHOOL GYM 2063	M			1-158
STORE ROOM 2073 BY ELECT RM	M			1-159
STORE ROOM 2073 BY ELECT RM	H			1-160
ELECTRICAL ROOM 2072	M			1-161
ELECTRICAL ROOM 2072	M			1-162
ELECTRICAL ROOM 2072	S			1-163
ELECTRICAL ROO 2071B	S			1-164
CORRIDOR 2071A	S			1-165
STORE ROOM 2071	S			1-166
CHANGE ROOM 2068 #1	S			1-167
CHANGE ROOM 2067 #2	S			1-168

Location Description	Device	Model	Address	Zone / Circuit #
CHANGE ROOM 2066 #3	S			1-169
CHANGE ROOM 2065 #4	S			1-170
2ND FLOOR STAIRS 4 DOOR HOLDERS	R			1-171
COMMUNITY GYM WEST EXIT	M			1-172
2ND FLOOR STAIR 5A	S			1-173
2ND FLOOR STAIR 6 EXIT (BOTTOM)	M			1-174
COMMUNITY GYM P.A MUTE	R			1-175
SCHOOL GYM P.A. MUTE	R			1-176

3RD FLOOR STAIR 3	S			2-10
3RD FLOOR CORRIDOR BY STAIR 3	M			2-11
3RD FLOOR CORRIDOR BY STAIR 3	S			2-12
3RD FLOOR CORRIDOR BY STAIR 3	R			2-13
MALE WASHROOM 3029	S			2-14
JANITORS ROOM 3032	H			2-15
FEMALE WASHROOM 3031	S			2-16
WASHROOM 3030	S			2-17
COMMUNICATIONS ROOM 3033	S			2-18
ELEVATOR 1 SHAFT	S			2-19
ELEVATOR 1 SPRINKLER	SO			2-20
3RD FLOOR CORRIDOR BY STAIR 2	M			2-21
3RD FLOOR STAIR 2	S			2-22
3RD FLOOR CORRIDOR BY STAIR 3	S			2-23
3RD FLOOR FIRE SHUTTER RELAY COORIDOR BY STAIR 3	R			2-24
3RD FLOOR CORRIDOR BY STAIR 1	M			2-25
3RD FLOOR CORRIDOR BY STAIR 1	S			2-26
3RD FLOOR CORRIDOR BY STAIR 1 DOOR HOLDER	R			2-28
3RD FLOOR STAIR 1	S			2-29
WASHROOM 3059A	S			2-30
CHEMISTRY STORES 3043	S			2-31
CHEMISTRY PREP 3042	S			2-32
3RD FLOOR SPRINKLER FLOW ZONE 1	F			2-33A

Location Description	Device	Model	Address	Zone / Circuit #
3RD FLOOR SPRINKLER SHUT OFF ZONE 1	SO			2-33B
3RD FLOOR SPRINKLER FLOW ZONE 2	F			2-34A
3RD FLOOR SPRINKLER SHUT OFF ZONE 2	SO			2-34B
3RD FLOOR SPRINKLER FLOW ZONE 3	F			2-35A
3RD FLOOR SPRINKLER SHUT OFF ZONE 3	SO			2-35B
CORRIDOR BY LAB 3062	R			2-36

CORRIDOR BY LAB 3062	S			2-37
CORRIDOR BY LAB 3062	M			2-38
CORRIDOR BY TWR#3 3063	M			2-39
CORRIDOR BY TWR#3 3063 BY WASHRM 3RD	S			2-40
MALE WASHROOM 3045	S			2-41
JANITORS ROOM 3048	H			2-42
STAFF WASHROOM 3047	S			2-43
FEMALE WASHROOM 3046	S			2-44
3RD FLOOR STAIR 4	S			2-45
3RD FLOOR CORRIDOR BY STAIR 4	M			2-46
3RD FLOOR CORRIDOR BY STAIR 4	S			2-47
3RD FLOOR CORRIDOR BY STAIR 4	R			2-48
COMMUNICATIONS ROOM 3064	S			2-49
BOILER ROOM 3065	H			2-50
BOILER ROOM 3065	H			2-51
BOILER ROOM 3065	M			2-52
AHU1 SUPPLY MECHANICAL ROOM 3066	DS			2-53
AHU MECHANICAL ROOM 3066	DS			2-54
MECHANICAL ROOM 3066	S			2-55
MECHANICAL ROOM 3066	M			2-60
MECHANICAL ROOM 3066	S			2-61
STORAGE ROOM 3081	S			2-62
CORRIDOR BY STORAGE ROOM 3061	M			2-63
3RD FLOOR STAIR 6	S			2-64
LAUNDRY 3052A	H			2-65
STAIR 6 3RD FLOOR	M			2-66

Location Description	Device	Model	Address	Zone / Circuit #
3RD FLOOR CORRIDOR BY STAIR 6	M			2-67
COMMUNICATIONS ROOM 3070A	S			2-68
ELEVATOR RM 3077	S			2-69

ELEVATOR MACHINE ROOM 3077 CAPTURE	R			2-71
ELEVATOR MACHINE ROOM 3077 ALTERNATE FLOOR	R			2-72
ELEVATOR MACHINE ROOM 3077 FF HAT	R			2-73
WASHROOM 3079	S			2-74
WASHROOM 3078	S			2-75
ELEVATOR 2 SPRINKLER	SO			2-76
ELEVATOR 2 SHAFT	S			2-77
STORAGE ROOM 3076A	S			2-78
STORAGE ROOM 3075A	S			2-79
3RD FLOOR STAIR 7	S			2-80
3RD FLOOR STAIR 7	S			2-81
3RD FLOOR STAIR 7	S			2-82
3RD FLOOR STAIR 7	S			2-83
3RD FLOOR CORRIDOR BY STAIR 5A	M			2-84
3RD FLOOR STAIR 5A	S			2-85
STORAGE ROOM 3073A	S			2-86
AHU2 SUPPLY MECHANICAL ROOM 4001	DS			2-102
MECHANICAL ROOM 4001	S			2-103
MECHANICAL ROOM 4001	M			2-104
MECHANICAL ROOM 4001	S			2-109
AHU7 SUPPLY MECHANICAL ROOM 4001	DS			2-110
AHU7 RETURN MECHANICAL ROOM 4001	DS			2-111
MECHANICAL ROOM 4001	F			2-112A
MECHANICAL ROOM 4001	SO			2-112B
MECHANICAL ROOM 4001	M			2-113

Location Description	Device	Model	Address	Zone / Circuit #	Remarks
SF 2 SHUTDSOWN MECHANICAL ROOM 4001	R			2-115	

MECHANICAL ROOM 4001					
SF4 SHUTDOWN MECHANICAL ROOM 4001	R			2-116	
SF7 SHUTDOWN MECHANICAL ROOM 4001	R			2-117	
SF3 SHUTDOWN MECHANICAL ROOM 4001	R			2-118	
MECHANICAL ROOM 4002	M			2-131	COMMUNITY SIDE
AHU9 SUPPLY MECHANICAL ROOM 4002	DS			2-132	COMMUNITY SIDE
AHU9 RETURN MECHANICAL ROOM 4002	DS			2-133	COMMUNITY SIDE
MECHANICAL ROOM 4002	S			2-134	COMMUNITY SIDE
MECHANICAL ROOM 4002	F			2-135A	NOTE 1
MECHANICAL ROOM 4022	SO			2-135B	NOTE 1
AHU8 SUPPLY MECHANICAL ROOM 4002	DS			2-136	COMMUNITY SIDE
MECHANICAL ROOM 4002	M			2-137	COMMUNITY SIDE
MECHANICAL ROOM 4002	S			2-138	COMMUNITY SIDE
AHU8 RETURN MECHANICAL ROOM 4002	DS			2-139	COMMUNITY SIDE
AHU8 SUPPLY MECHANICAL ROOM 4002	DS			2-140	COMMUNITY SIDE
MECHANICAL ROOM 4002	M			2-141	COMMUNITY SIDE
MECHANICAL ROOM 4001	LIM			DLC2	
MECHANICAL ROOM 4002	LIM			DLC2	
CORRIDOR BY CUSTODIAL 1065	H/S			SC1-1	
CAFETORIUM NW	H/S			SC1-1	
CORRIDR BY DRAMA 1068	H/S			SC1-1	
MUSIC 1069 WEST	H/S			SC1-1	
MUSIC 1069 NORTH	H/S			SC1-1	
ON STAGE 1ST FLOOR CAFETORIUM	H/S			SC1-1	
PRACTICE ROOM 1069A	H/S			SC1-1	
PRACTICE ROOM 1069B	H/S			SC1-1	
PRACTICE ROOM 1069C	H/S			SC1-1	
PRACTICE ROOM 1069C	EOL			SC1-1	
1ST FLOOR CORRIDOR BY STAIR 4	H/S			SC1-2	
WASHROOM 1055	H/S			SC1-2	
WASHROOM 1054	H/S			SC1-2	

Location Description	Device	Model	Address	Zone / Circuit #	I
CORRIDOR BY WORK ROOM 1050	H/S			SC1-2	
CORRIDOR BY PRINCIPALS OFFICE 1043	H/S			SC1-2	
CORRIDOR BY MAIN ENTRANCE 1040	H/S			SC1-2	
CORRIDOR BY PRINCIPALS OFFICE 1043	EOL			SC1-2	
SCHOOL GYM	H/S			SC1-3	
CHANGE ROOM 2065	H/S			SC1-3	
CHANGE ROOM 2066	H/S			SC1-3	
CHANGE ROOM 2067	H/S			SC1-3	
CHANGE ROOM 2068	H/S			SC1-3	
OUTSIDE STORAGE ROOM 2073	H/S			SC1-3	
MAIN ELECTRICAL ROOM 2072	H/S			SC1-3	
OUTSIDE STORAGE ROOM 2073	EOL			SC1-3	
CORRIDOR BY CLASSROOM 2043	H/S			SC1-4	
STAFF ROOM 2044	H/S			SC1-4	
WASHROOM 2045	H/S			SC1-4	
WASHROOM 2046	H/S			SC1-4	
2ND FLOOR CORRIDOR BY STAIR 4	H/S			SC1-4	
CORRIDOR BY ELECTRICAL ROOM 2055	H/S			SC1-4	
YOUTH HEALTH 2053	H/S			SC1-4	
EXIT CORRIDOR BY YOUTH HEALTH 2053	H/S			SC1-4	
SCHOOL GYM	H/S			SC1-4	
RECEPTION 2076	EOL			SC1-4	
RECEPTION 2076	H/S			SC1-5	
COMMUNITY GYM	H/S			SC1-5	
COMMUNITY GYM	H/S			SC1-5	
COMMUNITY CENTRE EXERCISE ROOM	H/S			SC1-5	
COMMUNITY GYM FEMALE CHANGE ROOM	H/S			SC1-5	
COMMUNITY GYM MALE CHANGE ROOM	H/S			SC1-5	
COMMUNITY GYM FEMALE WASHROOM	H/S			SC1-5	
OUTSIDE WASHROOM 2090	H/S			SC1-5	

OUTSIDE WASHROOM 2091	H/S			SC1-5
ROOM 2089	H/S			SC1-5

Location Description	Device	Model	Address	Zone / Circuit #
ROOM 2089	EOL			SC1-5
BOILER ROOM 3065	H/S			SC1-6
MECHANICAL ROOM 3066	H/S			SC1-6
WASHROOM 3046	H/S			SC1-6
WASHROOM 3045	H/S			SC1-6
CORRIDOR BY CHEMISTRY LAB 3044	H/S			SC1-6
CHEMISTRY LAB 2044	H/S			SC1-6
GROW ROOM 3061	H/S			SC1-6
CORRIDOR BY LEARNING CENTRE 3059	H/S			SC1-6
WASHROOM 3059A	H/S			SC1-6
MECHANICAL ROOM 4001	EOL			SC1-6
MECHANICAL ROOM 4001	H/S			SC1-6
MECHANICAL ROOM 4001	EOL			SC1-6
MECHANICAL ROOM 4002	H/S			SC1-7
MECHANICAL ROOM 4002	EOL			SC1-7
OUTSIDE BY MAIN ELECTRICAL ROOM	H/S1			SC1-8
OUTSIDE BY SCHOOL GYM	H/S1			SC1-8
OUTSIDE BY COMMUNITY GYM	H/S1			SC1-8
	EOL			SC1-8
OUTSIDE BY COMMUNITY CENTRE ENTRANCE	H/S1			SC1-9
OUTSIDE BY COMMUNITY CENTRE WEST SIDE	H/S1			SC1-9
	EOL			SC1-9
PAD TRIGGER	PAD			SC1-10
SPRINKLER WATER GONG	B			SC1-11
INSIDE WATER GONG	EOL			SC1-11
1ST FLOOR CORRIDOR BY STAIR 1	H/S			SC2-1
WASHROOM 1005	H/S			SC2-1
1ST FLOOR CORRIDOR BY STAIR 2	H/S			SC2-1
LIBRARY 1001A	H/S			SC2-1
WASHROOM 1029	H/S			SC2-1

WASHROOM 1028	H/S			SC2-1
TECH PRODUCTION 1015	H/S			SC2-1
CORRIDOR BY VISUAL ARTS 1025	H/S			SC2-1
CREATIVE COMMON 1021	H/S			SC2-1

Location Description	Device	Model	Address	Zone / Circuit #
CREATIVE COMMON 1020	H/S			SC2-1
CORRIDOR BY CLASSROOM 1018	H/S			SC2-1
CORRIDOR BY CLASSROOM 1019	H/S			SC2-1
CORRIDOR BY CLASSROOM 1019	EOL			SC2-1
2ND FLOOR CORRIDOR BY STAIR 1	H/S			SC2-2
2ND FLOOR CORRIDOR BY CLASS 8/9	H/S			SC2-2
2ND FLOOR CORRIDOR BY CLASS 6/7	H/S			SC2-2
2ND FLOOR WASHROOM 2008A	H/S			SC2-2
2ND FLOOR CORRIDOR BY STAIR 2	H/S			SC2-2
2ND FLOOR STUDENT SERVICES 2004	H/S			SC2-2
2ND FLOOR CORRIDOR BY ROOM 2027	H/S			SC2-2
2ND FLOOR FEMALE WASHROOM 2030	H/S			SC2-2
2ND FLOOR MALE WASHROOM 2029	H/S			SC2-2
2ND FLOOR CORRIDOR BY ROOM 2033	H/S			SC2-2
2ND FLOOR CORRIDOR BY ROOM 2025	H/S			SC2-2
2ND FLOOR CORRIDOR BY ROOM 2025	EOL			SC2-2
OUTSIDE BY PRINCIPALS OFFICE	H/S			SC2-4
OUTSIDE LOWER COURTYARD	H/S			SC2-4
3RD FLOOR CORRIDOR BY STAIR 3	H/S			SC2-3
3RD FLOOR CORRIDOR BY STAIR 1	H/S			SC2-3
3RD FLOOR CORRIDOR BY CLASS 28/29	H/S			SC2-3
3RD FLOOR CORRIDOR BY CLASS 26/27	H/S			SC2-3
3RD FLOOR CORRIDOR BY STAIR 2	H/S			SC2-3

3RD FLOOR FEMALE WASHROOM 3030	H/S			SC2-3
3RD FLOOR MALE WASHROOM 3029	H/S			SC2-3
3RD FLOOR CORRIDOR BY CLASS 31	H/S			SC2-3
3RD FLOOR CORRIDOR BY CLASS 36	H/S			SC2-3
3RD FLOOR CORRIDOR BY CLASS 36	EOL			SC2-3

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	ADJ ROOM 307	2	REMOTE
	ADJ RM 306	2	CEILING UNIT
	ADJ STAIR 3 (3RD)	2	REMOTE
	ADJ WASHROOM 3047	2	REMOTE
	ADJ WASHROOM 3047	2	REMOTE
	ADJ ROOM 318	2	REMOTE
	W/R 3045	2	REMOTE
	W/R 3046	2	REMOTE
	CUSTODIAL 3048	2	UNIT
	ADJ ROOM 303	2	UNIT
	ADJ 320	2	REMOTE
	ADJ W/R 3049	2	CEILING UNIT
	COMM RM 3033	2	UNIT
	STAIR TO ROOF	2	REMOTE
	MECH ROOM STAIR	2	REMOTE
	MECH ROOM TOP STAIR	2	REMOTE
	MECH ROOM @ DOOR	2	UNIT
	MECH ROOM TOP STAIR	2	UNIT
	MECH ROOM	2	REMOTE
	MECH ROOM	2	REMOTE
	MECH ROOM	2	REMOTE

	MECH ROOM	2	REMOTE
	MECH ROOM AT TRANSFORMER	2	UNIT
	ADJ ROOM 339	2	REMOTE
	ADJ ROOM 341	2	CEILING UNIT
	ADJ ROOM 342	2	REMOTE
	ADJ W/R 3031	2	UNIT
	ADJ 325	2	REMOTE
	ACADEMIC COMMON 3023	2	REMOTE
	ACADEMIC COMMON 3023	2	REMOTE
	ACADEMIC COMMON 3023	2	REMOTE
	ADJ 3034 ELECT RM	2	UNIT
	ADJ ROOM 328	2	REMOTE
	CUSTODIAL ROOM 3032	2	UNIT
	WOMEN WASHROOM 3030	2	REMOTE
	MENS WASHROOM 3029	2	REMOTE

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	IN ROOM 3032		UNIT
	ADJ ROOM 3032	2	REMOTE
	IN ROOM 3064		UNIT
	STAIR #1 TOP	2	CEILING UNIT
	STAIR #1 TOP	2	REMOTE
	STAIR #1 TOP	2	REMOTE
	ACADEMIC COMMON 2023	2	REMOTE
	ACADEMIC COMMON 2023	2	REMOTE
	ACADEMIC COMMON 2023	2	REMOTE
	ADJ ROOM 229	2	REMOTE
	ADJ ROOM 228	2	CEILING UNIT

	ADJ ELECTRICAL ROOM	2	REMOTE
	ADJ ROOM 226	2	REMOTE
	ADJ ROOM 224	2	REMOTE
	ADJ WASHROOM 2032	2	REMOTE
	MENS WASHROOM 2029	2	REMOTE
	WOMENS WASHROOM 2030	2	REMOTE
	CUSTODIAL ROOM 2032	2	UNIT
	ADJ RM 242	2	CEILING UNIT
	STAIR #2 LVL 2	2	REMOTE
	STAIR #2 LVL 2	2	REMOTE
	STAIR #2 1ST LANDING	2	REMOTE
	STAIR #2 1ST LANDING	2	REMOTE
	ADJ W/R 2008	2	REMOTE
	ADJ ROOM 238	2	CEILING UNIT
	ADJ ROOM 242	2	REMOTE
	COMM RM 2033	2	UNIT
	ADJ ROOM 242	2	REMOTE
	ADJ ROOM 201	2	REMOTE
	ADJ ROOM 202	2	UNIT
	ADJ ROOM 204	2	CEILING UNIT
	ADJ ROOM 203	2	REMOTE
	CUSTODIAL ROOM 2048	2	UNIT
	WOMENS WASHROOM 2046ADJ W/M 2047	2	REMOTE

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	MENS W/R 2045	2	REMOTE
	ADJ STAIR 4	2	REMOTE
	STAFF COPY ROOM	2	CEILING UNIT

			UNIT
	STAFF W/R	2	REMOTE
	STAFF W/R	2	REMOTE
	STAFF ROOM	2	REMOTE
	STAFF ROOM HALL	2	REMOTE
	ADJ ROOM 206	2	REMOTE
	ADJ ROOM 207	2	CEILING UNIT
	ADJ YOUTH HEALTH	2	REMOTE
	STAIR 4 (2ND LANDING)	2	WALL UNIT
	STAIR 4 2ND LANDING	2	REMOTE
	STAIR 4 AT EXIT	2	REMOTE
	STAIR 4 AT EXIT	2	REMOTE
	STAIR 1 2ND UNIT	2	WALL UNIT
	W/R 2008A	2	WALL UNIT
	STAIR 1 1ST FLOOR	2	CEILING UNIT
	STAIR 1 1ST FLOOR	2	REMOTE
	STAIR 1 1ST FLOOR	2	REMOTE
	CUSTODIAL 1031	2	WALL UNIT
	ADJ W/R 1030	2	REMOTE
	ADJ W/R 1030	2	CEILING UNIT
	MENS W/R 1030	2	REMOTE
	WOMENS W/R 1029	2	REMOTE
	ADJ ROOM 135	2	REMOTE
	ADJ ROOM 128	2	REMOTE
	ADJ ROOM 127	2	CEILING UNIT
	ADJ ROOM 129	2	REMOTE
	ROOM 1063		UNIT
	STAIR 3 LVL 1	2	WALL UNIT
	STAIR 3 LVL 1 LANDING	2	REMOTE
	STAIR 3 LVL 2	2	REMOTE
	STAIR 3 LEVEL 1 LANDING	2	REMOTE
	STAIR 3 LVL 2	2	REMOTE

	STAIR 3 LVL 2 LANDING	2	REMOTE
	STAIR 3 LVL 2 LANDING	2	REMOTE
	STAIR 3 LVL 3	2	UNIT

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	C
	STAIR 3 LVL 3	2	REMOTE	
	ADJ ROOM 137	2	REMOTE	
	LIBRARY AT DESK	2	REMOTE	
	ADJ ROOM 138	2	CEILING UNIT	
	STAIR 1 LVL 1	2	WALL UNIT	
	ADJ STAIR 1	2	REMOTE	
	STAIR 1 LVL 1.5	2	REMOTE	
	STAIR 1 LVL 1.5	2	REMOTE	
	STAIR 1 LVL 2	2	REMOTE	
	STAIR 1 LVL 2	2	REMOTE	
	ROOM 140	2	REMOTE	
	LIBRARY	2	REMOTE	
	MAIN ENT VEST	2	REMOTE	
	MAIN ENTRANCE	2	CEILING UNIT	
	MAIN ENTRANCE	2	REMOTE	
	ADJ ROOM 100	2	REMOTE	
	ADJ ROOM 106	2	REMOTE	
	ADJ ROOM 115	2	CEILING UNIT	
	STAGE BEHIND CURTAIN	2	WALL UNIT	
	ADJ ROOM 111	2	CEILING UNIT	
	CAFETORIUM (X8)	2	REMOTES	
	ADJ STORAGE B	2	REMOTE	
	STORAGE B	2	WALL UNIT	
	ADJ CUSTODIAL STORAGE	2	REMOTE	
	KITCHEN	2	CEILING UNIT	

	KITCHEN	2	REMOTE
	KITCHEN STORAGE	2	REMOTE
	CUSTODIAL ROOM 1057	2	WALL UNIT
	MENS WASHROOM 1054	2	REMOTE
	ADJ ROOM 1062	2	REMOTE
	STAIR 4 LVL 1	2	REMOTE
	STAIR 4 LVL 1	2	WALL UNIT
	ADMIN OFFICE	2	REMOTE
	ADMIN OFFICE	2	WALL UNIT
	HIGH SCHOOL GYM	2	UNIT + 1 REMOTE
	HIGH SCHOOL GYM	2	UNIT + 1 REMOTE

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Notes
	HIGH SCHOOL GYM	2	UNIT + 1 REMOTE	
	HIGH SCHOOL GYM	2	UNIT + 1 REMOTE	
	MECH RM 3065 AT DOOR	2	REMOTE	
	MECH ROOM 3065 AT FURNACE	2	REMOTE	
	MECH ROOM 3065 AT HOT WATER	2	WALL UNIT	
	MECH ROOM 3065 AT EXHUAUST FAN	2	REMOTE	
	MECH ROOM 3065 AT ROOF DOOR	2	REMOTE	
	MECH ROOM 3065 AT DOOR 3066	2	REMOTE	
	MECH ROOM 3066 AT DOOR	2	REMOTE	
	MECH ROOM 3066 AT STAIR	2	REMOTE	
	MECH ROOM 3066 AT STAIR	2	REMOTE	
	MECH ROOM 3066 BOTTOM STAIR	2	REMOTE	
	MECH ROOM 3066	2	REMOTE	
	MECH ROOM 3066	2	REMOTE	
	MECH ROOM 3066	2	REMOTE	

	MECH ROOM 3066	2	WALL UNIT	
	BEHIND RECEPTION	2	CEILING UNIT	COMMUNITY SIDE
	LOBBY	2	REMOTE	COMMUNITY SIDE
	LOBBY	2	REMOTE	COMMUNITY SIDE
	BOTTOM STAIRS	2	REMOTE	COMMUNITY SIDE
	ADJ ELEV 1ST FLOOR	2	CEILING UNIT	COMMUNITY SIDE
	ADJ LOCKER HALL	2	REMOTE	COMMUNITY SIDE
	ADJ W/R	2	CEILING UNIT	COMMUNITY SIDE
	MENS W/R	2	REMOTE	COMMUNITY SIDE
	WOMENS W/R	2	REMOTE	COMMUNITY SIDE
	CUSTODIAL 2084	2	WALL UNIT	COMMUNITY SIDE
	LOCKERS WOMENS (X2)	2	REMOTE	COMMUNITY SIDE
	MALE LOCKER (X2)	2	REMOTE	COMMUNITY SIDE
	SENIORS ROOM 3076	2	REMOTE	COMMUNITY SIDE
	IN GYM ROOM 2071		UNIT	COMMUNITY SIDE
	GYM AT STORAGE	2	WALL UNIT	COMMUNITY SIDE
	GYM AT DOOR	2	WALL UNIT	COMMUNITY SIDE
	GYM SCHOOL SIDE	2	REMOTE	COMMUNITY SIDE
	GYM AT SCORE BOARD	2	REMOTE	COMMUNITY SIDE
	GYM AT SCORE BOARD	2	REMOTE	COMMUNITY SIDE

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Notes
	GYM SCHOOL SIDE	2	REMOTE	COMMUNITY SIDE
	DAYCARE 2089		UNIT + 3 REMOTES	REMOTE HEAD IN EACH OUTSIDE WASHROOM
	2ND FLOOR RM 3070		UNIT + REMOTES	REMOTES IN 3076, 6079, 3078, BY 3077, BY 3070, BY 3073 (X2)
	MECH RM 2ND FL		UNIT + 3 REMOTES	COMMUNITY SIDE
	MECH RM 2ND FL		UNIT + 2 REMOTES	COMMUNITY SIDE

		REMOTES	
	STAIR 8A	UNIT + 1 REMOTE	REMOTE IN MECH RM STAIR
	GROUND FL RM 2092		

	LOCATION: Harry R. Hamilton	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
1	ZONE 1 - FIRST FLOOR		
2	MAIN ENTRANCE	M	ZONE 1
3	REAR ENTRANCE	M	ZONE 1
4	GYM	M	ZONE 1
5	GYM	M	ZONE 1
6	REAR ENTRANCE	EOL	ZONE 1
7	BY CLASSROOM 108		
8	ZONE 2 - SECOND FLOOR SOUTHWEST		
9	STAIRWELL BY LIBRARY	S	ZONE 2
10	OUTSIDE LIBRARY	M	ZONE 2
11	STAIRWELL BY ROOM 203	S	ZONE 2
12	BY RM 203	M	ZONE 2
13	BY RM 203	EOL	ZONE 2
14			
15	ZONE 3 - SECOND FLOOR NORTHEAST		
16	STAIRWELL BY ROOM 207	S	ZONE 3
17	BY ROOM 207	M	ZONE 3
18	STAIRWELL BY ROOM 210	S	ZONE 3
19	BY ROOM 210	M	ZONE 3
20	STAIRWELL BY ROOM 207	EOL	ZONE 3

21			
22	ZONE 4 - SUPERVISORY TANK #1		
23	TANK #1 CONTROL VALVE	TS	ZONE 4
24	SPRINKLER ROOM	EOL	ZONE 4
25			
26	ZONE 5 - SUPERVISORY TANK #2		
27	TANK #2 CONTROL VALVE	TS	ZONE 5
28	SPRINKLER ROOM	EOL	ZONE 5
29			
30	ZONE 6 - DUCT DETECTORS PENTHOUSE		
31	PENTHOUSE	DS	ZONE 6
32	PENTHOUSE	DS	ZONE 6
33	PENTHOUSE	EOL	ZONE 6
34			
35	ZONE 7 - SPRINKLER MAIN		
36	MAIN SPRINKLER PRESSURE ALARM	FSP	ZONE 7
37	SPRINKLER ROOM	EOL	ZONE 7
38			
39	ZONE 9 - SUPERVISORY MAIN		
40	MAIN SPRINKLER CONTROL VALVE	TS	ZONE 9
41	SPRINKLER ROOM	EOL	ZONE 9
42			
43	ZONE 10 - LOW WATER 1		
44	LOW WATER TANK #1	FPS	ZONE 10
45	SPRINKLER ROOM	EOL	ZONE 10
46			
47	ZONE 11 - LOW WATER 2		
48	LOW WATER TANK #2	FPS	ZONE 11
49	SPRINKLER ROOM	EOL	ZONE 11

50			
51	ZONE 12 - SPRINKLER LOW AIR		
52	LOW AIR PRESSURE SWITCH	FPS	ZONE 12
53	SPRINKLER ROOM	EOL	ZONE 12
54			
55	ZONE 13 - SUPERVISORY ROOM 138		
56	JANITORS ROOM 1ST FLOOR	TS	ZONE 13
57	JANITORS ROOM 1ST FLOOR	EOL	ZONE 13
58			
59	ZONE 14 - SUPERVISORY ROOM 215		
60	JANITORS ROOM 2ND FLOOR	TS	ZONE 14
61	JANITORS ROOM 2ND FLOOR	EOL	ZONE 14
62			
63	Signals		
64	BY ROOM 208	B	SIG 1
65	ACROSS FROM LIBRARY	B	SIG 1
66	BY ROOM 212	B	SIG 1
67	BY ROOM 204	B	SIG 1
68	BOYS WASHROOM 2ND FLOOR	B	SIG 1
69	GIRLS WASHROOM 2ND FLOOR	B	SIG 1
70	BY ROOM 204	EOL	SIG 1
71			
72	GYM	B	SIG 2
73	GYM	B	SIG 2
74	MAIN OFFICE	B	SIG 2
75	BY ROOM 109	B	SIG 2
76	BY ROOM 106	B	SIG 2
77	BY ELECTRICAL ROOM	B	SIG 2
78	BY ROOM 103	B	SIG 2
79	BY ROOM 103	EOL	SIG 2
Note	Flow switch & gate valve for Tank #1 are not wired to fire panel.		
Note	Fire alarm breaker in 1st fl. Janitor room next to elevator machine room.		

EMERGENCY LIGHTING

Line		Remot e	Cab.	Remar
------	--	------------	------	-------

#	EL UNIT Location	Head	Head	ks
1	2nd Floor Storage Room		Y	battery
2	**Outside Library	Y		
3	**Stairs By Room 203	Y		
4	**By Room 205	Y		
5	**Stairs By Room 207	Y		
6	**By Room 102	Y		
7	**By Electrical Room	Y		
8	**Gym	Y		
9	**Gym	Y		
10	2nd Floor Storage Room			breaker
11	**Stairs By Room 210	Y		
12	**By Room 208	Y		
13	**2nd Floor Girls Washroom	Y		
14	**By Room 212	Y		
15	**2nd Floor Boys Washroom	Y		
16	**Stairs By Library	Y		
17	**By Room 110	Y		
18	**By Room 106	Y		
19	**1st Floor Girls Washroom	Y		
20	**1st Floor Boys Washroom	Y		
21	**Gym	Y		
22	**Gym	Y		

PORTABLE CLASSROOM	2	COMBO
PORTABLE CLASSROOM	2	COMBO
PORTABLE CLASSROOM	2	COMBO
PORTABLE CLASSROOM	2	COMBO
PORTABLE CLASSROOM	2	EXIT SIGNS ONLY
PORTABLE CLASSROOM	2	EXIT SIGNS ONLY
FIRST FLOOR BY FA PANEL	2	AIMLITE
GYM ENTRY		COMBO
GYM STAGE		

Note: Emergency lighting: 2nd fl. breakers in custodian office Panel B breaker #15, storage rm Panel E breaker #12

	LOCATION: Millwood Elementary	Device	Device address or circuit number
FIRE ALARM PANEL: Mirtone 8020			
MANUAL PULL STATIONS			
1	MAIN ENTRANCE	M	ZONE 2
2	WEST STAIRS 1ST FLOOR	M	ZONE 2
3	BACK STAIRS EXIT by MUSIC ROOM	M	ZONE 2
4	OUTSIDE GYM STORAGE	M	ZONE 2
5	GYM BY CANTEEN	M	ZONE 2
6	GYM BY MAIN ENTRANCE	M	ZONE 2
7	GYM	M	ZONE 2
8	KITCHEN	M	ZONE 2
9	BACK STAIRS 2ND FLOOR	M	ZONE 3
10	WEST STAIRS 2ND FLOOR	M	ZONE 3
SMOKE DETECTORS			
1	BOTTOM WEST STAIRS	SI	ZONE 4
2	TOP WEST STAIRS	SI	ZONE 4
3	BOTTOM BACK STAIRS	SI	ZONE 5
4	TOP BACK STAIRS	SI	ZONE 5
5	ELEVATOR SHAFT	SI	ZONE 6
DUCT SMOKE DETECTORS			
1	GYM STORAGE	DS	ZONE 8
HEAT DETECTORS			
1	ELECTRICAL ROOM	RHT	ZONE 2
2	SPRINKLER ROOM	RHT	ZONE 2
SPRINKLERS			
1	SPRINKLER FLOW ALARM	FSP	ZONE 7
2	KITCHEN HOOD SPRINKLER	FSV	ZONE 9
3	SPRINKLER MAIN CONTROL VALVE	SV	ZONE 10
4	ELEVATOR PIT	SV	ZONE 12
5	BY ELEVATOR 2ND FLOOR	SV	ZONE 13
6	FAN ROOM #1	SV	ZONE 13
7	2ND FLOOR FAN ROOM #2 CONTROL VALV	SV	ZONE 3
8	KITCHEN HOOD SPRINKLER	SV	ZONE 14
NOTIFYING DEVICES			
1	BACK STAIRS 2ND FLOOR	B	SIG 1
2	MIDDLE 2ND FLOOR	B	SIG 1

3	WEST STAIRS 2ND FLOOR	B	SIG 1
4	FAN ROOM #2	B	SIG 1
5	WEST STAIRS 1ST FLOOR	B	SIG 1
6	GYM	B	SIG 2
7	GYM	B	SIG 2
8	BOYS SHOWER	B	SIG 2
9	GIRLS SHOWER	B	SIG 2
10	MAIN ENTRANCE	B	SIG 2
11	BACK STAIRS 1ST FLOOR	B	SIG 2
12	MIDDLE 1ST FLOOR	B	SIG 2

END OF LINE RESISTORS

1	RAMP TO STAGE	EOL	ZONE 14
2	FAN ROOM #1	EOL	ZONE 13
3	1ST FLOOR BY ELEVATOR	EOL	ZONE 12
4	SPRINKLER ROOM	EOL	ZONE 10
5	RAMP TO STAGE	EOL	ZONE 9
6	SPRINKLER ROOM	EOL	ZONE 7
7	GYM STORAGE ON DUCT DETECTOR	EOL	ZONE 8
8	ELEVATOR SHAFT	EOL	ZONE 6
9	TOP WEST STAIRS	EOL	ZONE 4
10	WEST STAIRS 2ND FLOOR	EOL	ZONE 3
11	TOP BACK STAIRS	EOL	ZONE 5
12	WEST STAIRS 1ST FLOOR	EOL	ZONE 2
13	BY SIDE ENTRANCE TO PLAYGROUND	EOL	ZONE 11

RELAYS

	AHU SHUT DOWN	RHT	
	Fire Door Number or Location		
	1 Bottom of West Stairs		
	2 Top of West Stairs		
	3 Bottom of Back Stairs		
	4 Top of Back Stairs		
	5 Middle Main Floor Hall		

EMERGENCY LIGHTING

Line#	EL UNIT Location	Remote	Cab.Head
1	OUTSIDE LIBRARY		Y
22	**Kitchen	REMOTES	
2	By Room 123		Y
3	**1st Floor Boys Washroom	REMOTES	
4	**1st Floor Girls Washroom	REMOTES	
5	By Room 132		Y

6	**Bottom West Stairwell	REMOTES	
7	By Room 209		Y
8	**Middle 2nd Floor	REMOTES	
9	**Middle West Stairwell	REMOTES	
10	**Top West Stairwell	REMOTES	
11	2nd Floor By Girls Washroom		Y
12	**2nd Floor Girls Washroom	REMOTES	
13	**2nd Floor Boys Washroom	REMOTES	
14	**BOTT BACKStairwell	REMOTES	
15	**Middle Back Stairwell	REMOTES	
16	**Top Back Stairwell	REMOTES	
20	FAN ROOM	REMOTES	
17	Gym #1 BY MAIN ENTRY		Y
18	**Main Entrance	REMOTES	
19	**Girls Shower Room	REMOTES	
	GYM #2 BY BOYS LOCKER RM		Y
	**Boys Shower	REMOTES	
	GYM BY MAIN ENTRY		Y
	GYM BY KITCHEN		Y
	GYM BY REAR EXIT		Y
	GYM STAGE		Y
	GYM STAGE EXIT		Y

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1	Breaker Panels for Emergency Lighting . Main Floor, Electrical Room , Panel "B" Cct # 39. Second Floor, Fan Room # 2
	Panel " C " Cct # 39

	LOCATION: Millwood High	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		

MANUAL PULL STATIONS			
SMOKE DETECTORS			
1	2ND FLOOR HALL BY ELEVATOR	M	ZONE 8
2	2ND FLOOR EXIT BY DOOR 209	M	ZONE 8
3	2ND FLOOR EXIT BY DOOR 201	M	ZONE 8
4	2ND FLOOR EXIT BY DOOR 227	M	ZONE 8
5	HALL BY ROOM 135	M	ZONE 9
6	HALL BY ROOM 140	M	ZONE 9
7	BY ART ROOM 125	M	ZONE 9
8	FILM & VIDEO ROOM 126	M	ZONE 9
9	BOILER ROOM EXIT	M	ZONE 9
10	MAIN ENTRANCE	M	ZONE 9
11	EXIT BY CAFETERIA STAIRS	M	ZONE 9
12	GYM STAGE EXIT BY ROOM 146	M	ZONE 9
13	GYM BY MAIN ENTRANCE	M	ZONE 10
14	GYM EXIT BY MENS LOCKER ROOM 153	M	ZONE 10
15	GYM EXIT BY ROOM 149	M	ZONE 10
16	GYM EXIT BY ROOM 148	M	ZONE 10
	IND. ARTS	M	ZONE 9
1	STAIRWELL #2 BY RM 232	S	ZONE 1
2	STAIRWELL #1 MAIN ENTRY	S	ZONE 2
3	STAIRWELL #3 BY RM 208	S	ZONE 3
4	ELEVATOR SHAFT	S	ZONE 7
5	2ND FLOOR HALL BY ELEVATOR	S	ZONE 8
6	2ND FLOOR EXIT BY DOORS 201	S	ZONE 8
7	HALL BY ROOM 136	S	ZONE 9
8	HALL BY ROOM 138	S	ZONE 9
9	BY ADMINISTRATION OFFICE 100	S	ZONE 9
10	HALL BY ROOM 123	S	ZONE 9
DUCT SMOKE DETECTORS			
SPRINKLER DEVICES			
NOTIFYING DEVICES			
1	A/U SYSTEM GYMNASIUM	DS	ZONE 4

2	A/U #1 NORTH	DS	ZONE 5
3	A/U #2 SOUTH	DS	ZONE 6
1	2ND FLOOR HALLWAY BY RM 214	FSP	ZONE 8
2	2ND FLOOR HALLWAY BY RM 214	SV	ZONE 8
3	HALL OUTSIDE BOILER ROOM	FSP	ZONE 9
4	HALL OUTSIDE BOILER ROOM	SV	ZONE 9
5	KITCHEN	SV	ZONE 9
6	ALARM LINE PRESSURE SWITCH	FSP	ZONE 11
7	MAIN CONTROL VALVE	SV	ZONE 11
8	KITCHEN HOOD FLOW	FSP	ZONE 12
9	KITCHEN HOOD TAMPER	SV	ZONE 12
10	ELEVATOR PIT VALVE	SV	ZONE 13
11	ANTI-FREEZE LOOP VALVE	SV	ZONE

NOTIFYING DEVICES

1	2ND FLOOR HALL BY ROOM 202	B	SIG 1
2	2ND FLOOR HALL BY ROOM 213	B	SIG 1
3	CAFETERIA	B	SIG 1
4	1ST FLOOR HALL BY ROOM 122	B	SIG 1
5	1ST FLOOR HALL BY ROOM	B	SIG 1
6	1ST FLOOR HALL BY CAFETERIA	B	SIG 1
7	ART ROOM 125	B	SIG 1
8	OUTSIDE MAIN ENTRANCE	B	SIG 1
9	GYM	B	SIG 2
10	2ND FLOOR HALL BY ROOM 235	B	SIG 2
11	2ND FLOOR HALL BY ROOM 223	B	SIG 2
12	MUSIC ROOM 144	B	SIG 2
13	1ST FLOOR HALL BY ROOM 143	B	SIG 2
14	1ST FLOOR HALL BY ROOM 132	B	SIG 2
15	BOILER ROOM	B	SIG 2

END OF LINE RESISTORS

1	STAIRWELL 227	EOL	ZONE 1
2	MAIN LOBBY STAIRS	EOL	ZONE 2
3	STAIRWELL 209	EOL	ZONE 3
4	GYM FAN ROOM	EOL	ZONE 4
5	PENTHOUSE MIDDLE OF STAIRS	EOL	ZONE 5
6	PENTHOUSE UNDER STAIRWELL	EOL	ZONE 6
7	BY ELEVATOR SHAFT	EOL	ZONE 7
8	2ND FLOOR HALL BY ELEVATOR	EOL	ZONE 8
9	GYM STAGE EXIT BY ROOM 146	EOL	ZONE 9
10	GYM EXIT BY ROOM 149	EOL	ZONE 10
11	SPRINKLER CAGE	EOL	ZONE 11
12	KITCHEN	EOL	ZONE 12
13	1ST FLOOR JANITORS ROOM	EOL	ZONE 13

14	2ND FLOOR HALL BY ROOM 213	EOL	SIG 1
15	GYM	EOL	SIG 2

Fire Door Number or Location

ENTRY TO HALL FOR RMS 131-135

ENTRY TO HALL FOR RMS 144-150

ENTRY TO GYM AREA

ENTRY TO GHALL FOR RMS 125-126

OFFICE HALL

ENTRY TO CAFETERIA

STAIRS BY RM 115

STAIRS BY RM 209

STAIRS BR RM 227

STAIRS BY RM 141

EMERGENCY LIGHTING

Line #	EL UNIT Location	MOD #	Manuf.
1	Main Entrance	S72/RRT	Lumacell
2	**Main Lobby - By Phones	REMOTE	REMOTE
3	**Main Lobby - Under Skylight	REMOTE	REMOTE
4	**By Room 114	REMOTE	REMOTE
5	Hall By Room 135	RG12 L072	Lumacell
6	Opposite Main Entrance	6JML36	Emergi-Lite
7	**By Room 123	REMOTE	REMOTE
8	Hall By Room 142	RG12 L072	Emergi-Lite
9	**Stairwell By Room 140	REMOTE	REMOTE
10	Hall To Gym By Room 143	RG12 L072	Lumacell
11	**Library	REMOTE	REMOTE
12	**Main Lobby - Left Hall	REMOTE	REMOTE
13	Hall By Boiler Room	RG36	Lumacell
14	**Cafeteria Wall By Boiler Room	REMOTE	REMOTE
15	**Boiler Room - Behind Door	REMOTE	REMOTE
16	**Boiler Room - Basement	REMOTE	REMOTE
17	Stairwell Outside Cafeteria	S72/RRT	Lumacell
18	Hall Outside Cafeteria	RG12 L072	Lumacell

19	Administration Office	2-T6	CPRO
20	Gym	3/2M	Emergi-Lite
21	Gym	3/2M	Emergi-Lite
22	Gym Exit Left	3/2M	Emergi-Lite
23	Gym Exit Right	3/2M	Emergi-Lite
24	**Side Hall By Room 223	REMOTE	REMOTE
25	**Hall By Room 202	REMOTE	REMOTE
26	Battery Pak By Room 233	RG12 S72	Lumacell
27	**Stairwell By Room 229	REMOTE	REMOTE
28	**Hall By Room 228 Front	REMOTE	REMOTE
29	**Hall By Room 228 Back	REMOTE	REMOTE
30	Battery Pak By Room 208	RG12 S72	Lumacell
31	**Cafeteria Stairwell	REMOTE	REMOTE
32	**Hall By Room 217	REMOTE	REMOTE
33	**Hall By Room 212	REMOTE	REMOTE

GIRLS CHANGE
ROOM

REMOTE

BOYS CHANGE
ROOM

REMOTE

CAFETERIA OUTSIDE
WALL

REMOTE

HALL ADJ 222

UNIT

BOILER ROOM

UNIT

BOILER ROOM

REMOTE

BOILER ROOM

UNIT

BOILER ROOM

REMOTE

JANITOR ROOM 241

UNIT

GYM STAGE

UNIT

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS	
	PANEL "D", MAIN ELECTRICAL RM, CCTS 4 & 10 CONTROL ALL EMERGENCY LIGHTS

		Device	Device address or circuit number	NOTES
	LOCATION: Sackville Heights			
	FIRE ALARM PANEL: Cerberus Pyrotronics MXL			
	Devices			
	EXIT, CORRIDOR 1 TO STAIR 1	MA	1-001	
	EXIT, GYM TO CORRIDOR 1	MA	1-002	
	EXIT, GYM TO CORRIDOR 2	MA	1-003	
	JANITORS CLOSET #1 (107)	RHTA	1-005	
	TELEPHONE / COMM ROOM 2 (109)	SA	1-006	
	LIBRARY, STORAGE ROOM (110)	SA	1-007	
	SUMP ROOM 164B BY ELEVATOR	SA	1-008	
	GLYCOL SPRINKLER SHUTOFF CANON	TS	1-011	
	SPRINKLER SHUTOFF ELEVATOR SHA	GV	1-012	
	EXIT, CORRIDOR 5 TO MAIN LOBBY	MA	1-013	
	TELEPHONE / COMM ROOM 1 (122)	SA	1-014	
	STORAGE (123B) [inside 123a]	SA	1-015	
	LOBBY EXIT	MA	1-016	
	ELECTRICAL ROOM (127)	SA	1-017	
	EXIT, BOILER ROOM	MA	1-019	
	OIL STORAGE ROOM (128)	RHTA	1-020	
	EXIT, BOILER ROOM	MA	1-021	
	KITCHEN (160)	RHTA	1-022	
	KITCHEN HOOD SYSTEM	RELA Y	1-023	
	KITCHEN, STORAGE ROOM (159)	SA	1-025	
	LEARNING CENTRE (162)	SA	1-026	
	CUST. STORAGE ROOM (156)	SA	1-027	
	GLYCOL SPRINKLER SHUTOFF (BOILER)	TS	1-028	
	STUDENT SUPPORT STORAGE ROOM	SA	1-032	
	EXIT, CORRIDOR 7 TO STAIR 4	MA	1-033	
	JANITORS CLOSET #2 (135)	SA	1-034	
	STAFF WASHROOM (139)	SA	1-035	
	MAIN FLOOR SPRINKLER FLOW (137)	FSV	1-036	
	SPRINKLER SHUTOFF, MAIN WATER (137)	TS	1-038	
	1ST FLOOR SPRINKLER SHUTOFF (137)	GV	1-039	
	MAIN SPRINKLER FLOW SWITCH (137)	FSV	1-040	
	SPRINKLER SHUTOFF, BACKFLOW 1 (137)	TS	1-041	
	OUTSIDE STORAGE ROOM (147)	SA	1-042	

	EXIT, CORRIDOR 7 TO STAIR 5	MA	1-043	
	EXIT, CORRIDOR 7 TO OUTSIDE	MA	1-044	
	TOP OF STAIRWELL 1	SA	2-001	
	EXIT, CORRIDOR 9 TO STAIR 1	MA	2-002	
	EXIT, FAN ROOM 1 TO CORRIDOR 9	MA	2-003	
	STORAGE ROOM 1 (249) [beside 248]	SA	2-004	
	FAN ROOM 1 (248)	RHTA	2-005	
	AHU 1, FAN ROOM 248	DSA	2-006	
	AHU 2, FAN ROOM 248	DSA	2-007	
	JANITORS CLOSET 3 (205A)	RHTA	2-008	
	EXIT, CORRIDOR 10 TO STAIR 3	MA	2-009	
	TOP OF STAIRWELL 3	SA	2-010	
	ELEVATOR MACHINE ROOM (211A)	SA	2-011	
	ELEVATOR SHAFT	SA	2-012	
	EXIT, CORRIDOR 10 TO CORRIDOR 11	MA	2-013	
	EXIT, CORRIDOR 11 TO CORRIDOR 12	MA	2-014	
	TOP OF STAIRWELL 2	SA	2-015	
	GUIDANCE OFFICE STORAGE (218)	SA	2-018	
	FAMILY STUDIES, RIGHT SIDE (222)	RHTA	2-019	
	FAMILY STUDIES, LEFT SIDE (222)	RHTA	2-020	
	STORAGE ROOM (246)	SA	2-021	
	STUDENT SUPPORT (245)	SA	2-022	
	FAN ROOM 2 (243)	RHTA	2-024	
	EXIT, 2ND FLOOR MECHANICAL ROOM	MA	2-025	
	2ND FLOOR MECHANICAL ROOM (243)	RHTA	2-026	
	EXIT, CORRIDOR 12 TO STAIR 4	MA	2-027	
	TOP OF STAIRWELL 4	SA	2-028	
	TELEPHONE / COMMUNICATIONS ROOM	SA	2-029	
	JANITORS CLOSET 4 (228)	HTA	2-030	
	SERVICE ROOM 3 (225) inside 2-029	RHTA	2-031	
	2ND FLOOR SPRINKLER FLOW (225)	FSV	2-032	
	2ND FLOOR SPRINKLER SHUTOFF (225)	GV	2-033	
	EXIT, CORRIDOR 12 TO STAIR 5	MA	2-034	
	TOP OF STAIRWELL 5	SA	2-035	
	ART ROOM, STORAGE CLOSET	RHTA	2-036	
	EXIT, GYM TO STAIRWELL 2	MA	2-038	
Signals				
	1ST FLOOR BY GYM	H/V	SIG 1	
	1ST FLOOR BY LIBRARY	H/V	SIG 1	
	1ST FLOOR BY CAFETERIA	H/V	SIG 1	
	1ST FLOOR BY ROOM 161	H/V	SIG 1	
	1ST FLOOR BY ROOM 134	H/V	SIG 1	
	1ST FLOOR BY ROOM 143	H/V	SIG 1	

	BOILER ROOM	H/V	SIG 1	
	GYM	H/V	SIG 1	
	GYM	H/V	SIG 1	
	BOYS CHANGE ROOM	H/V	SIG 1	
	GIRLS CHANGE ROOM	H/V	SIG 1	
	1ST FLOOR BOYS WASHROOM	V	SIG 1	
	1ST FLOOR BOYS WASHROOM	V	SIG 1	
	1ST FLOOR GIRLS WASHROOM	V	SIG 1	
	1ST FLOOR GIRLS WASHROOM	V	SIG 1	
	2ND FLOOR BY ROOM 232	H/V	SIG 1	
	2ND FLOOR BY TEL/COM ROOM	H/V	SIG 1	
	2ND FLOOR BY FAMILY STUDIES	H/V	SIG 1	
	2ND FLOOR BY ROOM 214C	H/V	SIG 1	
	2ND FLOOR BY ROOM 208	H/V	SIG 1	
	2ND FLOOR BY ROOM 202	H/V	SIG 1	
	MECHANICAL ROOM 243	H/V	SIG 1	
	FAN ROOM	H/V	SIG 1	
	2ND FLOOR BOYS WASHROOM	V	SIG 1	
	2ND FLOOR BOYS WASHROOM	V	SIG 1	
	2ND FLOOR GIRLS WASHROOM	V	SIG 1	
	2ND FLOOR GIRLS WASHROOM	V	SIG 1	

EMERGENCY LIGHTING				
Line #	EL UNIT Location	Cab. Head	MOD #	Manuf.
1	Stair 1	Y	RG12S144	LUMACELL
2	**Mid Stair 1		REMOTE	
3	**2nd Floor Stair 1		REMOTE	
4	1st Floor By Room 102	Y		LUMACELL
5	**By Room 103		REMOTE	
6	1st Floor By Girls Washroom	Y	RG12S144T B	LUMACELL
7	**By Library		REMOTE	
8	Tele / Comm Room 2 (109)	Y	RG12S144	LUMACELL
9	**By Tele / Comm Room		REMOTE	
10	**Boys Washroom		REMOTE	
11	**Girls Washroom		REMOTE	
12	Gym(BY LOBBY DOORS)	Y	RG12S144	LUMACELL
13	Gym by equipment room	Y	RG12S144	LUMACELL
14	Gym	Y	RG12S144	LUMACELL
15	Gym(BY CURTAIN)	Y	RG12S144	LUMACELL
16	Main Lobby	Y	RG12S144T B	LUMACELL
17	Boiler Room	Y	RG12S72	LUMACELL

18	1st floor electrical room	Y	RG12S144	LUMACELL
19	**Boiler Room Hall		REMOTE	
20	By Cafeteria	Y	RG12S144T B	LUMACELL
21	By Room 130	Y	RG12S144T B	LUMACELL
22	**By Door 117C		REMOTE	
23	**By Room 157		REMOTE	
24	Kitchen	Y	RG12S144	LUMACELL
25	**Kitchen		REMOTE	
26	Music Room 161	Y	RG12S72	LUMACELL
27	By Room 145	Y	RG12S144T B	LUMACELL
28	**By Room 142		REMOTE	
29	Janitors Room 135	Y	RG12 S144	LUMACELL
30	**Boys Washroom		REMOTE	
31	**Girls Washroom		REMOTE	
32	**Staff Washroom		REMOTE	
33	**By Room 151		REMOTE	
34	**By Storage Room 133		REMOTE	
35	Gym Storage	Y	RG12 S144	LUMACELL
36	**Boys Change Room		REMOTE	
37	**Girls Change Room		REMOTE	
38	Gym Stage	Y	RG12 S144	LUMACELL
	**Gym Stage		REMOTE	
	Stair 2	Y	RG12 S144	LUMACELL
	**Stair 2		REMOTE	
	Cafeteria by kitchen door	Y	RG 12S72	LUMACELL
	Cafeteria	Y	RG 12S72	LUMACELL
	Cafeteria	Y	RG 12S72	LUMACELL
	Cafeteria by music room	Y	EBST12072	Aim-Lite
	Mechanical Room 243	Y	RG12 S144	LUMACELL
	**Mechanical Room 243		REMOTE	
	By Room 219	Y	RG12 S144TB	LUMACELL
	**By Room 222		REMOTE	
	**By Room 214C		REMOTE	
	2nd Floor By Stair 3	Y	RG12 S144TB	LUMACELL
	**By Elevator Machine Room		REMOTE	
	Stair 3	Y	RG12 S144	LUMACELL
	**Stair 3		REMOTE	
	Fan Room 248	Y	RG12 S144	LUMACELL
	**Fan Room 248		REMOTE	
	By Room 203	Y	RG12 S144TB	LUMACELL
	**By Room 207A		REMOTE	
	**By Fan Room		REMOTE	
	**2nd Floor Boys Washroom		REMOTE	

	**2nd Floor Girls Washroom		REMOTE	
	Stair 5	Y	RG12 S144	LUMACELL
	**Stair 5 1st Floor		REMOTE	
	**Stair 5 2nd Floor		REMOTE	
	2nd Floor By Stair 5	Y	RG12 S144TB	LUMACELL
	**By Room 237		REMOTE	
	2nd Floor Tele / Comm 3 Room	Y	RG12 S144	LUMACELL
	**By Room 240		REMOTE	
	**By Stair 4		REMOTE	
	**2nd Floor Boys Washroom		REMOTE	
	**2nd Floor Girls Washroom		REMOTE	
	Stair 4	Y	RG12 S144	LUMACELL
	**Stair 4		REMOTE	

TECH NOTES:

1. BREAKERS LOCATED: 2ND FL RM 245 PANEL B #6 (DOES ALL OF 2ND FL)
1ST FL MAIN ELECT RM - PANEL A - #10, #16, #20.

	LOCATION: A.J.Smeltzer	Device
FIRE ALARM PANEL: Edwards QSC		
PULL STATIONS		
1	1ST FLOOR HALL BY CAFETERIA	M
2	1ST FLOOR MAIN ENTRANCE	M
3	1ST FLOOR BY ROOM 100	M
4	1ST FLOOR BY BOILER ROOM	M
5	GYM	M
6	GYM	M
7	1ST FLOOR BY ROOM 146	M
8	1ST FLOOR WOODSHOP	M
9	1ST FLOOR BY ROOM 115	M
11	1ST FLOOR WOODSHOP	EOL
12	2ND FLOOR TOP OF RAMP	M
14	2ND FLOOR BY ROOM 227	M
15	2ND FLOOR BY ROOM 226	M
16	2ND FLOOR BY ROOM 200	M
17	2ND FLOOR TOP OF RAMP	EOL
18	BOILER ROOM	M
20	BOILER ROOM	EOL
21	HEAT DETECTORS	
	ELECTRICAL ROOM	HT
10	KITCHEN SUPPRESSION	
	KITCHEN SYSTEM	SUPP
23	KITCHEN	EOL
24	DUCT SMOKE DETECTORS	
	GYM FAN ROOM SUPPLY #2	DS
26	GYM FAN ROOM	EOL
27	GYM FAN ROOM SUPPLY #3	DS
29	GYM FAN ROOM SUPPLY #3	DS
30	GYM FAN ROOM	EOL
31	LIBRARY OFFICE	DS
33	BOILER ROOM SUPPLY FAN #4	DS
34	BOILER ROOM	EOL
35	SPRINKLER DEVICES	
36	SPRINKLER PRESSURE SWITCH ALARM	FSP
37	BOILER ROOM	EOL
38	SPRINKLER MAIN CONTROL VALVE	TS

40	BOILER ROOM	EOL
41	NOTIFYING DEVICES	
42	1ST FL BY GIRLS LOCKER RM	B
43	1ST FL CORR BY 109	B
44	1ST FL CORR BY 106	B
45	1ST FL CORR BY GYM ADJ ROOM 128	B
46	1ST FL CORR BY GYM	B
47	1ST FL GYM	B
48	1ST FL GYM	B
50	1ST FL EAST CORR	B
49	2ND FL CORR BY RM 200	B
51	2ND FL CORR BY RM 222	B
52	2ND FL CORR BY ROOM 226	B
53	2ND FL CORR BY 214	B
54	2ND FL CORR BY 228	B
55	2ND FL CORR BY 222	EOL
Fire Door Number or Location		
ALL DOORS IN HALLWAYS		

EMERGENCY LIGHTS

Location

Model

1ST FLOOR EXIT TO STAIRS	REMOTE
--------------------------	--------

CEILING BY ROOM 5	SP T 50
-------------------	---------

MAIN ENTRANCE	REMOTE
---------------	--------

CEILING BY GUIDANCE OFFICE	SP T 50
----------------------------	---------

CEILING BY ROOM 23B	DUAL LITE
---------------------	-----------

CEILING BY ROOM 23D	DUAL LITE
---------------------	-----------

STAIRWELL BY ROOM 1	REMOTE
---------------------	--------

LOCKERS NEAR ROOM 23	REMOTE
----------------------	--------

BY EXIT NEAR ROOM 21	REMOTE
CEILING BY ROOM 13B	DUAL LITE
CEILING BY ROOM 16	DUAL LITE
EXIT TO STAIRS BY ROOM 18	REMOTE
MAIN ENTRANCE	DUAL LITE
RAMP	REMOTE
RAMP	REMOTE
BOILER ROOM EXIT	AIMLITE
STAIRWELL EXIT BY ROOM 24	LUMACELL
EXIT TO STAIRS BY ROOM 24	REMOTE
CEILING BY ROOM 25	DUAL LITE
WALL BY ROOM 44	AIMLITE
WALL BY LIBARY	LUMACELL
WALL BY LIBARY	REMOTE
EXIT TO RAMP	REMOTE
CEILING BY ROOM 37B	DUAL LITE
CEILING BY SEWING & FAMILY LIVING	DUAL LITE
EXIT TO SAFE REFUGE AREA	REMOTE
STAIRWELL 2ND FLOOR	EMERGILITE

CEILING BY ROOM 27B	DUAL LITE
---------------------	-----------

CEILING BY ROOM 29	DUAL LITE
--------------------	-----------

STAIRWELL EXIT	REMOTE
----------------	--------

STAIRWELL 2ND FLOOR	AIMLITE
---------------------	---------

LIBRARY WALL	AIMLITE
--------------	---------

GYM BY BOYS LOCKER ROOM	LUMACELL
-------------------------	----------

GYM BY GIRLS LOCKER ROOM	LUMACELL
--------------------------	----------

GYM OUTSIDE EXIT	LUMACELL
------------------	----------

GYM OUTSIDE EXIT	LUMACELL
------------------	----------

GYM DOOR TO HALL	EMERGILITE
------------------	------------

GYM DOOR TO HALL	EMERGILITE
------------------	------------

HIGH ON GYM WALL ABOVE MENS C/R	COMBO
---------------------------------	-------

HIGH ON GYM WALL ABOVE LEFT OUTSIDE EXIT	COMBO
--	-------

HIGH ON GYM WALL	COMBO
------------------	-------

HIGH ON GYM WALL	COMBO
------------------	-------

CEILING BY RM 45	DUAL LITE
------------------	-----------

CAFETERIA	REMOTE
-----------	--------

OUTSIDE CAFETERIA	DUAL LITE
-------------------	-----------

LHS GYM STAGE	UNIT
---------------	------

GYM STAGE	REMOTE
-----------	--------

GYM STAGE	REMOTE
RHS GYM STAGE	UNIT
GYM STAGE	REMOTE
ON STAGE LEFT	AIMLITE
ON STAGE LEFT	REMOTE
ON STAGE RIGHT	AIMLITE
ON STAGE RIGHT	REMOTE
MAIN OFFICE	REMOTE
MAIN OFFICE	REMOTE
MAIN OFFICE ABOVE CEILING	BATTERY PACK

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

1	1ST FLOOR BY ROOM 112: BREAKER "8", PANEL "B", BOILER ROOM STORAGE	
2	1ST FLOOR BY CAFETERIA: BREAKER "23", PANEL "B", BOILER ROOM STORAGE	
3	1ST FLOOR BY ROOM 115: BREAKER "25", PANEL "B", BOILER ROOM STORAGE	
4	CAFETERIA: BREAKER "21", PANEL "B", BOILER ROOM STORAGE	
5	1ST FLOOR BY ROOM 150: BREAKER "19", ROOM 155	
6	2ND FLOOR BY ROOM 224: BREAKER "7", PANEL "L", ROOM 215	
7	2ND FLOOR BY LIBRARY: BREAKER "17", PANEL "J", ROOM 219	

8	2ND FLOOR BY RAMP: BREAKER "11", PANEL "J", ROOM 219	
9	2ND FLOOR BY ROOM 212: BREAKER "1", PANEL "J", ROOM 219	
10	2ND FLOOR BY ROOM 223: BREAKER "3", PANEL "L", ROOM 219	
11	2ND FLOOR BY ROOM 225: BREAKER "22", PANEL "J", ROOM 219	

	LOCATION: Caudel Park	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
MANUAL PULL STATIONS			
1	MAIN ENTRANCE	M	ZONE 1
2	EXIT BY GYM FRONT	M	ZONE 1
3	1ST FLOOR EXIT BY ROOM 104	M	ZONE 1
4	EXIT BY GYM BACK	M	ZONE 1
5	BOILER ROOM	M	ZONE 1
6	2ND FLOOR BY STAFF ROOM	M	ZONE 4
7	2ND FLOOR BY ROOM 204	M	ZONE 1
8	3RD FLOOR BY ROOM 302	M	ZONE 1
9	3RD FLOOR BY ROOM 305	M	ZONE 1
HEAT DETECTORS			
1	1ST FLOOR ROOM 105	RHT	ZONE 1
2	1ST FLOOR FRIDGE ROOM	RHT	ZONE 1
3	1ST FLOOR CARETAKERS OFFICE	RHT	ZONE 1
4	1ST FLOOR ELECTRICAL ROOM	RHT	ZONE 1
5	STORAGE ROOM IN SERVICE ROOM	HT	ZONE 2
6	1ST FLOOR OFFICE STORAGE ROOM	RHT	ZONE 1
7	1ST FLOOR JANITOR ROOM	HT	ZONE 1

8	BOILER ROOM	HT	ZONE 2
9	GYM STORAGE	RHT	ZONE 3
10	2ND FLOOR STAFF KITCHEN	RHT	ZONE 4
11	2ND FLOOR VENTILATION ROOM	RHT	ZONE 4
12	2ND FLOOR STORAGE ROOM	RHT	ZONE 4
13	2ND FLOOR JANITOR'S ROOM	HT	ZONE 4
14	LIBRARY BY TEACHER'S DESK(2ND FL)	RHT	ZONE 4
15	LIBRARY (2ND FL)	RHT	ZONE 4
16	3RD FLOOR STAIRS BY 307	RHT	ZONE 5
17	3RD FLOOR STAIRS BY STAFFROOM	RHT	ZONE 5
18	3RD FLOOR JANITORS ROOM	RHT	ZONE 5
19	PANEL ROOM	RHT	ZONE 1

NOTIFYING DEVICES

1	GYM	B	SIG 1
2	BOILER ROOM	B	SIG 1
3	1ST FLOOR BY SERVICE ROOM	B	SIG 1
4	1ST FLOOR BY ROOM 105	B	SIG 1
5	2ND FLOOR BY JANITORS ROOM	B	SIG 1
6	3RD FLOOR BY ROOM 304	B	SIG 1

Fire Door Number or Location

BY RM 101

BY RM 105

BY RM 201

BY LIBRARY

BY RM 301

BY RM 307

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH
--------	------------------	-------------	-----------	----------

1	Boiler Room		Y	6V 12AH
2	Hall By Room 101 BATT PACK		Y	
3	**Hall By Room 101	Y		
4	Hall By Room 105 BATT PACK		Y	
5	**Hall By Room 105	Y		
6	GYM BACK-STAGE		Y	
7	GYM FRONT LEADING TO STAIRS		Y	
12	Gym Front Foyer		Y	
13	Gym Back Foyer		Y	
8	Gym Back Pack		Y	6V 12AH
9	**Gym Back Foyer	Y		
10	Gym Stage		Y	
11	**Gym Front Foyer	Y		
14	By Gym Back Rt.		Y	
15	By Gym Entry Back Loft		Y	
16	2nd Flr By Ventilation Rm PACK		Y	6V 12AH
17	**By Ventilation Room	Y		
18	**Stairs By Staff Room	Y		
19	2nd Flr By Rm 204 BATT PACK			
20	**By Room 204	Y		
21	**Stairs By Room 204	Y		
22	3rd Flr Janitors Rm BATT PACK		Y	
	**Hall By Room 303	Y		
23	**Stairs By Room 301	Y		
24	3rd Flr Music Storage BATT PACK		Y	
25	**By Room 307	Y		
26	**Stairs By Room 307	Y		
EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS				
	PANEL "A", CUJSTODIAL OFFICE, CCT# 18, CONTROLS LIGHT BY RM 105			
	PANEL "B", 2ND FL VENTILATION RM, CCT#7, CONTROLS LIGHTS: BY VENTILATION RM, STAIRS BY STAFFROOM			

	PANEL "C", 2ND FL BOOK STORAGE RM, CCT #18, CONTROLS LIGHTS: BY STAIRS BY 204, BY RM 204
	PANEL "F", BY RM 301, CCT #13, CONTROLS LIGHTS: HALL BY 303, STAIRS BY 301
	PANEL "E", BY RM 308, CCT #16, CONTROLS LIGHTS: HALL BY 307, STAIR BY 307
	GYM PANEL. CCT #1, CONTROLS LIGHTS: GYM FRONT, GYM REAR, GYM FRONT FOYER, GYM REAR FOYER
	GYM PANEL, CCT #8, CONTROLS GYM BACK PACK LIGHT & GYM REAR FOYER REMOTE

	LOCATION: Cavalier Dr.	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
MANUAL PULL STATIONS			
1	2ND FLOOR BY ROOM 214	M	ZON E 6
2	2ND FLOOR TOP OF CENTER STAIRS	M	ZON E 6
3	2ND FLOOR BY ROOM 202	M	ZON E 6
4	BOILER ROOM	M	ZON E 7
5	1ST FLOOR BY CENTER STAIRS	M	ZON E 7
6	1ST FLOOR BY STAFF ROOM	M	ZON E 7
7	1ST FLOOR BY ROOM 112	M	ZON E 7
8	1ST FLOOR BY ROOM 102	M	ZON E 7
9	INDUSTRIAL ARTS ROOM	M	ZON E 8
10	GYM FRONT	M	ZON E 8
11	GYM BACK	M	ZON E 8
12	MAIN ENTRANCE	M	ZON E 8
13	GYM ENTRANCE FROM LOBBY	M	ZON E 8
14	HALL EXIT BY INDUSTRIAL ARTS	M	ZON E 8

SMOKE DETECTORS			
1	WEST STAIRS	SI	ZONE 1
2	CENTER STAIRS	SI	ZONE 2
3	EAST STAIRS	SI	ZONE 3
DUCT SMOKE DETECTORS			
1	2ND FLOOR FAN ROOM SUPPLY FAN	DS	ZONE 5
2	2ND FLOOR FAN ROOM RETURN FAN	DS	ZONE 5
HEAT DETECTORS			
1	ELEVATOR MACHINE ROOM	HT	ZONE 7
SPRINKLER DEVICES			
1	SPRINKLER FLOW ALARM	FSP	ZONE 9
2	MAIN CONTROL VALVE	SV	ZONE 13
32	LOW PRESSURE	PS	ZONE 13
NOTIFYING CIRCUITS			
1	1ST FLOOR BY STUDENT COUNCIL OFFICE	E B	SIG 1
2	WOODSHOP	B	SIG 1
3	GYM FRONT	B	SIG 1
4	GYM BACK	B	SIG 1
5	1ST FLOOR BY OFFICE	B	SIG 1
6	1ST FLOOR BY CENTER STAIRS	B	SIG 1
7	1ST FLOOR BY ROOM 102	B	SIG 1
8	1ST FLOOR BY BOILER ROOM	B	SIG 1
9	1ST FLOOR BY ROOM 110	B	SIG 1

10	2ND FLOOR BY ROOM 203	B	SIG 1
11	2ND FLOOR BY ROOM 208	B	SIG 1
12	2ND FLOOR BY CENTER STAIRS	B	SIG 1
13	2ND FLOOR BY ROOM 212	B	SIG 1

END OF LINE RESISTORS

1	1ST FLOOR BY ROOM 102	EOL	ZON E 7
2	SPRINKLER ROOM	EOL	ZON E 13
3	SPRINKLER ROOM	EOL	ZON E 9
4	INDUSTRIAL ARTS ROOM	EOL	ZON E 8
5	2ND FLOOR BY ROOM 202	EOL	ZON E 6
6	WEST STAIRS	EOL	ZON E 1
7	2ND FLOOR FAN ROOM	EOL	ZON E 5
8	CENTER STAIRS	EOL	ZON E 2

EMERGENCY LIGHTING

Line#	EL UNIT Location	Remote	Cab.	Serial #	Manuf.	
1	Gym Front			CXU636-2	Aim-Lite	
2	Gym Back			CXU636-2	Aim-Lite	
3	Industrial Arts			RG36QB	Lumacell	
4	1st Floor By Industrial Arts			RG36QB	Lumacell	
5	1st Flr By Home Economics			RG36QB	Lumacell	
6	1st Floor By Main Office			RG36QB	Lumacell	
7	1st Floor By Janitors Room			RG36QB	Lumacell	
8	1st Floor By Room 106			RG36QB	Lumacell	
9	1st Floor By Room 101			RG36QB	Lumacell	
10	1st Floor By Caretakers Office			RG36QB	Lumacell	
11	1st Floor By Room 112			RG36QB	Lumacell	
12	Bottom Center Stairs			RG36QB	Lumacell	
13	**1st Floor Center Stairs		Y		REMOTE	
14	**2nd Floor Center Stairs		Y		REMOTE	
15	Bottom West Stairs			RG36QB	Lumacell	

	**1st Floor West Stairs	Y				
16	**1st Floor West Stairs		Y		REMOTE	
17	2nd Floor By Room 203			RG36QB	Lumacell	
18	**2nd Floor West Stairs		Y		REMOTE	
19	Electrical Rm In Boiler Room			RG36QB	Lumacell	
20	**Boiler Room		Y		REMOTE	
21	Bottom East Stairs			RG36QB	Lumacell	
22	**1st Floor East Stairs		Y		REMOTE	
23	2nd Floor By Room 214			RG36QB	Lumacell	
24	**2nd Floor East Stairs		Y		REMOTE	
25	2nd Floor By Room 208			RG36QB	Lumacell	
26	2nd Floor By Centre Stairs			RG36QB	Lumacell	
27	Stage Rt. On Stairs	Y				
28	Stage Left	Y				
29	Stage Left on Satirs	Y				
30	On Satge	Y	Y			

TECH NOTES:

EML BREAKERS:

- MAIN FLOOR BOILER ROOM
- MAIN FLOOR SMK ROOM
- MAIN FLOOR GYM STAGE
- 2ND FLOOR SINK ROOM.

	LOCATION: Hillside Park	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex 2001		
MANUAL PULL STATIONS			
	BY ROOM 101	M	ZONE 1
	BY ROOM 103	M	ZONE 1
	BY ROOM 206	M	ZONE 1
	BY ROOM 206	EOL	ZONE 1
	GYM REAR EXIT	M	ZONE 2
	GYM BY STAGE	M	ZONE 2
	EXIT BY LIBRARY	M	ZONE 2
	EXIT TOP OF RAMP	M	ZONE 2
	EXIT TOP OF RAMP	EOL	ZONE 2
	BY ROOM 306	M	ZONE 3
	BY ROOM 311	M	ZONE 3
	BY ROOM 311	EOL	ZONE 3
SPRINKLER DEVICES			
	SPRINKLER MAIN CONTROL VALVE	SV	ZONE 5
	BOILER ROOM	EOL	ZONE 5
	SPRINKLER PRESSURE SWITCH ALARM	FSP	ZONE 6
	BOILER ROOM	EOL	ZONE 6
DUCT SMOKE DETECTORS			
	GYM FAN ROOM #1 LOWER	DS	ZONE 7
	GYM FAN ROOM #2 UPPER	DS	ZONE 7
	GYM FAN ROOM	EOL	ZONE 7
	BOILER ROOM FAN ROOM #1	DS	ZONE 8
	BOILER ROOM FAN ROOM #2	DS	ZONE 8
	BOILER ROOM FAN ROOM #3	DS	ZONE 8
	BOILER ROOM FAN ROOM #4	DS	ZONE 8
	BOILER ROOM FAN ROOM	EOL	ZONE 8
HEAT DETECTORS			
	ELECTRICAL ROOM	HT	ZONE 9
	ELECTRICAL ROOM	EOL	ZONE 9
NOTIFYING DEVICES			
	GYM	B	SIG 1
	BY ROOM 306	B	SIG 1
	BY ROOM 102	B	SIG 1
	BY RAMP LOWER	B	SIG 1
	BY OFFICE	B	SIG 1
	BY LIBRARY	B	SIG 1
	GYM	B	SIG 2
	BY ROOM 310	B	SIG 2

	TOP OF RAMP	B	SIG 2
	BY MUSIC ROOM	B	SIG 2
	BY ROOM 206	B	SIG 2
	BY BOILER ROOM	B	SIG 2

RELAYS

	DOOR RELEASE		
	AHU SHUTDOWN		

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH	Manuf.
1	By Room 102		Y	6V7.2AH	LUMACELL
2	Boiler Room		Y	6V7.2AH	LUMACELL
3	By Boiler Room		Y	6V7.2AH	LUMACELL
4	Electrical Room		Y	6V7.2AH	LUMACELL
5	Fan Room In Boiler Room		Y	6V7.2AH	LUMACELL
6	Ramp Bottom		Y	6V7.2AH	LUMACELL
7	**Stairs By Room 103	Y			
8	By Office		Y	6V7.2AH	LUMACELL
9	By Room 207		Y	6V7.2AH	LUMACELL
10	By Music Room		Y	6V7.2AH	LUMACELL
11	Top Of Ramp		Y	6V7.2AH	LUMACELL
12	By Room 305		Y	6V7.2AH	LUMACELL
13	By Room 310		Y	6V7.2AH	LUMACELL
14	By Library		Y	6V7.2AH	LUMACELL
15	Gym Main Entrance		Y	6V7.2AH	LUMACELL
16	Gym By Stage		Y	6V7.2AH	LUMACELL
17	Gym By Outside Exit		Y	6V7.2AH	LUMACELL

	LOCATION: Leslie Thomas	Device	Device address or circuit number

FIRE ALARM PANEL:Edwards QS4

MANUAL PULL STATIONS

1	1ST FLR FRONT STAIR EXIT BY RM 103	M	ZONE 1
2	ELEV. LOBBY GROUND FLOOR	M	131
3	SCIENCE SHOP EXIT	M	ZONE 1
4	WOODSHOP EXIT BY RM 105	M	ZONE 1
5	1ST FLOOR KITCHEN/BAND RM EXIT	M	ZONE 1
6	MAIN ENTRANCE	M	ZONE 2
7	2ND FLOOR BACK STAIR EXIT	M	ZONE 2
8	GYM EXIT BY STAGE	M	ZONE 2
9	3RD FLOOR FRONT STAIR EXIT	M	ZONE 3
10	3RD FLR BACK STAIR EXIT BY RM 306	M	ZONE 3

DUCT SMOKE DETECTORS

1	AHU 3RD FLOOR	DS	ZONE 4
2	GYM STORAGE ROOM	DS	ZONE 5
3	BOILER ROOM AHU # 1	DS	ZONE 6

HEAT DETECTORS

1	GARBAGE ROOM	RHT	ZONE 7
2	STORAGE ROOM BY BOILER	HT	ZONE 8

SPRINKLER DEVICES

1	SPRINKLER MAIN CONTROL VALVE	TS	ZONE 9
2	SPRINKLER PRESSURE ALARM	FSP	ZONE 9
3	ELEV. 1ST FLOOR	SUPP	129
4	KITCHEN HOOD SYSTEM	SUPP	ZONE 10

NOTIFYING DEVICES

1	MUSIC ROOM	B	SIG 1
2	BY ROOM 101	B	SIG 1
3	CAFETERIA	B	SIG 1
4	WOODSHOP	B	SIG 1
5	SCIENCE SHOP	B	SIG 1
6	BY ROOM 105	B	SIG 1
7	BY ROOM 206	B	SIG 1
8	BY ROOM 209	B	SIG 1
9	BY ROOM 307	B	SIG 1
10	BY ROOM 311	B	SIG 1
11	ELEV. LOBBY FRONT	B	
12	GYM	B	SIG 1

END OF LINE RESISTORS

1	WOODSHOP EXIT	EOL	ZONE 1
2	HALL BY ROOM 206	EOL	ZONE 2
3	HALL BY ROOM 307	EOL	ZONE 3
4	GYM STORAGE ROOM	EOL	ZONE 5
5	AHU 3RD FLOOR	EOL	ZONE 4
6	BOILER ROOM	EOL	ZONE 6
7	GARBAGE ROOM	EOL	ZONE 7
8	BOILER ROOM	EOL	ZONE 8
9	BY SPRINKLER TREE	EOL	ZONE 9
10	KITCHEN	EOL	ZONE 10
11	BY ROOM 307	EOL	SIG 1

SMOKE DETECTORS

ELEV MACH	S	002
ELEV SHAFT	S	
ELEV LOBBY 2ND	S	005
ELEV LOBBY 3RD	S	001
COMM RM GROUND FLOOR	S	006
GROUND FLOOR OUTSIDE ELEVATOR LOBBY	S	007
GROUND FLOOR INSIDE ELEV LOBBY	S	004

Fire Door Number or Location

MAIN ENTRY LEV 2
 TOP STAIR FRONT ,LEV 3
 TOP STAIRS, REAR .,LEV 3
 LEV 2 REAR ,BY STAIRS

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote	Cab. Head	Manuf.
1	1st Floor Janitors Office		Y	Lumacell, Battery Pak
2	**1st Floor Main Stair	Y		

3	**2nd Floor Main Stair	Y		
4	**3rd Floor Main Stair	Y		
5	1st Floor Electrical Rm 107		Y	Emergi-Lite, Battery Pak
6	**Outside of Room	Y		
7	Woodshop RM 106			Lithonia, M636
8	Science Lab RM 107			Lumacell, RG36
9	Boiler Room			Emergi-Lite, 06JML36
10	Band Room			Emergi-Lite, 06JML36
11	Main Office			Lumacell, RG36
12	2nd Floor Electrical Rm 2B			Emergi-Lite, Battery Pak
13	Outside Of Room	Y		
14	Kitchen Storage			Lumacell, Battery Pak
15	**Main Entrance	Y		
16	**Cafeteria	Y		Remote
17	3rd Flr Store By Library 3B			Lumacell, Battery Pak
18	**Gym Front	Y		
19	3rd Floor Electrical Rm 3D			Lumacell, Battery Pak
20	**Outside Of Room	Y		
21	RCMP Office/Copy Rm			Lumacell, Battery Pak
22	**Gym Back	Y		
23	Rear Stairwell			Emergi-Lite, JML 36
24	**Rear Stairwell	Y		Remote
25	1ST FLOOR BOTTOM OF STAIRS		Y	
26	ELEV MACH ROOM		Y	
27	ELEV LOBBY 1ST FLOOR		Y	
28	ELEV LOBBY 1ST		Y	
29	ELEV LOBBY 2ND		Y	
30	ELEV LOBBY 3RD			
31	GYM STAGE LEFT		Y	
32	GYM STAGE RIGHT		Y	
33	GYM STAGE ABOVE ELEC BOX		Y	
34	GYM STAGE ABOVE ELEC BOX		Y	
35	GYM DOOR TO CORRIDOR		Y	
36	IN ROOM 2B		Y	

	LOCATION: Sackville High	Device	Device address or circuit number	Annunciation
	FIRE ALARM PANEL: Edwards QS-4			

Location Description	Device	Address	Zone / Circuit #
-----------------------------	---------------	----------------	-------------------------

MANUAL PULL STATIONS

SOUTH HALL 1ST FLOOR EXIT	M	D002	1
1ST FLOOR BY ELEVATOR	M	D010	6
CENTRE HALL 1ST FLOOR	M	D014	11
NORTH HALL 1ST FLOOR	M	D014	11
BOILER ROOM EXIT	M	D012	17
GYM NORTH EXIT	M	D008	21
GYM ADJ. EQUIPMENT ROOM	M	D008	21
BY ROOM 234	M	D003	2
MAIN LOBBY BY GYM	M	D011	7
MAIN ENTRANCE TO LOBBY	M	D011	7
GYM STAIRS 2ND FLOOR	M	D015	7
CORRIDOR EXIT BY ROOM 201	M	D015	7
NORTH HALL 3RD FLOOR	M	D016	8
CENTRE HALL 3RD FLOOR	M	D012	8

CORRIDOR STAIR EXIT BY ROOM 301	M	D016	8
BY ROOM 319	M	D010	8
SKILLED-TRADE LAB ROOM 127 BY EXIT #1 TO CORR.	M	D002	1
SKILLED-TRADE LAB ROOM 127 BY EXIT #2 TO CORR	M	D002	1
SKILLED-TRADE LAB STORAGE RM 127 BY EXIT TO OUTSIDE	M	D002	1

SMOKE DETECTORS

SOUTH STAIRS	S	D011
NORTH STAIRS	S	D001
GYM STAIR	S	D009
MAIN STAIR (CENTRE STAIR)	S	D013

HEAT DETECTORS

BOILER ROOM	HT		
BOILER ROOM	HT		
ELECTRICAL ROOM	HT		
ELEVATOR MECHANICAL ROOM	HT		
ELEVATOR SHAFT	HT		
FOOTBALL STORAGE ROOM	HT		
KITCHEN AREA	HT		
BIOLOGY 312	RHT	D012	8
BIOLOGY 312 BY	RHT	D012	8

BIOLOGY 312 BY CHALKBOARD	RHT	D012	8
BIOLOGY 313	RHT	D012	8
BIOLOGY 313 BY CHALKBOARD	RHT	D012	8
CHEMISTRY ROOM 304	RHT	D011	13
CHEMISTRY ROOM 304 BY CHALKBOARD	RHT	D011	13
CHEMISTRY ROOM 307	RHT	D011	13
CHEMISTRY ROOM 307 BY CHALKBOARD	RHT	D011	13
CHEMISTRY STORAGE ROOM 305	RHT	D011	13
CHEMISTRY STORAGE ROOM 306	RHT	D011	13
GUIDANCE AREA FIRST AID ROOM	RHT	D011	7
GYM STORAGE A	RHT	D008	21
GYM STORAGE B (CLOSEST TO OFFICE)	HT	D008	21
GYM STORAGE C	RHT	D008	21
JANITORS ROOM 1ST FLOOR	RHT	D010	6
JANITORS ROOM 243 2ND FLOOR	RHT	D011	7
JANITORS ROOM 3RD FLOOR	RHT		13
LEARNING CENTRE ROOM 234	HT		
LIBRARY STORAGE	RHT	D003	2
MAIN OFFICE	RHT	D011	7
PHYSICS 309	RHT	D012	8
PHYSICS 309 BY CHALKBOARD	RHT	D012	8

ROOM 310	RHT	D012	8
ROOM 311	RHT	D012	8
STAFF ROOM COAT STORAGE ROOM	RHT		7
SKILLED-TRADE LAB HEAT DETECTOR #1 RM. 127	RHT		1
SKILLED-TRADE LAB HEAT DETECTOR #2 RM. 127	RHT	D002	1
SKILLED-TRADE LAB HEAT DETECTOR #3 RM. 127	RHT	D002	1
SKILLED-TRADE LAB HEAT DETECTOR #4 RM. 127	RHT	D002	1
SKILLED-TRADE LAB HEAT DETECTOR #5 RM. 127	RHT	D002	1
SKILLED-TRADE LAB STORAGE ROOM	RHT	D002	1
STORAGE MAINTENANCE	HT		
CORNER STORE STORAGE ROOM	HT		
VENTILATION ROOM ABOVE GYM STORAGE A	RHT	D008	21
VENTILATION ROOM ABOVE GYM STORAGE B	RHT		
WOODWORKING OFFICE	HT		
YOUTH HEALTH ROOM 325	RHT	D012	8

NOTIFYING DEVICES

BOILER ROOM	B		SIG 1
DRAMA ROOM	B		SIG 1
GYM	B		SIG 1
GYM	B		SIG 1
HALL BY ROOM 201	B		SIG 1

HALL BY ROOM 203	B		SIG 1
HALL BY ROOM 231	B		SIG 1
HALL BY ROOM 303	B		SIG 1
HALL BY ROOM 322	B		SIG 1
HALL BY WOODWORKING	B		SIG 1
WOODWORKING SHOP	B		SIG 1
CAFETERIA	B		SIG 1
HALL BY CAFETERIA	B		SIG 2
HALL BY ROOM 103	B		SIG 2
HALL BY ROOM 107	B		SIG 2
HALL BY ROOM 111	B		SIG 2
HALL BY ROOM 209	B		SIG 2
HALL BY ROOM 310	B		SIG 2
HALL BY ROOM 313	B		SIG 2
HALL BY STAFF ROOM	B		SIG 2
MAIN LOBBY	B		SIG 2
MUSIC ROOM	B		SIG 2

END OF LINE RESISTORS

KITCHEN AREA	EOL		1
1ST FLOOR SOUTH SECTION	EOL		2
1ST FLOOR BY CAFETERIA	EOL		3
1ST FLOOR NORTH/CENTRE SECTION	EOL		4
BOILER ROOM	EOL		5
SOUTH STAIRS	EOL		6
GYM AREA	EOL		7

GYM AREA	EOL		
2ND FLOOR SOUTH SECTION	EOL		8
2ND FLOOR CENTRE SECTION	EOL		9
2ND FLOOR NORTH SECTION	EOL		10
ELEVATOR SHAFT	EOL		11
ELEVATOR MECHANICAL ROOM	EOL		12
NORTH STAIRS	EOL		13
3RD FLOOR NORTH SECTION	EOL		14
GYM STAIR	EOL		15
3RD FLOOR CENTRE SECTION	EOL		16
MAIN STAIR	EOL		17
SOUTH HALL 2ND FLOOR	EOL		18

AHU SHUTDOWN	RLY
DOOR RELEASE	RLY

EMERGENCY LIGHTS

Location	# of Heads	Model
2ND FLOOR JANITORS RM PAK #1		EMERGI-LITE 12E8L216
OUTSIDE STAFF RM		REMOTE
BY ROOM 313		REMOTE
MAIN STAIR 3RD TO 2ND		REMOTE
MAIN LOBBY		REMOTE
MAIN LOBBY		REMOTE
MAIN STAIR 2ND TO		REMOTE

MAIN STAIR 2ND TO 1ST		REMOTE
1ST FLOOR BY KITCHEN		REMOTE
SKILLED TRADES ROOM 112 UNIT 7		EXIDE Q75
HALL BY ROOM 127		REMOTE
HALL BY 231		REMOTE
HALL BY 322		REMOTE
IN ROOM 124		EMERGI-LITE 12ESL 216
STAIRS BY ROOM 122		REMOTE
STAIRS BY ROOM 234		REMOTE
STAIRS BY ROOM 320		REMOTE
1ST FLOOR JANITORS OFFICE		EMERGI-LITE 6JML36
CAFETERIA RIGHT EXIT		LITHONIA COMBO UNIT
CAFETERIA LEFT EXIT		LITHONIA COMBO UNIT
1ST FLOOR JANITORS ROOM		EMERGI-LITE 6JML36
FOOTBALL STORAGE RM		EXIDE Q12-2202H
HALL BY FOOTBALL STORAGE RM		REMOTE
BOILER RM		REMOTE
MUSIC RM		EMERGI-LITE JML36
1ST FLOOR BOOK RM PAK#1		EMRGI-LITE 12ESL213
HALL BY RM 108		REMOTE
HALL BY RM 208		REMOTE
HALL BY RM 308		EMERGI-REMOTE
1ST FLR BOOK RM		EMERGI-

TOILET BOOTH RM PAK #2		EMERGI- LITE 12ESL216
BOYS CHANGE RM		REMOTE
GIRLS CHANGE RM		REMOTE
GYM STORAGE RM		EMERGI- LITE 12EESL12 16
GYM		REMOTE
GYM		REMOTE
GYM		REMOTE
GYM		REMOTE
2ND FLR JANITORS RM PAK #2		EMERGI- LITE 12ESL216
GYM STAIRS 3RD TO 2ND		REMOTE
GYM STAIRS 2ND TO 1ST		REMOTE
LOCKER ROOM STAIRS		REMOTE
LOBBY BY GYM/MUSIC ROOM		REMOTE
LOBBY BY GYM/MUSIC ROOM		REMOTE
LOBBY BY GYM/MUSIC ROOM		REMOTE
STAIRS BY ROOM 101		REMOTE
STAIRS BY ROOM 201		REMOTE
STAIRS BY ROOM 301		REMOTE
ROOM 306 (IN ROOM 307) #1		EMERGI- LITE 12ESL216
ROOM 306 (IN ROOM 307) #2		EMERGI- LITE 12ESL216
SKILLED TRADES ROOM 122		AIM LITE
ROOM 122 AT EXIT		COMBO UNIT
ROOM 122 AT EXIT		COMBO

		UNIT
HALL ADJ 203		REMOTE
HALL ADJ 103		REMOTE
HALL ADJ 303		REMOTE
HALL ADJ 101		LUMACELL
ROOM 122 BACK		COMBO
ROOM 122 UNIT #2 (ADJ FILE CAB)		
ROOM 119 ARTS		COMBO UNITS
ROOM 119 ARTS		COMBO
ROOM 118 CARPENTRY	EXIT	COMBO
ROOM 117 CARPENTRY		COMBO
ROOM 119 BACK		COMBO
VENTILLATION ROOM		UNIT

Fire Door Number or Location
1st Flr by Art Room
1st Flr by Rm 105
1ST Flr by Rm 113 / Elevator
1st Flr bottom Centre stair / Vestibule
1st Flr South Stairwell
1st Flr Stair by Rm 101 /NORTH STAIR
2nd Flr by Rm 205
2nd Flr by Rm 216 / NOT FOUND
2nd Flr by Rm 228
2nd Flr Gym Stair
2nd Flr Main Lobby Left
2nd Flr Main Lobby Right
2nd Flr North Stair by Rm 201
2nd Flr South Stair by Rm 234
3rd Flr by Rm 316
3rd Flr Gym Stair
3rd Flr to left of Center Stair
3rd Flr Stair by Rm 301 /North stairway
3rd Flr Stair by Rm 319 South Stairwell

	LOCATION: Smokey Dr.	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards 6500		
MANUAL PULL STATIONS			
1	2ND FLOOR BY ROOM 201	M	ZONE 7
2	2ND FLOOR BY ROOM 211	M	ZONE 7
3	GYM	M	ZONE 6
4	BOILER ROOM	M	ZONE 6
5	MAIN ENTRANCE	M	ZONE 6
6	REAR EXIT BY STAGE	M	ZONE 6
SPRINKLER DEVICES			
1	CONTROL VALVE	SV	ZONE 3
2	MAIN CONTROL VALVE	SV	ZONE 3
3	PRESSURE SWITCH ALARM	FSP	ZONE 2
RELAYS, ETC			
1	FIRE PUMP OFF	SV	ZONE 4
2	FIRE PUMP RUNNING	SV	ZONE 5
HEAT DETECTORS			
1	2ND FLOOR JANITORS ROOM	RHT	ZONE 7
2	1ST FLOOR JANITORS ROOM	RHT	ZONE 6
3	ELECTRICAL ROOM	RHT	ZONE 1
NOTIFYING DEVICES			
1	2ND FLOOR BY ROOM 204	H/S	SIG 1
2	2ND FLOOR BY ROOM 210	H/S	SIG 1
3	2ND FLOOR BY ROOM 204	H/S	SIG 1
4	1ST FLOOR BY ROOM 103	H/S	SIG 2
5	1ST FLOOR BY LIBRARY	H/S	SIG 2
6	BOILER ROOM	H/S	SIG 2
7	GYM	H/S	SIG 2
END OF LINE RESISTORS			
1	SPRINKLER ROOM	EOL	ZONE 2
2	SPRINKLER ROOM	EOL	ZONE 3
3	1ST FLOOR BY LIBRARY	EOL	SIG 2
4	2ND FLOOR BY ROOM 201	EOL	ZONE 7
5	GYM	EOL	ZONE 6
6	SPRINKLER ROOM	EOL	ZONE 5
7	SPRINKLER ROOM	EOL	ZONE 4

8	ELECTRICAL ROOM	EOL	ZONE 1
---	-----------------	-----	--------

EMERGENCY LIGHTING			
Line#	EL UNIT Location	Remote	Cab.Head
1	Sprinkler Room		Y
2	By Staff Room		Y
3	** By Office	Y	
4	** By Library	Y	
5	By Room 105		Y
6	By Room 101		Y
7	Rear Stairwell		Y
8	** Hall By Stage	Y	
9	Hall By Room 202		Y
10	Hall By Room 206		Y
11	Hall By Room 209		Y
12	Gym		Y
13	Gym		Y
14	Gym rear exit	combo	
15	Stairwell toward office		Y
16	Gym by Stairs		Y
17	Gym Exit Office Hall	combo	

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS			
BY 1ST FLOOR JAN ROOM PANEL B CCT 2 AND 17			
2ND FLOOR JANITOR ROOM CCT 31,33,34			

	LOCATION: Sycamore Lane	Device	Device address or circuit number
	FIRE ALARM PANEL: Microm 79021		
MANUAL PULL STATIONS			
1	2ND FLOOR HALL BY ROOM 201	M	ZONE 03
2	2ND FLOOR HALL BY ROOM 207	M	ZONE 03
3	EXIT BY GYM	M	ZONE 04
4	MAIN ENTRANCE	M	ZONE 04
5	GYM BY STAGE	M	ZONE 05
6	GYM	M	ZONE 05
7	1ST FLOOR BY ROOM 101	M	ZONE 09
8	1ST FLOOR BY ROOM 107	M	ZONE 09
9	BOILER ROOM 121	M	ZONE 10
HEAT DETECTORS			
1	2ND FLOOR HALL BY ROOM 201	RHT	ZONE 03
2	2ND FLOOR HALL BY ROOM 203	RHT	ZONE 03
3	2ND FLOOR HALL BY ROOM 208	RHT	ZONE 03
4	2ND FLOOR HALL BY ROOM 211	RHT	ZONE 03
5	2ND FLOOR JANITORS ROOM 211	RHT	ZONE 03
6	TOP OF BACK STAIRS	HT	ZONE 03
7	TOP OF FRONT STAIRS	RHT	ZONE 03
8	HALL OUTSIDE GYM	RHT	ZONE 04
9	LIBRARY	RHT	ZONE 04
10	GYM STAGE	HT	ZONE 05
11	GYM STORAGE	HT	ZONE 05
12	1ST FLOOR BY ROOM 101	RHT	ZONE 09
13	1ST FLOOR BY ROOM 103	RHT	ZONE 09
14	1ST FLOOR BY ROOM 108	RHT	ZONE 09
15	1ST FLOOR BY ROOM 111	RHT	ZONE 09
16	1ST FLOOR JANITORS ROOM 111	RHT	ZONE 09
17	ROOM 101	RHT	ZONE 09
18	ROOM 103	RHT	ZONE 09
19	BOILER ROOM 121	RHT	ZONE 10
20	CARETAKER ROOM	RHT	ZONE 10
21	SWITCH ROOM 120	RHT	ZONE 10
NOTIFYING DEVICES			
1	GYM	B	SIG 1

2	GYM HALL	B	SIG 1
3	MAIN ENTRANCE	B	SIG 1
4	1ST FLOOR BY ROOM 106	B	SIG 1
5	2ND FLOOR BY ROOM 206	B	SIG 1
END OF LINE RESISTORS			
1	2ND FLOOR HALL BY ROOM 207	EOL	ZONE 03
2	GYM	EOL	ZONE 05
3	1ST FLOOR BY ROOM 107	EOL	ZONE 09
4	BOILER ROOM 212	EOL	ZONE 10
	DOOR RELEASE	RLY	

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head	MODEL	Bat. VAH
1	1st Floor By Room 107		COMBO	
2	1st Floor By Room 103		COMBO	
3	Bottom Front Stairs		COMBO	
4	Boiler Room Exit		COMBO	6V 7AH
5	Hall Exit By Gym		COMBO	
6	Gym BY STAGE	Y		
7	Gym		COMBO	
8	Top Front Stairs		COMBO	
9	2nd Floor By Room 203		COMBO	
10	2nd Floor By Room 207		COMBO	
11	Main Entrance		COMBO	
12	Gym Storage Room 122		UNIT	
13	Gym	Y		
14	Gym	Y		
17	Hall Exit By Gym	Y		
18	1st Floor Janitors Room		BATTERY PACK	
19	Hall By Room 111	Y		
20	Back Stair 1st Floor	Y		
21	2nd Floor Janitors Room 211		BATTERY PACK	
22	Hall By Room 211	Y		
23	Back Stair 2nd Floor	Y		
EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS				

	NOTE #1-EML PANEL LOCATION:BY CARETAKERS DOOR,PANEL "R" CCT# 20.
	Battery packs in Janitors rooms 211, 111
	CCT 23 PANEL P BOTTOM HALL

	LOCATION: Beechville Lakeside Timberlea P-2	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex		

MANUAL PULL STATIONS

1	CAFETERIA EXIT	M	ZONE 01
2	CARETAKER'S OFFICE	M	ZONE 01
3	EAST EXIT BY ROOM 101	M	ZONE 01
4	MAIN ENTRANCE	M	ZONE 01
5	NORTH EXIT	M	ZONE 01
6	CENTRE STAIRS	M	ZONE 02
7	EAST EXIT BY ROOM 223 STORAGE	M	ZONE 02
8	NORTH STAIRS	M	ZONE 02
9	GYM	M	ZONE 03
10	OUTDOOR STORAGE	M	ZONE 16

SMOKE DETECTORS

1	CARETAKER'S OFFICE STORAGE	SI	ZONE 01
2	ELECTRICAL RM IN JANITORS RM	SI	ZONE 04
3	CENTER STAIRS #232	SI	ZONE 05
4	EAST STAIRS #233	SI	ZONE 06
5	STAIRWELL # 271 (BEHIND GYM STAGE)	SI	ZONE 07
6	STAIRS BY ROOM 202 STAIR #230	SI	ZONE 09

HEAT DETECTORS

1	LIBRARY AUDIO STORAGE	RHT	ZONE 01
2	QUIET RM 121	RHT	ZONE 01
3	SPRINKLER RM	RHT	ZONE 01
4	STORAGE RM 115	RHT	ZONE 01
5	STORAGE RM 120	RHT	ZONE 01
6	STORAGE RM 134	RHT	ZONE 01
7	ART RM STORAGE (2ND FLOOR)	RHT	ZONE 02
8	STORAGE RM 202	RHT	ZONE 02
9	STORAGE RM 202	RHT	ZONE 02
10	STORAGE RM 230	RHT	ZONE 02
11	GYM STORAGE	RHT	ZONE 03
12	FAN RM # 1	RHT	ZONE 08
13	KITCHEN STORAGE	RHT	ZONE 10
14	FAN ROOM #2	RHT	ZONE 13
15	OUTDOOR STORAGE	RHT	ZONE 16
16	ELEVATOR SHAFT	RHT	ZONE 17

DUCT SMOKE DETECTORS

1	FAN ROOM #1	DS	ZONE 14
2	FAN ROOM #1	DS	ZONE 14
3	FAN ROOM #2	DS	ZONE 15
4	FAN ROOM #2	DS	ZONE 15

SPRINKLER DEVICES

1	SYSTEM #1 WATERFLOW ALARM	FSP	ZONE 11
---	---------------------------	-----	---------

2	SYSTEM #2 WATERFLOW ALARM	FSP	ZONE 11
3	SYSTEM #1 CONTROL VALVE	SV	ZONE 12
4	SYSTEM #2 CONTROL VALVE	SV	ZONE 12
5	MAIN SPRINKLER CONTROL VALVE	SV	ZONE 12
6		SV	ZONE 18
7	OUTSIDE ELEVATOR 1ST FLOOR	SV	ZONE 19
8	OUTSIDE ELEVATOR 2ND FLOOR	SV	ZONE 20
9	SPRINKLER PRESSURE SUPV (RM 108	PS	ZONE 21
10	KITCHEN RANGE TAMPER	SV	ZONE 22
10	KITCHEN RANGE FLOW	FSP	ZONE 22
	MAIN ENTRANCE	B	SIG 1
1	GYM	B	SIG 1
2	MUSIC RM	B	SIG 1
3	CAFETERIA	B	SIG 1
4	CARETAKERS OFFICE	B	SIG 1
5	HALL BY ROOM 113	B	SIG 1
6	HALL BY ROOM 109	B	SIG 1
7	HALL BY STAFF ROOM	B	SIG 1
8	HALL BY ROOM 101	B	SIG 1
9	OUTSIDE FAN ROOM #1	B	SIG 2
10	IN FAN ROOM #2	B	SIG 2
	HALL BY STORAGE ROOM 210	B	SIG 2
1	HALL BY ROOM 204	B	SIG 2
2	HALL BY ROOM 217	B	SIG 2
3	HALL BY ROOM 221	B	SIG 2
4	END OF LINE RESISTORS		
5	FAN ROOM #2	EOL	ZONE 15
6	KITCHEN	EOL	ZONE 22
	CARETAKER'S OFFICE STORAGE	EOL	ZONE 1
1	SPRINKLER ROOM	EOL	ZONE 17

2	JANITOR ELECTRICAL ROOM	EOL	ZONE 18
3	OUTSIDE ELEVATOR 2ND FLOOR	EOL	ZONE 20
4	SPRINKLER ROOM	EOL	ZONE 21
5	OUTSIDE ELEVATOR 1ST FLOOR	EOL	ZONE 19
6	OUTDOOR STORAGE	EOL	ZONE 16
7	FAN ROOM #2	EOL	ZONE 13
8	FAN ROOM #1	EOL	ZONE 14
9	STORAGE RM 230	EOL	ZONE 2
10	GYM STORAGE	EOL	ZONE 3
11	ELECTRICAL RM IN JANITORS RM	EOL	ZONE 4
12	SPRINKLER ROOM	EOL	ZONE 12
13	NORTH STAIRS # 232	EOL	ZONE 5
14	EAST STAIRS # 233	EOL	ZONE 6
15	STAIRWELL # 271 (BEHIND GYM STAGE)	EOL	ZONE 7
16	CENTRE STAIRS # 230	EOL	ZONE 9
	FAN RM # 1	EOL	ZONE 8

Fire Door Number or Location
MAIN LOBBY ENTRY TO GYM AREA
MAIN LOBBY ENTRY TO EAST WING
MAIN LOBBY ENTRY TO WEST WING
MAIN LOBBY AT CENTER STAIRS
2ND LEVEL TOP OF CENTER STAIRS

EMERGENCY LIGHTING

Line #	EL UNIT Location	Remote Head
--------	------------------	-------------

1	ELECTRICAL ROOM 1ST FLOOR	
2	**GIRLS LOCKER ROOM	Y
3	**BOYS LOCKER ROOM	Y
4	**CARETAKERS OFFICE	Y
5	**BY CENTRE STAIRS	Y
6	**BY OFFICE	Y
7	**IN OFFCE	Y
8	**GYM HALL	Y
9	**GYM ENTRY	Y
10	**GYM	Y
11	**GYM	Y
12	**Boys Shower	Y
13	**Girls Shower	Y
14	**Fan Room # 2	Y
15	**Fan Room # 2 Stairs	Y
16	**Storage Room 203	Y
17	**Music Room	Y
18	**Music Room Hall	Y
19	**Girls Washroom 107	Y
20	**Boys Washroom 109	Y
21	**By Girls Washroom	Y
22	**By Room 111	Y
23	**By Room113	Y
24	**Cafeteria Exit	Y
25	**Bottom East Stairs	Y
26	**By Cafeteria	Y
27	**Cafeteria	Y
29	**Bottom of North Stairs	Y
30	Fan Room #1 2nd Floor	
31	**Outside Fan Room	Y
32	**Outside Fan Room	Y
33	**Top of Centre Stairs	Y
34	**By Room 204	Y
35	**By Room 208	Y
36	**Top of North Stairs	Y
37	**North Stairs	Y
38	**Boys Washroom 216	Y
39	**Girls Wasroom 212	Y
40	**By Room 217	Y
41	**By Room 221	Y
42	**Top of East Stairs	Y
43	**East Stairs	Y

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS	
	EMERGENCY LIGHT BREAKER PANEL IS IN ELECTRICAL ROOM IN THE CARETAKER'S OFFICE
	TO THE RIGHT OF PANEL 312- CCT#2

	LOCATION: East St. Margarets	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex 4010		

MANUAL PULL STATIONS

1	1ST Floor Near Front Entrance	MA	M1-1
2	1ST FLOOR BY GYM	MA	M1-2
3	1ST FLOOR BY ROOM 14	MA	M1-4
4	1ST FLOOR NEAR REAR ENTRANCE	MA	M1-5
5	1ST FLOOR CENTER STAIRS	MA	M1-3
7	2ND Floor BY ROOM 110 NORTH	MA	M1-6
8	2ND FLOOR BY ROOM 113 SOUTH	MA	M 1-7
10	BOILER ROOM	MA	M1-8

HEAT DETECTORS

1	BOILER ROOM	RHTTA	M1-9
---	-------------	-------	------

NOTIFYING DEVICES

1	BOILER ROOM	K	NAC 1
2	BY ROOM 14 LOWER LEVEL	K	NAC 2
3	BY GYM ENTRY LOWER LEVEL	K	NAC 2
4	BY ROOM 113 UPPER LEVEL	K	NAC 2
5	BY ROOM 110 UPPER LEVEL	K	NAC 2

END OF LINE RESISTORS

1	1ST FLOOR BY ROOM 14	EOL	
2	2ND FLOOR BY ROOM 110	EOL	

SPRINKLER DEVICES

TANK 2 LOW WATER	SUPV	M1-11
TANK 1 LOW WATER	SUPV	M1-10
MAIN GATE VALVE	GV	M1-13
SPRINKLER FLOW	FS	M1-12
SUPERVISORY TANK 1	SPV	M1-16
SUPERVISORY TANK 2	SPV	M1-15

Fire Door Number or Location

TOP STAIR MAIN ENTRY
BOTT STAIR MAIN ENTRY

BOTT STAIR CANTER ENTRY

TOP STAIR CENTER ENTRY

EMERGENCY LIGHTS

1ST FLOOR CORRIDOR		EMERGILIT E	
1ST FLOOR MULTIPURPOSE ROOM		LUMACELL	
1ST FLOOR MULTIPURPOSE ROOM		LUMACELL	
1ST FLOOR CENTRE EXIT		EXIT	AC ONLY NO DC BACKUP
STAIRWELL EXIT NEAR MUSIC		EXIT	AC ONLY NO DC BACKUP
1ST FLOOR EXIT NEAR GIRLS BATHROOM		EXIT	AC ONLY NO DC BACKUP
2ND FLOOR STAIRWELL		EMERGILIT E	
2ND FLOOR CORRIDOR		AIMLITE	
CENTER STAIRWELL		AIMLITE	
2ND FLOOR STAIRWELL EXIT		EXIT	
2ND FLOOR CENTRE STAIR EXIT		EXIT	
2ND FLOOR STAIRWELL EXIT		EXIT	AC ONLY NO DC BACKUP/ REPLACED 1X408 BULB
2ND FL STAIR		EMERGILIT E	
BOILER RM		EXIT COMBO	
TANK RM		AIMLITE	

	LOCATION: Shatford Memorial	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex 4008		
2	MAIN HALLWAY REAR	MA	M-1
3	FRONT HALL WEST	MA	M-2
4	EAST MAIN ENTRANCE	MA	M-3
5	EXCEL STAIR	STA	M-4
6	NORTH STORAGE	STA	M-5
7	FRONT ENTRY EAST	STA	M-6
8	OUTSIDE MUSIC ROOM	MA	M-7
9	STAIRS BY MUSIC ROOM	MA	M-8
10	EXCEL STAIR EXIT	MA	M-9
11	MAIN GYM ENTRY	MA	M-10
12	REAR CENTER STAIRS	MA	M-11
13	CHAIR STORAGE	RHT	M-12
14	BASEMENT STORAGE	RHT	M-13
15	CARETAKER OFFICE	RHT	M-14
16	STORAGE UNDER STAIR	RHT	M-15
17	NORTHEND STAIRWELL	STA	M-16
18	SUPPLY RM JANITOR RM LEV 2 NEAR W/R	STA	M-17
19	STAIRS BY MUSIC ROOM	STA	M-18
20	NORTH CLOSET	STA	M-19
21	GYM	MA	M-20
22	FURNACE ROOM	MA	M-21
23	FURNACE ROOM	RHT	M-22
24	OUTSIDE KITCHEN	MA	M-23
25	MAIN HALLWAY FRONT	MA	M-24
26	WEST FRONT ENTRANCE	MA	M-25
27	NURSERY ROOM	MA	M-26
28	RESOURCE ROOM EXIT	MA	M-27
29	FURNACE ROOM STORAGE	RHT	M-28
30	DOOR RELEASE	RELAY	M-29
31	ELECTRICAL ROOM	RHT	M-30
32	PHYS-ED OFFICE	RHT	M-31
33	PHYS-ED STORAGE	RHT	M-32

34	NURSERY ROOM	STA	M-33
35	FRONT STAIRS WEST	STA	M-34
36	ATTIC	STA	M-35
37	ATTIC	RHT	M-36
39	NORTH END	B	SIG 1
40	NORTH HALL NORTH STAIRS	B	SIG 1
41	NORTH HALL REAR BOTTOM HALL	B	SIG 1
42	MAIN HALL NORTHEAST	B	SIG 1
43	MAIN HALL	B	SIG 1
44	FRONT HALL	B	SIG 1
45	GYM	B	SIG 1
46	NURSERY ROOM	B	SIG 1
47	WEST END	B	SIG 1
48	MAIN HALL NORTHEAST	EOL	SIG 1

Location	# of Heads	Model	Notes
STAIRS BY KITCHEN		EMERGILITE	BREAKER (UPPER HALL)
MAIN ENTRANCE EAST		EMERGILITE	
MAIN ENTRANCE WEST		AIMLITE	
MAIN HALL		LUMACELL	
MAIN HALL		EMERGLITE	
GYM		EMERGILITE	BREAKER ADJ. FURNACE RM
GYM REAR		EMERGLITE	
1ST FLR BACK HALL BY GYM		EMERGILITE	
1ST FLR BACK HALL BY LIBRARY		EMERGILITE	
1ST FLR BACK HALL BY MSUCI & FRENCH RM		EMERGILITE	
EAST STAIRS		EMERGILITE	
WEST STAIRS		EMERGILITE	
2ND FLOOR BACK HALL BY WOMENS		EMERGILITE	BULB REQUIRED 6V 9W BAYONET CAP
EXCEL		COMBO UNIT	BULB REQUIRED 6V 9W BAYONET CAP
BACKDOOR STAIRS EXIT RUNNING MAN		UNIT COMBO	NEW
SDIE DOOR STAIRS EXIT RUNNING MAN		UNIT COMBO	NEW
EXIT SIGNS			

EXIT SIGNS			
GYM NEAR		EXIT	NEEDS BATTERY (EX800RC, UNIT NO.)
GYM FAR		EXIT	
STAIRS NEAR GYM		EXIT	
MAIN ENTRANCE		EXIT	
CORR BY STAFF RM		EXIT	
BY LIBRARY		EXIT	
BY MUSIC RM		EXIT	
IN STAIRS BY MUSIC RM		EXIT	
TOP OF STAIRS BY ART RIGHT HAND SIDE		EXIT	
TOP OF STAIRS BY ART LEFT HAND SIDE		EXIT	
MAIN ENTRANCE EAST EXIT RUMMING MAN UNIT		EXIT	NEW
EXIT FRONT CORR LEFT		EXIT	
EXIT COMBO BOTTOM FRONT LEFT CLASSRM		EXIT	

	LOCATION: Bay View High	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards QS4		
1ST/MAIN FLOOR			
MANUAL PULL STATIONS			
1	WEST WATER ROOM (OUTSIDE)	MA	126
2	ADJ TO WEST STAIR 1001	MA	127
3	OUTSIDE STORAGE RM 1071	MA	132
4	GYM RM 1043 EXIT#3	MA	133
5	GYM RM 1043 EXIT#2	MA	134
6	GYM RM 1043 EXIT#1	MA	135
7	GYM ENTRANCE RM 1043	MA	136
8	ADJ TO RM 1026 SEMINAR RM	MA	137
9	LIBRARY RM 1072 EXIT #2	MA	138
10	LIBRARY RM 1072 EXIT #1	MA	139
11	MAIN ENTRANCE	MA	140
12	LANGUAGE CLASSROOM 1116	MA	141
13	ALTERNATE EDUCATION RM 1106	MA	142
14	1084 PRODUCTION TECH AREA	MA	143
15	1086 BOILER/SPRINKLER RM	MA	144
16	1085 BOTTOM OF EAST STAIRS	MA	145
17	1070 CAFETERIA EXIT	MA	146
18	BY CLASSROOM 19/ RM 1130	MA	171
19	MUSIC RM 1109	MA	172
SMOKE DETECTORS			
1	STORAGE RM 1005	SMK	1
2	REC STORAGE RM 1051 SMK/ STUDENT COUNSELOR OFFICE	SMK	2
3	GYM STORAGE RM 1045	SMK	3
4	KITCHEN STORAGE RM 1075	SMK	4
5	STORAGE RM 1108	SMK	6
6	STORAGE RM 1127	SMK	7
HEAT DETECTORS			
1	BOILER RM 1086 HEAT	RHT	5
2	BOILER RM 1086 HEAT	RHT	41
2ND FLOOR			
MANUAL PULL STATIONS			
3	MECH RM 2047	MA	173

4	ADJ TO PHYSICS LAB RM 2058	MA	184
5	ADJ TO CLASSROOM 32 2075	MA	185
1	ADJ TO 2002 CLASSROOM 20	MA	188
2	ADJ TO VISUAL ARTS RM 2027	MA	189

SMOKE DETECTORS

1	TOP OF STAIRS BY RM 2048	SMK	8
2	MAIN ELECTRICAL RM 2049	SMK	9
3	TOP OF SOUTH/EAST STAIRS	SMK	10
4	COMM / SERVER RM 2059	SMK	11
5	ELEC RM 2073	SMK	12
6	TOP OF EAST STAIRS (2077)	SMK	13
7	REC RM 2046	SMK	14
8	STORAGE RM 2065	SMK	15
9	2001 WEST STAIRS	SMK	18
10	STORAGE RM 2006	SMK	19
11	COMM RM 2017	SMK	20
12	TOP OF SOUTH WEST STAIRS	SMK	21
13	ELEC RM 2026	SMK	22
14	ELEVATOR LOBBY	SMK	23

NOTIFYING DEVICES

1ST FLOOR

	BY CLASSROOM 1130	HV	
	BY CLASSROOM 1122	HV	
	BY CLASSROOM 1116	HV	
	IN MUSIC RM 1109	HV	
	BY CLASSROOM 1107	HV	
	BY CLASSROOM 1092	HV	
	ACROSS FROM RM 1077	HV	
	IN PRODUCTION TECH RM 1084	HV	
	CAFETERIA BY DRAMA RM 1047	HV	
	CAFETERIA	HV	
	GYM	HV	
	GYM	HV	
	GYM	HV	
	MAIN OFFICE BY 1095	HV	
	STUDENT SERVICES RM 1052	HV	
	BY ELEVATOR MAIN LOBBY	HV	
	LIBRARY	HV	
	GYM BY GIRLS CHANGE RM	HV	
	GYM BY BOYS CHANGE RM	HV	
	BOYS CHANGE RM	HV	
	GIRLS CHANGE RM	HV	
	OUTSIDE TEEN HEALTH CENTER	HV	

	BY CLASSROOM 1013	HV	
	BY CLASSROOM 1003	HV	
	WATER TREATMENT RM (OUTSIDE)	HV	
	WATER TREATMENT RM (OUTSIDE)	EOL	
2ND FLOOR			
	BY RECYCLING 2005	HV	
	BY RECYCLING 2005	EOL	
	BY CLASSROOM 2013	HV	
	ACROSS FROM RM 2016	HV	
	NEAR RM 2024	HV	
	OUTSIDE RM 2034	HV	
	MEZZANINE MAIN LOBBY	HV	
	NEAR RM 2045	HV	
	BY CLASSROOM 2046	HV	
	IN ELECTRICAL RM 2049	HV	
	MECH RM 2047	HV	
	MECH RM 2047	HV	
	NEAR RM 2057	HV	
	BY CLASSROOM 2063	HV	
	BY CLASSROOM 2068	HV	
	BY CLASSROOM 2075	HV	
	BY CLASSROOM 2075	EOL	

EMERGENCY LIGHTING		
Location	# of Heads	Model
BOTTOM WESTERN STAIRWELL		AIM-LITE
MIDDLE WEST STAIRWELL		REMOTE
TOP WEST STAIRWELL		REMOTE
BY RM 1008		AIM-LITE
BY RM 1002		REMOTE
BY RM 1010		REMOTE
BY RM 1014		REMOTE

BY RM 1016		AIM-LITE
STAFF WASHRM BY 1016		REMOTE
BOYS WASHRM BY 1016		REMOTE
HANDICAP WASHRM BY 1016		REMOTE
SOUTH WEST STAIR		AIM-LITE
OUTSIDE GYM ENTRY		AIM-LITE
GYM ENTRY		REMOTE
INSIDE GYM ENTRY		REMOTE
BY RM 1026		REMOTE
BY CHANGE RM 1032		REMOTE
GIRLS CHANGE RM 1032		UNIT
GIRLS CHANGE RM 1032		REMOTE
BY CHANGE RM 1042		REMOTE
BOYS CHANGE RM 1042		AIM-LITE
BOYS CHANGE RM 1042		REMOTE
BOYS CHANGE RM 1042		REMOTE
OUTSIDE OFFICE		REMOTE
OUTSIDE LIBRARY		REMOTE
MAIN ENTR AREA BY ELEV		REMOTE

MAIN ENTR AREA BY ELEV		REMOTE
HALLWAY TO CAFETERIA		AIM-LITE
GIRLS WASHRM BY CAFETERIA #12		REMOTE
GIRLS WASHRM BY CAFETERIA		REMOTE
CAFETERIA		AIM-LITE
CAFETERIA		REMOTE
CAFETERIA		REMOTE
KITCHEN		AIM-LITE

Location	# of Heads	Model	(
INSIDE MAIN DOORS #19		AIM-LITE	
MAIN ENTR DOORS BY OFFICE		REMOTE	
MAIN ENTR BY STUDENT COUNCIL		REMOTE	
LIBRARY		REMOTE	
BY RM 1091 #11		AIM-LITE	
BY OFFICE 1090		AIM-LITE UNIT	
BOYS WASHRM ACROSS FROM 1106		REMOTE	
BY RM 1077		REMOTE	
BY 1070 CAFETERIA		AIM-LITE	

DOORS		
EXIT BY CAFETERIA SIDE EXIT #13		AIM-LITE
BY RM 1101 STAFF RM		AIM-LITE
STAFF RM WASHRM		REMOTE
STAFF RM WASHRM		REMOTE
BY RM 1114		REMOTE
BY RM 1109 MUSIC RM #15		UNIT
BY RM 121		REMOTE
BY RM 1123		REMOTE
BY RM 1125		REMOTE
BY RM 1129		REMOTE
SOUTH/EAST STAIRWELL #14		UNIT
OUTSIDE RM 1050 DRAMA RM		REMOTE
BEHIND STAGE/RM 1047 DRAMA		AIM-LITE
EAST STAIRWELL		AIM-LITE
BOILER RM #32		AIM-LITE
BOILER RM ENTR		REMOTE
BOILER RM		REMOTE
BACK STAIRWELL EXIT FROM ELEC RM 2049		REMOTE
TEEN HEALTH CTR		REMOTE

WASHRM		
PRODUCTION TECH RM 1084		REMOTE
PRODUCTION TECH RM 1094		REMOTE
GYM		REMOTE
GYM REAR EXIT		AIM-LITE
GYM SIDE EXIT		REMOTE

Location	# of Heads	Model
GYM SIDE EXIT BY MAIN ENTRY		REMOTE
EQUIPMENT RM		REMOTE
2ND FLOOR		
BOTTOM EAST STAIR		AIM-LITE
MIDDLE EAST STAIR		REMOTE
TOP EAST STAIR		REMOTE
STORAGE RM 2065		REMOTE
BY RM 2071		AIM-LITE
ELEC RM 2073		REMOTE
BY RM 2076		REMOTE
BY RM 2062		REMOTE

SERVER RM 2059/IN RM 2060		AIM-LITE
SOUTH/EAST STAIRWELL		REMOTE
SOUTH/EAST STAIRWELL		REMOTE
BY RM 2063		AIM-LITE
BY RM 2058		REMOTE
BY RM 2057		REMOTE
BY RM 2062		REMOTE
MECH RM 2047		AIM-LITE
MECH RM 2047 (REAR)		AIM-LITE
ELEC RM 2049		AIM-LITE
OUTSIDE ELEC RM 2049 (BEHIND RM 2047)		REMOTE
EAST BOYS WASHRM ENTRY		AIM-LITE
EAST BOYS WASHRM		REMOTE
EAST GIRLS WASHRM ENTRY		REMOTE
EAST GIRLS WASHRM		REMOTE
OUTSIDE WASHRM EAST WING		AIM-LITE
BY RM 2039		REMOTE
BY RM 2042		REMOTE

MAIN STAIRWELL		REMOTE
ELEV RM 2035		AIM-LITE
OUTSIDE RM 2029		REMOTE
BY RM 2032		REMOTE
OUTSIDE RM 2029 VIS ARTS		REMOTE

Location	# of Heads	Model
MAIN MEZZ BY 2029		LUMACELL
MAIN MEZZ		REMOTE
BY RM 2052		REMOTE
BY RM 2051/JANITOR RM		REMOTE
BATHROOM BY 2051		REMOTE
WEST GIRLS WASHRM ENTRY		AIM-LITE
WEST GIRLS WASHRM		REMOTE
WEST BOYS WASHRM ENTRY		REMOTE
WEST BOYS WASHRM		REMOTE
OUTSIDE WASHRMS WEST WING		AIM-LITE
LEV 2 HANDICAP WASHRM		REMOTE
RM 2022		REMOTE

ELEC RM 2026		UNIT
SOUTH/WEST STAIRWELL		REMOTE
SOUTH/WEST STAIRWELL		REMOTE
SOUTH/WEST STAIRS		UNIT
COMM RM 2017		UNIT
BY RM 2024		REMOTE
BY RM 2017		REMOTE
BY RM 2008		UNIT
BY RM 2014		REMOTE
BY RM 2010		REMOTE
BY RM 2002		REMOTE

	LOCATION: Tantallon Jr. PR-2
	FIRE ALARM PANEL: Edwards FS 1004
	FIRE ALARM DEVICES

Location Description	Device	Zone / Circuit #
SOUTH END 1ST FLOOR BY RM 101	M	1
MAIN ENTRANCE	M	1
GYM	M	2
ENTRANCE BY GYM SIMPLEX	M	2
NORTH END 1ST FLOOR BY RM 115	M	2
BOILER ROOM	M	2
SOUTH END 2ND FLOOR BY LIBRARY	M	3
NORTH END 2ND FLOOR BY RM 213	M	4
SOUTH STAIRWELL	S	3
NORTH STAIRWELL	S	4
FAN ROOM 2ND FLOOR	DUCT	5
FAN ROOM 2ND FLOOR	DUCT	5
GYM	H/S	2
HALL 1ST FLOOR	H/S	2
HALL 1ST FLOOR	H/S	2
HALL 1ST FLOOR	H/S	2
1SR FLOOR GIRLS WASHROOM	H/S	2
1ST FLOOR BOYS WASHROOM	H/S	2
BOILER ROOM	H/S	2
2ND FLOOR BOYS WASHROOM	H/S	2
2ND FLOOR GIRLS WASHROOM	H/S	1
HALL 2ND FLOOR	H/S	1
HALL 2ND FLOOR	H/S	1
SPRINKLER - LOW WATER	SUPV	10
SPRINKLER	FLOW	7

Note: Sprinkler-low water EOL Zone 10

Fire Door Number or Location

MAIN ENTRANCE LEFT

MAIN ENTRANCE RIGHT

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model
	BOYS WASHRM X 2		REMOTE
	GIRLS WASHRM X 2		REMOTE
	GYM ENTRANCE		REMOTE
	MAIN ENTRANCE		REMOTE
	SOUTH END		REMOTE
	BOILER RM		REMOTE
	BY BOILER RM		REMOTE
	BOTTOM STAIRS #2		REMOTE
	BOTTOM STAIRS #1		REMOTE
	GYM		REMOTE
	GYM		REMOTE
	GYM		REMOTE
	GYM		REMOTE
	2ND FL JAN. RM		UNIT
	2ND FL BOYS WASHRM X 2		
	2ND FL GIRLS WASHRM X 2		
	2ND FL HALL		REMOTE
	2ND FL HALL		REMOTE
	TOP STAIRS #2		
	TOP STAIRS #1		REMOTE
	1ST FL JAN. RM		UNIT
	ELEC RM IN BOILER RM		COMBO
	BOILER RM EXIT		COMBO
	GYM STAGE	2	COMBO
	STAIRS BACK STAGE	1	REMOTE
	BACK STAGE	2	REMOTE

	LOCATION: Five Bridges	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards EST 2		
1	1ST FLOOR		
2	1ST FL SOUTH PULL STATION	MA	205
3	KITCHEN EXIT	MA	229
4	1ST EAST EXIT PULL STATION	MA	225
5	1ST FL CENTER STAIRS	MA	216
6	1ST FL NORTH STAIR PULL STATION	MA	208
7	1FL NEAR MUSIC ROOM PULL STATION	MA	209
8	1ST FL WEST AHU ROOM PULL STATION	MA	210
9	KITCHEN STORAGE	SA	115
10	1ST FL LOBBY SMOKE	SA	129
11	1ST FL LOBBY TO WEST SMOKE	SA	128
12	1ST FL WEST SERVER RM 141	SA	125
13	1ST FL MAIN ELECTRICAL ROOM	SA	108
14	1ST FL MAIN ELECTRICAL ROOM REAR	SA	111
15	1ST FL ELECTRICAL CLOSET RM 137	SA	112
16	1ST FL LOBBY TO SOUTH CORRIDOR	SA	126
17	1ST FL FAN ROOM AHU#2 SUPPLY DUCT SMOK	DSA	110
18	1ST FL FAN ROOM AHU#1 SUPPLY DUCT SMOK	DSA	109
19	ELEVATOR ROOM	SA	107
	ELEVATOR PIT	HT	228
20	2ND FLOOR		
21	2ND FL SOUTH CORRIDOR PULL STATION	MA	204
22	2ND FL NORTH STAIRS PULL STATION	MA	207
23	1ST FL MAIN ENTRANCE PULL STATION	MA	203
24	2ND FL WEST STAIR PULL STATION	MA	206
25	2ND FLOOR GYM PULL STATION	MA	211
26	2ND FL SOUTH CORRIDOR ADJ 207 SMOKE	SA	116
27	2ND FL SOUTH CORRIDOR ADJ 217 SMOKE	SA	117

28	2ND FL LOBBY SMOKE	SA	121
29	2ND FL WEST LOBBY CORR ADJ 222 SMOKE	SA	122
30	2ND FL NORTH CORR ADJ 264 SMOKE	SA	124
31	2ND FL WEST CORRIDOR ADJ RM 230 SMOKE	SA	118
32	2ND FL WEST CORRIDOR ADJ RM 233 SMOKE	SA	120
33	2ND FL WEST CORRIDOR ADJ RM 222 SMOKE	SA	123
34	2ND FL ELECTRICAL CLOSET RM 237	SA	113
35	2ND FL IT ROOM	S	130
36	WOODWORKING 1ST FLOOR EXIT	MA	234
	3RD FLOOR		
37	3RD FL CENTER STAIRS PULL STATION	MA	212
38	3RD FL SOUTH STAIR PULL STATION	MA	213
39	3RD FL WEST STAIR PULL STATION	MA	214
40	3RD FL NORTH STAIR PULL STATION	MA	215
41	3RD FL TOP OF MAIN STAIR SMOKE	SA	103
42	3RD FL TOP OF SOUTH STAIR SMOKE	SA	104
43	3RD FL TOP OF WEST STAIR SMOKE	SA	105
44	3RD FL TOP OF NORTH STAIR SMOKE	SA	106
45	3RD FL ELECTRICAL CLOSET RM 332	SA	114
46	3RD FL ROOF FAN AREA	DSA	
47	3RD FL ROOF FAN AREA	DSA	
49	SPRINKLER DEVICES		
50	LOW WATER TANK#2	SV	238
51	LOW WATER TANK#1	SV	218
52	MAIN GATE VALVE	SV	237
53	GATE VALVE TANK #1	SV	237
54	GATE VALVE TANK #2	SV	237
55	SPRINKLER ROOM FLOW	FSP	217
57	RELAYS		
58	EXHAUST FAN SHUT DOWN DISH WASHER	AUX	231
59	AHU'S SHUTDOWNS	AUX	227
60	FAN DOOR RELAY	AUX	220
	DOOR HOLDERS		
61	ELEVATOR RECALL	DH	
64	1ST FL SOUTH STAIRS	DH	
65	2ND FL SOUTH STAIRS	DH	
66	3RD FL SOUTH STAIRS	DH	

67	1ST FL CORR TO WEST	DH	
68	2ND FL CORR TO WEST	DH	
69	3RD FL CORR TO WEST	DH	
70	1ST FL WEST STAIRS	DH	
71	2ND FL WEST STAIRS	DH	
72	3RD FL WEST STAIRS	DH	
73	1ST FL MENS WASHROOM	DH	
74	2ND FL CORR TO NORTH	DH	
75	3RD FL CORR TO NORTH	DH	
76	1ST FL NORTH STAIRS	DH	
77	2ND FL NORTH STAIRS	DH	
78	3RD FL NORTH STAIRS	DH	
80	HORN STROBES		
81	1ST FL BOYS WASHROOM	HS	
82	1ST FL GIRLS WASHROOM	HS	
83	1ST FL BY RM 152	HS	
84	1ST FL CENTER LOBBY	HS	
85	1ST FL CORR BY RM 124	HS	
86	CAFETERIA 1ST FL	HS	
87	1ST FL SERVICE WATER TANK AREA	HS	
89	GYM 2ND FL	HS	
90	2ND FL CORR BY MALE CHANGE RM	HS	
91	MENS LOCKER RM	HS	
92	FEMALES LOCKER RM	HS	
93	2ND FL CORR BY RM 219	HS	
94	2ND FL MENS WASHROOM	HS	
95	2ND FL WOMENS WASHROOM	HS	
97	3RD FL MENS WASHROOM	HS	
98	3RD FL WOMENS WASHROOM	HS	
99	3RD FL CORR BY RM 316	HS	
100	3RD FL CORR BY RM 334	HS	
101	3RD FL CORR CENTER STAIRS	HS	
102	3RD FL CORR BY RM 300	HS	
103	1ST FL KITCHEN	HS	
104	1ST FL MUSIC ROOM	B	

EMERGENCY LIGHTING			
Line #	EL UNIT Location	Remote	Cab. Head
1	TOP OF STAIRS LEFT 3RD FL		6V 7AH
2	BY ROOM 300 3RD FLOOR		6V 7AH
3	BY ROOM 303 3RD FLOOR		6V 7AH

4	TOP OF CENTER STAIRS 3RD FL		6V 7AH
5	3RD FL NEAR RM337		6V 7AH
6	3RD FL NEAR RM334		6V 7AH
7	TOP OF STAIRS NEAR 335 3RD FL		6V 7AH
8	3RD FL BY WASHROOM		6V 7AH
9	3RD FL ACROSS FROM 314		6V 7AH
10	3RD FL BY 322		6V 7AH
11	3RD FL STAIRS BY 319		6V 7AH
12	3RD FLOOR BY BOYS W/R		6V 7AH
13	3RD FLOOR WOMENS W/R		6V 7AH
14	3RD FLOOR BY LIBRARY		6V 7AH
15	STAIRWELL BY ROOM 300		6V 7AH
1	STAIRS BY 256		6V 7AH
2	2ND FL BY ROOM 261		6V 7AH
3	2ND FL BY ROOM 263B		6V 7AH
4	2ND FL NEAR WASHROOMS		6V 7AH
5	2ND FL MAIN ENTRANCE		6V 7AH
6	2ND FL BOYS WASHROOM		6V 7AH
7	2ND FLOOR CORR TO ELEVATOR		6V 7AH
8	2ND FL CENTER STAIRS		6V 7AH
9	2ND FL NEAR 219	Y	
10	2ND FL CENTER OFFICE		6V 7AH
11	OFFICE BY WASHROOM	Y	
12	2ND FL CORR BY 222		6V 7AH
13	2ND FL CORR BY 231		6V 7AH
14	2ND FL CORR BY 230	Y	
15	2ND FL STAIRS BY 233		6V 7AH
16	2ND FL CORR BY GYM/ELECTRICAL ROOM		6V 7AH
17	2ND FL CORR BY GYM/OFFICE	Y	
18	2ND FL STAIRS BY FEMALE CHANGE RM		6V 7AH
19	2ND FL GYM		6V 7AH
20	2ND FL GYM		6V 7AH
21	2ND FL GYM LEFT OF EMG EXIT		6V 7AH
22	2ND FL STAGE RIGHT GYM		6V 7AH
23	2ND FL ACROSS FROM 252		6V 7AH
24	2nd FLOOR GIRLS WASHROOM		6V 7AH
1	STAIRS BY CAFT .1ST FLOOR		6V 7 AH
2	1ST FL BY ROOM 106		6V 7 AH
3	1ST FL BY ROOM 124		6V 7 AH
4	1ST FL CORR TO STAFF RM		6V 7 AH
5	1ST FL CENTER STAIRS		6V 7 AH
6	1ST FL CENTER STAIRS		6V 7 AH
7	1ST FL CORR TO ELEV		6V 7 AH

8	1ST FL MALE WASHROOM		6V 7 AH
9	1ST FL FEMALE WASHROOM		6V 7 AH
10	1ST FL CORR BY WASHROOMS		6V 7 AH
14	1ST FL SERVICE CORR BY BOILER RM		6V 7 AH
15	1ST FL BOILER RM		6V 7 AH
16	ENTRANCE TO BOILER RM	Y	
17	SPRINKLER TANK RM		6V 7 AH
18	SERVICE CORR BY ELECT VAULT		6V 7 AH
19	WATER TANK ROOM		6V 7 AH
20	ELECTRICAL VAULT		6V 7 AH
21	FAN ROOM 1ST FLOOR		6V 7 AH
22	ELECTRICAL VAULT		6V 7 AH
23	HOME ECK CLASSROOM 118		6V 7 AH
24	HOME ECK CLASSROOM 118	Y	
25	SERVICE ENTRANCE		6V 7 AH
26	HOT WATER TANK ROOM		6V 4.5 AH
27	SERVER ROOM		6V 7 AH

HOT WATER TANK ROOM			
SERVER ROOM			
CAFETERIA			
CORRIDOR BY ROOM 143			
CORRIDOR BY ROOM 145			
BOTTOM NORTH STAIRWELL @ 108			
STAIR AT 147			
CAFETERIA		REMOTE	
1ST FLOOR WOODWORKING		AIMLITE	
1ST FLOOR WOODWORKING		COMBO	
1ST FLOOR FAN ROOM		LUMACELL (UNIT)	
1ST FLOOR BAND DOOR		CEILING UNIT (BATTERY)	
1ST FLOOR CORRIDOR BY ROOM 225		UNIT	
1ST FLOOR STAIRS BY CAFETERIA		UNIT	
FAN ROOM			

CLASSROOM		UNIT	
-----------	--	------	--

	LOCATION: Beechville Lakeside Timberlea 3-5 Annex	Device	Device address or circuit number
	FIRE ALARM PANEL: Edwards FS		

MANUAL PULL STATIONS

1	GYM	M	ZN 1
2	GYM	M	ZN 1
3	GYM EXIT	M	ZN 1
4	FURNACE RM	M	ZN 2
5	HOME EC. RM (THROUGH RM 200)	M	ZN 3
6	WEST HALL 2ND FLOOR	M	ZN 4
7	EAST HALL 2ND FLOOR	M	ZN 4
8	MAIN ENTRANCE	M	ZN 6
9	EAST HALL ACROSS FROM RM 101	M	ZN 6
10	WEST HALL 1ST FLOOR BY ROOM 108	M	ZN 6

SMOKE DETECTORS

1	HALLWAY 2ND FLOOR	S	ZN 4
2	HALLWAY BY ROOM 106	S	ZN 6
34	EAST STAIRWELL 2ND FLOOR	S	ZN 8
4	WEST STAIRWELL 2ND FLOOR	S	ZN 7

DUCT SMOKE DETECTORS

1	FAN RM	DS	ZN 3
---	--------	----	------

HEAT DETECTORS

1	FURNACE RM	HT	ZN 2
2	FURNACE RM	HT	ZN 2
3	ELECTRICAL RM	RHT	ZN 2
4	FAN RM	RHT	ZN 3
5	SEWING RM STORAGE BY COOKING	RHT	ZN 3
6	COOK RM STORAGE	RHT	ZN 3
7	202 GAME STORAGE / LEARNING CTR	RHT	ZN 4
8	BOOK STORAGE 2ND FLOOR	RHT	ZN 4
9	JANITOR'S RM 2ND FLOOR	RHT	ZN 4
10	LIBRARY STORAGE 2ND FLOOR	RHT	ZN 4
11	ART ROOM 1ST FLOOR	RHT	ZN 6
12	ART ROOM 1ST FLOOR	RHT	ZN 6
13	CARETAKER'S OFFICE	RHT	ZN 6
14	GYM STORAGE	RHT	ZN 6
15	STORAGE RM BY EAST STAIRWELL 1ST	RHT	ZN 6

NOTIFYING APPLIANCES

1	MAIN ENTRANCE	B	SIG 1
2	EAST HALL 1ST FLOOR	B	SIG 1
3	GYM	B	SIG 1
4	GYM	B	SIG 1
5	FURNACE RM	B	SIG 1
6	WOODSHOP 1ST FLOOR	B	SIG 1
7	METAL SHOP 1ST FLOOR	B	SIG 1
8	COMPUTER RM 1ST FLOOR	B	SIG 1
9	WEST HALL 1ST FLOOR	B	SIG 1
10	EAST HALL 2ND FLOOR	B	SIG 1
11	STAFF ROOM 2ND FLOOR	B	SIG 1
12	WEST HALL 2ND FLOOR	B	SIG 1
13	HOME EC.	B	SIG 1
48	OLD BOY'S CHANGE ROOM	RHT	ZN 6
49	OLD GIRL'S CHANGE ROOM	RHT	ZN 6

Fire Door Number or Location
MAIN LOBBY BY WEST STAIRS
MAIN LOBBY ENTRY TO CORRIDOR
2ND LEVEL TOP OF WEST STAIRS
2ND LEVEL TOP OF EAST STAIRS
2ND LEVEL MIDDLE CORRIDOR
1ST LEVEL BOTTOM STAIR WEST
1ST FLOOR BY MEN'S WASHROOM - Right Door Failed

EMERGENCY LIGHTING				
Line #	EL UNIT Location	Remote Head	Cab. Head	Bat. VAH
1	GYM (LEFT OF STAGE)		Y	
2	GYM (RIGHT OF STAGE)		Y	
3	MAIN ENTRANCE	Y		
4	EAST STAIRWELL	Y		
5	WEST STAIRWELL	Y		
6	2ND FLOOR HALL	Y		
7	2ND FLOOR HALL	Y		
8				
9	HALLWAY OUTSIDE 202	Y		
	HALLWAY OUTSIDE 208	Y		

	LIBRARY		Y	
	ROOM 202 STORAGE			
	CAFETERIA EXIT BY GYM		Y	6V 7AH
	CAFETERIA EXIT TO HALL		Y	6V 7AH
	GYM EXIT BY CAFÉ		Y	
	PANEL IN GYM CCT # 4,18,19,25		Y	
	BY ROOM 101		Y	
	BOYS DOWN		Y	
	BOYS UP		Y	
	GIRLS DOWN		Y	
	GIRLS UP			
	METAL SHOP		Y	
	BOOK STORAGE BY RM 209			
	Breaker #4 panel in book room storage turns on 1/2 2nd fl. hallway			

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

2nd West Stair, Storage 202 and West Hallway 208 all connected by Storage 202.

2nd East Hall 202 and Stairs connected FUL cct 21.

	LOCATION: Tantallon 3-6	Device	Device address or circuit number
	FIRE ALARM PANEL: Simplex 4100U		
1	Gym BY STAGE RIGHT	M	1
2	Gym, MAIN ENTRY	M	1
3	Gym, LEFT STAGE AREA	M	1
4	NORTH END 1ST FLR BY MAIN ELEC RM	M	3
5	FRONT ENTRY	M	3
6	BOILER ROOM	M	4
7	TOP OF WHEELCHAIR RAMP	M	5
8	NORTH END 2ND FLOOR	M	5
9	LEARNING CENTRE ROOM	M	2
10	SOUTH END 2ND FLOOR	M	5
SMOKE DETECTORS			
1	FIRST FLOOR HALL	SI	ZONE 3
2	NORTH STAIRWELL, MAIN	STTA	6
3	SOUTH STAIRWELL	STTA	7
4	HALL 2ND FLOOR	SI	5
HEAT DETECTORS			
3	ROOM 134(PHYS ED TEACHER)	RHT	ZONE 3
4	CAFETERIA STORAGE	RHT	ZONE 3
5	EXCEL ROOM STORAGE #1	RHT	ZONE 3
6	EXCEL ROOM STORAGE #2 BY RM 152	RHT	ZONE 3
7	JANITORS ROOM 102	RHT	ZONE 3
8	1ST FLOOR CARETAKERS OFFICE	RHT	ZONE 4
9	BOILER ROOM	HT	ZONE 4
10	ELECTRICAL ROOM	RHT	ZONE 4
11	BOILER ROOM	HT	ZONE 4
12	BOILER ROOM STORAGE	RHT	ZONE 4
13	ROOM 214 JANITOR CLOSET	RHT	5
14	JANITORS ROOM 228	RHT	5
15	LIBRARY STORAGE 225	HT	5
17	WHEELCHAIR RAMP, TOP	RHT	5
18	WHEELCHAIR RAMP, NEAR TOP	RHT	5

19	WHEELCHAIR RAMP, CENTER UP LEV	RHT	5
20	WHEELCHAIR RAMP, CENTER	RHT	5
21	WHEELCHAIR RAMP, LOWER CENTER	RHT	5
22	WHEELCHAIR RAMP, BOTTOM	RHT	5
23	FAN ROOM	HT	5
24	ROOM 152 BACK STORAGE	RHT	5
25	ROOM 235 STORAGE	RHT	2
26	ROOM 236 STORAGE	RHT	2
27	AV STORAGE	RHT	5

NOTIFYING DEVICES

1	HALL FIRST FLOOR	B	SIG 1
2	HALL FIRST FLOOR	B	SIG 1
3	MAIN ENTRY	B	SIG 1
4	GYM EXIT	B	SIG 1
5	GYM	B	SIG 1
6	HALL SECOND FLOOR	B	SIG 1
7	HALL SECOND FLOOR	B	SIG 1
8	STAFF ROOM	B	SIG 1
9	COOKING 234	B	SIG 1
10	SEWING 234	B	SIG 1
11	WOOD SHOP	B	SIG 1
12	BOILER ROOM	B	SIG 1

EMERGENCY LIGHTING			
Line#	EL UNIT Location	Remote	Cab.Head
	MAIN ELECTRICAL ROOM, PNL "C", CCT # 21		
1	MAIN ENTRANCE		
2	BY ROOM 113		
3	BY ROOM 110		
4	BY ROOM 109		
5	BY ROOM 102		
#	CAFETERIA ENTRANCE		
#	CAFETERIA EXIT		
	IN FAN ROOM CCT #3		
6	TOP FLR BY 232		
7	SIDE STAIRWELL		
	ACROSS FROM 206		
	IN ROOM 214, CCT#9		
8	BY LIBRARY		
#	ACROSS FROM 210		

#	FRONT STAIRWELL		
	IN AV ROOM 222, CCT# 21		
9	IN ROOM 222 AV ROOM		
	GYM BREAKER PANEL		
#	GYM DOOR		COMBO
	GYM HALL DOOR LEFT		UNIT
#	GYM HALL DOOR RIGHT		UNIT
	UNKNOWN BREAKER		
#	MIDDLE OF RAMP		
	TOP OF RAMP		
	EXIT AT BOTTOM OF RAMP		
#	BOTTOM OF RAMP		
	BOILER ROOM , CCT# 17		
#	BOILER ROOM		
	EXIT REAR GYM		EXIT COMBO
	RM THROUGH 152 UNIT #19		
	IN RM 122 #12		
	RM 152		
	BY MAIN OFFICE		UNIT
	STAGE RIGHT		UNIT
	STAGE BACK RIGHT		REMOTE
	STAGE BACK LEFT		REMOTE
	STAGE LEFT		REMOTE
	ELECT RM		AIMLITE
	RM 102		AIMLITE
	OFFICE		EMERGILITE

	LOCATION: Grosvenor Wentworth	Device	Device address or circuit number
FIRE ALARM PANEL: Edwards 6500			
MANUAL PULL STATIONS			
1	FIRE PANEL EXIT	M	ZONE 1
2	MAIN ENTRANCE	M	ZONE 1
3	SOUTH EXIT TO PARKING	M	ZONE 1
4	TOP OF RAMP	M	ZONE 1
5	SPRINKLER ROOM	M	ZONE 1
6	EXIT BY AV ROOM	M	ZONE 2
7	GYM HALL BY PHYS. ED. ROOM	M	ZONE 2
8	GYM	M	ZONE 2
9	GYM	M	ZONE 2
12	GYM	M	ZONE 2
10	EXIT BY ROOM 118	M	ZONE 2
11	BOILER ROOM	M	ZONE 3
SMOKE DETECTORS			
1	ELECTRICAL ROOM	S	ZONE 2
HEAT DETECTORS			
3	TEACHERS ROOM	RHT	ZONE 1
4	TEACHERS ROOM WASHROOM	RHT	ZONE 1
5	COMPUTER ROOM	RHT	ZONE 1

6	STORAGE BY COMPUTER ROOM	RHT	ZONE 1
7	STAFF WASHROOM	RHT	ZONE 1
8	PRIVATE WASHROOM IN GIRLS WASHROOM	RHT	ZONE 1
9	SPRINKLER ROOM	RHT	ZONE 1
10	READING RECOVERY CLOSET	RHT	ZONE 1
1	BOILER ROOM LEFT	HT	ZONE 3
2	BOILER ROOM RIGHT	HT	ZONE 3

SPRINKLER DEVICES

1	SPRINKLER ROOM PRESSURE ALARM\	FSP	ZONE 1
2	SPRINKLER ROOM MAIN CONTROL VALVE	SV	ZONE 1

NOTIFYING DEVICES

1	SOUTH HALL	B	SIG 1
2	TOP OF RAMP MID HALL	B	SIG 1
3	MAIN ENTRANCE	B	SIG 1
4	BY LIBRARY	B	SIG 2
5	BY ROOM 116	B	SIG 2
6	BY AV ROOM	B	SIG 2
7	GYM HALL	B	SIG 2
8	GYM HALL	B	SIG 2
9	GYM	B	SIG 2
10	GYM	B	SIG 2
11	ABOVE FIRE PANEL	H/V	N/A

END OF LINE RESISTORS

1	BY ROOM 116	EOL	SIG 2
2	TOP OF RAMP	EOL	ZONE 1
3	EXIT BY ROOM 118	EOL	ZONE 2
4	BOILER ROOM	EOL	ZONE 3

FIRE ALARM NOTES AND RECOMMENDATIONS

	Pressure Flow Switch In Sprinkler Room Is Tied Directly To Horn/Strobe Located Above(BLUE IN COLOR)
--	---

EMERGENCY LIGHTING

Location	# of Heads	Model	
SOUTH EXIT ADJ ROOM #10		LUMACELL RG38-LMC	
SOUTH HALL BY OFFICE		LUMACELL RG38-LMC	
BY OFFICE		LUMACELL RG38-LMC	
BY FIRE PANEL		LUMACELL RG38-LMC	
BY TEACHERS ROOM		LUMACELL RG38-LMC	
TOP OF RAMP		LUMACELL RG38-LMC	
EXCEL		LUMACELL RG38-LMC	
JANITOR ROOM BATTERY PAK		EMERGI-LITE	
ELECTRICAL ROOM		REMOTE	
BY ROOM 114		LUMACELL RG38-LMC	
BY ROOM 118		EMERGI-LITE JML 36 2	
LIBRARY HALL BATTERY PAK		DUAL LITE COMBO	
LIBRARY HALL		REMOTE	
AV EXIT BATTERY PAK		EMERGI-LITE 6 JML 36	
AV AREA		REMOTE	
JANITOR ROOM BATTERY PAK		DUAL LITE LDS 160	
GYM HALL FAR END		REMOTE	
PORTABLE #1		COMBO UNIT	
PORTABLE #1		COMBO UNIT	
BOYS CHANGE ROOM		EMERGI-LITE 6 JML 36	
GYM HALL		REMOTE	
GIRLS CHANGE ROOM		EMERGI-LITE 6 JML	

ROOM		DATE 2016 36
GYM STORAGE BATTERY PAK		DUAL LITE LDS 180
GYM BY STORAGE ROOM		REMOTE
GYM ADJ GIRLS CHANGE ROOM		DUAL LITE LDS 180
GYM REAR EXIT LHS		LUMACELL RG36
BOILER ROOM		UNIT
SPRINKLER ROOM		LUMACELL RG36
PORTABLE 1		COMBO X 2
ELEC RM		REMOTE
PORTABLE 2		COMBO X 2
LIBRARY HALL AT MILK FRIDGE		AIMLITE

	LOCATION: Rocky Lake Elementary FIRE ALARM PANEL: Mirtone	Device	Device address or circuit number	Annunciation

MANUAL PULL STATIONS

1	NORTH END 2ND FLOOR/BY LIBRARY	M	Zone #7	
2	CENTER STAIRS 2ND FLR/BY GIRLS W/R	M	Zone #7	
3	SOUTH END 2ND FLOOR/BY BAND ROOM	M	Zone #7	
4	CENTER STAIRS 3RD FLR/BY GIRLS W/R	M	Zone #8	
5	NORTH END 3RD FLOOR/ BY ROOM 301	M	Zone #8	
6	SOUTH END 3RD FLOOR/ BY ROOM 310	M	Zone #8	
7	NORTH END 1ST FLOOR/BY GYM ENTRY	M	Zone #11	
8	MAIN ENTRANCE	M	Zone #11	
9	BACK STAIRS 1ST FLOOR/BY ROOM 106	M	Zone #11	
10	CENTER STAIRS 1ST FLOOR	M	Zone #11	
11	CAFETERIA	M	Zone #11	
12	GYM	M	Zone #12	
13	DRAFTING EXIT BY ELECTRICAL ROOM	M	Zone #13	
14	BASEMENT HALL EXIT	M	Zone #13	
15	BOILER ROOM	M	Zone #14	

SMOKE DETECTORS

1	1ST FLOOR NORTH HALL BY ROOM 106	SI	Zone #1	
2	2ND FLOOR BY CENTER STAIRS	SI	Zone #2	
3	CENTER STAIRS BY GIRLS WASHROOM	SI	Zone #8	
4	NORTH STAIRS BY ROOM 300	SI	Zone #8	
5	SOUTH STAIRS BY ROOM 309	SI	Zone #8	
6	BACK STAIRS BY GYM ENTRY	SI	Zone #11	
7	ELEVATOR SHAFT	SI	Zone #15	
8	ELEVATOR MECH. ROOM	SI	Zone #16	

HEAT DETECTORS

1	JANITOR ROOM 2ND FLOOR	RHT	Zone #7	
2	SEWING ROOM (2ND FLOOR)	RHT	Zone #7	
3	COOKING ROOM (2ND FLOOR)	RHT	Zone #7	
4	LIBRARY STORAGE	RHT	Zone #7	
5	JANITOR ROOM 3RD FLOOR	RHT	Zone #8	
6	WOODSHOP STORAGE	RHT	Zone #13	
7	ELECTRICAL ROOM	HT	Zone #13	
8	BOILER ROOM	HT	Zone #14	
9	KITCHEN	HT	Zone # 14	

NOTIFYING DEVICES

1	HALL 3RD FLOOR	B	Sig #1	
2	HALL 3RD FLOOR	B	Sig #1	
3	HALL 2ND FLOOR	B	Sig #1	
4	HALL 2ND FLOOR	B	Sig #1	
5	BOILER ROOM	B	Sig #1	
6	BASEMENT	B	Sig #1	
7	BASEMENT	B	Sig #1	
8	CAFETERIA	B	Sig #1	
9	GYM	B	Sig #1	
10	1ST FLOOR NORTH HALL	B	Sig #1	

END OF LINE RESISTORS

1	BOILER ROOM	EOL	Zone #14	
2	NORTH END 2ND FLOOR	EOL	Zone #7	
3	1ST FLOOR NORTH HALL	EOL	Zone #1	
4	2ND FLOOR BY ROOM 205	EOL	Zone #2	
5	SOUTH END 3RD FLOOR	EOL	Zone #8	
6	CAFETERIA	EOL	Zone #11	
7	BASEMENT HALL EXIT	EOL	Zone #13	
8	DOOR RELEASE	R		

Fire Door Number or Location

MAIN LOBBY BY RM 100
MAIN LOBBY REAR
MAIN LOBBY TO GYM
2ND LEV BY LIBRARY
2ND LEV BY SEWING ROOM
2ND LEV BY BAND ROOM
2ND LEV BY RM 209
3RD LEV BY RM 309
3RD LEV BY RM 308
3RD LEV BY RM 300
3RD LEV BY ROOF ACCESS

EMERGENCY LIGHTING

Line #	EL UNIT Location	MOD #	Manuf.
1	Main Lobby	COMBO	
2	Cafeteria(ON SIDE WALL)		
3	Cafeteria Exit	COMBO	
4	Gym by Stage		
5	Gym		

6	Gym, MAIN ENTRY		
7	By Room 100 Double Doors	COMBO	
8	By Room 106	COMBO	
9	By Room 102	UNIT	
#	2ND FL Stairs by Library	UNIT	
#	By Library	COMBO	
#	By Room 201 Double Doors	COMBO	
#	By Room 207 Double Doors	COMBO	
#	Center Stairs BY RM 202	UNIT	
#	3rd Floor by Room 304	UNIT	
#	3rd Floor Stair by Room 309	UNIT	
#	Stairs by Room 301	UNIT	
#	By Room 104 Double Doors	COMBO	
#	Stairwell to Boys Lockers		
#	BOYS LOCKER		
#	TECH ED ROOM ENTRY	COMBO	
#	TECH ED ROOM EXIT	COMBO	
#	BASEMENT CORRIDOR		
#	BASEMENT SOUTH EXIT	UNIT	
#	CENTER STAIR IN STAIR	UNIT	
#	3RD FL BY ROOF ACCESS	COMBO	

EMERGENCY LIGHTING NOTES AND RECOMMENDATIONS

- 1 EMERGENCY LIGHTS ARE CONTROLLED BY PANEL ACROSS
FROM ROOM 100, CTT#16
 - 2 ALSO, THIS BREAKER SHUTS OFF WALL OUTLETS MAIN OFFICE.....
-

Fire Alarm System Information - Bedford South School

1 of 6

FIRE ALARM DEVICES - System Manufacturer EDWARDS IO 1000

Location Desc	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
DEVICES															
1ST FLOOR NEAR ELEVATOR	S	SIGA-OSD	1		✓			✓	✓						
1ST FLOOR NEAR STAIR 1 ROOM 1011	S	SIGA-OSD	2		✓			✓	✓						
1ST FLOOR NEAR BACK EXIT/STAIR	S	SIGA-OSD	3		✓			✓	✓						
2ND FLOOR NEAR STAIR 1	S	SIGA-OSD	4		✓			✓	✓						
TOP OF STAIR 1	S	SIGA-OSD	5		✓			✓	✓						
2ND FLOOR NEAR MECH. ROOM 2022	S	SIGA-OSD	6		✓			✓	✓						
TOP OF BACK STAIR 2	S	SIGA-OSD	7		✓			✓	✓						
2ND FLOOR NEAR BACK STAIR 2	S	SIGA-OSD	8		✓			✓	✓						
2ND FLOOR NEAR ELEVATOR	S	SIGA-OSD	9		✓			✓	✓						
TOP OF STAIR 3	S	SIGA-OSD	10		✓			✓	✓						
2ND FLOOR NEAR STAIR 3	S	SIGA-OSD	11		✓			✓	✓						
ELEVATOR SHAFT	S	SIGA-OSD	12		✓			✓	✓						
LAN ROOM 1040 IN LIBRARY	S	SIGA-OSD	13		✓			✓	✓						
1ST FLOOR NEAR STAIR 3	S	SIGA-OSD	14		✓			✓	✓						
BOILER ROOM 1063	M	SIGA-270	126		✓			✓	✓						
1ST FLOOR NEAR STAIR 1	M	SIGA-270	127		✓			✓	✓						
1ST FLOOR NEAR BACK STAIR 2	M	SIGA-270	128		✓			✓	✓						
MAIN ENTRANCE	M	SIGA-270	129		✓			✓	✓						
1ST FLOOR NEAR STAIR #3	M	SIGA-270	130		✓			✓	✓						
GYM NEAR OFFICE EXIT	M	SIGA-270	131		✓			✓	✓						
GYM BACK CORNER	M	SIGA-270	132		✓			✓	✓						
2ND FLOOR NEAR STAIR 1 ROOM 2046	M	SIGA-270	133		✓			✓	✓						
2ND FLOOR NEAR BACK STAIR 2	M	SIGA-270	134		✓			✓	✓						
2ND FLOOR NEAR STAIR 3	M	SIGA-270	135		✓			✓	✓						
BOILER ROOM 0163	FS	VSR-F	136		✓				✓						
ABOVE CEILING NEAR STAIR 3 (1ST FL)	FS	VSR-F	137		✓				✓						
ABOVE CEILING NEAR STAIR 3 (1ST FL)	TS	705	138		✓				✓						
ABOVE CEILING STAIR 3 (2ND FL)	FS	VSR-F	139		✓				✓						
ABOVE CEILING STAIR 3 (2ND FL)	TS	705	140		✓				✓						

FIRE ALARM DEVICES

Location Desc	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
BOILER ROOM 1063	TS		141		✓				✓						
BOILER ROOM 1063	TS		142		✓				✓						
ELEVATOR PIT 1ST FLOOR	TS		143		✓				✓						
KITCHEN RECYCLE RM 1079 SHUNT TRIP	RLY	SIGA-CR	144		✓			✓							
DOOR HOLDERS - EST2 PANEL	RLY	SIGA-CR	145		✓			✓							
MECH RM 2062 FAN 3 SHUTDOWN	RLY	SIGA-CR	146		✓			✓							
OUTSIDE BOILER RM SPRINKLER BELL	RLY	SIGA-CR	147		✓			✓							
MECH RM 2062 BOOSTER PANEL	RLY	SIGA-CR	148		✓			✓							
BOOSTER PANEL 2ND FL BELLS ROOM 2062	CT2		149		✓			✓							
SPARE INPUT AT BOOSTER PANEL			150		✓			✓							
KITCHEN RANGE HOOD - INACCESSIBLE	CT2		151		✓				✓						
SPARE	CT2		152		✓										

SIGNAL CCT. #1 - 1ST FLOOR

NEAR CLASSROOM 1031	H	757-5A-T		1	✓			✓							
NEAR CLASSROOM 1031	V			1	✓			✓							
GROUP WORKROOM 1030	H	757-5A-T		1	✓			✓							
GROUP WORKROOM 1030	V			1	✓			✓							
WASHROOM IN RM 1030	V	202-5A-T		1	✓			✓							
BAYS WASHROOM 1043	H	202-5A-T		1	✓			✓							
NEAR CLASSROOM 1034	H	757-5A-T		1	✓			✓							
NEAR CLASSROOM 1034	V			1	✓			✓							
WASHROOM 1029	V	202-5A-T		1	✓			✓							
GROUP WORKROOM 1020	H	757-5A-T		1	✓			✓							
GROUP WORKROOM 1020	V			1	✓			✓							
NEAR CLASSROOM 1027	H	757-5A-T		1	✓			✓							
NEAR CLASSROOM 1027	V			1	✓			✓							
GIRLS WASHROOM 1048	V	202-5A-T		1	✓			✓							
GROUP WORKROOM 1010	H	757-5A-T		1	✓			✓							
GROUP WORKROOM 1010	V			1	✓			✓							
WASHROOM IN ROOM 1020	V	202-5A-T		1	✓			✓							
NEAR CLASSROOM 1015	H	757-5A-T		1	✓			✓							
NEAR CLASSROOM 1015	V			1	✓			✓							
LIBRARY	H	757-5A-T		1	✓			✓							

D

C6.2 FIRE ALARM DEVICES

Location Desc	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
LIBRARY	V			1	✓			✓							
NEAR CLASSROOM 1031	EOL			1	✓										

SIGNAL CCT. #2 - 1ST FLOOR NORTH

MAIN LOBBY	H	757-5A-T		2	✓			✓							
MAIN LOBBY	V			2	✓			✓							
CENTRE CORRIDOR NEAR LIBRARY	H	757-5A-T		2	✓			✓							
CENTRE CORRIDOR NEAR LIBRARY	V			2	✓			✓							
CAFETERIA	H	757-5A-T		2	✓			✓							
CAFETERIA	V			2	✓			✓							
GYM	H	757-5A-T		2	✓			✓							
GYM	V			2	✓			✓							
GYM	H	757-5A-T		2	✓			✓							
GYM	V			2	✓			✓							
GYM - GIRLS CHANGE ROOM	V	202-5A-T		2	✓			✓							
GYM - GIRLS WASHROOM	H	757-5A-T		2	✓			✓							
GYM - BOYS WASHROOM	H	757-5A-T		2	✓			✓							
GYM - BOYS WASHROOM	V			2	✓			✓							
GYM - BOYS CHANGE ROOM	V	202-5A-T		2	✓			✓							
CORRIDOR NEAR KITCHEN	H	757-5A-T		2	✓			✓							
CORRIDOR NEAR KITCHEN	V			2	✓			✓							
WASHROOM 1067	V	202-5A-T		2	✓			✓							
WASHROOM 1068	V	202-5A-T		2	✓			✓							
MUSIC ROOM	H	757-5A-T		2	✓			✓							
MAIN OFFICE	H			2	✓			✓							
	EOL				✓										
BOILER ROOM	H			2	✓			✓							
GYM - GIRLS CHANGE ROOM	V			2	✓			✓							
PORTABLE #1	H/S	G1-HDVM			✓			✓							

SIGNAL CCT. #3 - 2ND FLOOR NORTH

NEAR STAIR 3	H	757-5A-T		3	✓			✓							
NEAR STAIR 3	V			3	✓			✓							
NEAR MULTIMEDIA 2020	H	757-5A-T		3	✓			✓							
NEAR MULTIMEDIA 2020	V			3	✓			✓							

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #	Start Time	Finish Time	Current (A)	Voltage (V)	Battery Date	Battery Type	Op Cnfrm	Ser vice	Notes
	ELECT. RM 2062-PANEL 3201												
	2ND FL ADJ 2065 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE NEAR RM 2046		DUAL-LITE	3201							✓		
	REMOTE WASHRM 2065		DUAL-LITE	3201							✓		
	2ND FL ADJ ELECT RM 2062 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE NEAR RM 2036		DUAL-LITE	3201							✓		
	REMOTE ELECT RM 2062		DUAL-LITE	3201							✓		
	REMOTE STAIR #1		DUAL-LITE	3201							✓		
	2ND FL ADJ CLASS 2026 UNIT		DUAL-LITE	3201			7	2X6V 7AH			✓		
	REMOTE NEAR 2026		DUAL-LITE	3201							✓		
	2ND FL ADJ RM 2018 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE MALE WASHRM 2055		DUAL-LITE	3201							✓		
	REMOTE FEMALE WASHRM 2056		DUAL-LITE	3201							✓		
	2ND FL MECH RM 2022 UNIT		DUAL-LITE	3201			7	2X6V 7AH			✓		
	REMOTE ADJ 2022		DUAL-LITE	3201							✓		
	STAIR #2 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE BOTTOM STAIR #2		DUAL-LITE	3201							✓		
	2ND FL ADJ RM 2075 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE WASHRM 2073		DUAL-LITE	3201							✓		
	REMOTE WASHRM 2074		DUAL-LITE	3201							✓		
	STAIR #3 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE STAIR #3		DUAL-LITE	3201							✓		
	REMOTE ADJ 2070		DUAL-LITE	3201							✓		
	STAIR #1 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE STAIR #1		DUAL-LITE	3201							✓		
	1ST FL ADJ 1045 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE ADJ RM 1021		DUAL-LITE	3201							✓		
	1ST FL GYM ADJ CAFE UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE WEST SIDE		DUAL-LITE	3201							✓		
	REMOTE CAFETERIA		DUAL-LITE	3201							✓		
	1ST FL GYM ADJ OUTDOORS UNIT		DUAL-LITE	3201			7	2X6			✓		
	1ST FL FEMALE WASHRM 1060 UNIT		DUAL-LITE	3201			7	2X6			✓		
	REMOTE SHOWER RM 1059		DUAL-LITE	3201							✓		
	1ST FL MENS WASHRM 1057 UNIT		DUAL-LITE	3201			7	2X6			✓		

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #	Start Time	Finish Time	Current (A)	Voltage (V)	Battery Date	Battery Type	Op Cnfrm	Ser vice	Notes
	REMOTE SHOWER RM 1058		DUAL-LITE	3201							✓		
	REMOTE OFFICE RM 1054		DUAL-LITE	3201							✓		
	ELECT RM 1044-PANEL 3101												
	1ST FL ADJ RM 1031 UNIT		DUAL-LITE	3101			7	2X6			✓		
	REMOTE ADJ RM 1044			3101							✓		
	REMOTE WASHRM 1036		DUAL-LITE	3101							✓		
	1ST FL WASHRM 1048 UNIT			3101			7	2X6			✓		
	REMOTE WASHRM 1043		DUAL-LITE	3101							✓		
	REMOTE WASHRM 1047		DUAL-LITE	3101							✓		
	1ST FL MULTIPURPOSE 1061 UNIT		DUAL-LITE	3101			7	2X6			✓		
	1ST FL CAFE STAGE UNIT		DUAL-LITE	3101			7	2X6			✓		
	REMOTE ADJ 1084		DUAL-LITE	3101							✓		
	REMOTE STAGE		DUAL-LITE	3101							✓		
	1ST FL ADJ WASHRM 1068 UNIT		DUAL-LITE	3101			7	2X6			✓		
	REMOTE WASHRM 1068		DUAL-LITE	3101							✓		
	REMOTE WASHRM 1067		DUAL-LITE	3101							✓		
	1ST FL STAIR #3 UNIT		DUAL-LITE	3101			7	2X6			✓		
	REMOTE BOILER RM		DUAL-LITE	3101							✓		
	REMOTE KITCHEN		DUAL-LITE	3101							✓		
	1ST FL LIBRARY UNIT		DUAL-LITE	3101			7	2X6			✓		
	1ST FL ADJ 1014 UNIT		DUAL-LITE	3101			7	2X6			✓		
	REMOTE NEAR 1014		DUAL-LITE	3101							✓		
	1ST FL ADJ 1027 UNIT		DUAL-LITE	3101			7	2X6			✓		
	1ST FL ADJ 1021 UNIT		DUAL-LITE	3101			7	2X6			✓		
	1ST FL WASHRM 1043 UNIT		DUAL-LITE	3101			7	2X6			✓		
	1ST FL ADJ LIBRARY BY STAIR UNIT		DUAL-LITE	3101			7	2X6			✓		
	1ST FL LIBRARY BY MAIN ENT. UNIT		DUAL-LITE	3101			7	2X6				✓	
	1ST FL EXIT LIGHTS		DUAL-LITE	3101						0120822E	✓		
	2ND FL EXIT LIGHTS		DUAL-LITE	3101						0120822E	✓		
	GYM EXIT LIGHTS		0120822E	3101						0120822E		✓	

1 of 5

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
TOP NORTH STAIR	S		1		✓			✓	✓						
TOP WEST STAIR	S		2		✓			✓	✓						
TOP SOUTH STAIR	S		3		✓			✓	✓						
ELEVATOR SHAFT	S		4		✓			✓	✓						
PENTHOUSE 1 AHU #6	RLY	SIGA-CR	126		✓			✓	✓						
PENTHOUSE 1 AHU #5	RLY	SIGA-CR	127		✓			✓	✓						
PENTHOUSE 1 AHU #1	RLY	SIGA-CR	128		✓			✓	✓						
PENTHOUSE 1 AHU #3	RLY	SIGA-CR	129		✓			✓	✓						
PENTHOUSE 1 AHU #4	RLY	SIGA-CR	130		✓			✓	✓						
DOOR HOLDERS	RLY	SIGA-CR	131		✓			✓	✓						IN PANEL
ADDER PANEL RELAY	RLY	SIGA-CR	132		✓			✓	✓						

[illegible][illegible]

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
MAIN GATE VALVE #2			154												
BACKFLOW #1			155												
1ST FLOOR GYM STORAGE	M	SIGA-270	156												
2ND FLOOR SOUTH STAIR	M	SIGA-270	157		✓			✓	✓						
1ST FLOOR BOILER RM	M	SIGA-270	158												

1ST FLOOR GYM NORTH	M	M61-B	159		✓			✓	✓						
1ST FLOOR WEST EXIT	M	SIGA-270	160		✓			✓	✓						
1ST FLOOR NORTH EXIT	M	SIGA-270	161		✓			✓	✓						
1ST FLOOR GYM BACK	M	M61-B	162		✓			✓	✓						
1ST FLOOR SOUTH EXIT	M	SIGA-270	163		✓			✓	✓						
2ND FLOOR NORTH STAIR	M	SIGA-270	164		✓			✓	✓						
1ST FLOOR MAIN ENTRANCE	M	SIGA-270	165		✓			✓	✓						
2ND FLOOR WEST STAIR	M	SIGA-270	166		✓			✓	✓						
PENTHOUSE #2	M	SIGA-270	167		✓			✓	✓						
PENTHOUSE #1	M	SIGA-270	168		✓				✓						
2ND FLOOR TOP MAIN STAIR	M	SIGA-270	169		✓			✓	✓						
1ST FLOOR ELEVATOR PT VALVE	GV		170												
2ND FLOOR ELEVATOR SHAFT VALVE	GV		171												
KITCHEN HOOD ALARM			172												
BELL STROBE #3 ADDER	TRBL	SIGA-CR	173		✓				✓	✓					
WHEELCHAIR LIFT SPRINKLER VALVE			174												

HORN STOBES

PENTHOUSE 1 ADDER PANEL	RLY		132		✓			✓							
IN 2029 TECH PROD.	H/S				✓			✓							
NEAR 2033	H				✓			✓							
NEAR LIBRARY 2021	H/S				✓			✓							
IN PENTHOUSE #1	H/S				✓			✓							ABOVE ADDER
2ND FLOOR ADJ. MAIN STAIRS	H/S				✓			✓							BY 2044
2ND FLOOR ADJ. 2038	H/S				✓			✓							
2ND FLOOR GIRLS WASHROOM	H/S				✓			✓							MAIN STAIRS
2ND FLOOR BOYS WASHROOM	H/S				✓			✓							MAIN STAIRS

Fire Alarm system Info - MADELINE SYMONDS MIDDLE SCHOOL

3 of 5

8

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
2ND FLOOR CORRIDOR BEHIND MAIN STAIRS	H/S				✓			✓							
2ND FLOOR BY 2049/ 2047	H/S				✓			✓							
2ND FLOOR BY 2057/ 2055	H/S				✓			✓							
PENTHOUSE #2	H/S				✓			✓							
2ND FLOOR ADJ. TO 2064/ 2062	H/S				✓			✓							
1ST FLOOR ADJ. TO 1075	H/S				✓			✓							
1ST FLOOR BEHIND MAIN STAIR	STROBE ONLY				✓										
1ST FLOOR GIRLS WASHROOM	STROBE ONLY				✓										
1ST FLOOR BOYS WASHROOM	H/S				✓			✓							
1ST FLOOR ADJ. 1094/ 1092	H/S				✓			✓							
1ST FLOOR LOBBY ADJ. CAFETERIA	H/S				✓			✓							
1ST FLOOR CORRIDOR BY CAFETERIA	H/S				✓			✓							
1ST FLOOR ADJ. NORTH EXIT	H/S				✓			✓							
1ST FLOOR CAFETERIA STAGE RIGHT	H/S				✓			✓							
1ST GYM #1	H/S				✓			✓							
1ST FLOOR GYM #2	H/S				✓			✓							
BOYS LOCKER RM	H/S				✓			✓							
BOYS SHOWER IN LOCKER RM	H/S				✓			✓							
GIRLS LOCKER RM	H/S				✓										
GIRLS SHOWER RM	H/S				✓			✓							
1ST FLOOR STAFF WASHROOM (FEMALE)	STROBE ONLY				✓			✓							
1ST FLOOR WASHROOM (MALE)	STROBE ONLY				✓			✓							
MAIN LOBBY ADJ. TO ELEVATOR MACHINE RM	H/S				✓			✓							

[illegible]

[illegible]

Fire Alarm System Information - Park West School

1 of 9



FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
----------------------	--------	-------	---------	---------------------	------	-----	------	-----	-----	-----	-----	----	-----	------	---------

EDWARDS EST3 PANEL

1ST FLOOR BY STAIR 1	S		1		✓			✓	✓						
ELECT. RM 1044	S		2		✓			✓	✓						
COMM. RM 1040	S		3		✓			✓	✓						
1ST FLOOR BY ELEVATOR	S		4		✓			✓	✓						
ELEVATOR SHAFT	S		5		✓										
TOP STAIR 1	S		6		✓			✓	✓						
2ND FLOOR BY STAIR 1	S		7		✓			✓	✓						
2ND FLOOR BY STAIR 3	S		8		✓			✓	✓						
TOP STAIR 3	S		9		✓			✓	✓						
2ND FLOOR BY ELEVATOR	S		10		✓			✓	✓						
2ND FLOOR BY MECH. RM	S		11		✓			✓	✓						
2ND FLOOR BY STAIR 2	S		12		✓			✓	✓						
1ST FLOOR BY STAIR 2	S		13		✓			✓	✓						
1ST FLOOR BY STAIR 3	S		14		✓			✓	✓						
1ST FLOOR BACK CORR.	S		15		✓			✓	✓						
TOP OF STAIR 2	S		16		✓			✓	✓						
PORTABLE TEACHER LOUNGE	S	SIGA-OSD	18		✓			✓	✓						
PORTABLE CLASSROOM 2	S	SIGA-OSD	19		✓			✓	✓						
PORTABLE CLASSROOM 1	S	SIGA-OSD	17		✓			✓	✓						
PORTABLE BY CLASSROOM 3	S	SIGA-OSD	20		✓			✓	✓						
PORTABLE CLASSROOM 3	S	SIGA-OSD	21		✓			✓	✓						
PORTABLE CLASSROOM 4	S	SIGA-OSD	22		✓			✓	✓						
PORTABLE BY CLASSROOM 4	S	SIGA-OSD	23		✓			✓	✓						
PORTABLE CLASSROOM 5	S	SIGA-OSD	24		✓			✓	✓						
PORTABLE CLASSROOM 6	S	SIGA-OSD	25		✓			✓	✓						
PORTABLE CLASSROOM 7	S	SIGA-OSD	26		✓			✓	✓						
PORTABLE CLASSROOM 8	S	SIGA-OSD	27		✓			✓	✓						
PORTABLE BY CLASSROOM 9	S	SIGA-OSD	28		✓			✓	✓						
PORTABLE BY CLASSROOM 10	S	SIGA-OSD	29		✓			✓	✓						
PORTABLE BY CLASSROOM 11	S	SIGA-OSD	30		✓			✓	✓						
PORTABLE BY CLASSROOM 7	S	SIGA-OSD	31		✓			✓	✓						

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
2ND FLOOR FLOW	FLOW	SIGA-CT2	140		✓			✓							
2ND FLOOR GV	SUPV	SIGA-CT2	141		✓										
KITCHEN HOOD ALARM	ALM	CT1	142		✓			✓							
BOILER RM GV		CT2	143		✓										
ELEV. SHAFT GV		CT2	144		✓										
BOOSTER TROUBLE	SUPV	CT1	145		✓										
DOOR HOLDERS	RLY	SIGA-CR	146		✓			✓	✓						
KITCHEN SHUNT TRIP	RLY	SIGA-CR	147		✓			✓	✓						
AHU 2 SHUTDOWN	RLY	SIGA-CR	148		✓			✓	✓						
BOOSTER ALTERNATE	RLY	SIGA-CR	149		✓			✓	✓						
	RLY	SIGA-CR	150		✓			✓	✓						
PORTABLE MAIN ENTRANCE	M		151		✓			✓	✓						
PORTABLE ENTRANCE BY WASHROOMS	M		152		✓			✓	✓						
PORTABLE ENTRANCE BY ELECT. RM	M		153		✓			✓	✓						
PORTABLE BOOSTER TROUBLE	SUPV		154		✓										

SIGNAL CCT. CLASS A- PORTABLES

CLASSROOM 1	H/S		NAC 1/2		✓			✓							
CLASSROOM 2	H/S		NAC 1/2		✓			✓							
CLASSROOM 3	H/S		NAC 1/2		✓			✓							
CLASSROOM 4	H/S		NAC 1/2		✓			✓							
CLASSROOM 5	H/S		NAC 1/2		✓			✓							
CLASSROOM 6	H/S		NAC 1/2		✓			✓							
CLASSROOM 7	H/S		NAC 1/2		✓			✓							
CLASSROOM 8	H/S		NAC 1/2		✓			✓							
CLASSROOM 9	H/S		NAC 1/2		✓			✓							
CLASSROOM 10	H/S		NAC 1/2		✓			✓							
CLASSROOM 11	H/S		NAC 1/2		✓			✓							
CLASSROOM 12	H/S		NAC 1/2		✓			✓							
MALE WASHROOM	H/S		NAC 1/2		✓			✓							
FEMALE WASHROOM	H/S		NAC 1/2		✓			✓							
BY CLASSROOM 2	H/S		NAC 1/2		✓			✓							
BY CLASSROOM 4	H/S		NAC 1/2		✓			✓							
BY CLASSROOM 6	H/S		NAC 1/2		✓			✓							
BY CLASSROOM 8	H/S		NAC 1/2		✓			✓							

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
BY CLASSROOM 9	H/S		NAC 1/2		✓			✓							
BY CLASSROOM 11	H/S		NAC 1/2		✓			✓							

SIGNAL CCT. #1 - 1ST FLOOR NORTHEAST

MAIN LOBBY	H	757-5A-T		1	✓			✓							
MAIN LOBBY	V			1	✓			✓							
MAIN OFFICE	H	757-5A-T		1	✓			✓							
CORRIDOR NEAR KITCHEN	H	757-5A-T		1	✓			✓							
CORRIDOR NEAR KITCHEN	V			1	✓			✓							
WASHROOM NEAR KITCHEN	V	202-5A-T		1	✓			✓							
WASHROOM NEAR KITCHEN	V	202-5A-T		1	✓			✓							
BOILER ROOM	H	757-5A-T		1	✓			✓							
MUSIC ROOM	H	757-5A-T		1	✓			✓							
GYM	H	757-5A-T		1	✓			✓							
GYM	V			1	✓			✓							
GYM	H	757-5A-T		1	✓			✓							
GYM	V			1	✓			✓							
GYM - GIRLS CHANGE ROOM	V	202-5A-T		1	✓			✓							
GYM - GIRLS WASHROOM	H	757-5A-T		1	✓			✓							
GYM - GIRLS WASHROOM	V			1	✓			✓							
GYM - BOYS CHANGE ROOM	V	202-5A-T		1	✓			✓							
GYM - BOYS WASHROOM	H	757-5A-T		1	✓			✓							
GYM - BOYS WASHROOM	V	757-5A-T		1	✓			✓							
CENTRE CORRIDOR	H			1	✓			✓							
CENTRE CORRIDOR	V	757-5A-T		1	✓			✓							
CAFETERIA	H			1	✓			✓							
CAFETERIA	V			1	✓			✓							
GYM - BOYS CHANGE ROOM	EOL			1	✓										

SIGNAL CCT. #2 - 1ST FLOOR NORTHWEST

BACK CORRIDOR NEAR FIRE DOORS	H	757-5A-T		2	✓			✓							
BACK CORRIDOR NEAR FIRE DOORS	V			2	✓			✓							
BOY'S WASHROOM	V	202-5A-T		2	✓			✓							
ROOM 1030	H	757-5A-T		2	✓			✓							

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
ROOM 1030	V			2	✓			✓							
BACK CORRIDOR	H	757-5A-T		2	✓			✓							
BACK CORRIDOR	V			2	✓			✓							
HANDICAP WASHROOM	V	202-5A-T		2	✓			✓							
CLASSROOM 1025	H	757-5A-T		2	✓			✓							
ROOM 1020	H	757-5A-T		2	✓			✓							
ROOM 1020	V			2	✓			✓							
CORRIDOR NEAR STAIR 1	H	757-5A-T		2	✓			✓							
CORRIDOR NEAR STAIR 1	V			2	✓			✓							
GIRLS WASHROOM	V	202-5A-T		2	✓			✓							
ROOM 1010	H	757-5A-T		2	✓			✓							
ROOM 1010	V			2	✓			✓							
HANDICAP WASHROOM 1010	V	202-5A-T		2	✓			✓							
FRONT CORRIDOR NEAR FIRE DOORS	H	757-5A-T		2	✓			✓							
FRONT CORRIDOR NEAR FIRE DOORS	V			2	✓			✓							
LIBRARY	H	757-5A-T		2	✓			✓							
LIBRARY	V			2	✓			✓							
WASHROOM 1036	V	202-5A-T		2	✓			✓							
BACK CORRIDOR NEAR FIRE DOORS	EOL			2	✓										
PORTABLE #7	H/S	G1-HDVM		2	✓			✓							

SIGNAL CCT. #3 - 2ND FL N.E. (SIGNAL CC1 - EST1-MECH RM)

NEAR BACK STAIR #2	H	757-5A-T		3	✓			✓							
NEAR BACK STAIR #2	V			3	✓			✓							
GIRLS WASHROOM 2056	V	202-5A-T		3	✓			✓							
BOYS WASHROOM 2055	V	202-5A-T		3	✓			✓							
ROOM 2007	H	757-5A-T		3	✓			✓							
CORRIDOR BY 2018	H	757-5A-T		3	✓			✓							
ROOM 2020	V			3	✓			✓							
ROOM 2020	H	757-5A-T		3	✓			✓							
ROOM 2071 (HORN ONLY)	H	757-5A-T		3	✓			✓							
NEAR STAIR 3	H	757-5A-T		3	✓			✓							
NEAR STAIR 3	V			3	✓			✓							
FAMILY STUDIES 2012	H	757-5A-T		3	✓			✓							
FAMILY STUDIES 2012	V			3	✓			✓							

100

[illegible]

[illegible]

[illegible]

Fire Alarm System Information - Sackville Heights Elementary

Pg 1 of 8

FIRE ALARM DEVICES System Manufacturer : EDWARDS Model: IO

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
DEVICES															
SMOKE ADJ. MULTIMEDIA RM. 2029 2ND FLR.	S	SIGA-IS	001		✓			✓	✓						
SMOKE TOP OF STAIR #2	S	SIGA-IS	002		✓			✓	✓						
SMOKE ADJ. CLASSROOM 2033 2ND FL	S	SIGA-IS	003		✓			✓	✓						
SMOKE TOP OF STAIR #1	S	SIGA-IS	004		✓			✓	✓						
SMOKE ADJ. GROUP WORK RM 2016 2ND FL	S	SIGA-IS	005		✓			✓	✓						
SMOKE ADJ. GYM MAIN CORRIDOR 1ST FL	S	SIGA-IS	006		✓			✓	✓						
SMOKE ADJ. CLASSROOM 1039 1ST FL	S	SIGA-IS	007		✓			✓	✓						
SMOKE ADJ. CLASSROOM 1025 1ST FL	S	SIGA-IS	008		✓			✓	✓						
SMOKE GENERAL STORAGE RM 2038 2ND FLOOR	S	SIGA-IS	009		✓			✓	✓						
SMOKE RECYCLE RM 1055 1ST FL	S	SIGA-IS	010		✓			✓	✓						
SMOKE STORAGE RM 1058 1ST FL	S	SIGA-IS	011		✓			✓	✓						
SMOKE ADJ. RECYCLE RM 1055 1ST FL	S	SIGA-IS	012		✓			✓	✓						
SMOKE CUSTODIAN RM 1059 1ST FL	S	SIGA-IS	013		✓			✓	✓						
SMOKE STORAGE RM 1061 1ST FL	S	SIGA-IS	014		✓			✓	✓						
SMOKE ELEVATOR MACHINE RM 2041	S	SIGA-IS	015		✓			✓	✓						
SMOKE TOP OF ELEVATOR SHAFT	S	SIGA-IS	016		✓										
SMOKE CUSTODIAN ROOM 2040	S	SIGA-IS	017		✓			✓	✓						
SMOKE OUTSIDE STORAGE ROOM 1071	S	SIGA-IS	018		✓			✓	✓						
SMOKE KITCHEN STORAGE ROOM 1067	S	SIGA-IS	019		✓			✓	✓						
SMOKE GYM STORAGE ROOM 1072	S	SIGA-IS	020		✓			✓	✓						
1ST FL ISO LOBBY CORR ADJ LIBRARY	ISO	SIGA-IM	021		✓					✓			✓		
2NS FL ISO LOBBY CORR ADJ LIBRARY	ISO	SIGA-IM	022		✓					✓			✓		
PORTABLES ISO LOBBY CORR ADJ LIBRARY	ISO	SIGA-IM	023		✓					✓			✓		
SIGNAL CCT. #1		AUDIBLE	201		✓										
SIGNAL CCT. #2		AUDIBLE	202		✓										
PULL ADJ. STAIR #2 2ND FLOOR	M	SIGA-270	126		✓			✓	✓						
PULL ADJ. STAIR #1 2ND FLOOR	M	SIGA-270	127		✓			✓	✓						
PULL ADJ. GYM EXIT	M	SIGA-270	128		✓			✓	✓						

Fire Alarm System Information - Sackville Heights Elementary

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
DEVICES															
SMOKE ADJ. MULTIMEDIA RM. 2029 2ND FLR.	S	SIGA-IS	001		✓			✓	✓						
SMOKE TOP OF STAIR #2	S	SIGA-IS	002		✓			✓	✓						
SMOKE ADJ. CLASSROOM 2033 2ND FL	S	SIGA-IS	003		✓			✓	✓						
SMOKE TOP OF STAIR #1	S	SIGA-IS	004		✓			✓	✓						
SMOKE ADJ. GROUP WORK RM 2016 2ND FL	S	SIGA-IS	005		✓			✓	✓						
SMOKE ADJ. GYM MAIN CORRIDOR 1ST FL	S	SIGA-IS	006		✓			✓	✓						
SMOKE ADJ. CLASSROOM 1039 1ST FL	S	SIGA-IS	007		✓			✓	✓						
SMOKE ADJ. CLASSROOM 1025 1ST FL	S	SIGA-IS	008		✓			✓	✓						
SMOKE GENERAL STORAGE RM 2038 2ND FLOOR	S	SIGA-IS	009		✓			✓	✓						
SMOKE RECYCLE RM 1055 1ST FL	S	SIGA-IS	010		✓			✓	✓						
SMOKE STORAGE RM 1058 1ST FL	S	SIGA-IS	011		✓			✓	✓						
SMOKE ADJ. RECYCLE RM 1055 1ST FL	S	SIGA-IS	012		✓			✓	✓						
SMOKE CUSTODIAN RM 1059 1ST FL	S	SIGA-IS	013		✓			✓	✓						
SMOKE STORAGE RM 1061 1ST FL	S	SIGA-IS	014		✓			✓	✓						
SMOKE ELEVATOR MACHINE RM 2041	S	SIGA-IS	015		✓			✓	✓						
SMOKE TOP OF ELEVATOR SHAFT	S	SIGA-IS	016		✓										
SMOKE CUSTODIAN ROOM 2040	S	SIGA-IS	017		✓			✓	✓						
SMOKE OUTSIDE STORAGE ROOM 1071	S	SIGA-IS	018		✓			✓	✓						
SMOKE KITCHEN STORAGE ROOM 1067	S	SIGA-IS	019		✓			✓	✓						
SMOKE GYM STORAGE ROOM 1072	S	SIGA-IS	020		✓			✓	✓						
1ST FL ISO LOBBY CORR ADJ LIBRARY	ISO	SIGA-IM	021		✓					✓			✓		
2NS FL ISO LOBBY CORR ADJ LIBRARY	ISO	SIGA-IM	022		✓					✓			✓		
PORTABLES ISO LOBBY CORR ADJ LIBRARY	ISO	SIGA-IM	023		✓					✓			✓		
SIGNAL CCT. #1		AUDIBLE	201		✓										
SIGNAL CCT. #2		AUDIBLE	202		✓										
PULL ADJ. STAIR #2 2ND FLOOR	M	SIGA-270	126		✓			✓	✓						
PULL ADJ. STAIR #1 2ND FLOOR	M	SIGA-270	127		✓			✓	✓						
PULL ADJ. GYM EXIT	M	SIGA-270	128		✓			✓	✓						

Fire Alarm System Information - Sackville Heights Elementary

3 of 8

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
PULL CORR. ADJ. ELECT. RM 1053 1ST FL	M	SIGA-270	129		✓			✓	✓						
PULL ADJ. MAIN ENTRANCE	M	SIGA-270	130		✓			✓	✓						
PULL ADJ. STAIR #1 1ST FL	MM	SIGA-270	131		✓			✓	✓						
PULL ADJ. MECH RM 1054 EXIT 1ST FLOOR	M	SIGA-270	132		✓			✓	✓						
PULL ADJ. MECH RM 2043 EXIT 2ND FL	M	SIGA-270	133		✓			✓	✓						
PULL ADJ. OUTSIDE STORAGE RM. 1071	M	SIGA-270	134		✓			✓	✓						
PULL ADJ. CAFETERIA 1065 EXIT	M	SIGA-270	135		✓			✓	✓						
PULL ADJ. MUSIC ROOM 1062 EXIT	M	SIGA-270	136		✓			✓	✓						
PULL ADJ. STAIR #2 1ST FL	M	SIGA-270	137		✓			✓	✓						
RELAY FOR SPRINKLER SYSTEM OUTSIDE BELL	RLY	SIGA-CR	215		✓										
RELAY FOR DOOR HOLDERS 1ST FLOOR	RLY	SIGA-CR	216		✓										
RELAY FOR DOOR HOLDERS 2ND FLOOR	RLY	SIGA-CR	217		✓										
GATE VALVE FOR ELEV. PIT 1ST FL CLOSED	TS	SIGA-CT1	218		✓										
GATE VALVE FOR ELEV. SHAFT 2ND FL CLOSED	TS	SIGA-CT1	219		✓										
SPRK MAIN FLOW SWITCH (SPRK RM)	FS	SIGA-CT2	220		✓										
SPRK GATE VALVES (SPRK RM)	FS	SIGA-CT2	221		✓										
SPRK 1ST FLOOR FLOW SWITCH (SPRK RM)	FS	SIGA-CT2	222		✓										
SPRK 2ND FLOOR FLOW SWITCH (SPRK RM)	FS	SIGA-CT2	223		✓										
KITCHEN HOOD SYSTEM	IM	SIGA-CT1	224		✓										
RELAY FOR PROPANE SHUTDOWN	RLY	SIGA-CR	225		✓										
AHU SHUTDOWN	RLY	RELAY			✓										
PORTABLE #1	CT2	SIGA-CT2	226		✓			✓	✓	✓			✓		
PORTABLE #1 REAR PULL STN	M	270-SPOW	226		✓			✓	✓	✓			✓		
PORTABLE #1 FRONT PULL STN	M	270-SPOW	226		✓			✓	✓	✓			✓		
PORTABLE #1 FRONT PULL STN	EOL		226		✓				✓	✓			✓		
PORTABLES #2	CT2	SIGA-CT2	227		✓			✓	✓	✓			✓		
PORTABLE #2 REAR PULL STN	M	270-SPOW	227		✓			✓	✓	✓			✓		
PORTABLE #2 FRONT PULL STN	M	270-SPOW	227		✓			✓	✓	✓			✓		
PORTABLE #2 FRONT PULL STN	EOL		227		✓				✓	✓			✓		

Fire Alarm System System Information - Sackville Heights Elementary

4 of 8

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
PULL CORR. ADJ. ELECT. RM 1053 1ST FL	M	SIGA-270	129		✓			✓	✓						
PULL ADJ. MAIN ENTRANCE	M	SIGA-270	130		✓			✓	✓						
PULL ADJ. STAIR #1 1ST FL	MM	SIGA-270	131		✓			✓	✓						
PULL ADJ. MECH RM 1054 EXIT 1ST FLOOR	M	SIGA-270	132		✓			✓	✓						
PULL ADJ. MECH RM 2043 EXIT 2ND FL	M	SIGA-270	133		✓			✓	✓						
PULL ADJ. OUTSIDE STORAGE RM. 1071	M	SIGA-270	134		✓			✓	✓						
PULL ADJ. CAFETERIA 1065 EXIT	M	SIGA-270	135		✓			✓	✓						
PULL ADJ. MUSIC ROOM 1062 EXIT	M	SIGA-270	136		✓			✓	✓						
PULL ADJ. STAIR #2 1ST FL	M	SIGA-270	137		✓			✓	✓						
RELAY FOR SPRINKLER SYSTEM OUTSIDE BELL	RLY	SIGA-CR	215		✓										
RELAY FOR DOOR HOLDERS 1ST FLOOR	RLY	SIGA-CR	216		✓										
RELAY FOR DOOR HOLDERS 2ND FLOOR	RLY	SIGA-CR	217		✓										
GATE VALVE FOR ELEV. PIT 1ST FL CLOSED	TS	SIGA-CT1	218		✓										
GATE VALVE FOR ELEV. SHAFT 2ND FL CLOSED	TS	SIGA-CT1	219		✓										
SPRK MAIN FLOW SWITCH (SPRK RM)	FS	SIGA-CT2	220		✓										
SPRK GATE VALVES (SPRK RM)	FS	SIGA-CT2	221		✓										
SPRK 1ST FLOOR FLOW SWITCH (SPRK RM)	FS	SIGA-CT2	222		✓										
SPRK 2ND FLOOR FLOW SWITCH (SPRK RM)	FS	SIGA-CT2	223		✓										
KITCHEN HOOD SYSTEM	IM	SIGA-CT1	224		✓										
RELAY FOR PROPANE SHUTDOWN	RLY	SIGA-CR	225		✓										
AHU SHUTDOWN	RLY	RELAY			✓										
PORTABLE #1	CT2	SIGA-CT2	226		✓			✓	✓	✓			✓		
PORTABLE #1 REAR PULL STN	M	270-SPOW	226		✓			✓	✓	✓			✓		
PORTABLE #1 FRONT PULL STN	M	270-SPOW	226		✓			✓	✓	✓			✓		
PORTABLE #1 FRONT PULL STN	EOL		226		✓				✓	✓			✓		
PORTABLES #2	CT2	SIGA-CT2	227		✓			✓	✓	✓			✓		
PORTABLE #2 REAR PULL STN	M	270-SPOW	227		✓			✓	✓	✓			✓		
PORTABLE #2 FRONT PULL STN	M	270-SPOW	227		✓			✓	✓	✓			✓		
PORTABLE #2 FRONT PULL STN	EOL		227		✓				✓	✓			✓		

Fire Alarm System Information - Sackville Heights Elementary

5 of 8

FIRE ALARM DEVICES

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
PORTABLE #3	CT2	SIGA-CT2	228		✓			✓	✓	✓			✓		
PORTABLE #3 FRONT PULL STN	M	270-SPOW	228		✓			✓	✓	✓			✓		
PORTABLE #3 REAR PULL STN	M	270-SPOW	228		✓			✓	✓	✓			✓		
PORTABLE #3 REAR PULL STN	EOL		228		✓				✓	✓			✓		
PORTABLE #4	CT2	SIGA-CT2	229		✓			✓	✓	✓			✓		
PORTABLE #4 REAR PULL STN	M	270-SPOW	229		✓			✓	✓	✓					
PORTABLE #4 FRONT PULL STN	M	270-SPOW	229		✓			✓	✓	✓					
PORTABLE #4 FRONT PULL STN	EOL		229		✓				✓	✓			✓		
PORTABLES BPS PANEL (BOILER RM)	CC1	SIGA-CC1	230		✓			✓	✓	✓			✓		

PORTABLES BOOSTER (BOILER RM)

NAC CCT #1

PORTABLE #1

PORTABLE #1	H/S	G1-HDVM		1	✓			✓			96DB		✓		
PORTABLE #1	EOL			1	✓				✓	✓			✓		

NAC CCT #2

PORTABLE #2	H/S	G1-HDVM		2	✓			✓			96DB		✓		
PORTABLE #2	EOL			2	✓				✓	✓			✓		

NAC CCT #3

PORTABLE #3	H/S	G1-HDVM		3	✓			✓			96DB		✓		
PORTABLE #3	EOL			3	✓				✓	✓			✓		

NAC CCT #4

PORTABLE #4	H/S	G1-HDVM		4	✓			✓			96DB		✓		
PORTABLE #4	EOL			4	✓				✓	✓			✓		

HORN/STROBE CCT. - 1ST FLOOR


BY ROOM 1025 IN EXTENDED HALLWAY	H/S				✓			✓							
BY ROOM 1025 IN MAIN HALLWAY	H/S				✓			✓							

EMERGENCY LIGHTS

Unit #	Location	# of Heads	Model	Circuit #	Start Time	Finish Time	Current (A)	Voltage (V)	Battery Date	Battery Type	Op Cnfrm	Ser vice	Notes
	EXIT TO STAIR	1	EXIT LIGHT								✓		
	EXIT FROM STAIR 1	1	EXIT LIGHT								✓		
	BOTTOM OF STAIR 1	1	REMOTE								✓		
	CORR BY 1025		12DEL72-3								✓		
	CORR BY 1031	2	REMOTE								✓		
	CORR BY 1019	2	12DEL72-3								✓		
	GYM ENTRANCE	1	EXIT LIGHT								✓		
	GYM	2	REMOTE								✓		
	GYM	2	12DEL72-3								✓		
	GYM	2	12DEL72-3								✓		
	GYM EXIT	1	EXIT LIGHT								✓		
	GYM BY GYM STAGE EXIT	2	REMOTE								✓		
	GYM	2	REMOTE								✓		
	GYM	1	EXIT LIGHT								✓		
	FRONT ENTR. 1ST FL	2	12DEL72-3								✓		
	MAIN ENTR.	1	EXIT LIGHT								✓		
	OUTSIDE RM 1062	2	12DEL72-3								✓		
	EXIT FROM MUSIC RM 1062	1	EXIT LIGHT								✓		
	REAR EXIT BY 1053	1	EXIT LIGHT								✓		
	FEMALE WASHRM 1046	1	REMOTE								✓		
	FEMALE WASHRM 1050		REMOTE								✓		
	BOTTOM OF STAIR 2	2	REMOTE								✓		
	EXIT FROM STAIR 2	1	EXIT LIGHT								✓		
	EXIT TO STAIR 2	1	EXIT LIGHT								✓		
	CORR BY 1047	2	12DEL72-3								✓		
	CORR BY 1025	3	12DEL72-3								✓		
	CORR BY 1036	2	12DEL72-3								✓		
	CORR BY 1041	2	REMOTE								✓		
	MALE WASHRM 1049	1	REMOTE								✓		
	MALE WASHRM 1045	1	REMOTE								✓		
	REAR EXIT FROM GYM	2	12DEL72-3								✓		
	REAR EXIT FROM GYM	1	EXIT LIGHT								✓		
	GYM - 4 UNITS	2	12DEL72-3								✓		
	FEMALE CHANGE RM 1076	1	REMOTE								✓		
	MALE CHANGE RM 1078	1	REMOTE								✓		
	CAFETERIA ENTR.	2	12DEL72-3								✓		
	CAFETERIA ENTR.	1	EXIT LIGHT								✓		

[illegible]

[illegible]

**FIRE ALARM DEVICES**

Location Description	Device	Model	Address	Zone / Circuit #	Inst	Smk	Miss	Alm	Ann	Sup	Dec	FS	Grd	Serv	Remarks
OUTSIDE 123	EOL			4	✓										
OUTSIDE ROOM 157	HORN			3	✓			✓							
OUTSIDE ROOM 157	STRB			4	✓			✓							
BOILER ROOM 179	HORN			3	✓			✓							
BOILER ROOM 179	STRB			4	✓			✓							
WASHROOM 166	STRB			4	✓			✓							
WASHROOM 164	STRB			4	✓			✓							
OUTSIDE ROOM 134	HORN				✓			✓							
OUTSIDE ROOM 134	STRB				✓			✓							
CORRIDOR BY 166	HORN				✓			✓							
CORRIDOR BY 166	STRB				✓			✓							
INSIDE 123	HORN				✓			✓							
INSIDE 123	STRB				✓			✓							

[illegible]

[illegible]

BUILDING NAME: Ravines Bedford**DATE:** April 20, 2023**ADDRESS:** 50 Broad Street**SYSTEM MANUFACTURER:**

Bedford, Nova Scotia

Siemens

MODEL NO.: Cerberus Pro Modular**WO#:****5 FIELD DEVICE RECORD**

(Reference: Clause 4.2.7 and Section 6)

5.1 FIELD DEVICE TESTING - LEGEND AND NOTES

(Reference: Clauses 6.4.1.3, 6.4.1.4, 6.4.1.5, 6.4.5.1-B, 6.8.1.1-B, 6.8.2.2-B, 6.8.2.4, Sections 5.2, 5.3, 5.4)

DEVICE	DESCRIPTION	TYPE	MODEL NO
B	Bell	Siemens	SFM24-6A
DS	Duct Smoke Detector (Notes 1 & 4)	Siemens	FDBZ492-HR
EOL	End of Line Resistor	Siemens	EL300-C
FS	Sprinkler Flow Switch (Note 5)	Siemens	XTRI-S/D
FSD	Fire Smoke Damper	Siemens	XTRI-D
H/S	Horn/Strobe	Siemens	SLH5WW-FB
HT	Heat Detector Fixed 135°	Siemens	HI921
IM	Input Module	Siemens	XTRI
ISO	Isolation Module	Siemens	XTRI-M
M1	Manual Pull Station	Siemens	XTRI-M/MS51-C
M	Manual Pull Station	Siemens	HMS-SA
PS	Sprinkler Pressure Switch	Siemens	XTRI-S/D
R	Relay Output	Siemens	XTRI-R
S	Smoke Detector (Notes 1 & 2)	Siemens	OP921
TS	Sprinkler <i>Supervisory Device</i> (Note 6)	Siemens	XTRI-S/D

5.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.12.1, 6.12.2, Section 5.1)

A - Correctly Installed

B - Requires Service, Repairs,
Cleaning or MissingC - Alarm Operation
ConfirmedD - Annunciation
Indication ConfirmedE - Supervision of Wiring
Device Confirmed**BUILDING NAME:** Bedford Ravines

Location	Device	Circuit #	A	B	C	D	E	Remarks
Level 1								
Door Mag Classroom 1106	R	1-1	✓		✓	✓	✓	
Corridor By Classroom 1106	S	1-2	✓		✓	✓	✓	
Corridor By Classroom 1106	M	1-3	✓		✓	✓	✓	
Kitchen 1101B	HT	1-4	✓		✓	✓	✓	
Classroom 1103	M	1-5	✓		✓	✓	✓	
Classroom 1101	M	1-6	✓		✓	✓	✓	
Corridor By Room 1098	S	1-7	✓		✓	✓	✓	
Corridor By Room 1098	M	1-8	✓		✓	✓	✓	
Corridor By Washroom 1097	S	1-9	✓		✓	✓	✓	
Corridor By Washroom 1097	M	1-10	✓		✓	✓	✓	
Washroom 1097	S	1-11	✓		✓	✓	✓	Isolator
Janitor Room 1070	HT	1-12	✓		✓	✓	✓	
Sector A South Sprinkler Control Valve	TS	1-13	✓		✓	✓	✓	A/C Washroom 1083A Isolator
Sector A North Sprinkler Control Valve	TS	1-14	✓		✓	✓	✓	Near A/C Washroom 1083A
Storage Room 1076C	S	1-15	✓		✓	✓	✓	
Washroom 1078	S	1-16	✓		✓	✓	✓	

Corridor By Washroom 1078	S	1-17	✓		✓	✓	✓	
Corridor By Washroom 1078	M	1-18	✓		✓	✓	✓	
Corridor By Classroom 1080	S	1-19	✓		✓	✓	✓	
Corridor By Classroom 1080	M	1-20	✓		✓	✓	✓	
Storage Room 1088B	S	1-21	✓		✓	✓	✓	
Corridor By Storage 1088B	M	1-22	✓		✓	✓	✓	
Corridor By Storage 1088B	S	1-23	✓		✓	✓	✓	
Learning Center 1083	M	1-24	✓		✓	✓	✓	
Storage Room 1083B	S	1-25	✓		✓	✓	✓	
Sub Comm Room 1077	S	1-26	✓		✓	✓	✓	
Door Mag Sub Comm Room 1077	R	1-27	✓		✓	✓	✓	
Sub Comm Room 1077	S	1-86	✓		✓	✓	✓	
Sub Comm Room 1077	S	1-87	✓		✓	✓	✓	
Supply Fan 12 Shutdown	R	1-28	✓		✓	✓	✓	Sub Comm Room 1077
Elevator Lobby By Room 1077	S	1-29	✓		✓	✓	✓	
Elevator2-1 Pit Sprinkler Control Valve	TS	1-30	✓		✓	✓	✓	
Corridor By Stair ST10-1	S	1-31	✓		✓	✓	✓	
Corridor By Stair ST10-1	M	1-32	✓		✓	✓	✓	
Stair ST10-1 Sprinkler Control Valve	TS	1-33	✓		✓	✓	✓	
By Student Council 1071	S	1-34	✓		✓	✓	✓	
By Student Council 1071	M	1-35	✓		✓	✓	✓	
Fire Smoke Damper #14 Alarm	FSD	1-36A	✓		✓	✓	✓	Practice Room 1096A Isolator
Fire Smoke Damper #14 Trouble	FSD	1-36B	✓		✓	✓	✓	Practice Room 1096A
Door Mag Corridor By Room 1095	R	1-88	✓		✓	✓	✓	
Level 2								
Fire Smoke Damper #15 Alarm	FSD	1-37A	✓		✓	✓	✓	Staff Work Room 2082 Isolator
Fire Smoke Damper #15 Trouble	FSD	1-37B	✓		✓	✓	✓	Staff Work Room 2082
Door Mag Classroom 2090	R	1-38	✓		✓	✓	✓	
Corridor By Stair ST12-2	S	1-39	✓		✓	✓	✓	
Corridor By Stair ST12-2	M1	1-40	✓		✓	✓	✓	Isolator
Top Of Stair ST12-2	S	1-41	✓		✓	✓	✓	
Fire Smoke Damper #19 Alarm	FSD	1-42A	✓		✓	✓	✓	Room 2087 Isolator
Fire Smoke Damper #19 Trouble	FSD	1-42B	✓		✓	✓	✓	Room 2087
Fire Smoke Damper #18 Alarm	FSD	1-43A	✓		✓	✓	✓	Room 2087
Fire Smoke Damper #18 Trouble	FSD	1-43B	✓		✓	✓	✓	Room 2087
Corridor By Staff Room 2084	S	1-44	✓		✓	✓	✓	Isolator
Fire Smoke Damper #70 Alarm	FSD	1-45A	✓		✓	✓	✓	Corridor 2000G Isolator
Fire Smoke Damper #70 Trouble	FSD	1-45B	✓		✓	✓	✓	Corridor 2000G
Corridor By Staff Room 2084	M	1-46	✓		✓	✓	✓	
Corridor By Washroom 2081	S	1-47	✓		✓	✓	✓	Isolator
Corridor By Washroom 2081	M	1-48	✓		✓	✓	✓	
Fire Smoke Damper #69 Alarm	FSD	1-49A	✓		✓	✓	✓	Corridor 2000E
Fire Smoke Damper #69 Trouble	FSD	1-49B	✓		✓	✓	✓	Corridor 2000E
Washroom 2081	S	1-50	✓		✓	✓	✓	
Fire Smoke Damper #68 Alarm	FSD	1-51A	✓		✓	✓	✓	Classroom 2083
Fire Smoke Damper #68 Trouble	FSD	1-51B	✓		✓	✓	✓	Classroom 2083

Fire Smoke Damper #11 Alarm	FSD	1-52A	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #11 Trouble	FSD	1-52B	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #67 Alarm	FSD	1-53A	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #67 Trouble	FSD	1-53B	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #65 Alarm	FSD	1-54A	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #65 Trouble	FSD	1-54B	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #12 Alarm	FSD	1-55A	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #12 Trouble	FSD	1-55B	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #13 Alarm	FSD	1-56A	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #13 Trouble	FSD	1-56B	✓		✓	✓	✓	Sector A Duct Shaft
Fire Smoke Damper #62 Alarm	FSD	1-57A	✓		✓	✓	✓	Washroom 2070
Fire Smoke Damper #62 Trouble	FSD	1-57B	✓		✓	✓	✓	Washroom 2070
Washroom 2070	S	1-58	✓		✓	✓	✓	
Corridor By Washroom 2070	S	1-59	✓		✓	✓	✓	Isolator
Janitor Room 2065	HT	1-60	✓		✓	✓	✓	
Fire Smoke Damper #58 Alarm	FSD	1-61A	✓		✓	✓	✓	Learning Center 2067 Isolator
Fire Smoke Damper #58 Trouble	FSD	1-61B	✓		✓	✓	✓	Learning Center 2067
Fire Smoke Damper #59 Alarm	FSD	1-62A	✓		✓	✓	✓	Corridor 2000E Isolator
Fire Smoke Damper #59 Trouble	FSD	1-62B	✓		✓	✓	✓	Corridor 2000E
Fire Smoke Damper #61 Alarm	FSD	1-63A	✓		✓	✓	✓	Corridor 2000E
Fire Smoke Damper #61 Trouble	FSD	1-63B	✓		✓	✓	✓	Corridor 2000E
Corridor By Washroom 2070	M	1-64	✓		✓	✓	✓	
Corridor By Classroom 2072	S	1-65	✓		✓	✓	✓	Isolator
Fire Smoke Damper #60 Alarm	FSD	1-66A	✓		✓	✓	✓	Corridor 2000F
Fire Smoke Damper #60 Trouble	FSD	1-66B	✓		✓	✓	✓	Corridor 2000F
Corridor By Classroom 2070	M	1-67	✓		✓	✓	✓	
Fire Smoke Damper #09 Alarm	FSD	1-68A	✓		✓	✓	✓	Small Group Work Room 2076
Fire Smoke Damper #09 Trouble	FSD	1-68B	✓		✓	✓	✓	Small Group Work Room 2076
Storage Room 2078A	S	1-69	✓		✓	✓	✓	Isolator
Top Of Stair ST1-2	S	1-70	✓		✓	✓	✓	
Corridor By Classroom 2077	S	1-71	✓		✓	✓	✓	Isolator
Corridor By Classroom 2077	M	1-72	✓		✓	✓	✓	
Classroom 2077 Door Mag	R	1-73	✓		✓	✓	✓	
Fire Smoke Damper #57 Alarm	FSD	1-74A	✓		✓	✓	✓	Learning Center 2067 Isolator
Fire Smoke Damper #57 Trouble	FSD	1-74B	✓		✓	✓	✓	Learning Center 2067
Storage Room 2067B	S	1-75	✓		✓	✓	✓	
Supply Fan 15 Shutdown	R	1-76	✓		✓	✓	✓	Sub Comm Rm 2061
Sub Comm 2061 Door Mag	R	1-77	✓		✓	✓	✓	
Sub Comm Room 2061	S	1-78	✓		✓	✓	✓	
Elevator Lobby 2000E	S	1-79	✓		✓	✓	✓	
Corridor By Classroom 2064	S	1-80	✓		✓	✓	✓	
Corridor By Classroom 2064	M1	1-81	✓		✓	✓	✓	Isolator
Sector A+B 2nd Floor Control Valve	TS	1-82	✓		✓	✓	✓	
Sector A+B 2nd Floor Sprinkler Flow	FS	1-83	✓		✓	✓	✓	Stair ST10-2 58 Sec
Corridor By Music Room 2062	S	1-84	✓		✓	✓	✓	Isolator
Corridor By Music Room 2062	M1	1-85	✓		✓	✓	✓	Isolator

BPS 1 Sub Comm Room 1077	BPS	1-90	✓		✓	✓	✓	
BPS 1 Expander Sub Comm Room 1077	BPS	1-91	✓		✓	✓	✓	
BPS 3 Sub Comm Room 2061	BPS	1-92	✓		✓	✓	✓	
BPS 5Sub Comm Room 2026	BPS	1-94	✓		✓	✓	✓	
BPS 5 Expander Sub Comm Room 2026	BPS	1-95	✓		✓	✓	✓	
BPS 4 Sub Comm Room 1030	BPS	1-96	✓		✓	✓	✓	
BPS 2 Expander Sub Comm Room 1030	BPS	1-97	✓		✓	✓	✓	
Level 1								
Communication Room 1077	HS	BPS1-1	✓		✓	✓	✓	
Library 1073	HS	BPS1-1	✓		✓	✓	✓	
Corridor By Sub Comm 1077	HS	BPS1-1	✓		✓	✓	✓	
Assisted Care Washroom 1083A	HS	BPS1-1	✓		✓	✓	✓	
Corridor By Assisted Care Washroom 1083A	HS	BPS1-1	✓		✓	✓	✓	
Washroom 1078	HS	BPS1-1	✓		✓	✓	✓	
Classroom 1080	HS	BPS1-1	✓		✓	✓	✓	
Corridor By Classroom 1082	HS	BPS1-1	✓		✓	✓	✓	
Classroom 1082	HS	BPS1-1	✓		✓	✓	✓	
Classroom 1088	HS	BPS1-1	✓		✓	✓	✓	
Corridor By Classroom 1093	HS	BPS1-1	✓		✓	✓	✓	
Classroom 1091	HS	BPS1-1	✓		✓	✓	✓	
Classroom 1087	HS	BPS1-1	✓		✓	✓	✓	
Learning Center 1083	HS	BPS1-1	✓		✓	✓	✓	
Music Room 1096	HS	BPS1-2	✓		✓	✓	✓	
Practice Room A 1096A	HS	BPS1-2	✓		✓	✓	✓	
Practice Room B 1096B	HS	BPS1-2	✓		✓	✓	✓	
Corridor By Music Room 1096	HS	BPS1-2	✓		✓	✓	✓	
Classroom 1100	HS	BPS1-2	✓		✓	✓	✓	
Classroom 1104	HS	BPS1-2	✓		✓	✓	✓	
Corridor By Classroom 1106	HS	BPS1-2	✓		✓	✓	✓	
Classroom 1103	HS	BPS1-2	✓		✓	✓	✓	
Classroom 1101	HS	BPS1-2	✓		✓	✓	✓	
Corridor By Classroom 1099	HS	BPS1-2	✓		✓	✓	✓	
Washroom 1097	HS	BPS1-2	✓		✓	✓	✓	
Classroom 1099	HS	BPS1-2	✓		✓	✓	✓	
Guidance Suite 1072	HS	BPS1-2	✓		✓	✓	✓	
Resource Room 1076	HS	BPS1-2	✓		✓	✓	✓	
Level 2								
Classroom 2068	HS	BPS3-2	✓		✓	✓	✓	
Washroom 2070	HS	BPS3-2	✓		✓	✓	✓	
Corridor by Classroom 2074	HS	BPS3-2	✓		✓	✓	✓	
Classroom 2074	HS	BPS3-2	✓		✓	✓	✓	
Corridor By Classroom 2077	HS	BPS3-2	✓		✓	✓	✓	
Classroom 2075	HS	BPS3-2	✓		✓	✓	✓	
Learning Center 2067	HS	BPS3-2	✓		✓	✓	✓	
Corridor Room 2082	HS	BPS3-1	✓		✓	✓	✓	

Washroom 2081	HS	BPS3-1	✓		✓	✓	✓	
Corridor By Classroom 2085	HS	BPS3-1	✓		✓	✓	✓	
Classroom 2085	HS	BPS3-1	✓		✓	✓	✓	
Classroom 2089	HS	BPS3-1	✓		✓	✓	✓	
Corridor By Classroom 2090	HS	BPS3-1	✓		✓	✓	✓	
Classroom 2088	HS	BPS3-1	✓		✓	✓	✓	
Staff Room 2084	HS	BPS3-1	✓		✓	✓	✓	
Corridor By Music Room 2062	HS	BPS3-1	✓		✓	✓	✓	
Sector A West Courtyard Exterior	ST1	BPS1-3	✓		✓	✓	✓	
Sector A West Exterior	ST1	BPS1-3	✓		✓	✓	✓	
Sector A Front Exterior	ST1	BPS1-3	✓		✓	✓	✓	

5.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.12.1, 6.12.2, Section 5.1)

A - Correctly Installed

B - Requires Service, Repairs,
Cleaning or Missing

C - Alarm Operation
Confirmed

D - Annunciation
Indication Confirmed

E - Supervision of Wiring
Device Confirmed

BUILDING NAME: Bedford Ravines

Location	Device	Circuit #	A	B	C	D	E	Remarks
Level 1								
Main Communication Room 1005A	S	3-1	✓		✓	✓	✓	
Work Room 1001F	S	3-2	✓		✓	✓	✓	
Corridor Admin E1001 Exit	M	3-3	✓		✓	✓	✓	
Secure Reception 1009	M	3-4	✓		✓	✓	✓	
Corridor By Seminar 1011	M	3-5	✓		✓	✓	✓	
Washroom 1013	S	3-6	✓		✓	✓	✓	
Corridor By Washroom 1013 Door Mag	R	3-7	✓		✓	✓	✓	
Corridor By Washroom 1013	S	3-8	✓		✓	✓	✓	
Corridor By Washroom 1013	M	3-9	✓		✓	✓	✓	
Recycling Room 1008	HT	3-10	✓		✓	✓	✓	
Fire Smoke Damper 33 Alarm	FSD	3-11A	✓		✓	✓	✓	By Kitchen 1006
Fire Smoke Damper 33 Trouble	FSD	3-11B	✓		✓	✓	✓	By Kitchen 1006
Sector B Center Stair Control Valve	TS	3-12	✓		✓	✓	✓	
Kitchen Hood System Release	IM	3-13	✓		✓	✓	✓	
Fire Smoke Damper 29 Alarm	FSD	3-14A	✓		✓	✓	✓	By Kitchen 1006
Fire Smoke Damper 29 Trouble	FSD	3-14B	✓		✓	✓	✓	By Kitchen 1006
Kitchen 1006	M	3-15	✓		✓	✓	✓	
Kitchen Storage 1006A	S	3-16	✓		✓	✓	✓	
Kitchen Shunt Trip Relay	R	3-17	✓		✓	✓	✓	Kitchen Storage 1006A
Secure Reception 1001	M	3-18	✓		✓	✓	✓	
Water Room E1000	HT	3-19	✓		✓	✓	✓	
Backflow Valve A	TS	3-20	✓		✓	✓	✓	
Backflow Valve B	TS	3-21	✓		✓	✓	✓	
Backflow Test Valve	TS	3-22	✓		✓	✓	✓	Normally Closed Valve
Fire Hydrant Control Valve	TS	3-23	✓		✓	✓	✓	
Sprinkler Control Header Valve	TS	3-24B	✓		✓	✓	✓	
Sector A 1st Floor Flow	FS	3-25A	✓		✓	✓	✓	44 Sec
Sector A 1st Floor Control Valve	TS	3-25B	✓		✓	✓	✓	

Sector B 1st Floor Flow	FS	3-26A	✓		✓	✓	✓	37 Sec
Sector B 1st Floor Control Valve	TS	3-26B	✓		✓	✓	✓	
Main Sprinkler Flow 1	FS	3-27A	✓		✓	✓	✓	
Main Sprinkler Control Valve 1	TS	3-27B	✓		✓	✓	✓	
Main Sprinkler Flow 2	FS	3-28A	✓		✓	✓	✓	
Main Sprinkler Control Valve 2	TS	3-28B	✓		✓	✓	✓	
Sector A Standpipe Flow	FS	3-29A	✓		✓	✓	✓	
Sector A Standpipe Control Valve	TS	3-29B	✓		✓	✓	✓	
Water Room E1000 Exit	M	3-30	✓		✓	✓	✓	
Main Exit By Seminar 1002	M	3-31	✓		✓	✓	✓	
Washroom 1004	S	3-32	✓		✓	✓	✓	
Corridor By Washroom 1004	S	3-33	✓		✓	✓	✓	
Corridor By Washroom 1004 Door Mag	R	3-34	✓		✓	✓	✓	
Corridor By Washroom 1004	M	3-35	✓		✓	✓	✓	
Recycling Room 1069	HT	3-36	✓		✓	✓	✓	
Cafeteria 1045D Exit	M	3-135	✓		✓	✓	✓	
Cafeteria 1045D Exit	ISO	3-147	✓		✓	✓	✓	
Corridor By Washroom 2057	M	3-37	✓		✓	✓	✓	
Corridor By Washroom 2057	ISO	3-143	✓		✓	✓	✓	
Corridor By Washroom 2057	S	3-38	✓		✓	✓	✓	
Washroom 2057	S	3-39	✓		✓	✓	✓	
Fire Smoke Damper 71 Alarm	FSD	3-40A	✓		✓	✓	✓	Washroom 2057 Isolator
Fire Smoke Damper 71 Trouble	FSD	3-40B	✓		✓	✓	✓	Washroom 2057 Isolator
Fire Smoke Damper 109 Alarm	FSD	3-41A	✓		✓	✓	✓	Washroom 2057
Fire Smoke Damper 109 Trouble	FSD	3-41B	✓		✓	✓	✓	Washroom 2057
Storage Room 1050B	S	3-42	✓		✓	✓	✓	Isolator (3-43,139)
Fire Smoke Damper 77 Alarm	FSD	3-43A	✓		✓	✓	✓	Drama 1056
Fire Smoke Damper 77 Trouble	FSD	3-43B	✓		✓	✓	✓	Drama 1056
Fire Smoke Damper 76 Alarm	FSD	3-44A	✓		✓	✓	✓	Drama 1056 Isolator
Fire Smoke Damper 76 Trouble	FSD	3-44B	✓		✓	✓	✓	Drama 1056 Isolator
P.A. Mute Gym Storage 1052	R	3-153	✓		✓	✓	✓	
Level 2								
Fire Smoke Damper 74 Alarm	FSD	3-45A	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 74 Trouble	FSD	3-45B	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 24 Alarm	FSD	3-46A	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 24 Trouble	FSD	3-46B	✓		✓	✓	✓	Fan Room 2007Z
Fan Room 2007Z Sprinkler Flow	FS	3-47A	✓		✓	✓	✓	Fan Room 2007Z 30 Sec
Fan Room 2007Z Sprinkler Control Valve	TS	3-47B	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 72 Alarm	FSD	3-48A	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 72 Trouble	FSD	3-48B	✓		✓	✓	✓	Fan Room 2007Z
Mechanical Room Stair ST8-2	S	3-134	✓		✓	✓	✓	
Fan Room 2007Z Exit	M	3-49	✓		✓	✓	✓	
Fan Room 2007Z Exit	ISO	3-149	✓		✓	✓	✓	Isolator (3-134)
Fire Smoke Damper 73 Alarm	FSD	3-50A	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 73 Trouble	FSD	3-50B	✓		✓	✓	✓	Fan Room 2007Z
Fan Room 2007Z	S	3-51	✓		✓	✓	✓	

AHU #3 Shutdown	R	3-52	✓		✓	✓	✓	Fan Room 2007Z
Fan Room 2007Z	S	3-53	✓		✓	✓	✓	
AHU #2 Shutdown	R	3-54	✓		✓	✓	✓	
Fire Smoke Damper 20 Alarm	FSD	3-55A	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 20 Trouble	FSD	3-55B	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 21 Alarm	FSD	3-56A	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 21 Trouble	FSD	3-56B	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 22 Alarm	FSD	3-57A	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 22 Trouble	FSD	3-57B	✓		✓	✓	✓	Fan Room 2007Z
Fan Room 2007Z	S	3-58	✓		✓	✓	✓	
ERV-2 Shutdown	R	3-59	✓		✓	✓	✓	Fan Room 2007Z
Fan Room 2007Z Exit	M	3-60	✓		✓	✓	✓	
Fan Room 2007Z Exit	ISO	3-150	✓		✓	✓	✓	Isolator (3-49,50,51,52,53,5
Stairwell By Electrical Room 2005z	S	3-61	✓		✓	✓	✓	
Main Electrical Room 2005Z	M	3-62	✓		✓	✓	✓	
Main Electrical Room 2005Z	ISO	3-151	✓		✓	✓	✓	Isolator (3-61)
Main Electrical Room 2005Z	S	3-63	✓		✓	✓	✓	Isolator
Outdoor Storage E1002	M	3-64	✓		✓	✓	✓	
Outdoor Storage E1002	ISO	3-144	✓		✓	✓	✓	Isolator(3-64 - 94)
Outdoor Storage E1002	HT	3-65	✓		✓	✓	✓	
Gym Area Level 1								
Change Room 1059	S	3-66	✓		✓	✓	✓	
Gym Storage 1063	S	3-67	✓		✓	✓	✓	
Gym Storage 1063 PA Mute	R	3-68	✓		✓	✓	✓	
Main Electrical Room Stair Control Valve	TS	3-69B	✓		✓	✓	✓	Active Healthy Living 1065
Sector B North Sprinkler Flow	FS	3-70A	✓		✓	✓	✓	42 Sec
Sector B North Control Valve	TS	3-70B	✓		✓	✓	✓	Active Healthy Living 1065
Fire Smoke Damper 25 Alarm	FSD	3-71A	✓		✓	✓	✓	Active Healthy Living 1065
Fire Smoke Damper 25 Trouble	FSD	3-71B	✓		✓	✓	✓	Active Healthy Living 1065
Fan Room 2000Z Stairwell Control Valve	TS	3-72	✓		✓	✓	✓	Active Healthy Living 1065
Cafeteria 1045C Exit	M	3-73	✓		✓	✓	✓	
Comm Rm 1054 Supply Fan Shutdown	R	3-74	✓		✓	✓	✓	Communication Room 1054
Communication Room 1054	S	3-75	✓		✓	✓	✓	
Gym Storage 1052	S	3-76	✓		✓	✓	✓	
Chair Storage	S	3-77	✓		✓	✓	✓	
Chair Storage	S	3-78	✓		✓	✓	✓	
Chair Storage	S	3-79	✓		✓	✓	✓	
Chair Storage	S	3-80	✓		✓	✓	✓	
Chair Storage	S	3-81	✓		✓	✓	✓	
Chair Storage	S	3-82	✓		✓	✓	✓	
Chair Storage	S	3-83	✓		✓	✓	✓	
Chair Storage	S	3-84	✓		✓	✓	✓	
Chair Storage	S	3-137	✓		✓	✓	✓	
Cafeteria 1045B	M	3-85	✓		✓	✓	✓	
Cafeteria 1045B	M	3-86	✓		✓	✓	✓	
Boiler Room Stair Control Valve	TS	3-87A	✓		✓	✓	✓	Active Healthy Living 1047

Fan Room 2000Z Stair Control Valve	TS	3-87B	✓		✓	✓	✓	Active Healthy Living 1047
Fire Smoke Damper 37 Alarm	FSD	3-88A	✓		✓	✓	✓	Active Healthy Living 1047
Fire Smoke Damper 37 Trouble	FSD	3-88B	✓		✓	✓	✓	Active Healthy Living 1047
Fire Smoke Damper 40 Alarm	FSD	3-89A	✓		✓	✓	✓	Change Room 1051
Fire Smoke Damper 40 Trouble	FSD	3-89B	✓		✓	✓	✓	Change Room 1051
Change Room 1051	S	140	✓		✓	✓	✓	
Gym 1053 Right Exit	M	3-138	✓		✓	✓	✓	
Gym 1053 Left Exit	M	3-92	✓		✓	✓	✓	
Gym 1055 Right Exit	M	3-93	✓		✓	✓	✓	
Gym 1055 Left Exit	M	3-94	✓		✓	✓	✓	
Gym 1055 Left Exit	ISO	3-145	✓		✓	✓	✓	Isolator
Level 2								
Boiler Room 2003Z	M	3-95	✓		✓	✓	✓	
Boiler Room 2003Z	ISO	3-146	✓		✓	✓	✓	Isolator
Boiler Room 2003Z	S/CO	3-96	✓		✓	✓	✓	
Boiler Room 2003Z	HT	3-97	✓		✓	✓	✓	
Supply Fan 10 Shutdown	R	3-98	✓		✓	✓	✓	Boiler Room 2003Z
Boiler Room 2003Z	S/CO	3-99	✓		✓	✓	✓	
Fire Smoke Damper 39 Alarm	FSD	3-100A	✓		✓	✓	✓	Fan Room 2000Z
Fire Smoke Damper 39 Trouble	FSD	3-100B	✓		✓	✓	✓	Fan Room 2000Z
Fan Room 2000Z	S	3-101	✓		✓	✓	✓	
Fire Smoke Damper 38 Alarm	FSD	3-102A	✓		✓	✓	✓	Fan Room 2000Z
Fire Smoke Damper 38 Trouble	FSD	3-102B	✓		✓	✓	✓	Fan Room 2000Z
AHU #1 Shutdown	R	3-103	✓		✓	✓	✓	Fan Room 2000Z
Fan Room 2000Z	S	3-104	✓		✓	✓	✓	
Fire Smoke Damper 85 Alarm	FSD	3-105A	✓		✓	✓	✓	Fan Room 2000Z
Fire Smoke Damper 85 Trouble	FSD	3-105B	✓		✓	✓	✓	Fan Room 2000Z
Fire Smoke Damper 36 Alarm	FSD	3-106A	✓		✓	✓	✓	Fan Room 2000Z
Fire Smoke Damper 36 Trouble	FSD	3-106B	✓		✓	✓	✓	Fan Room 2000Z
ERV-1 Shutdown	R	3-107	✓		✓	✓	✓	Fan Room 2000Z
Fan Room 2000Z	M	3-108	✓		✓	✓	✓	
Boiler Room 2003Z Sprinkler Flow	FS	3-109A	✓		✓	✓	✓	22 Sec Isolator (3-95 - 108)
Boiler Room 2003Z Control Valve	TS	3-109B	✓		✓	✓	✓	Isolator (3-110)
Mechanical Room Stair ST5-2	S	3-110	✓		✓	✓	✓	
Fire Smoke Damper 113 Alarm	FSD	3-111A	✓		✓	✓	✓	Washroom 2002 Isolator
Fire Smoke Damper 113 Trouble	FSD	3-111B	✓		✓	✓	✓	Washroom 2002 Isolator
Washroom 2002	S	3-112	✓		✓	✓	✓	
Fire Smoke Damper 83 Alarm	FSD	3-113A	✓		✓	✓	✓	Washroom 2002
Fire Smoke Damper 83 Trouble	FSD	3-113B	✓		✓	✓	✓	Washroom 2002
Corridor By Washroom 2002	S	3-114	✓		✓	✓	✓	
Corridor By Washroom 2002	M	3-115	✓		✓	✓	✓	
Fire Smoke Damper 34 Alarm	FSD	3-116A	✓		✓	✓	✓	By Resource 2005
Fire Smoke Damper 34 Trouble	FSD	3-116B	✓		✓	✓	✓	By Resource 2005
Fire Smoke Damper 112 Alarm	FSD	3-117A	✓		✓	✓	✓	By Classroom 2003
Fire Smoke Damper 112 Trouble	FSD	3-117B	✓		✓	✓	✓	By Classroom 2003
Fire Smoke Damper 114 Alarm	FSD	3-118A	✓		✓	✓	✓	By Classroom 2001

Fire Smoke Damper 114 Trouble	FSD	3-118B	✓		✓	✓	✓	By Classroom 2001
Fire Smoke Damper 115 Alarm	FSD	3-119A	✓		✓	✓	✓	By Classroom 2001
Fire Smoke Damper 115 Trouble	FSD	3-119B	✓		✓	✓	✓	By Classroom 2001
Corridor By Stair ST1-2	S	3-120	✓		✓	✓	✓	
Fire Smoke Damper 32 Alarm	FSD	3-121A	✓		✓	✓	✓	By Stair ST1-2
Fire Smoke Damper 32 Trouble	FSD	3-121B	✓		✓	✓	✓	By Stair ST1-2
Corridor By Stair ST1-2	ISO	3-152	✓		✓	✓	✓	Isolator (3-123,124)
Corridor By Stair ST1-2	M	3-122	✓		✓	✓	✓	
Sector B/C+D 2nd Floor Control Valve	TS	3-123	✓		✓	✓	✓	Stair ST1-2
Sector B/C+D 2nd Floor Sprinkler Flow	FS	3-124A	✓		✓	✓	✓	Stair ST1-2 55 Sec
Fire Smoke Damper 30 Alarm	FSD	3-125A	✓		✓	✓	✓	By Sub Comm 2052
Fire Smoke Damper 30 Trouble	FSD	3-125B	✓		✓	✓	✓	By Sub Comm 2052
Fire Smoke Damper 31 Alarm	FSD	3-126A	✓		✓	✓	✓	By Sub Comm 2052 Isolator
Fire Smoke Damper 31 Trouble	FSD	3-126B	✓		✓	✓	✓	By Sub Comm 2052 Isolator
Fire Smoke Damper 111 Alarm	FSD	3-127A	✓		✓	✓	✓	By Classroom 2054
Fire Smoke Damper 111 Trouble	FSD	3-127B	✓		✓	✓	✓	By Classroom 2054
Fire Smoke Damper 110 Alarm	FSD	3-128A	✓		✓	✓	✓	By Classroom 2054
Fire Smoke Damper 110 Trouble	FSD	3-128B	✓		✓	✓	✓	By Classroom 2054
Fire Smoke Damper 27 Alarm	FSD	3-129A	✓		✓	✓	✓	Classroom 2056
Fire Smoke Damper 27 Trouble	FSD	3-129B	✓		✓	✓	✓	Classroom 2056
Classroom 2054 Door Mag	R	3-130	✓		✓	✓	✓	
Fire Smoke Damper 28 Alarm	FSD	3-136A	✓		✓	✓	✓	By Sub Comm 2052
Fire Smoke Damper 28 Trouble	FSD	3-136B	✓		✓	✓	✓	By Sub Comm 2052
Sub Comm Room 2052	S	3-131	✓		✓	✓	✓	
Supply Fan Shutdown	R	3-132	✓		✓	✓	✓	Sub Comm Room 2052
BAS Relay	R	3-133	✓		✓	✓		Main Communication Room
Drama Room 1056 PA Mute	R	3-139	✓		✓	✓	✓	
Fire Smoke Damper 75 Alarm	FSD	3-141	✓		✓	✓	✓	Fan Room 2007Z Isolator
Fire Smoke Damper 75 Trouble	FSD	3-141	✓		✓	✓	✓	Fan Room 2007Z Isolator
Fire Smoke Damper 84 Alarm	FSD	3-142	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 84 Trouble	FSD	3-142	✓		✓	✓	✓	Fan Room 2007Z
Fire Smoke Damper 23 Alarm	FSD	3-148A	✓		✓	✓	✓	Gym Storage 1063
Fire Smoke Damper 23 Trouble	FSD	3-148B	✓		✓	✓	✓	Gym Storage 1063
1st Floor								
Main Comm Room 1005A	HS	SC1	✓		✓	✓	✓	
Corridor By Kitchen 1006	HS	SC1	✓		✓	✓	✓	
Kitchen 1006	HS	SC1	✓		✓	✓	✓	
Secure Reception 1009	HS	SC1	✓		✓	✓	✓	
Admin Secure Exit	HS	SC1	✓		✓	✓	✓	
Secure Reception 1001	HS	SC1	✓		✓	✓	✓	
Corridor By Secure Reception 1001	HS	SC1	✓		✓	✓	✓	
Washroom 1004	HS	SC1	✓		✓	✓	✓	
Water Room E1000	HS	SC1	✓		✓	✓	✓	
Cafeteria 1054D	HS	SC1	✓		✓	✓	✓	
Gym 1055	HS	SC2	✓		✓	✓	✓	
Gym 1055	HS	SC2	✓		✓	✓	✓	

Change Room 1059	HS	SC2	✓		✓	✓	✓	
Outside Storage Room E1002	HS	SC2	✓		✓	✓	✓	
Gym 1053	HS	SC2	✓		✓	✓	✓	
Change Room 1051	HS	SC2	✓		✓	✓	✓	
Gym 1053	HS	SC2	✓		✓	✓	✓	
Cafeteria 1045C	HS	SC2	✓		✓	✓	✓	
Cafeteria 1045C	HS	SC3	✓		✓	✓	✓	
Cafeteria 1045	HS	SC3	✓		✓	✓	✓	
Drama Room 1056	HS	SC3	✓		✓	✓	✓	
Stage 1050	HS	SC3	✓		✓	✓	✓	
Practice Room A 1050C	HS	SC3	✓		✓	✓	✓	
Practice Room B 1050D	HS	SC3	✓		✓	✓	✓	
Cafeteria 1045C	HS	SC3	✓		✓	✓	✓	
Washroom 1013	HS	SC3	✓		✓	✓	✓	
Gym Storage 1052	HS	SC3	✓		✓	✓	✓	
2nd Floor								
Fan Room 2007Z	HS	BPS4-3	✓		✓	✓	✓	
Fan Room 2007Z	HS	BPS4-3	✓		✓	✓	✓	
Main Electrical Room 2005Z	HS	BPS4-3	✓		✓	✓	✓	
Boiler Room 2003Z	HS	BPS4-3	✓		✓	✓	✓	
Fan Room 2000Z	HS	BPS4-3	✓		✓	✓	✓	
Washroom 2057	HS	BPS4-4	✓		✓	✓	✓	
Corridor By Room 2058	HS	BPS4-4	✓		✓	✓	✓	
Classroom 2054	HS	BPS4-4	✓		✓	✓	✓	
Classroom 2056	HS	BPS4-4	✓		✓	✓	✓	
Corridor By Comm Room 2052	HS	BPS4-4	✓		✓	✓	✓	
Corridor By Room 2005	HS	BPS4-4	✓		✓	✓	✓	
Classroom 2007	HS	BPS4-4	✓		✓	✓	✓	
Washroom 20002	HS	BPS4-4	✓		✓	✓	✓	
Gym Exterior	ST1	SC4	✓		✓	✓	✓	
Outside Water Room	B	SC6	✓		✓	✓	✓	Rings on Any Water Flow
Outside Water Room	EOL	SC6	✓				✓	
Sector B Front	ST1	SC4	✓		✓	✓	✓	

5.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.12.1, 6.12.2, Section 5.1)

A - Correctly Installed

B - Requires Service, Repairs,
Cleaning or Missing

C - Alarm Operation
Confirmed

D - Annunciation
Indication Confirmed

E - Supervision of Wiring
Device Confirmed

BUILDING NAME: Bedford Ravines

Location	Device	Circuit #	A	B	C	D	E	Remarks
Level 2								
Corridor By Room 2004	S	4-100	✓		✓	✓	✓	Isolator (4-101-106)
Corridor By Room 2004	M	4-101	✓		✓	✓	✓	
Corridor By Stair ST2-2	M	4-102	✓		✓	✓	✓	
Corridor By Stair ST2-2	S	4-103	✓		✓	✓	✓	
Elevator EL4-2 Lobby	S	4-104	✓		✓	✓	✓	
Library 2013 Door Mag	R	4-105	✓		✓	✓	✓	

Sub Comm Room 2026	S	4-106	✓		✓	✓	✓	
Storage Room 2032A	S	4-107	✓		✓	✓	✓	
Fire Smoke Damper #86 Alarm	FSD	4-108A	✓		✓	✓	✓	Program A Room 2032A
Fire Smoke Damper #86 Trouble	FSD	4-108B	✓		✓	✓	✓	Program A Room 2032A
Storage Room 2032B	S	4-109	✓		✓	✓	✓	
Fire Smoke Damper #87 Alarm	FSD	4-110A	✓		✓	✓	✓	Storage Room 2032B
Fire Smoke Damper #87 Trouble	FSD	4-110B	✓		✓	✓	✓	Storage Room 2032B
Corridor By Stair ST3-2	S	4-111	✓		✓	✓	✓	Isolator (4-112)
Top Of Stair ST3-2	S	4-112	✓		✓	✓	✓	
Corridor By Stair ST3-2	M	4-113	✓		✓	✓	✓	
Corridor By Stair ST3-2	ISO	4-233	✓		✓	✓	✓	Isolator (4-114-147)
Classroom 2049 Door Mag	R	4-114	✓		✓	✓	✓	
Washroom 2041	S	4-115	✓		✓	✓	✓	
Fire Smoke Damper #93 Alarm	FSD	4-116A	✓		✓	✓	✓	Washroom 2041
Fire Smoke Damper #93 Trouble	FSD	4-116B	✓		✓	✓	✓	Washroom 2041
Fire Smoke Damper #92 Alarm	FSD	4-117A	✓		✓	✓	✓	Washroom 2041
Fire Smoke Damper #92 Trouble	FSD	4-117B	✓		✓	✓	✓	Washroom 2041
Corridor By Classroom 2032	S	4-118	✓		✓	✓	✓	
Fire Smoke Damper #89 Alarm	FSD	4-119A	✓		✓	✓	✓	Corridor 2000C
Fire Smoke Damper #89 Trouble	FSD	4-119B	✓		✓	✓	✓	Corridor 2000C
Fire Smoke Damper #88 Alarm	FSD	4-120A	✓		✓	✓	✓	Corridor 2000C
Fire Smoke Damper #88 Trouble	FSD	4-120B	✓		✓	✓	✓	Corridor 2000C
Corridor By Classroom 2032	M	4-121	✓		✓	✓	✓	
Corridor By Janitors Office 2030	S	4-122	✓		✓	✓	✓	
Corridor By Janitors Office 2030	M	4-123	✓		✓	✓	✓	
Fire Smoke Damper # 91 Alarm	FSD	4-124A	✓		✓	✓	✓	Corridor By Janitors Office 2030
Fire Smoke Damper # 91 Trouble	FSD	4-124B	✓		✓	✓	✓	Corridor By Janitors Office 2030
Fire Smoke Damper # 100 Alarm	FSD	4-125A	✓		✓	✓	✓	Corridor By Janitors Office 2030
Fire Smoke Damper # 100 Trouble	FSD	4-125B	✓		✓	✓	✓	Corridor By Janitors Office 2030
Fire Smoke Damper #98 Alarm	FSD	4-126A	✓		✓	✓	✓	Corridor By Janitors Office 2030
Fire Smoke Damper #98 Trouble	FSD	4-126B	✓		✓	✓	✓	Corridor By Janitors Office 2030
Fire Smoke Damper #119 Alarm	FSD	4-127A	✓		✓	✓	✓	Corridor By Janitors Office 2030
Fire Smoke Damper #119 Trouble	FSD	4-127B	✓		✓	✓	✓	Corridor By Janitors Office 2030
Janitors Room 2028	HT	4-128	✓		✓	✓	✓	
Fire Smoke Damper #94 Alarm	FSD	4-129A	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #94 Trouble	FSD	4-129B	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #45 Alarm	FSD	4-130A	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #45 Trouble	FSD	4-130B	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #103 Alarm	FSD	4-131A	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #103 Trouble	FSD	4-131B	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #102 Alarm	FSD	4-132A	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #102 Trouble	FSD	4-132B	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #42 Alarm	FSD	4-133A	✓		✓	✓	✓	Library 2013
Fire Smoke Damper #42 Trouble	FSD	4-133B	✓		✓	✓	✓	Library 2013
Fire Smoke Damper # 106 Alarm	FSD	4-134A	✓		✓	✓	✓	By Stair ST9-2 Ladder
Fire Smoke Damper # 106 Trouble	FSD	4-134B	✓		✓	✓	✓	By Stair ST9-2 Ladder

Fire Smoke Damper # 107 Alarm	FSD	4-135A	✓		✓	✓	✓	By Stair ST9-2 Ladder
Fire Smoke Damper # 107 Trouble	FSD	4-135B	✓		✓	✓	✓	By Stair ST9-2 Ladder
Fire Smoke Damper # 108 Alarm	FSD	4-136A	✓		✓	✓	✓	By Stair ST9-2 Ladder
Fire Smoke Damper # 108 Trouble	FSD	4-136B	✓		✓	✓	✓	By Stair ST9-2 Ladder
Fire Smoke Damper # 46 Alarm	FSD	4-137A	✓		✓	✓	✓	By Stair ST9-2 Ladder
Fire Smoke Damper # 46 Trouble	FSD	4-137B	✓		✓	✓	✓	By Stair ST9-2 Ladder
By Stair ST9-2 Ladder	S	4-138	✓		✓	✓	✓	
By Stair ST9-2 Ladder	M	4-139	✓		✓	✓	✓	
Corridor By Washroom 2016	S	4-140	✓		✓	✓	✓	
Corridor By Washroom 2016	M	4-141	✓		✓	✓	✓	
Washroom 2016	S	4-142	✓		✓	✓	✓	
Storage Room 2017C	S	4-143	✓		✓	✓	✓	
Fire Smoke Damper # 53 Alarm	FSD	4-144A	✓		✓	✓	✓	Corridor 2000B
Fire Smoke Damper # 53 Trouble	FSD	4-144B	✓		✓	✓	✓	Corridor 2000B
Fire Smoke Damper # 54 Alarm	FSD	4-145A	✓		✓	✓	✓	Corridor 2000B
Fire Smoke Damper # 54 Trouble	FSD	4-145B	✓		✓	✓	✓	Corridor 2000B
Fire Smoke Damper # 55 Alarm	FSD	4-146A	✓		✓	✓	✓	Corridor 2000B
Fire Smoke Damper # 55 Trouble	FSD	4-146B	✓		✓	✓	✓	Corridor 2000B
Corridor By Stair ST4-2	S	4-147	✓		✓	✓	✓	
Corridor By Stair ST4-2 Door Mag	R	4-148	✓		✓	✓	✓	Isolator (4-149)
Top of Stair ST4-2	S	4-149	✓		✓	✓	✓	
Corridor By Stair ST4-2	M	4-150	✓		✓	✓	✓	
Corridor By Stair ST4-2	ISO	4-234	✓		✓	✓	✓	Isolator (4-150)
Corridor By Stair ST4-2	ISO	4-236	✓		✓	✓	✓	Isolator
SF-17 Shutdown	R	4-232	✓		✓	✓	✓	Sub Comm 2026
Level 1								
Corridor By Stair ST4-1	M	4-151	✓		✓	✓	✓	
Corridor By Stair ST4-1	ISO	4-235	✓		✓	✓	✓	Isolator (4-151 - 4-231)
Corridor By Stair ST4-1	S	4-152	✓		✓	✓	✓	
Corridor By Stair ST4-1 Door Mag	R	4-153	✓		✓	✓	✓	
Fire Smoke Damper #56 Alarm	FSD	4-154A	✓		✓	✓	✓	Chem Lab 1026
Fire Smoke Damper #56 Trouble	FSD	4-154B	✓		✓	✓	✓	Chem Lab 1026
Lab Prep 1024A	S	4-155	✓		✓	✓	✓	
Fire Smoke Damper #50 Alarm	FSD	4-156A	✓		✓	✓	✓	Chem Lab 1024
Fire Smoke Damper #50 Trouble	FSD	4-156B	✓		✓	✓	✓	Chem Lab 1024
Fire Smoke Damper #51 Alarm	FSD	4-157A	✓		✓	✓	✓	Chem Lab 1024
Fire Smoke Damper #51 Trouble	FSD	4-157B	✓		✓	✓	✓	Chem Lab 1024
Fire Smoke Damper #52 Alarm	FSD	4-158A	✓		✓	✓	✓	By Chem Lab 1024
Fire Smoke Damper #52 Trouble	FSD	4-158B	✓		✓	✓	✓	By Chem Lab 1024
Washroom 1022	S	4-159	✓		✓	✓	✓	
Sector C/D North Sprinkler Control Valve	TS	4-160A	✓		✓	✓	✓	
Sector C/D South Sprinkler Control Valve	TS	4-160B	✓		✓	✓	✓	
Sector C/D 1st Floor Sprinkler Flow	FS	4-161A	✓		✓	✓	✓	23 Sec
Sector C/D 1st Floor Sprinkler Control Valve	TS	4-161B	✓		✓	✓	✓	
Fire Smoke Damper # 116 Alarm	FSD	4-162a	✓		✓	✓	✓	By Info Tech 1029
Fire Smoke Damper # 116 Trouble	FSD	4-162B	✓		✓	✓	✓	By Info Tech 1029

Corridor by Info Tech 1029	S	4-163	✓		✓	✓	✓	
Corridor By Washroom 1022	M	4-164	✓		✓	✓	✓	
Corridor By Washroom 1022	S	4-165	✓		✓	✓	✓	
Corridor by Info Tech 1029	M	4-166	✓		✓	✓	✓	
Guidance Suite 1015	M	4-167	✓		✓	✓	✓	
Sector C/D Stair ST2-1 Sprinkler Control Valve	TS	4-168	✓		✓	✓	✓	
Fire Smoke Damper # 44 Alarm	FSD	4-169A	✓		✓	✓	✓	Storage Room 1031A
Fire Smoke Damper # 44 Trouble	FSD	4-169B	✓		✓	✓	✓	Storage Room 1031A
Fire Smoke Damper # 43 Alarm	FSD	4-170A	✓		✓	✓	✓	Storage Room 1031A
Fire Smoke Damper # 43 Trouble	FSD	4-170B	✓		✓	✓	✓	Storage Room 1031A
Storage Room 1031A	S	4-171	✓		✓	✓	✓	
Corridor By Itinerant 1034	S	4-172	✓		✓	✓	✓	
Corridor By Itinerant 1034	M	4-173	✓		✓	✓	✓	
Corridor By Room 1036	S	4-174	✓		✓	✓	✓	
Corridor By Room 1036	M	4-175	✓		✓	✓	✓	
Storage Room 1036B	S	4-176	✓		✓	✓	✓	
Learning Center 1036	M	4-177	✓		✓	✓	✓	
Washroom 1035	S	4-178	✓		✓	✓	✓	
Classroom 1043 Door Mag	R	4-179	✓		✓	✓	✓	
Corridor By Stair ST3-1	M	4-180	✓		✓	✓	✓	
Corridor By Stair ST3-1	S	4-181	✓		✓	✓	✓	Isolator
Sub Comm 1030	S	4-215	✓		✓	✓	✓	
Janitor Room 2032	HT	4-216	✓		✓	✓	✓	
Fire Smoke Damper # 02 Alarm	FSD	4-217	✓		✓	✓	✓	By Sub Comm 1030
Fire Smoke Damper # 02 Trouble	FSD	4-217	✓		✓	✓	✓	By Sub Comm 1030
Corridor By Sub Comm 1030 Door Mag	R	4-218	✓		✓	✓	✓	
Elevator Lobby EL4-1	S	4-219	✓		✓	✓	✓	
Corridor By Stair ST2-1	S	4-220	✓		✓	✓	✓	
Corridor By Stair ST2-1	M	4-221	✓		✓	✓	✓	
Corridor By Room 1012	M	4-222	✓		✓	✓	✓	
Corridor By Room 1012	S	4-223	✓		✓	✓	✓	
Atrium AT4-1	S	4-224	✓		✓	✓	✓	
Atrium AT4-1	S	4-225	✓		✓	✓	✓	
Atrium AT4-1	S	4-226	✓		✓	✓	✓	
Atrium AT4-1	S	4-227	✓		✓	✓	✓	
SF-13 Shutdown	R	4-228	✓		✓	✓	✓	Sub Comm 1030
Fire Smoke Damper # 05 Alarm	FSD	4-229	✓		✓	✓	✓	Resource 1033
Fire Smoke Damper # 05 Trouble	FSD	4-229	✓		✓	✓	✓	Resource 1033
Fire Smoke Damper # 04 Alarm	FSD	4-230	✓		✓	✓	✓	Resource 1033
Fire Smoke Damper # 04 Trouble	FSD	4-230	✓		✓	✓	✓	Resource 1033
Resource Room 1033	DS	4-231	✓		✓	✓	✓	0.11% in/wc
Level 0								
Corridor By Stair ST3-0	S	4-1	✓		✓	✓	✓	Isolator (all level 0 devices)
Sector C/D Level 0 Sprinkler Control Valve	TS	4-2	✓		✓	✓	✓	
Sector C/D Level 0 Sprinkler Flow	FS	4-3	✓		✓	✓	✓	49 Sec
Corridor By Stair ST3-0	M	4-48	✓		✓	✓	✓	

Skilled Traded Room 0015	M	4-4	✓		✓	✓	✓	
Storage Crib 0015A	S	4-5	✓		✓	✓	✓	
Fire Smoke Damper #118 Alarm	FSD	4-6A	✓		✓	✓	✓	Skilled Trades 0015
Fire Smoke Damper #118 Trouble	FSD	4-6B	✓		✓	✓	✓	Skilled Trades 0015
Fire Smoke Damper #117 Alarm	FSD	4-7A	✓		✓	✓	✓	Skilled Trades 0015
Fire Smoke Damper #117 Trouble	FSD	4-7B	✓		✓	✓	✓	Skilled Trades 0015
Corridor 0000E	S	4-8	✓		✓	✓	✓	
Corridor By Skilled Trades 0015	S	4-9	✓		✓	✓	✓	
Production Lab 0013	M	4-10	✓		✓	✓	✓	
Fire Smoke Damper #03 Alarm	FSD	4-11A	✓		✓	✓	✓	Production Lab 0013
Fire Smoke Damper #03 Trouble	FSD	4-11B	✓		✓	✓	✓	Production Lab 0013
Visual Arts Room 0009	M	4-12	✓		✓	✓	✓	
Production Lab 005	M	4-13	✓		✓	✓	✓	
AHU-11 Shutdown	R	4-14	✓		✓	✓	✓	DC Make Up Room 0003B
DC Make Up Room 0003B	DS	4-15	✓		✓	✓	✓	0.05 in/wc
DC Make Up Room 0003B	S	4-16	✓		✓	✓	✓	
Outdoor Storage Room E100	M	4-17	✓		✓	✓	✓	
Outdoor Storage Room E100	HT	4-18	✓		✓	✓	✓	
Fire Smoke Damper #06 Alarm	FSD	4-19A	✓		✓	✓	✓	Outdoor Storage Room E10
Fire Smoke Damper #06 Trouble	FSD	4-19B	✓		✓	✓	✓	Outdoor Storage Room E10
Storage Room 0003	S	4-20	✓		✓	✓	✓	
Fire Smoke Damper #08 Alarm	FSD	4-21A	✓		✓	✓	✓	Electrical Room 0003A
Fire Smoke Damper #08 Trouble	FSD	4-21B	✓		✓	✓	✓	Electrical Room 0003A
Electrical Room 0003A	S	4-22	✓		✓	✓	✓	
Electrical Room 0003A	S	4-23	✓		✓	✓	✓	
Fire Smoke Damper #07 Alarm	FSD	4-24A	✓		✓	✓	✓	Electrical Room 0003A
Fire Smoke Damper #07 Trouble	FSD	4-24B	✓		✓	✓	✓	Electrical Room 0003A
Corridor By Stair ST4-0	M	4-25	✓		✓	✓	✓	
Corridor By Stair ST4-0	S	4-26	✓		✓	✓	✓	
Corridor 0000A	S	4-27	✓		✓	✓	✓	
Corridor By Production Lab0005	S	4-28	✓		✓	✓	✓	
Storage Room 0008	S	4-29	✓		✓	✓	✓	
Mezzanine 1000Z	S	4-30	✓		✓	✓	✓	
Washroom 0010	S	4-31	✓		✓	✓	✓	
Storage Room 1002Z	S	4-32	✓		✓	✓	✓	
Mezzanine 1000Z	M	4-55	✓		✓	✓	✓	
Maker Space 0012	S	4-33	✓		✓	✓	✓	
Elevator EL1-1 Pit Sprinkler Control Valve	TS	4-34	✓		✓	✓	✓	
Storage Room 0012A	S	4-35	✓		✓	✓	✓	
Supply Fan Shutdown	R	4-36	✓		✓	✓	✓	N1 Communication Room 0
Door Mag Communication Room 0014	R	4-37	✓		✓	✓	✓	
Communication Room 0012A	S	4-38	✓		✓	✓	✓	
Communication Room 0012A	S	4-39	✓		✓	✓	✓	
Communication Room 0012A	S	4-40	✓		✓	✓	✓	
Communication Room 0012A	S	4-41	✓		✓	✓	✓	
Communication Room 0012A	S	4-42	✓		✓	✓	✓	

Janitor Room 0016	HT	4-43	✓		✓	✓	✓	
Corridor By Comm Room 0014	M	4-44	✓		✓	✓	✓	
Corridor By Maker Space 0012	S	4-45	✓		✓	✓	✓	
Mezzanine 1000Z	S	4-46	✓		✓	✓	✓	
Mezzanine 1000Z Elevator Lobby	S	4-47	✓		✓	✓	✓	
Storage Room 1000Z	S	4-49	✓		✓	✓	✓	
Storage Room 1000Z	S	4-50	✓		✓	✓	✓	
Storage Room 1000Z	S	4-51	✓		✓	✓	✓	
Storage Room 1000Z	S	4-52	✓		✓	✓	✓	
Fire Smoke Damper #01 Alarm	FSD	4-53A	✓		✓	✓	✓	Storage Room 1000Z
Fire Smoke Damper #01 Trouble	FSD	4-53B	✓		✓	✓	✓	Storage Room 1000Z
Storage Room 1000Z	S	4-54	✓		✓	✓	✓	Isolator
Exterior								
Sector C Rear East Exterior	ST1	BPS5-3	✓		✓	✓	✓	
Sector C Rear Courtyard	ST1	BPS5-3	✓		✓	✓	✓	
Sector Front Exterior	ST1	BPS5-3	✓		✓	✓	✓	
Level 1								
Learning Center 1036	HS	BPS2-1	✓		✓	✓	✓	
Corridor By Room 1046	HS	BPS2-1	✓		✓	✓	✓	
Corridor By Room 1042	HS	BPS2-1	✓		✓	✓	✓	
Washroom 1035	HS	BPS2-1	✓		✓	✓	✓	
Corridor By Learning Center 1036	HS	BPS2-1	✓		✓	✓	✓	
Learning Center 1036	HS	BPS2-1	✓		✓	✓	✓	
Corridor By Janitor Room 1032	HS	BPS2-1	✓		✓	✓	✓	
Corridor By Room 1025	HS	BPS2-2	✓		✓	✓	✓	
Corridor By Room 1026	HS	BPS2-2	✓		✓	✓	✓	
Washroom 1022	HS	BPS2-2	✓		✓	✓	✓	
Room 1024A	HS	BPS2-2	✓		✓	✓	✓	
Corridor By Washroom 1022	HS	BPS2-2	✓		✓	✓	✓	
Shower Room 1015F	HS	BPS2-2	✓		✓	✓	✓	
Guidance Suite 1015	HS	BPS2-2	✓		✓	✓	✓	
Atrium Top Of Stairs	HS	BPS2-2	✓		✓	✓	✓	
Open Area By Student Council 1012	HS	BPS2-2	✓		✓	✓	✓	
Level 2								
Corridor By Room 2042	HS	BPS5-1	✓		✓	✓	✓	
Corridor By Room 2043	HS	BPS5-1	✓		✓	✓	✓	
Washroom 2041	HS	BPS5-1	✓		✓	✓	✓	
Corridor By Room 2032	HS	BPS5-1	✓		✓	✓	✓	
Room 2032	HS	BPS5-1	✓		✓	✓	✓	
Shower Room 2032C	HS	BPS5-1	✓		✓	✓	✓	
Corridor By Janitor Room 2028	HS	BPS5-1	✓		✓	✓	✓	
Corridor By Room 2031	HS	BPS5-2	✓		✓	✓	✓	
Corridor By Room 2022	HS	BPS5-2	✓		✓	✓	✓	
Washroom 2016	HS	BPS5-2	✓		✓	✓	✓	
Corridor By Washroom 2016	HS	BPS5-2	✓		✓	✓	✓	
Staff Room 2017	HS	BPS5-2	✓		✓	✓	✓	

Washroom 2017B	HS	BPS5-2	✓		✓	✓	✓	
Corridor By Media Room 2009	HS	BPS5-2	✓		✓	✓	✓	
Level 0								
Corridor 0000E	HS	BPS2-3	✓		✓	✓	✓	
Welding Room 0015C	HS	BPS2-3	✓		✓	✓	✓	
Skilled Trades 0015	HS	BPS2-3	✓		✓	✓	✓	
Corridor By Production Lab 0013	HS	BPS2-3	✓		✓	✓	✓	
Production Lab 0013	HS	BPS2-3	✓		✓	✓	✓	
Janitors Room 0016	HS	BPS2-3	✓		✓	✓	✓	
Production Lab 0005	HS	BPS2-4	✓		✓	✓	✓	
Storage Room 0003	HS	BPS2-4	✓		✓	✓	✓	
Outdoor Storage E-100	HS	BPS2-4	✓		✓	✓	✓	
Corridor By Storage Room 0003	HS	BPS2-4	✓		✓	✓	✓	
Corridor By Innovation 00007	HS	BPS2-4	✓		✓	✓	✓	
Corridor By Storage Room 0008	HS	BPS2-4	✓		✓	✓	✓	
Washroom 0010	HS	BPS2-4	✓		✓	✓	✓	
Communication Room 0014	HS	BPS2-4	✓		✓	✓	✓	
Mezzanine 1000Z	HS	BPS2-4	✓		✓	✓	✓	

5.2 INDIVIDUAL DEVICE RECORD

(Reference: Clauses 6.12.1, 6.12.2, Section 5.1)

A - Correctly Installed

B - Requires Service, Repairs,
Cleaning or Missing

C - Alarm Operation
Confirmed

D - Annunciation
Indication Confirmed

E - Supervision of Wiring
Device Confirmed

BUILDING NAME: Bedford Ravines

Location	Device	Circuit #	A	B	C	D	E	Remarks
Level 3								
Elevator Lobby EL2-2	S	2-1	✓		✓	✓	✓	
Elevator2-3 Hoistway Control Valve	TS	2-2	✓		✓	✓	✓	
Main Elevator Recall	R	2-3	✓		✓	✓	✓	
Alternate Elevator Recall	R	2-4	✓		✓	✓	✓	
Elevator Fire Hat	R	2-5	✓		✓	✓	✓	
Top of Elevator Shaft EL2-2	S	2-6	✓		✓	✓	✓	
Fire Smoke Damper #64 Alarm	FSD	2-7A	✓		✓	✓	✓	Fan Room 3030
Fire Smoke Damper #64 Trouble	FSD	2-7B	✓		✓	✓	✓	Fan Room 3030
Fire Smoke Damper #63 Alarm	FSD	2-8A	✓		✓	✓	✓	Fan Room 3030
Fire Smoke Damper #63 Trouble	FSD	2-8B	✓		✓	✓	✓	Fan Room 3030
Fan Room 3030 Exit	M	2-9	✓		✓	✓	✓	
Fire Smoke Damper #62 Alarm	FSD	2-10A	✓		✓	✓	✓	Fan Room 3030
Fire Smoke Damper #62 Trouble	FSD	2-10B	✓		✓	✓	✓	Fan Room 3030
Fire Smoke Damper #66 Alarm	FSD	2-11A	✓		✓	✓	✓	Fan Room 3030
Fire Smoke Damper #66 Trouble	FSD	2-11B	✓		✓	✓	✓	Fan Room 3030
Supply Fan #6 Shutdown	R	2-12	✓		✓	✓	✓	
Fan Room 3030	S	2-13	✓		✓	✓	✓	
ERV #5 Shutdown	R	2-14	✓		✓	✓	✓	
AHU #6 Duct Smoke	DS	2-15	✓		✓	✓	✓	0.08% in/wc Fan Room 303
Supply Fan #5 Shutdown	R	2-16	✓		✓	✓	✓	
Fire Smoke Damper #16 Alarm	FSD	2-17A	✓		✓	✓	✓	Fan Room 3030
Fire Smoke Damper #16 Trouble	FSD	2-17B	✓		✓	✓	✓	Fan Room 3030

Storage Room 3041	S	2-18	✓		✓	✓	✓	
Storage Room 3041	M	2-19	✓		✓	✓	✓	
Janitor Room 3043	HT	2-20	✓		✓	✓	✓	
Corridor By Room 3035A	R	2-21	✓		✓	✓	✓	
Corridor By Room 3035A	S	2-22	✓		✓	✓	✓	
Corridor By Room 3035A	M	2-23	✓		✓	✓	✓	Isolator
Top of Stair ST10-3	S	2-24	✓		✓	✓	✓	
Fire Smoke Damper #26 Alarm	FSD	2-26A	✓		✓	✓	✓	Washroom 3020
Fire Smoke Damper #26 Trouble	FSD	2-26B	✓		✓	✓	✓	Washroom 3020
Washroom 3020	S	2-25	✓		✓	✓	✓	
Change Room 3027B	S	2-27	✓		✓	✓	✓	
Corridor By Classroom 3025	S	2-28	✓		✓	✓	✓	
Corridor By Classroom 3025 Door Mag	R	2-29	✓		✓	✓	✓	
Corridor By Classroom 3025	S	2-30	✓		✓	✓	✓	
Prep Room 3025A	S	2-31	✓		✓	✓	✓	
Sub Comm Room 3023	S	2-32	✓		✓	✓	✓	
Fire Smoke Damper #82 Alarm	FSD	2-33A	✓		✓	✓	✓	Outside Sub Comm 3023 Is
Fire Smoke Damper #82 Trouble	FSD	2-33B	✓		✓	✓	✓	Outside Sub Comm 3023 Is
Fire Smoke Damper #81 Alarm	FSD	2-34A	✓		✓	✓	✓	Outside Sub Comm 3023
Fire Smoke Damper #81 Trouble	FSD	2-34B	✓		✓	✓	✓	Outside Sub Comm 3023
Sector E/F Sprinkler Control Valve	TS	2-35	✓		✓	✓	✓	
Top of Stair ST1-3 Sprinkler Flow	FS	2-36	✓		✓	✓	✓	
Top Of Stair ST1-3	S	2-37	✓		✓	✓	✓	
Corridor By Stair ST1-3	M	2-38	✓		✓	✓	✓	Isolator
Corridor By Stair ST1-3	S	2-39	✓		✓	✓	✓	Isolator
Mechanical 3016 SF #4 Relay	R	2-40	✓		✓	✓	✓	
Fire Smoke Damper #80 Alarm	FSD	2-41A	✓		✓	✓	✓	Mechanical Room 3016
Fire Smoke Damper #80 Trouble	FSD	2-41B	✓		✓	✓	✓	Mechanical Room 3016
Fire Smoke Damper #79 Alarm	FSD	2-42A	✓		✓	✓	✓	Mechanical Room 3016
Fire Smoke Damper #79 Trouble	FSD	2-42B	✓		✓	✓	✓	Mechanical Room 3016
Mechanical Room 3016	M	2-43	✓		✓	✓	✓	
Fire Smoke Damper #78 Alarm	FSD	2-44A	✓		✓	✓	✓	Mechanical Room 3016
Fire Smoke Damper #78 Trouble	FSD	2-44B	✓		✓	✓	✓	Mechanical Room 3016
AHU#4 Mech Room 3016	DS	2-45	✓		✓	✓	✓	0.19% in/wc
ERV #4 Shutdown Mech Room 3016	R	2-46	✓		✓	✓	✓	Mechanical Room 3016
Mechanical Room 3016	S	2-47	✓		✓	✓	✓	
Supply Fan 101 Shutdown	R	2-48	✓		✓	✓	✓	
Washroom 3008	S	2-49	✓		✓	✓	✓	Isolator
Fire Smoke Damper #35 Alarm	FSD	2-50A	✓		✓	✓	✓	Washroom 3008 Isolator ch
Fire Smoke Damper #35 Trouble	FSD	2-50B	✓		✓	✓	✓	Washroom 3008 Isolator
Top of Stair ST2-2	S	2-51	✓		✓	✓	✓	
Corridor By Stair ST2-2	M	2-52	✓		✓	✓	✓	Isolator
Corridor By Stair ST2-2	S	2-53	✓		✓	✓	✓	
Corridor By Stair ST2-2 Door Mag	R	2-54	✓		✓	✓	✓	Isolator
Ladder Exit from Fan Room 3021	S	2-55	✓		✓	✓	✓	
Fan Room 3021	M	2-56	✓		✓	✓	✓	Isolator

Fan Room 3021 Man Door Exit	M	2-57	✓		✓	✓	✓	
Fire Smoke Damper #105 Alarm	FSD	2-58A	✓		✓	✓	✓	
Fire Smoke Damper #105 Trouble	FSD	2-58B	✓		✓	✓	✓	
Supply Fan #7 Shut Down	R	2-59	✓		✓	✓	✓	
Fire Smoke Damper #101 Alarm	FSD	2-60A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #101 Trouble	FSD	2-60B	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #104 Alarm	FSD	2-61A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #104 Trouble	FSD	2-61B	✓		✓	✓	✓	Fan Room 3021
Fan Room 3021	S	2-62	✓		✓	✓	✓	
AHU#7 Fan Room 3021	DS	2-63	✓		✓	✓	✓	0.11% in/wc
ERV #8 Shutdown Fan Rm 3021	R	2-64	✓		✓	✓	✓	
Supply Fan #8 Shutdown	R	2-65	✓		✓	✓	✓	
Supply Fan #9 Shutdown	R	2-66	✓		✓	✓	✓	
Fire Smoke Damper #93 Alarm	FSD	2-67A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #93 Trouble	FSD	2-67B	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #97 Alarm	FSD	2-68A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #97 Trouble	FSD	2-68B	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #96 Alarm	FSD	2-69A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #96 Trouble	FSD	2-69B	✓		✓	✓	✓	Fan Room 3021
Fan Room 3021 Exit	M	2-70	✓		✓	✓	✓	
Fire Smoke Damper #90 Alarm	FSD	2-71A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #90 Trouble	FSD	2-71B	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #1 Alarm	FSD	2-72A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #1 Trouble	FSD	2-72B	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #6 Alarm	FSD	2-73A	✓		✓	✓	✓	Fan Room 3021
Fire Smoke Damper #6 Trouble	FSD	2-73B	✓		✓	✓	✓	Fan Room 3021
Learning Center 3019 Closet	S	2-74	✓		✓	✓	✓	
Communications Closet 3021A	S	2-75	✓		✓	✓	✓	
Elevator1-3 Hoistway Control Valve	TS	2-76	✓		✓	✓	✓	
Elevator Fire Hat EL1-3	R	2-77	✓		✓	✓	✓	
Main Elevator Recall EL1-3	R	2-78	✓		✓	✓	✓	
Alternate Elevator Recall EL1-3	R	2-79	✓		✓	✓	✓	
Elevator EL1-3 Lobby	S	2-80	✓		✓	✓	✓	Isolator
Top Of Elevator EL1-3 Shaft	S	2-81	✓		✓	✓	✓	
AHU#10 Mech Room 3016	DS	2-82	✓		✓	✓	✓	0.18% in/wc
AHU #5 Fan Room 3030	DS	2-83	✓		✓	✓	✓	0.09% in/wc
Supply Fan #18 Shutdown	R	2-84	✓		✓	✓	✓	Sub Comm Room 2032
AHU#8 Fan Room 3021	DS	2-85	✓		✓	✓	✓	0.13% in/wc
Sector E&F								
Fan Room 3021	HS	BPS4-1	✓		✓	✓	✓	
Corridor By Classroom 3017	HS	BPS4-1	✓		✓	✓	✓	
Learning Center 3019	HS	BPS4-1	✓		✓	✓	✓	
Corridor By Classroom 3010	HS	BPS4-1	✓		✓	✓	✓	
Washroom 3008	HS	BPS4-1	✓		✓	✓	✓	
Assisted Care Washroom 3009	HS	BPS4-1	✓		✓	✓	✓	

Corridor By Classroom 3001	HS	BPS4-1	✓		✓	✓	✓	
Corridor By Mechanical Room 3016	HS	BPS4-1	✓		✓	✓	✓	
Mechanical Room 3016	HS	BPS4-1	✓		✓	✓	✓	
Classroom 3025	HS	BPS4-2	✓		✓	✓	✓	
Corridor By Classroom 3018	HS	BPS4-2	✓		✓	✓	✓	
Corridor By Classroom 3031	HS	BPS4-2	✓		✓	✓	✓	
Washroom 3022	HS	BPS4-2	✓		✓	✓	✓	
Corridor By Room 3025A	HS	BPS4-2	✓		✓	✓	✓	
Corridor By Janitor Room 3043	HS	BPS4-2	✓		✓	✓	✓	
Fan Room 3030	HS	BPS4-2	✓		✓	✓	✓	

5.3 SIGNALLING DEVICE SOUND LEVEL MEASUREMENT

(Reference: Clause 6.10.1-B, 6.10.1-F and 6.10.1-H)

BUILDING NAME: Ravines Bedford

Zone	Location	DBA	Alarm Signal DBA	Remarks
A	Music Room	44	100	Door Closed
A	Washroom Stall	51	91	Door Closed
A	Room 1106	43	91	Door Closed
A	Stairwell	42	78	
A	Room 2078	53	92	Door Closed
A	Room 2073	56	92	Door Closed
A	Communication Room	49	76	Door Closed
B	Washroom 1004 Stall	39	80	Door Closed
B	Seminar 1002	41	77	Door Closed
B	Gym Comm Room 1054	39	77	Door Closed
B	Gym Storage 1050B	51	79	
B	Classroom 2060	45	83	Door Closed
B	Comm Room 2052	43	79	Door Closed
B	Classroom 2003	44	76	Door Closed
B	Change Room 1051 Stall	39	77	Door Closed
C/D	North Stairwell	41	78	
C/D	South Stairwell	44	73	
C/D	Room 1043	50	81	Door Closed
C/D	Room 1042	44	83	Door Closed
C/D	Room 1017	49	77	Door Closed
C/D	Room 2047	39	83	Door Closed
C/D	Room 2020	49	78	Door Closed
0	Stairwell South	60	81	
0	Innovation Lab 0011	42	77	Door Closed
0	Visual Arts Storage 0009	40	74	Door Closed
0	Innovation 0007	44	78	Door Closed
0	Skilled Traded North	51	89	Door Closed
E/F	Classroom 3014	47	75	Door Closed
E/F	Fan Room 3021	44	79	Door Closed
E/F	Classroom 3003	51	82	Door Closed
E/F	Room 3037	63	91	Door Closed

E/F	Mechanical Room 3016	61	75	Door Closed
E/F	Fan Room 3030	59	88	Door Closed



- ☒ Smoke detectors in stairwells
- ☒ Smoke detectors in corridors
- ☐ Emergency telephones at exits

Acknowledge Alarm: Depress button:	Acknowledge	Acknowledge Trouble: Depress button:	Acknowledge
Bells: Depress button:	Signal Silence	Reset Panel (<i>only after alarms, troubles, and supervisories have been acknowledged</i>) Depress button:	Reset
Acknowledge Supervisory: Depress button:			

Voice System Operation then pick up microphone and hold in the 'Push to Talk' button on the side of the microphone Wait seconds for pre-announce tone, then speak clearly When finished, release 'Push to Talk' button 2. At fire panel, pick up fire phone and select which floor you wish to activate as being called into use by using selector switch assigned to floor being called in from. 3. Speak clearly. General Location of Devices	Emergency Telephone Operation ☐ Portable Handsets ☐ Field Mounted Handsets Operation: 1. Plug in or pick up remotely mounted fire fighters hand set. 2. At fire panel, pick up fire phone and select which floor you wish to activate as being called into use by using selector switch assigned to floor being called in from. 3. Speak clearly.	Emergency Power Supply ☒ Location of AC Breaker ☒ Size of battery: ☒ Maintenance-free ☐ Generator supply fire alarm panel ☒ Battery load calculations: = Ah
☒ Pull stations at exit	☒ Strobes in public areas	
☒ Smoke/heat detectors in elevator shafts	☐ Ancillary system connected:	
☒ Smoke/heat detectors in storage rooms	☐	
	☐	
☐ Fire Detectors inside suites	☐ Audibles inside suites	
Procedure for Resetting System		

Emergency Lighting List - West Bedford					
Manufacturer	Model	Room #	Designation	Capacity/watt	Mount type
Lumacell		0003A	L3001-1	72	
Lumacell		0003	L3001-5	36	
Lumacell		0003	L3001-7	72	
Lumacell		E-100	L3001-5	36	
Lumacell		0003B	L3001-1	36	
Lumacell		0005	L3001-5	72	
Lumacell		0000E	L3001-7	72	
Lumacell		ST3-0	L3001-7	72	
Lumacell		0015	L3001-3	72	
Lumacell		0013	L3001-3	72	
Lumacell		0008 storage	L3001-7	72	
Lumacell		0016	L3001-3	36	
Lumacell		0016	L3001-7	72	
Lumacell		0014	L3001-1	72	
Lumacell		0012 storage	L3001-5	72	
Lumacell		10012	L3001-7	36	
Lumacell		10012	L3001-7	36	
Lumacell		ST4-0	L3001-7	72	
Lumacell		ST1-1	L3102-3	72	
Lumacell		1000J corridor	L310-18 (c)	72	
Lumacell		1082	L3102-3 (c)	72	
Lumacell		1087	L3102-51 (c)	72	
Lumacell		1080	L3102-51	36	
Lumacell		1000I corridor	L3102-18 (c)	72	
Lumacell		1083	L3102-5 (c)	72	
Lumacell		ST10-1	L3102-18 (c)	72	
Lumacell		1077	L3101-1	72	
Lumacell		1072	L3102-11 (c)	72	
Lumacell		1099	L3102-7	36	
Lumacell		1096A	L3102-13	36	
Lumacell		1054	EL3101-9	72	
Lumacell		1063	EL3101-11	72	
Lumacell		1063	EL3101-5	36	
Lumacell		1063	EL3101-5	72	
Lumacell		12-1 stair	L3102-7	72	
Lumacell		1000K	L302-18	72	
Lumacell		1045C	EL3101-8	72	
Lumacell		1054	EL3101-1	72	
Lumacell		1052	EL3101-15	72	
Lumacell		1052	EL3101-5	72	
Lumacell		1051A	EL3101-6	72	
Lumacell		1045B	EL3101-8	72	
Lumacell		1050 stage	EL3101-6	36	
Lumacell		1056	EL3101-6	36	
Lumacell		1052	EL3101-13	72	
Lumacell		1051S	EL3101-6	72	
Lumacell		1000C corridor	EL3101-3 (c)	72	
Lumacell		1006A	EL3101-7	36	
Lumacell		1045	EL3101-10	72	
Lumacell		1009	EL3101-7	72	
Lumacell		1001G	EL3101-5	72	
Lumacell		1000B	EL3101-3 (c)	72	
Lumacell		E1000	EL3101-1	36	
Lumacell		1000H	L3102-10	72	Ceiling mount
Lumacell		ST3-1	L3102-10	72	
Lumacell		1000D	EL3101-3 (c)	72	
Lumacell		1005A	EL3101-1	72	
Lumacell		1005	EL3101-7	36	
Lumacell		ST1-1	EL3101-3	72	
Lumacell		1030	L3102-1	72	Wall mount
Lumacell		1036D	L3102-6	36	Wall mount
Lumacell		Unknown	L3102-10	72	Ceiling mount
Lumacell		1015	L3102-12	36	Ceiling mount
Lumacell		1000G	3102-10	72	Ceiling mount
Lumacell		1042A	L3102-16	36	Ceiling mount
Lumacell		ST4-1	L3102-10	72	Wall mount
Lumacell		ST11-2	L3201-15	72	Wall mount
Lumacell		2000F	L3201-15	72	Ceiling mount
Lumacell		2067A	L3201-5	36	Wall mount
Lumacell		2000E	L3201-15	72	Ceiling mount

Lumacell		2061	L3201-1	36	Wall mount	pg 71
Lumacell		ST10-2	L3201-15	72	Wall mount	pg 72
Lumacell		ST12-2	L3201-15	72	Wall mount	pg 73
Lumacell		ST3-2	L3201-8	72	Wall mount	pg 74
Lumacell		2041	L3201-8	72	Ceiling mount	pg 75
Lumacell		2032	L3201-6	36	Ceiling mount	pg 76
Lumacell		2026	L3201-1	72	Wall mount	pg 77
Lumacell		2013	L3201-10	72	Ceiling mount	pg 78
Lumacell		2017	L3201-12	72	Ceiling mount	pg 79
Lumacell		2016	L3201-14	72	Ceiling mount	pg 80
Lumacell		ST4-2	L3201-14	72	Wall mount	pg 81
Lumacell		2002	L3201-19	72	Ceiling mount	pg 82
Lumacell		ST1-2	L3201-19	72	Wall mount	pg 83
Lumacell		2052	L3201-1	72	Wall mount	pg 84
Lumacell		2057	L3201-19	72	Ceiling mount	pg 85
Lumacell		2007Z	L3201-1	72	Wall mount	pg 86
Lumacell		2005Z	EL3201-1	72	Wall mount	pg 87
Lumacell		2007 hall	L3201-1	72	Wall mount	pg 88
Lumacell		2003Z	L3201-1	72	Wall mount	pg 89
Lumacell		2000Z	L3201-1	72	Wall mount	pg 90
Lumacell		3000B	L3301-3	72	Ceiling mount	pg 91
Lumacell		3030	L3301-1	72	Wall mount	pg 92
Lumacell		3000 corridor	L3301-8	72	Ceiling mount	pg 93
Lumacell		ST10-3	L3301-8	72	Wall mount	pg 94
Lumacell		3022	L3301-8	72	Ceiling mount	pg 95
Lumacell		3023	L3301-1	72	Wall mount	pg 96
Lumacell		3000 hall	L3301-8	72	Ceiling mount	pg 97
Lumacell		ST1-3	L3301-8	72	Wall mount	pg 98
Lumacell		3016	L3301-1	72	Wall mount	pg 99
Lumacell	LN1BSWD	1000Z mezz	L3001-2		Wall mount	pg 100
Lumacell	LN1BSWD	1000Z mezz	L3001-2		Wall mount	pg 101
Lumacell	LN1BSWD	ST4-61	L3001-2		Wall mount	pg 102
Lumacell	LN11BWSP	000A corridor	L3001-2		Wall mount	pg 103
Lumacell	LN2BSD	000A corridor	L3001-2		Ceiling mount	pg 104
Lumacell	LN1BWSD	000S	L3001-2		Wall mount	pg 105
Lumacell	LN1BWSD	000A corridor	L3001-2		Wall mount	pg 106
Lumacell	LN1BWSD	000B corridor	L3001-2		Wall mount	pg 107
Lumacell	LN1BWSD	0009	L3001-2		Wall mount	pg 108
Lumacell	LN2BWSD	000P	L3001-2		Ceiling mount	pg 109
Lumacell	LN2BWSD	000P	L3001-2	N/A	Ceiling mount	pg 110
Lumacell	LN1BWSD	ST3-0	L3001-2	N/A	Wall mount	pg 111
Lumacell	LN1BWSD	000E	L3001-2	N/A	Wall mount	pg 112
Lumacell	LN1BWSD	0015	L3001-2	N/A	Wall mount	pg 113
Lumacell	LN1BWSD	E1001	EL3101-2			pg 114
Lumacell	LN1BWSD	ST1-1	EL3101-2			pg 115
Lumacell	LN1BWSD	1009	EL3101-2			pg 116
Lumacell	LN1BWSD	100D	EL3101-2			pg 117
Lumacell	LN2BWSD	1000D	EL3101-2			pg 118
Lumacell	LN1BWSD	1045A	EL3102-2			pg 119
Lumacell	LN1BWSD	ST6-1	EL3102-2			pg 120
Lumacell	LN1BWSD	1053	EL3101-2			pg 121
Lumacell	LN1BWSD	ST7-1	EL3101-2			pg 122
Lumacell	LN1BWSD	1055	EL3101-2			pg 123
Lumacell	LN1BWSD	ST8-1	EL3101-2			pg 124
Lumacell	LN1BWSD	1045C	EL3101-2			pg 125
Lumacell	LN1BWSD	1045D	EL3102-2			pg 126
Lumacell	LN1BWSD	1000B	EL3102-2			pg 127
Lumacell	LN2BWSD	1000B	EL3101-2			pg 128
Lumacell	LN1BWSD	1073	L3102-2			pg 129
Lumacell	LN1BWSD	ST10-1	L3102-2			pg 130
Lumacell	LN2BWSD	1000I	L3102-2			pg 131
Lumacell	LN1BWSD	1000J	L3102-2			pg 132
Lumacell	LN2BWSD	1000J	L3102-2			pg 133
Lumacell	LN1BWSD	1000J	L3102-2			pg 134
Lumacell	LN1BWSD	1000I	L3102-2			pg 135
Lumacell	LN1BWSD	1000I	L3102-2			pg 136
Lumacell	LN1BWSD	1000K	L3102-2			pg 137
Lumacell	LN1BWSD	1000K	L3102-2			pg 138
Lumacell	LN1BWSD	1105 vestibule	L3102-2			pg 139
Lumacell	LN1BWSD	ST12-1	L3102-2			pg 140
Lumacell	LN1BWSD	000P corridor	L3001-2	N/A	Wall mount	pg 141
Lumacell	LN1BWSD	000E corridor	L3001-2	N/A	Wall mount	pg 142
Lumacell	LN1BWSD	0013	L3001-2	N/A	Wall mount	pg 143

Lumacell	LN2BWSD	1000H	L3102-2	pg 144
Lumacell	LN1BWSD	1000H stairs	L3102-2	pg 145
Lumacell	LN1BWSD	1000H	L3102-2	pg 146
Lumacell	LN2BWSD	Atrium	L3102-2	pg 147
Lumacell	LN1BWSD	Atrium	L3102-2	pg 148
Lumacell	LN1BWSD	1000G	L3102-2	pg 149
Lumacell	LN2BWSD	1000G	L3102-2	pg 150
Lumacell	LN1BWSD	2000 hall	L3201-2	pg 151
Lumacell	LN1BWSD	2000G	L3201-2	pg 152
Lumacell	LN2BWSD	2000G	L3201-2	pg 153
Lumacell	LN1BWSD	ST12-2	L3201-2	pg 154
Lumacell	LN2BWSD	2000 corridor	L3201-2	pg 155
Lumacell	LN2BWSD	2000E	L3201-2	pg 156
Lumacell	LN1BWSD	ST10-2	L3201-2	pg 157
Lumacell	LN1BWSD	ST11-2	L3201-2	pg 158
Lumacell	LN1BWSD	ST5-2	EL3101-2	pg 159
Lumacell	LN1BWSD	2007Z	EL3101-2	pg 160
Lumacell	LN2BWSD	2000 corridor	L3201-2	pg 161
Lumacell	LN1BWSD	2000 corridor	L3201-2	pg 162
Lumacell	LN1BWSD	ST-2	L3201-2	pg 163
Lumacell	LN2BWSD	2000 corridor	L3201-2	pg 164
Lumacell	LN1BWSD	2000A corridor	L3201-2	pg 165
Lumacell	LN1BWSD	ST3-2	L3201-2	pg 166
Lumacell	LN2BWSD	2000C	L3201-2	pg 167
Lumacell	LN1BWSD	2000 hallway	L3201-2	pg 168
Lumacell	LN1BWSD	ST4-2	L3201-2	pg 169
Lumacell	LN2BWSD	2000B	L3201-2	pg 170
Lumacell	LN1BWSD	2000B	L3201-2	pg 171
Lumacell	LN1BWSD	3016	L3301-2	pg 172
Lumacell	LN1BSWD	ST1-3	L3301-2	pg 173
Lumacell	LN1BWSD	3030	3301-2	pg 174
Lumacell	LN1BWSD	3000B	L3301-2	pg 175
Lumacell	LN2BWSD	3000 hallway	L3301-2	pg 176
Lumacell	LN1BWSD	ST10-3	L3301-2	pg 177
Lumacell	LN1BWSD	3021	L3301-2	pg 178
Lumacell	LN1BWSD	ST2-2	L3301-2	pg 179