



**RFP# 4299**  
**Recladding and Window Replacement**  
**Dartmouth High School**  
**Addendum #1**

**To:** All Proponents

**Date:** June 11, 2026

**From:** Nancy Rideout, Purchasing Manager  
Office: (902) 464-2000 ext. 2222  
Email: [nrideout@hrce.ca](mailto:nrideout@hrce.ca)

---

The bid documents shall be amended, and new drawings and clauses added, and shall become part of the contract documents as follows:

**Question 1:** Can we get a 2-week extension on the tender closing date for this project?

**Response:** No, this would affect the project timeline. The closing date will not be extended.

**The closing date is Thursday - June 18, 2026 at 2pm ATL.**

**Question 2:** Section 00 41 73, Separate Price Section #2, notes aluminum front entry system to be included. Please confirm scope of work & provide specification for new doors, framing & hardware required on the west elevation?

**Response:** Please disregard this reference to new aluminum entrance system. No new entrance system is to be included in this scope of work.



**Question 3:** Section 08 80 00, item 2.1.3:

- Part A) Please consider the equal Guardian SunGuard SN68 Low-E from Prelco to the spec'd products [Solarban 60 & Cardinal 272]?
- Part B) Vision Glass units are required to be selected from full range of manufacturers tints. Tinted glass has a wide price range and some tints require minimum buy quantities. We would like to propose either of the following tints from Prelco: Gray, Bronze, Green or Arctic Blue tints with Guardian SunGuard SN68 Low-E. Or will clear sealed units with Guardian SunGuard SN68 Low-E be acceptable for the new windows?
- Part C) Please refer to manufacturers data sheets with for sealed unit performance for all options with Guardian SunGuard SN68 Low-E as well as the sealed unit comparison sheet for these glass options.

**Response:**

- Part A)  
Guardian SunGuard SN68 Low-E from Prelco will be an acceptable alternative.
- Part B)  
Clear sealed units with Low-E to be priced.
- Part C)  
Acknowledge receipt of these data sheets.

**End of Addendum #1 – RFP# 4299**

---

***PLEASE SIGN BELOW AND RETURN WITH BID DOCUMENTS:***

---

Signature

---

Organization Name