

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 1	MPX522	Wednesday, May 13, 2020	0.003	Passed	0.4100	Passed	
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 2	MPX523	Wednesday, May 13, 2020	0.001	Passed	0.0610	Passed	
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 3	MPX524	Wednesday, May 13, 2020	0.007	Exceeded	0.0580	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	1st Floor Girls Wash Room tap 4	MPX525	Wednesday, May 13, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Fountain by 1st Floor Janitors Closet	MPX526	Wednesday, May 13, 2020	-	Passed	0.5700	Passed	
A. J. Smeltzer Junior High School	1st Floor Janitors Closet tap	MPX527	Wednesday, May 13, 2020	0.022	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 1	MPX528	Wednesday, May 13, 2020	0.033	Exceeded	0.0670	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 2	MPX529	Wednesday, May 13, 2020	0.001	Passed	0.0840	Passed	
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 3	MPX530	Wednesday, May 13, 2020	0.001	Passed	0.0700	Passed	
A. J. Smeltzer Junior High School	1st Floor Boys Wash Room tap 4	MPX531	Wednesday, May 13, 2020	0.002	Passed	0.4500	Passed	
A. J. Smeltzer Junior High School	Fountain by Room 16	MPX532	Wednesday, May 13, 2020	0.026	Exceeded	0.1400	Passed	New Fountain to be installed. Other sources available.
A. J. Smeltzer Junior High School	Wood Shop tap 1	MPX533	Wednesday, May 13, 2020	0.012	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Wood Shop tap 2	MPX534	Wednesday, May 13, 2020	0.020	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Kitchen Wash Room tap	MPX535	Wednesday, May 13, 2020	0.007	Exceeded	0.0490	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Kitchen sink 1 tap 1	NND038	Tuesday, September 1, 2020	0.001	Passed	0.0130	Passed	
A. J. Smeltzer Junior High School	Kitchen sink 2 tap 1	MPX537	Wednesday, May 13, 2020	0.001	Passed	0.2600	Passed	
A. J. Smeltzer Junior High School	Kitchen sink 2 tap 2	NND039	Tuesday, September 1, 2020	0.001	Passed	0.0150	Passed	
A. J. Smeltzer Junior High School	Class Room 115 tap	MPX539	Wednesday, May 13, 2020	0.095	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Class Room 115 Wash Room tap	MPX540	Wednesday, May 13, 2020	0.012	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Guidance Room Wash Room tap	MPX541	Wednesday, May 13, 2020	0.001	Passed	0.0880	Passed	
A. J. Smeltzer Junior High School	Main Office Wash Room tap	MPX542	Wednesday, May 13, 2020	-	Passed	0.0590	Passed	
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 1	MPX543	Wednesday, May 13, 2020	0.053	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 2	MPX544	Wednesday, May 13, 2020	0.002	Passed	0.1300	Passed	
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 3	MPX545	Wednesday, May 13, 2020	0.002	Passed	0.1500	Passed	
A. J. Smeltzer Junior High School	2nd Floor Girls Wash Room tap 4	MPX546	Wednesday, May 13, 2020	0.002	Passed	0.1200	Passed	
A. J. Smeltzer Junior High School	Fountain by 2nd Floor Janitors Closet	MPX547	Wednesday, May 13, 2020	0.002	Passed	0.1200	Passed	New Fountain to be installed.
A. J. Smeltzer Junior High School	2nd Floor Janitors Closet tap	MPX548	Wednesday, May 13, 2020	0.002	Passed	0.0420	Passed	
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 1	MPX549	Wednesday, May 13, 2020	0.006	Exceeded	0.0210	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 2	MPX550	Wednesday, May 13, 2020	0.002	Passed	0.0590	Passed	
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 3	MPX551	Wednesday, May 13, 2020	-	Passed	0.0067	Passed	
A. J. Smeltzer Junior High School	2nd Floor Boys Wash Room tap 4	MPX552	Wednesday, May 13, 2020	0.001	Passed	0.0084	Passed	
A. J. Smeltzer Junior High School	Class Room 222 tap	MPX553	Wednesday, May 13, 2020	0.001	Passed	0.0250	Passed	
A. J. Smeltzer Junior High School	Family Living Class Room tap	MPX554	Wednesday, May 13, 2020	0.290	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Food Lab Wash Room tap	MPX555	Wednesday, May 13, 2020	0.060	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Food Lab sink tap	NND040	Tuesday, September 1, 2020	0.002	Passed	0.0180	Passed	
A. J. Smeltzer Junior High School	Food Lab washtub tap	NND041	Tuesday, September 1, 2020	0.001	Passed	0.0130	Passed	
A. J. Smeltzer Junior High School	Food Lab tap 1	NND042	Tuesday, September 1, 2020	0.001	Passed	0.0160	Passed	
A. J. Smeltzer Junior High School	Food Lab tap 2	NND043	Tuesday, September 1, 2020	0.001	Passed	0.0120	Passed	
A. J. Smeltzer Junior High School	Food Lab tap 3	NND044	Tuesday, September 1, 2020	0.011	Exceeded	0.0160	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Food Lab tap 4	NND045	Tuesday, September 1, 2020	0.001	Passed	0.0130	Passed	
A. J. Smeltzer Junior High School	Fountain by Food Lab	-	-	-	-	-	-	New Fountain installed. Lab results pending.
A. J. Smeltzer Junior High School	Library Room 43A tap	MPX562	Wednesday, May 13, 2020	0.015	Exceeded	0.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Class Room 227 tap	MPX563	Wednesday, May 13, 2020	0.001	Passed	0.0530	Passed	
A. J. Smeltzer Junior High School	Class Room 26 tap	MPX564	Wednesday, May 13, 2020	0.014	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
A. J. Smeltzer Junior High School	Staff Room 27A Wash Room tap	MPX565	Wednesday, May 13, 2020	0.004	Passed	0.0280	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
A. J. Smeltzer Junior High School	Staff Room 27 Kitchen tap	MPX566	Wednesday, May 13, 2020	0.001	Passed	0.0350	Passed	
A. J. Smeltzer Junior High School	Staff Room 27B Wash Room tap	MPX567	Wednesday, May 13, 2020	0.060	Exceeded	0.0520	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Fountain by Room 16	MYH081	Tuesday, June 23, 2020	0.005	Passed	0.8500	Passed	
Admiral Westphal Elementary School	Janitors Closet by Girls Wash Room	MYH082	Tuesday, June 23, 2020	-	Passed	0.0670	Passed	
Admiral Westphal Elementary School	Special Needs Wash Room tap by Room 19	MYH083	Tuesday, June 23, 2020	0.001	Passed	0.1600	Passed	
Admiral Westphal Elementary School	Class Room 24 tap 1	MYH084	Tuesday, June 23, 2020	0.010	Exceeded	0.7700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Class Room 24 tap 2	MYH085	Tuesday, June 23, 2020	0.030	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Room 23 Sink tap	MYH086	Tuesday, June 23, 2020	0.005	Passed	0.2700	Passed	
Admiral Westphal Elementary School	Fountain by Room 21	NLJ916	Monday, August 24, 2020	0.004	Passed	0.0870	Passed	
Admiral Westphal Elementary School	Class Room 16 tap	MYH088	Tuesday, June 23, 2020	0.003	Passed	0.5300	Passed	
Admiral Westphal Elementary School	Girls Wash Room tap 1 by Room 12	MYH089	Tuesday, June 23, 2020	0.038	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Girls Wash Room tap 2 by Room 12	MYH090	Tuesday, June 23, 2020	0.054	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Girls Wash Room tap 3 by Room 12	MYH092	Tuesday, June 23, 2020	0.009	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Girls Wash Room tap 4 by Room 12	MYH093	Tuesday, June 23, 2020	0.013	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Room 10 Wash Room tap	MYH094	Tuesday, June 23, 2020	0.066	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Boys Wash Room tap 1 by Room 12	MYH095	Tuesday, June 23, 2020	0.059	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Boys Wash Room tap 2 by Room 12	MYH096	Tuesday, June 23, 2020	0.007	Exceeded	0.0850	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Boys Wash Room tap 3 by Room 12	MYH097	Tuesday, June 23, 2020	0.052	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Boys Wash Room tap 4 by Room 12	MYH098	Tuesday, June 23, 2020	0.017	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Janitors Closet tap by Room 12	MYH099	Tuesday, June 23, 2020	0.014	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Fountain by Janitors Closet tap	MYH100	Tuesday, June 23, 2020	0.002	Passed	0.1900	Passed	
Admiral Westphal Elementary School	Class Room 5 tap	MYH101	Tuesday, June 23, 2020	0.010	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Gender Neutral Wash Room tap by Room 4	MYH102	Tuesday, June 23, 2020	0.007	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Janitors Closet tap by Room 4	MYH103	Tuesday, June 23, 2020	0.030	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Class Room 4 tap	MYH104	Tuesday, June 23, 2020	0.006	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Class Room 3 Wash Room tap	MYH105	Tuesday, June 23, 2020	0.012	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Class Room 3	MYH106	Tuesday, June 23, 2020	0.010	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Staff Room Female Wash Room tap 1	MYH107	Tuesday, June 23, 2020	0.006	Exceeded	0.0640	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Staff Room Female Wash Room tap 2	MYH108	Tuesday, June 23, 2020	0.012	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Admiral Westphal Elementary School	Staff Room Male Wash Room tap 1	MYH109	Tuesday, June 23, 2020	0.003	Passed	0.0780	Passed	
Admiral Westphal Elementary School	Staff Kitchen tap	MYH110	Tuesday, June 23, 2020	0.004	Passed	0.4600	Passed	
Admiral Westphal Elementary School	Principal's Office Wash Room tap	MYH111	Tuesday, June 23, 2020	0.023	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Alderney Elementary School	Staff Wash Room tap by Main Entrance	NAN882	Tuesday, June 30, 2020	0.004	Passed	0.1200	Passed	
Alderney Elementary School	Janitors Closet tap in Sprinkler Room	NAN883	Tuesday, June 30, 2020	0.003	Passed	0.1800	Passed	
Alderney Elementary School	1st Floor Girls Wash Room tap 1	PZN580	Wednesday, June 30, 2021	0.001	Passed	0.0200	Passed	Faucet remediated
Alderney Elementary School	1st Floor Girls Wash Room tap 2	PZN581	Wednesday, June 30, 2021	-	Passed	0.0130	Passed	Faucet remediated
Alderney Elementary School	Fountain by Main Entrance	QTT463	Monday, September 27, 2021	-	Passed	0.1400	Passed	Fountain replaced
Alderney Elementary School	1st Floor Boys Wash Room tap 1	PZN578	Wednesday, June 30, 2021	0.001	Passed	0.0430	Passed	Faucet remediated
Alderney Elementary School	1st Floor Boys Wash Room tap 2	PZN579	Wednesday, June 30, 2021	-	Exceeded	0.0370	Passed	Faucet remediated
Alderney Elementary School	Fountain by Wash Rooms	QTT464	Monday, September 27, 2021	0.003	Passed	0.1300	Passed	Fountain replaced
Alderney Elementary School	Basement Janitors Closet tap Room 109	NAN889	Tuesday, June 30, 2020	0.001	Passed	0.0790	Passed	
Alderney Elementary School	Basement Girls Wash Room tap 1	PZN582	Wednesday, June 30, 2021	-	Passed	0.0190	Passed	Faucet remediated
Alderney Elementary School	Basement Girls Wash Room tap 2	PZN583	Wednesday, June 30, 2021	-	Passed	0.0260	Passed	Faucet remediated
Alderney Elementary School	Basement Girls Wash Room tap 3	PZN584	Wednesday, June 30, 2021	0.001	Passed	0.0340	Passed	Faucet remediated
Alderney Elementary School	Basement Boys Wash Room tap 1	PZN585	Wednesday, June 30, 2021	-	Passed	0.0097	Passed	Faucet remediated

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Alderney Elementary School	Basement Boys Wash Room tap 2	PZN586	Wednesday, June 30, 2021	-	Passed	0.0091	Passed	Faucet remediated
Alderney Elementary School	Basement Boys Wash Room tap 3	PZN587	Wednesday, June 30, 2021	-	Exceeded	0.0130	Passed	Faucet remediated
Alderney Elementary School	Basement Fountain by Wash Rooms	QTT465	Monday, September 27, 2021	-	Passed	0.0023	Passed	Fountain replaced
Alderney Elementary School	Basement Staff Room tap	NAN897	Tuesday, June 30, 2020	0.005	Passed	0.0830	Passed	
Ash Lee Jefferson Elementary School	Class Room 207 tap	MVG462	Tuesday, June 9, 2020	-	Passed	0.4200	Passed	
Ash Lee Jefferson Elementary School	Staff Room tap	MVG463	Tuesday, June 9, 2020	0.001	Passed	0.2100	Passed	
Ash Lee Jefferson Elementary School	Gender Neutral Wash Room 214 tap	MVG464	Tuesday, June 9, 2020	0.001	Passed	0.4400	Passed	
Ash Lee Jefferson Elementary School	Room 219 Kitchen tap 1	MVG465	Tuesday, June 9, 2020	-	Passed	0.2100	Passed	
Ash Lee Jefferson Elementary School	Room 219 Kitchen tap 2	MVG466	Tuesday, June 9, 2020	0.001	Passed	0.8100	Passed	
Ash Lee Jefferson Elementary School	Room 219 Kitchen tap 3	MVG467	Tuesday, June 9, 2020	0.014	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ash Lee Jefferson Elementary School	Room 219 Kitchen tap 4	MVG468	Tuesday, June 9, 2020	0.002	Passed	0.1200	Passed	
Ash Lee Jefferson Elementary School	Gym Office 231 tap	MVG469	Tuesday, June 9, 2020	0.003	Passed	1.6000	Passed	
Ash Lee Jefferson Elementary School	Girls Change Room tap	MVG470	Tuesday, June 9, 2020	0.001	Passed	0.2200	Passed	
Ash Lee Jefferson Elementary School	Fountain by Gym	MVG471	Tuesday, June 9, 2020	0.001	Passed	0.4300	Passed	Fountain Replacement in progress.
Ash Lee Jefferson Elementary School	Boys Change Room tap	MVG472	Tuesday, June 9, 2020	-	Passed	0.2200	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 1 by Change Room	MVG473	Tuesday, June 9, 2020	0.001	Passed	0.1400	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 2 by Change Room	MVG474	Tuesday, June 9, 2020	0.002	Passed	0.1100	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 3 by Change Room	MVG475	Tuesday, June 9, 2020	0.019	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ash Lee Jefferson Elementary School	Janitors Closet tap	MVG476	Tuesday, June 9, 2020	-	Passed	0.3000	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 1	MVG477	Tuesday, June 9, 2020	0.005	Passed	0.4800	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 2	MVG478	Tuesday, June 9, 2020	0.001	Passed	0.3100	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 3	MVG479	Tuesday, June 9, 2020	0.001	Passed	0.0610	Passed	
Ash Lee Jefferson Elementary School	Fountain by 2nd Floor Wash Rooms	MVG480	Tuesday, June 9, 2020	0.006	Exceeded	1.9000	Passed	Fountain Replacement in progress.
Ash Lee Jefferson Elementary School	Girls Wash Room tap 1 by Room 271	MVG481	Tuesday, June 9, 2020	-	Passed	0.3100	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 2 by Room 271	MVG482	Tuesday, June 9, 2020	-	Passed	0.1200	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 3 by Room 271	MVG483	Tuesday, June 9, 2020	-	Passed	0.1100	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 4 by Room 271	MVG484	Tuesday, June 9, 2020	-	Passed	0.1100	Passed	
Ash Lee Jefferson Elementary School	Fountain by Room 271	MVG485	Tuesday, June 9, 2020	-	Passed	1.5000	Passed	Fountain Replacement in progress.
Ash Lee Jefferson Elementary School	Janitors Closet tap	MVG486	Tuesday, June 9, 2020	-	Passed	0.4200	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 1 by Room 281	MVG487	Tuesday, June 9, 2020	-	Passed	0.1200	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 2 by Room 281	MVG488	Tuesday, June 9, 2020	0.002	Passed	0.5900	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 3 by Room 281	MVG489	Tuesday, June 9, 2020	0.001	Passed	0.3000	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 4 by Room 281	MVG490	Tuesday, June 9, 2020	0.001	Passed	0.2700	Passed	
Ash Lee Jefferson Elementary School	Class Room 281 tap	MVG491	Tuesday, June 9, 2020	0.002	Passed	0.2400	Passed	
Ash Lee Jefferson Elementary School	Gender Neutral Wash Room 284 tap	MVG492	Tuesday, June 9, 2020	0.001	Passed	0.4400	Passed	
Ash Lee Jefferson Elementary School	Class Room 287 tap	MVG493	Tuesday, June 9, 2020	0.002	Passed	0.8200	Passed	
Ash Lee Jefferson Elementary School	Class Room 256 tap	MVG494	Tuesday, June 9, 2020	-	Passed	0.0630	Passed	
Ash Lee Jefferson Elementary School	Class Room 258 tap	MVG495	Tuesday, June 9, 2020	0.013	Exceeded	0.9000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ash Lee Jefferson Elementary School	Class Room 260 tap	MVG496	Tuesday, June 9, 2020	-	Passed	0.5000	Passed	
Ash Lee Jefferson Elementary School	Fountain by Room 127	MVG497	Tuesday, June 9, 2020	0.004	Passed	0.7400	Passed	Fountain Replacement in progress
Ash Lee Jefferson Elementary School	Girls Wash Room 128 tap 1	MVG498	Tuesday, June 9, 2020	0.008	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ash Lee Jefferson Elementary School	Girls Wash Room 128 tap 2	MVG499	Tuesday, June 9, 2020	0.003	Passed	0.2600	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room 128 tap 3	MVG500	Tuesday, June 9, 2020	0.003	Passed	0.1000	Passed	
Ash Lee Jefferson Elementary School	Janitors Closet Room 127 tap	MVG501	Tuesday, June 9, 2020	0.001	Passed	0.2800	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room 126 tap 1	MVG502	Tuesday, June 9, 2020	0.053	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Ash Lee Jefferson Elementary School	Boys Wash Room 126 tap 2	MVG503	Tuesday, June 9, 2020	0.001	Passed	0.1500	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room 126 tap 3	MVG504	Tuesday, June 9, 2020	0.004	Passed	0.1200	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 1	MVG513	Tuesday, June 9, 2020	0.001	Passed	0.5500	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 2	MVG505	Tuesday, June 9, 2020	0.001	Passed	0.5900	Passed	
Ash Lee Jefferson Elementary School	Girls Wash Room tap 3	MVG512	Tuesday, June 9, 2020	0.000	Passed	0.5800	Passed	
Ash Lee Jefferson Elementary School	Staff Room Wash Room tap 1	MVG506	Tuesday, June 9, 2020	-	Passed	0.0920	Passed	
Ash Lee Jefferson Elementary School	Staff Room Wash Room tap 2	MVG507	Tuesday, June 9, 2020	0.002	Passed	0.2300	Passed	
Ash Lee Jefferson Elementary School	Fountain by Room 105	QKE730	Monday, August 16, 2021	0.004	Passed	0.7000	Passed	Fountain replaced
Ash Lee Jefferson Elementary School	Boys Wash Room tap 1	MVG509	Tuesday, June 9, 2020	0.001	Passed	1.1000	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 2	MVG510	Tuesday, June 9, 2020	0.004	Passed	0.4400	Passed	
Ash Lee Jefferson Elementary School	Boys Wash Room tap 3	MVG511	Tuesday, June 9, 2020	0.002	Passed	0.6900	Passed	
Astral Drive Elementary School	2nd Floor Boys Wash Room tap 1	MXV292	Friday, June 19, 2020	0.006	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	2nd Floor Boys Wash Room tap 2	MXV293	Friday, June 19, 2020	0.003	Passed	0.1200	Passed	
Astral Drive Elementary School	2nd Floor Boys Wash Room tap 3	MXV294	Friday, June 19, 2020	0.003	Passed	0.1400	Passed	
Astral Drive Elementary School	2nd Floor Girls Wash Room tap 1	MXV295	Friday, June 19, 2020	0.003	Passed	0.1100	Passed	
Astral Drive Elementary School	2nd Floor Girls Wash Room tap 2	MXV296	Friday, June 19, 2020	0.004	Passed	0.0330	Passed	
Astral Drive Elementary School	2nd Floor Girls Wash Room tap 3	MXV297	Friday, June 19, 2020	-	Passed	0.0100	Passed	
Astral Drive Elementary School	Janitors Closet Room 217 tap	MXV298	Friday, June 19, 2020	0.001	Passed	0.0600	Passed	
Astral Drive Elementary School	Art Room 215 tap	MXV299	Friday, June 19, 2020	0.005	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	Staff Room 216 tap	MXV300	Friday, June 19, 2020	0.001	Passed	0.1900	Passed	
Astral Drive Elementary School	Staff Room 216 Wash Room 1	MXV301	Friday, June 19, 2020	0.005	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	Staff Room 216 Wash Room 2	MXV302	Friday, June 19, 2020	0.003	Passed	0.1500	Passed	
Astral Drive Elementary School	Fountain by Room 216	MXV303	Friday, June 19, 2020	-	Passed	0.2900	Passed	New Fountain installed. Lab results pending.
Astral Drive Elementary School	1st Floor Boys Wash Room tap 1	MXV304	Friday, June 19, 2020	0.017	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	1st Floor Boys Wash Room tap 2	MXV305	Friday, June 19, 2020	0.004	Passed	0.1600	Passed	
Astral Drive Elementary School	1st Floor Boys Wash Room tap 3	MXV306	Friday, June 19, 2020	0.001	Passed	0.0170	Passed	
Astral Drive Elementary School	1st Floor Girls Wash Room tap 1	MXV307	Friday, June 19, 2020	0.005	Passed	0.0660	Passed	
Astral Drive Elementary School	1st Floor Girls Wash Room tap 2	MXV308	Friday, June 19, 2020	0.065	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	1st Floor Girls Wash Room tap 3	MXV309	Friday, June 19, 2020	0.017	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	Class Room 105 tap	MXV310	Friday, June 19, 2020	0.003	Passed	0.1800	Passed	
Astral Drive Elementary School	Class Room 105 Wash Room tap	MXV311	Friday, June 19, 2020	0.041	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	Class Room 107 tap	NLS543	Tuesday, August 25, 2020	0.002	Passed	0.0690	Passed	
Astral Drive Elementary School	Main Office Staff Wash Room tap	MXV313	Friday, June 19, 2020	0.000	Passed	0.0350	Passed	
Astral Drive Elementary School	Fountain by Office	MXV314	Friday, June 19, 2020	0.001	Passed	0.0360	Passed	New Fountain installed. Lab results pending.
Astral Drive Elementary School	Class Room 101 tap	NLS541	Tuesday, August 25, 2020	0.001	Passed	0.0430	Passed	
Astral Drive Elementary School	Class Room 102 tap	NLS540	Tuesday, August 25, 2020	0.001	Passed	0.0450	Passed	
Astral Drive Elementary School	Class Room 102 Wash Room tap	MXV317	Friday, June 19, 2020	0.003	Passed	0.1700	Passed	
Astral Drive Elementary School	Janitors Closet 115 tap	MXV318	Friday, June 19, 2020	0.001	Passed	0.0300	Passed	
Astral Drive Elementary School	Class Room 103 tap	MXV319	Friday, June 19, 2020	0.032	Exceeded	0.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	Boiler Room tap	MXV344	Friday, June 19, 2020	0.019	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Elementary School	Fountain by Gym	NLS539	Tuesday, August 25, 2020	0.000	Passed	0.0390	Passed	
Astral Drive Elementary School	Class Room 104 tap 1	NLS542	Tuesday, August 25, 2020	0.001	Passed	0.0390	Passed	
Astral Drive Elementary School	Music Room 109 tap	NLS538	Tuesday, August 25, 2020	0.001	Passed	0.0170	Passed	
Astral Drive Junior High School	Girls Wash Room tap 1 by Room 204	MXU330	Friday, June 19, 2020	0.005	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Girls Wash Room tap 2 by Room 204	MXU331	Friday, June 19, 2020	0.001	Passed	0.0500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Astral Drive Junior High School	Girls Wash Room tap 3 by Room 204	MXU332	Friday, June 19, 2020	0.054	Exceeded	0.0450	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Girls Wash Room tap 4 by Room 204	MXU333	Friday, June 19, 2020	0.002	Passed	0.0480	Passed	
Astral Drive Junior High School	Science Lab 204 tap 1	MXU334	Friday, June 19, 2020	0.028	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Science Lab 204 tap 2	MXU335	Friday, June 19, 2020	0.031	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Science Lab 204 tap 3	MXU336	Friday, June 19, 2020	0.036	Exceeded	0.8300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Science Lab 204 tap 4	MXU337	Friday, June 19, 2020	0.002	Passed	0.0570	Passed	
Astral Drive Junior High School	Science Lab 206 tap 1	MXU338	Friday, June 19, 2020	0.011	Exceeded	0.0760	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Science Lab 206 tap 2	MXU339	Friday, June 19, 2020	0.047	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Class Room Lab 211 tap 1	MXU344	Friday, June 19, 2020	0.025	Exceeded	1.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Class Room Lab 211 tap 2	MXU345	Friday, June 19, 2020	0.042	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Class Room Lab 211 tap 3	MXU346	Friday, June 19, 2020	0.400	Exceeded	5.6000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Class Room Lab 211 tap 4	MXU347	Friday, June 19, 2020	0.028	Exceeded	2.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Boys Wash Room tap 1 by Room 232	MXU348	Friday, June 19, 2020	0.001	Passed	0.0380	Passed	
Astral Drive Junior High School	Boys Wash Room tap 2 by Room 232	MXU349	Friday, June 19, 2020	0.001	Passed	0.0310	Passed	
Astral Drive Junior High School	Boys Wash Room tap 3 by Room 232	MXU350	Friday, June 19, 2020	0.001	Passed	0.0310	Passed	
Astral Drive Junior High School	Janitors Closet 232 tap	MXU351	Friday, June 19, 2020	-	Passed	0.0320	Passed	
Astral Drive Junior High School	Fountain by Room 232	NLS557	Tuesday, August 25, 2020	0.001	Passed	0.0320	Passed	New Fountain installed. Lab results pending.
Astral Drive Junior High School	Office Wash Room 193 tap	MXU353	Friday, June 19, 2020	0.038	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Office Room 194 tap	NLS556	Tuesday, August 25, 2020	0.078	Exceeded	0.0430	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	1st Floor Staff Kitchen tap	MXU358	Friday, June 19, 2020	0.001	Passed	0.0370	Passed	
Astral Drive Junior High School	Staff Room Wash Room 181 tap	MXU359	Friday, June 19, 2020	0.001	Passed	0.0370	Passed	
Astral Drive Junior High School	Staff Room Wash Room 182 tap	MXU360	Friday, June 19, 2020	0.001	Passed	0.0360	Passed	
Astral Drive Junior High School	Girls Wash Room tap 1 by Room 143	MXU361	Friday, June 19, 2020	0.002	Passed	0.0410	Passed	
Astral Drive Junior High School	Girls Wash Room tap 2 by Room 143	MXU362	Friday, June 19, 2020	-	Passed	0.0400	Passed	
Astral Drive Junior High School	Fountain by Room 143	PXW801	Thursday, June 24, 2021	0.004	Passed	0.0920	Passed	Fountain replaced
Astral Drive Junior High School	Boys Wash Room tap 1 by Room 143	MXU364	Friday, June 19, 2020	0.001	Passed	0.0740	Passed	
Astral Drive Junior High School	Boys Wash Room tap 2 by Room 143	MXU365	Friday, June 19, 2020	0.002	Passed	0.0580	Passed	
Astral Drive Junior High School	Home Ec. 174 tap 1	MXU366	Friday, June 19, 2020	0.002	Passed	0.2300	Passed	
Astral Drive Junior High School	Home Ec. 174 tap 2	MXU367	Friday, June 19, 2020	0.004	Passed	0.4100	Passed	
Astral Drive Junior High School	Wood Shop 165 tap	MXU368	Friday, June 19, 2020	0.015	Exceeded	0.6800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Janitors Closet 164 tap	MXU369	Friday, June 19, 2020	0.003	Passed	0.0430	Passed	
Astral Drive Junior High School	1st Floor Canteen tap 1	MXU370	Friday, June 19, 2020	0.001	Passed	0.0770	Passed	
Astral Drive Junior High School	1st Floor Canteen tap 2	MXU371	Friday, June 19, 2020	0.001	Passed	0.0650	Passed	
Astral Drive Junior High School	Gym Office 153 Wash Room tap	MXU372	Friday, June 19, 2020	0.002	Passed	0.0510	Passed	
Astral Drive Junior High School	Girls Locker Room tap 1	MXU373	Friday, June 19, 2020	0.001	Passed	0.1000	Passed	
Astral Drive Junior High School	Girls Locker Room tap 2	MXU374	Friday, June 19, 2020	0.002	Passed	0.1000	Passed	
Astral Drive Junior High School	Boys Locker Room tap 1	MXU375	Friday, June 19, 2020	0.004	Passed	0.1100	Passed	
Astral Drive Junior High School	Boys Locker Room tap 2	MXU376	Friday, June 19, 2020	0.001	Passed	0.0440	Passed	
Astral Drive Junior High School	Gym Office 157 Wash Room tap	MXU377	Friday, June 19, 2020	0.002	Passed	0.0540	Passed	
Astral Drive Junior High School	Class Room 143 tap	MXU378	Friday, June 19, 2020	0.002	Passed	0.0540	Passed	
Astral Drive Junior High School	Art Room 142 tap 1	MXU379	Friday, June 19, 2020	0.330	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Art Room 142 tap 2	MXU380	Friday, June 19, 2020	0.600	Exceeded	3.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Student Services 141 Wash Room tap	MXU381	Friday, June 19, 2020	0.009	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Resource Room 140 tap	NLS555	Tuesday, August 25, 2020	0.001	Passed	0.0310	Passed	
Astral Drive Junior High School	1st Floor Boys Wash Room tap 1 by Room 132	MXU383	Friday, June 19, 2020	0.330	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Astral Drive Junior High School	1st Floor Boys Wash Room tap 2 by Room 132	MXU384	Friday, June 19, 2020	0.025	Exceeded	0.0560	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	1st Floor Boys Wash Room tap 3 by Room 132	MXU385	Friday, June 19, 2020	0.025	Exceeded	0.0690	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	Janitors Closet 132 tap	MXU386	Friday, June 19, 2020	0.002	Passed	0.0540	Passed	
Astral Drive Junior High School	Fountain by Room 132	MXU389	Friday, June 19, 2020	-	Passed	0.6700	Passed	
Astral Drive Junior High School	1st Floor Girls Wash Room tap 1 by Room 133	MXU390	Friday, June 19, 2020	0.005	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Astral Drive Junior High School	1st Floor Girls Wash Room tap 2 by Room 133	MXU391	Friday, June 19, 2020	0.004	Passed	0.0920	Passed	
Astral Drive Junior High School	1st Floor Girls Wash Room tap 3 by Room 133	MXU392	Friday, June 19, 2020	0.001	Passed	0.0610	Passed	
Astral Drive Junior High School	1st Floor Girls Wash Room tap 4 by Room 133	MXU393	Friday, June 19, 2020	0.001	Passed	0.0980	Passed	
Atl. Mem. Elem- Shad Bay	Fountain by Room 107	MUQ842	Thursday, June 4, 2020	0.011	Exceeded	1.1000	Passed	New Fountain to be installed. Other sources available.
Atl. Mem. Elem- Shad Bay	Pre-Primary Wash Room tap	MUQ843	Thursday, June 4, 2020	0.030	Exceeded	1.9000	Passed	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Pre-Primary Class Room tap	MUQ845	Thursday, June 4, 2020	2.000	Exceeded	0.5900	Passed	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Gym Wash Room tap	MUQ846	Thursday, June 4, 2020	0.014	Exceeded	5.4000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Boys Wash Room tap	MUQ847	Thursday, June 4, 2020	0.021	Exceeded	1.9000	Passed	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Janitors Office tap	MUQ848	Thursday, June 4, 2020	0.097	Exceeded	6.6000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Girls Wash Room tap	MUQ849	Thursday, June 4, 2020	0.028	Exceeded	2.8000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Music Room 108 tap	MUQ850	Thursday, June 4, 2020	0.960	Exceeded	1.3000	Passed	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Fountain across from Boys Wash Room	MUQ851	Thursday, June 4, 2020	0.016	Exceeded	6.7000	Exceeded	New Fountain to be installed. Other sources available.
Atl. Mem. Elem- Shad Bay	Common Room tap	MUQ852	Thursday, June 4, 2020	0.029	Exceeded	1.5000	Passed	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Gender Neutral Wash Room tap	MUQ853	Thursday, June 4, 2020	0.039	Exceeded	3.2000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Boys Wash Room tap 1	MUQ854	Thursday, June 4, 2020	0.030	Exceeded	0.9700	Passed	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Boys Wash Room tap 2	MUQ855	Thursday, June 4, 2020	0.021	Exceeded	3.1000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Boys Wash Room tap 3	MUQ856	Thursday, June 4, 2020	0.026	Exceeded	2.3000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Boys Wash Room tap 4	MUQ857	Thursday, June 4, 2020	0.027	Exceeded	0.9000	Passed	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Janitors Closet tap	MUQ858	Thursday, June 4, 2020	0.017	Exceeded	9.9000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Fountain by Janitors Closet	MUQ859	Thursday, June 4, 2020	0.026	Exceeded	5.4000	Exceeded	New Fountain to be installed. Other sources available.
Atl. Mem. Elem- Shad Bay	Girls Wash Room tap 1	MUQ860	Thursday, June 4, 2020	0.021	Exceeded	2.8000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Girls Wash Room tap 2	MUQ941	Thursday, June 4, 2020	0.005	Exceeded	3.3000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Girls Wash Room tap 3	MUQ910	Thursday, June 4, 2020	0.013	Exceeded	2.2000	Exceeded	Signage added to instruct handwashing only
Atl. Mem. Elem- Shad Bay	Girls Wash Room tap 4	MUQ911	Thursday, June 4, 2020	0.017	Exceeded	3.1000	Exceeded	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Fountain by Girls Wash Room	MUM349	Thursday, June 4, 2020	0.010	Exceeded	0.6700	Passed	New Fountain to be installed. Other sources available.
Atlantic Memorial-Terence Bay Elementary School	Girls Wash Room tap 1	MUM350	Thursday, June 4, 2020	0.085	Exceeded	0.0990	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Girls Wash Room tap 2	MUM351	Thursday, June 4, 2020	0.017	Exceeded	0.3700	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Janitors Closet tap	MUM352	Thursday, June 4, 2020	0.006	Exceeded	0.2500	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Boys Wash Room tap 1	MUM353	Thursday, June 4, 2020	0.018	Exceeded	0.0540	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Boys Wash Room tap 2	MUM354	Thursday, June 4, 2020	0.016	Exceeded	0.0600	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Gender Neutral Wash Room tap 1 by Reading Room	MUM355	Thursday, June 4, 2020	0.045	Exceeded	0.1700	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Gender Neutral Wash Room tap 2 by Reading Room	MUM356	Thursday, June 4, 2020	0.019	Exceeded	0.2100	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Gender Neutral Wash Room tap at end of the building	MUM357	Thursday, June 4, 2020	0.120	Exceeded	0.1300	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Gender Neutral Wash Room 1 tap	MUM358	Thursday, June 4, 2020	0.019	Exceeded	0.2100	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Gender Neutral Wash Room 2 tap	MUM368	Thursday, June 4, 2020	0.025	Exceeded	0.1200	Passed	Signage added to instruct handwashing only
Atlantic Memorial-Terence Bay Elementary School	Staff Room tap	MUM369	Thursday, June 4, 2020	0.015	Exceeded	0.1900	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Class Room 3 Wash Room tap	MXK161	Thursday, June 18, 2020	0.170	Exceeded	0.1100	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Fountain by Girls Wash Room	MXK162	Thursday, June 18, 2020	0.001	Passed	0.1100	Passed	
Atlantic View Elementary School	Girls Wash Room tap 1 by Fountain	MXK163	Thursday, June 18, 2020	0.016	Exceeded	0.0110	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Girls Wash Room tap 2 by Fountain	MXK164	Thursday, June 18, 2020	0.014	Exceeded	0.0290	Passed	Signage added to instruct handwashing only

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Atlantic View Elementary School	Girls Wash Room tap 3 by Fountain	MXK165	Thursday, June 18, 2020	0.005	Exceeded	0.0130	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Janitors Closet tap between Wash Rooms	MXK166	Thursday, June 18, 2020	-	Passed	0.0130	Passed	
Atlantic View Elementary School	Boys Wash Room tap 1 by Janitors Closet	MXK167	Thursday, June 18, 2020	0.006	Exceeded	0.0340	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Boys Wash Room tap 2 by Janitors Closet	MXK168	Thursday, June 18, 2020	0.083	Exceeded	0.5800	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Girls Locker Room tap	MXK187	Thursday, June 18, 2020	0.310	Exceeded	0.1700	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Gym Staff Wash Room tap	MXK188	Thursday, June 18, 2020	0.250	Exceeded	0.0170	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Gym Caretaker Room tap in Gym	MXK189	Thursday, June 18, 2020	0.007	Exceeded	0.7300	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Gym Kitchen/Café tap	MXK190	Thursday, June 18, 2020	0.350	Exceeded	0.0130	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Gym Kitchen sink tap	MXK191	Thursday, June 18, 2020	0.120	Exceeded	0.0750	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Art/Music Room tap	MXK192	Thursday, June 18, 2020	0.045	Exceeded	0.0820	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Staff Kitchen tap	MXK193	Thursday, June 18, 2020	0.013	Exceeded	0.0180	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Main Office Sick Room tap	MXK194	Thursday, June 18, 2020	0.067	Exceeded	0.6500	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Main Office Staff Wash Room 1 tap	MXK195	Thursday, June 18, 2020	0.080	Exceeded	0.1600	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Main Office Staff Wash Room 2 tap	MXK196	Thursday, June 18, 2020	0.083	Exceeded	0.1200	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Boys Wash Room tap 3 by Janitors Closet	MXK202	Thursday, June 18, 2020	0.031	Exceeded	0.1900	Passed	Signage added to instruct handwashing only
Atlantic View Elementary School	Breakfast Club Room tap	MXK206	Thursday, June 18, 2020	0.014	Exceeded	0.1300	Passed	Signage added to instruct handwashing only
Auburn Drive High School	Science Lab 301 tap	MXA146	Tuesday, June 16, 2020	-	Passed	1.1000	Passed	
Auburn Drive High School	Science Lab 302 tap 1	MXA147	Tuesday, June 16, 2020	-	Passed	0.7600	Passed	
Auburn Drive High School	Science Lab 302 tap 2	MXA148	Tuesday, June 16, 2020	0.001	Passed	0.7600	Passed	
Auburn Drive High School	Science Lab 302 tap 3	MXA149	Tuesday, June 16, 2020	-	Passed	0.9500	Passed	
Auburn Drive High School	Science Lab 302 tap 4	MXA150	Tuesday, June 16, 2020	0.001	Passed	0.9200	Passed	
Auburn Drive High School	Science Lab 303 tap 1	MXA151	Tuesday, June 16, 2020	-	Passed	1.0000	Passed	
Auburn Drive High School	Science Lab 303 tap 2	MXA152	Tuesday, June 16, 2020	0.004	Passed	0.4600	Passed	
Auburn Drive High School	Science Lab 303 tap 3	MXA153	Tuesday, June 16, 2020	0.001	Passed	0.4400	Passed	
Auburn Drive High School	Science Lab 303 tap 4	MXA154	Tuesday, June 16, 2020	0.001	Passed	0.7600	Passed	
Auburn Drive High School	Fountain by Room 304	MXA155	Tuesday, June 16, 2020	-	Passed	1.2000	Passed	
Auburn Drive High School	Fountain by Room 307	MXA156	Tuesday, June 16, 2020	0.007	Exceeded	0.3400	Passed	New Fountain to be installed. Other sources available.
Auburn Drive High School	Class Room 313 tap 1	MXA157	Tuesday, June 16, 2020	0.026	Exceeded	0.0620	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Class Room 313 tap 2	MXA158	Tuesday, June 16, 2020	0.020	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Class Room 313 tap 3	MXA159	Tuesday, June 16, 2020	0.010	Exceeded	0.0300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Class Room 313 tap 4	MXA160	Tuesday, June 16, 2020	0.002	Passed	0.5200	Passed	
Auburn Drive High School	Class Room 313 tap 5	MXA161	Tuesday, June 16, 2020	-	Passed	0.3500	Passed	
Auburn Drive High School	Prep Room 314 tap	MXA162	Tuesday, June 16, 2020	0.001	Passed	0.5400	Passed	
Auburn Drive High School	Science Lab 314 tap 1	MXA163	Tuesday, June 16, 2020	-	Passed	0.9100	Passed	
Auburn Drive High School	Science Lab 314 tap 2	MXA164	Tuesday, June 16, 2020	0.001	Passed	0.5900	Passed	
Auburn Drive High School	Science Lab 315 tap 3	NBS263	Tuesday, July 7, 2020	0.001	Passed	0.6300	Passed	
Auburn Drive High School	Science Lab 315 tap 4	NBS264	Tuesday, July 7, 2020	0.002	Passed	0.1600	Passed	
Auburn Drive High School	Science Lab 314 tap 5	MXA167	Tuesday, June 16, 2020	-	Passed	1.1000	Passed	
Auburn Drive High School	Science Lab 314 tap 6	MXA168	Tuesday, June 16, 2020	-	Passed	0.7000	Passed	
Auburn Drive High School	Science Lab 314 tap 7	MXA169	Tuesday, June 16, 2020	-	Passed	0.7700	Passed	
Auburn Drive High School	Science Lab 314 tap 8	MXA170	Tuesday, June 16, 2020	-	Passed	0.7400	Passed	
Auburn Drive High School	Science Lab 314 tap 9	MXA171	Tuesday, June 16, 2020	-	Passed	0.7500	Passed	
Auburn Drive High School	Science Lab 315 tap 1	MXA172	Tuesday, June 16, 2020	0.180	Exceeded	0.6400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Science Lab 315 tap 2	MXA173	Tuesday, June 16, 2020	0.003	Passed	0.8100	Passed	
Auburn Drive High School	Science Lab 315 tap 3	MXA174	Tuesday, June 16, 2020	-	Passed	0.6400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Auburn Drive High School	Science Lab 315 tap 4	MXA175	Tuesday, June 16, 2020	0.002	Passed	0.2100	Passed	
Auburn Drive High School	Science Lab 315 tap 5	MXA176	Tuesday, June 16, 2020	0.025	Exceeded	0.5300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Science Lab 315 tap 6	MXA177	Tuesday, June 16, 2020	0.010	Exceeded	0.7300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Science Lab 315 tap 7	MXA178	Tuesday, June 16, 2020	0.005	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Science Lab 315 tap 8	MXA179	Tuesday, June 16, 2020	0.001	Passed	0.8700	Passed	
Auburn Drive High School	Science Lab 315 tap 9	MXA180	Tuesday, June 16, 2020	0.002	Passed	0.4700	Passed	
Auburn Drive High School	Boys Wash Room tap 1 by Room 301	MXA181	Tuesday, June 16, 2020	0.001	Passed	0.5000	Passed	
Auburn Drive High School	Boys Wash Room tap 2 by Room 301	MXA182	Tuesday, June 16, 2020	-	Passed	0.1900	Passed	
Auburn Drive High School	Boys Wash Room tap 3 by Room 301	MXA183	Tuesday, June 16, 2020	0.001	Passed	0.0570	Passed	
Auburn Drive High School	Boys Wash Room tap 4 by Room 301	MXA184	Tuesday, June 16, 2020	0.006	Exceeded	0.7700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Boys Wash Room tap 5 by Room 301	MXA185	Tuesday, June 16, 2020	0.001	Passed	0.1600	Passed	
Auburn Drive High School	Staff Wash Room 1 tap by Room 301	MXA186	Tuesday, June 16, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Staff Wash Room 2 tap by Room 301	MXA187	Tuesday, June 16, 2020	0.001	Passed	0.6600	Passed	
Auburn Drive High School	Girls Wash Room tap 1 by Room 301	MXA188	Tuesday, June 16, 2020	0.003	Passed	0.4900	Passed	
Auburn Drive High School	Girls Wash Room tap 2 by Room 301	MXA189	Tuesday, June 16, 2020	-	Passed	0.5400	Passed	
Auburn Drive High School	Girls Wash Room tap 3 by Room 301	MXA190	Tuesday, June 16, 2020	0.005	Passed	0.3900	Passed	
Auburn Drive High School	Girls Wash Room tap 4 by Room 301	MXA191	Tuesday, June 16, 2020	0.003	Passed	0.1500	Passed	
Auburn Drive High School	Girls Wash Room tap 5 by Room 301	MXA192	Tuesday, June 16, 2020	0.005	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Janitors Closet tap by Wash Rooms	MXA193	Tuesday, June 16, 2020	0.001	Passed	0.3600	Passed	
Auburn Drive High School	Fountain by Stairs	MXA194	Tuesday, June 16, 2020	-	Passed	0.1600	Passed	
Auburn Drive High School	Music Room 201 tap	MXA195	Tuesday, June 16, 2020	0.011	Exceeded	0.5400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Fountain by Room 202	MXA196	Tuesday, June 16, 2020	0.001	Passed	0.2300	Passed	
Auburn Drive High School	Fine Arts Room 202 tap 1	MXA197	Tuesday, June 16, 2020	-	Passed	0.9500	Passed	
Auburn Drive High School	Fine Arts Room 202 tap 2	MXA198	Tuesday, June 16, 2020	-	Passed	0.4300	Passed	
Auburn Drive High School	Fine Arts Room 203 tap 1	MXA199	Tuesday, June 16, 2020	0.006	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Fine Arts Room 203 tap 2	MXA200	Tuesday, June 16, 2020	0.038	Exceeded	0.6700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Fine Arts Room 204 tap	MXA201	Tuesday, June 16, 2020	-	Passed	0.7300	Passed	
Auburn Drive High School	Fountain by Room 207	MXA202	Tuesday, June 16, 2020	0.001	Passed	0.3500	Passed	
Auburn Drive High School	Class Room 209 tap	MXA203	Tuesday, June 16, 2020	0.004	Passed	0.2600	Passed	
Auburn Drive High School	Gender Neutral Wash Room 209 tap 1	MXA204	Tuesday, June 16, 2020	0.006	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Gender Neutral Wash Room 209 tap 2	MXA205	Tuesday, June 16, 2020	-	Passed	0.4800	Passed	
Auburn Drive High School	Fountain by Room 212	MXA206	Tuesday, June 16, 2020	-	Passed	0.0890	Passed	
Auburn Drive High School	Janitors Closet tap by Student Services	MXA207	Tuesday, June 16, 2020	-	Passed	0.1500	Passed	
Auburn Drive High School	Student Services tap	MXA208	Tuesday, June 16, 2020	0.021	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Male Staff Room Wash Room tap	MXA209	Tuesday, June 16, 2020	0.001	Passed	0.0580	Passed	
Auburn Drive High School	Female Staff Room Wash Room tap	MXA210	Tuesday, June 16, 2020	-	Passed	0.2900	Passed	
Auburn Drive High School	Staff Room Kitchen tap	MXA211	Tuesday, June 16, 2020	0.001	Passed	0.3100	Passed	
Auburn Drive High School	Library Wash Room tap	MXA212	Tuesday, June 16, 2020	0.002	Passed	1.0000	Passed	
Auburn Drive High School	Library tap	MXA213	Tuesday, June 16, 2020	-	Passed	0.0350	Passed	
Auburn Drive High School	Cafeteria tap 1	MXA214	Tuesday, June 16, 2020	0.001	Passed	0.3000	Passed	
Auburn Drive High School	Cafeteria tap 2	MXA215	Tuesday, June 16, 2020	-	Passed	0.0550	Passed	
Auburn Drive High School	Cafeteria tap 3	MXA216	Tuesday, June 16, 2020	0.005	Exceeded	0.7500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Gym Gender Neutral Wash Room tap	MXA217	Tuesday, June 16, 2020	0.007	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Gym Boys Change Room tap 1	MXA218	Tuesday, June 16, 2020	0.004	Passed	0.4600	Passed	
Auburn Drive High School	Gym Boys Change Room tap 2	MXA219	Tuesday, June 16, 2020	0.001	Passed	0.3000	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Auburn Drive High School	Gym Female Change Room tap 1	MXA220	Tuesday, June 16, 2020	0.006	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Gym Female Change Room tap 2	MXA221	Tuesday, June 16, 2020	-	Passed	0.4700	Passed	
Auburn Drive High School	Fountain in Gym	MXA222	Tuesday, June 16, 2020	0.005	Exceeded	0.7600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Gym Office Wash Room tap	MXA223	Tuesday, June 16, 2020	0.001	Passed	0.7600	Passed	
Auburn Drive High School	Fountain by Room 223	MXA224	Tuesday, June 16, 2020	-	Passed	0.1200	Passed	
Auburn Drive High School	Janitors Closet tap in Maintenance Room	MXA225	Tuesday, June 16, 2020	0.005	Exceeded	0.7300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Food Lab Class Room 213 wash tap	NLS564	Tuesday, August 25, 2020	0.002	Passed	0.0470	Passed	
Auburn Drive High School	Class Room 213 tap 1	MXA227	Tuesday, June 16, 2020	-	Passed	0.3700	Passed	
Auburn Drive High School	Class Room 213 tap 2	MXA228	Tuesday, June 16, 2020	-	Passed	0.4600	Passed	
Auburn Drive High School	Class Room 213 tap 3	MXA229	Tuesday, June 16, 2020	0.001	Passed	0.9500	Passed	
Auburn Drive High School	Class Room 214 tap 1	MXA230	Tuesday, June 16, 2020	0.002	Passed	0.7700	Passed	
Auburn Drive High School	Class Room 214 tap 2	MXA231	Tuesday, June 16, 2020	0.002	Passed	0.2800	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 1	MXA232	Tuesday, June 16, 2020	0.004	Passed	0.2000	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 2	MXA233	Tuesday, June 16, 2020	0.001	Passed	0.2600	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 3	MXA234	Tuesday, June 16, 2020	0.001	Passed	0.1900	Passed	
Auburn Drive High School	Main Floor Girls Wash Room tap 4	MXA235	Tuesday, June 16, 2020	0.001	Passed	0.1600	Passed	
Auburn Drive High School	Main Floor Boys Wash Room tap 1	MXA236	Tuesday, June 16, 2020	0.001	Passed	0.1500	Passed	
Auburn Drive High School	Main Floor Boys Wash Room tap 2	MXA237	Tuesday, June 16, 2020	0.001	Passed	0.1300	Passed	
Auburn Drive High School	Main Floor Boys Wash Room tap 3	MXA238	Tuesday, June 16, 2020	0.017	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Main Floor Boys Wash Room tap 4	MXA239	Tuesday, June 16, 2020	-	Passed	0.2500	Passed	
Auburn Drive High School	Janitors Closet 110 tap	MXH473	Wednesday, June 17, 2020	0.001	Passed	0.3000	Passed	
Auburn Drive High School	Janitors Closet 111 tap	MXH474	Wednesday, June 17, 2020	0.002	Passed	0.3600	Passed	
Auburn Drive High School	Janitors Closet 112 tap	MXH475	Wednesday, June 17, 2020	0.002	Passed	0.1700	Passed	
Auburn Drive High School	Basement Boys Wash Room tap 1	MXH476	Wednesday, June 17, 2020	0.001	Passed	0.1100	Passed	
Auburn Drive High School	Basement Boys Wash Room tap 2	MXH477	Wednesday, June 17, 2020	0.001	Passed	0.1200	Passed	
Auburn Drive High School	Basement Boys Wash Room tap 3	MXH478	Wednesday, June 17, 2020	0.001	Passed	0.0970	Passed	
Auburn Drive High School	Gender Neutral Wash Room tap by Boys Wash Room	MXH479	Wednesday, June 17, 2020	0.001	Passed	0.1600	Passed	
Auburn Drive High School	Fountain between Gender Neutral Wash Rooms	MXH480	Wednesday, June 17, 2020	0.005	Exceeded	0.2600	Passed	New Fountain to be installed. Other sources available.
Auburn Drive High School	Gender Neutral Wash Room tap by Girls Wash Room	MXH481	Wednesday, June 17, 2020	0.025	Exceeded	0.5800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Basement Girls Wash Room tap 1	MXH482	Wednesday, June 17, 2020	0.010	Exceeded	0.0450	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Basement Girls Wash Room tap 2	MXH483	Wednesday, June 17, 2020	0.002	Passed	0.0260	Passed	
Auburn Drive High School	Basement Girls Wash Room tap 3	MXH484	Wednesday, June 17, 2020	0.001	Passed	0.0290	Passed	
Auburn Drive High School	Basement Girls Wash Room tap 4	MXH485	Wednesday, June 17, 2020	0.006	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Auburn Drive High School	Basement Girls Wash Room tap 5	MXH486	Wednesday, June 17, 2020	-	Passed	0.0180	Passed	
Auburn Drive High School	Janitors Closet tap by Girls Wash Room	MXH487	Wednesday, June 17, 2020	0.001	Passed	1.0000	Passed	
Auburn Drive High School	Science Lab 315 tap 3 Room 315	NBS263	Tuesday, July 7, 2020	0.001	Passed	0.6300	Passed	
Auburn Drive High School	Science Lab tap 4 Room 315	NBS264	Tuesday, July 7, 2020	0.002	Passed	0.1600	Passed	
Basinview Drive Community School	Caretaker Office tap	MSP510	Wednesday, May 27, 2020	-	Passed	0.0190	Passed	
Basinview Drive Community School	Class Room 131 tap	MSP511	Wednesday, May 27, 2020	-	Passed	0.4200	Passed	
Basinview Drive Community School	Class Room 132 tap	MSP512	Wednesday, May 27, 2020	0.001	Passed	0.1900	Passed	
Basinview Drive Community School	Class Room 133 Wash Room tap	MSP513	Wednesday, May 27, 2020	0.001	Passed	0.1200	Passed	
Basinview Drive Community School	Class Room 133 tap	MSP514	Wednesday, August 26, 2020	-	Passed	0.0110	Passed	
Basinview Drive Community School	Janitors Closet tap by Room 133	MSP515	Wednesday, May 27, 2020	0.001	Passed	0.0900	Passed	
Basinview Drive Community School	Gender Neutral Wash Room 137 tap	MSP516	Wednesday, May 27, 2020	-	Passed	0.0980	Passed	
Basinview Drive Community School	Class Room 138 tap	MSP517	Wednesday, May 27, 2020	0.001	Passed	0.6700	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Basinview Drive Community School	Class Room 139 Wash Room tap	MSP518	Wednesday, May 27, 2020	-	Passed	0.0420	Passed	
Basinview Drive Community School	Class Room 139 tap	MSP519	Wednesday, May 27, 2020	-	Passed	0.0460	Passed	
Basinview Drive Community School	Staff Wash Room 1 by Room 139	MSP524	Wednesday, May 27, 2020	-	Passed	0.0590	Passed	
Basinview Drive Community School	Staff Wash Room 2 by Room 139	MSP525	Wednesday, May 27, 2020	-	Passed	0.0750	Passed	
Basinview Drive Community School	Staff Room Kitchen tap	MSP526	Wednesday, May 27, 2020	-	Passed	0.0170	Passed	
Basinview Drive Community School	1st Floor Boys Wash Room tap 1	MSP527	Wednesday, May 27, 2020	-	Passed	0.0280	Passed	
Basinview Drive Community School	1st Floor Boys Wash Room tap 1	MSP528	Wednesday, May 27, 2020	-	Passed	0.0310	Passed	
Basinview Drive Community School	1st Floor Girls Wash Room tap 1	MSP529	Wednesday, May 27, 2020	0.001	Passed	0.1500	Passed	
Basinview Drive Community School	1st Floor Girls Wash Room tap 2	MSP530	Wednesday, May 27, 2020	-	Passed	0.1100	Passed	
Basinview Drive Community School	Fountain by 1st Floor Girls Wash Room	MSP531	Wednesday, May 27, 2020	0.001	Passed	0.2800	Passed	
Basinview Drive Community School	Class Room tap Room 106	MSP532	Wednesday, May 27, 2020	0.001	Passed	0.1800	Passed	
Basinview Drive Community School	Class Room tap Room 107	MSP533	Wednesday, May 27, 2020	-	Passed	0.0700	Passed	
Basinview Drive Community School	Boiler Room tap after Room 107	MSP534	Wednesday, May 27, 2020	-	Passed	0.0073	Passed	
Basinview Drive Community School	Music Room tap	MSP535	Wednesday, May 27, 2020	-	Passed	0.0088	Passed	
Basinview Drive Community School	Boys Locker Room tap 1	MSP536	Wednesday, May 27, 2020	0.002	Passed	0.0540	Passed	
Basinview Drive Community School	Boys Locker Room tap 2	MSP537	Wednesday, May 27, 2020	-	Passed	0.0240	Passed	
Basinview Drive Community School	Fountain in Boys Locker Room	MSP538	Wednesday, May 27, 2020	0.001	Passed	0.3800	Passed	
Basinview Drive Community School	Fountain in Girls Locker Room	NLV833	Wednesday, August 26, 2020	0.000	Passed	0.0110	Passed	
Basinview Drive Community School	Girls Locker Room tap 1	MSP540	Wednesday, May 27, 2020	0.002	Passed	0.1600	Passed	
Basinview Drive Community School	Girls Locker Room tap 2	MSP541	Wednesday, May 27, 2020	0.003	Passed	0.0560	Passed	
Basinview Drive Community School	Girls Locker Room Wash Room tap	MSP542	Wednesday, May 27, 2020	-	Passed	0.0130	Passed	
Basinview Drive Community School	Cafeteria large sink tap	MSP543	Wednesday, May 27, 2020	-	Passed	0.4700	Passed	
Basinview Drive Community School	Cafeteria small sink tap	MSP544	Wednesday, May 27, 2020	0.003	Passed	0.9300	Passed	
Basinview Drive Community School	Mech Room tap after 207	MSP545	Wednesday, May 27, 2020	-	Passed	0.0540	Passed	
Basinview Drive Community School	Class Room 212 tap	NLV834	Wednesday, August 26, 2020	0.000	Passed	0.0060	Passed	
Basinview Drive Community School	Class Room 213 Wash Room tap	MSP547	Wednesday, May 27, 2020	-	Passed	0.0210	Passed	
Basinview Drive Community School	Class Room 213 tap	MSP548	Wednesday, May 27, 2020	0.001	Passed	0.1700	Passed	
Basinview Drive Community School	2nd Floor Boys Wash Room tap 1	MSP549	Wednesday, May 27, 2020	-	Passed	0.0170	Passed	
Basinview Drive Community School	2nd Floor Boys Wash Room tap 2	MSP550	Wednesday, May 27, 2020	-	Passed	0.0170	Passed	
Basinview Drive Community School	2nd Floor Boys Wash Room tap 3	MSP551	Wednesday, May 27, 2020	0.002	Passed	0.0550	Passed	
Basinview Drive Community School	2nd Floor Girls Wash Room tap 1	MSP552	Wednesday, May 27, 2020	0.001	Passed	0.1000	Passed	
Basinview Drive Community School	2nd Floor Girls Wash Room tap 2	MSP553	Wednesday, May 27, 2020	-	Passed	0.0330	Passed	
Basinview Drive Community School	2nd Floor Girls Wash Room tap 3	MSP554	Wednesday, May 27, 2020	-	Passed	0.0370	Passed	
Basinview Drive Community School	Fountain by 2nd Floor Girls Wash Room	MSP555	Wednesday, May 27, 2020	0.001	Passed	0.6200	Passed	
Basinview Drive Community School	Mech. Room tap	MSP556	Wednesday, May 27, 2020	-	Passed	0.0061	Passed	
Basinview Drive Community School	Gender Neutral Staff Wash Room tap	MSP557	Wednesday, May 27, 2020	0.001	Passed	0.0490	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 1 by Room 203	MUQ659	Thursday, June 4, 2020	0.002	Passed	0.0740	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 2 by Room 203	MUQ660	Thursday, June 4, 2020	0.018	Exceeded	0.0960	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 3 by Room 203	MUQ661	Thursday, June 4, 2020	0.010	Exceeded	0.1200	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Janitors Closet tap by Boys Wash Room	MUQ662	Thursday, June 4, 2020	0.022	Exceeded	0.1100	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Fountain by Janitors Closet	MUQ663	Thursday, June 4, 2020	0.004	Passed	0.1200	Passed	
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 1 by Room 201	MUQ664	Thursday, June 4, 2020	0.003	Passed	0.1800	Passed	
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 2 by Room 201	MUQ665	Thursday, June 4, 2020	0.002	Passed	0.1300	Passed	
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 3 by Room 201	MUQ666	Thursday, June 4, 2020	0.001	Passed	0.0820	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 1 in Basement	MUQ667	Thursday, June 4, 2020	0.002	Passed	0.0840	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 2 in Basement	MUQ668	Thursday, June 4, 2020	0.005	Passed	0.1200	Passed	
Beaver Bank-Kinsac Elementary School	Fountain in Basement by Wash Rooms	MUQ669	Thursday, June 4, 2020	0.003	Passed	0.0980	Passed	
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 1 in Basement	MUQ670	Thursday, June 4, 2020	0.011	Exceeded	0.1200	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 2 in Basement	MUQ671	Thursday, June 4, 2020	0.004	Passed	0.0860	Passed	
Beaver Bank-Kinsac Elementary School	Janitors Closet tap in Basement	MUQ672	Thursday, June 4, 2020	0.001	Passed	0.0820	Passed	
Beaver Bank-Kinsac Elementary School	Breakfast Club Room tap in Basement	MUQ673	Thursday, June 4, 2020	0.001	Passed	0.0760	Passed	
Beaver Bank-Kinsac Elementary School	Class Room 202 tap	MUQ674	Thursday, June 4, 2020	0.001	Passed	0.1700	Passed	
Beaver Bank-Kinsac Elementary School	Class Room 203 tap	MUQ675	Thursday, June 4, 2020	0.003	Passed	0.1900	Passed	
Beaver Bank-Kinsac Elementary School	Main Office Staff Wash Room tap	MUQ676	Thursday, June 4, 2020	0.006	Exceeded	0.1100	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Staff Room tap	MUQ677	Thursday, June 4, 2020	0.001	Passed	0.0620	Passed	
Beaver Bank-Kinsac Elementary School	Staff Room Male Wash Room	MUQ678	Thursday, June 4, 2020	0.018	Exceeded	0.1300	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Staff Room Female Wash Room	MUQ679	Thursday, June 4, 2020	0.012	Exceeded	0.8800	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Class Room 217 tap	MUQ680	Thursday, June 4, 2020	0.002	Passed	0.0410	Passed	
Beaver Bank-Kinsac Elementary School	Staff Wash Room tap by Room 217	MUQ681	Thursday, June 4, 2020	0.001	Passed	0.0260	Passed	
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 1 by Room 204	MUQ682	Thursday, June 4, 2020	0.008	Exceeded	0.1100	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 2 by Room 204	MUQ683	Thursday, June 4, 2020	0.011	Exceeded	0.0960	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 3 by Room 204	MUQ684	Thursday, June 4, 2020	0.005	Exceeded	0.0720	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 4 by Room 204	MUQ685	Thursday, June 4, 2020	0.005	Exceeded	0.0690	Passed	Signage added to instruct handwashing only
Beaver Bank-Kinsac Elementary School	Girls Wash Room tap 5 by Room 204	MUQ686	Thursday, June 4, 2020	0.004	Passed	0.0650	Passed	
Beaver Bank-Kinsac Elementary School	Janitors Closet 204 tap	MUQ687	Thursday, June 4, 2020	0.002	Passed	0.0240	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 1 by Room 204	MUQ688	Thursday, June 4, 2020	0.003	Passed	0.0570	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 2 by Room 204	MUQ689	Thursday, June 4, 2020	0.001	Passed	0.0520	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 3 by Room 204	MUQ690	Thursday, June 4, 2020	0.001	Passed	0.0250	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 4 by Room 204	MUQ691	Thursday, June 4, 2020	0.004	Passed	0.0390	Passed	
Beaver Bank-Kinsac Elementary School	Boys Wash Room tap 5 by Room 204	MUQ692	Thursday, June 4, 2020	0.002	Passed	0.0620	Passed	
Beaver Bank-Kinsac Elementary School	Fountain by Boys Wash Room	MUQ693	Thursday, June 4, 2020	0.007	Exceeded	0.2200	Passed	New Fountain to be installed. Other sources available.
Beaver Bank-Monarch Drive Elementary School	Fountain by Room 224	MUN104	Thursday, June 4, 2020	-	Passed	0.0071	Passed	
Beaver Bank-Monarch Drive Elementary School	Art Room 205B tap	MUN105	Thursday, June 4, 2020	0.006	Exceeded	0.0150	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Fountain by Girls Wash Room	MUN106	Thursday, June 4, 2020	0.001	Passed	0.0420	Passed	
Beaver Bank-Monarch Drive Elementary School	2nd Floor Girls Wash Room tap 1	MUN107	Thursday, June 4, 2020	0.003	Passed	0.1900	Passed	
Beaver Bank-Monarch Drive Elementary School	2nd Floor Girls Wash Room tap 2	MUN108	Thursday, June 4, 2020	0.002	Passed	0.4800	Passed	
Beaver Bank-Monarch Drive Elementary School	2nd Floor Girls Wash Room tap 3	MUN109	Thursday, June 4, 2020	0.002	Passed	0.2600	Passed	
Beaver Bank-Monarch Drive Elementary School	2nd Floor Boys Wash Room tap 1	MUN110	Thursday, June 4, 2020	0.020	Exceeded	0.6100	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	2nd Floor Boys Wash Room tap 2	MUN111	Thursday, June 4, 2020	0.100	Exceeded	2.0000	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	2nd Floor Boys Wash Room tap 3	MUN112	Thursday, June 4, 2020	0.008	Exceeded	0.6000	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Janitors Closet 210 tap	MUN113	Thursday, June 4, 2020	0.001	Passed	0.0200	Passed	
Beaver Bank-Monarch Drive Elementary School	Class Room 122 tap	MUN114	Thursday, June 4, 2020	0.002	Passed	0.0130	Passed	
Beaver Bank-Monarch Drive Elementary School	Class Room 122 Wash Room tap	MUN115	Thursday, June 4, 2020	0.009	Exceeded	0.0550	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Class Room 124 Wash Room tap	MUN116	Thursday, June 4, 2020	0.016	Exceeded	0.0700	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Class Room tap Room 124	MUN117	Thursday, June 4, 2020	0.001	Passed	0.0280	Passed	
Beaver Bank-Monarch Drive Elementary School	Class Room tap Room 123	MUN118	Thursday, June 4, 2020	0.004	Passed	0.0039	Passed	
Beaver Bank-Monarch Drive Elementary School	Fountain by Room 123	MUN119	Thursday, June 4, 2020	-	Passed	0.0033	Passed	
Beaver Bank-Monarch Drive Elementary School	Class Room 121 tap	MUN120	Thursday, June 4, 2020	0.002	Passed	0.0064	Passed	
Beaver Bank-Monarch Drive Elementary School	Girls Wash Room tap 1 by Room 121	MUN121	Thursday, June 4, 2020	0.035	Exceeded	1.6000	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Girls Wash Room tap 2 by Room 121	MUN122	Thursday, June 4, 2020	0.027	Exceeded	0.5800	Passed	Signage added to instruct handwashing only

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Beaver Bank-Monarch Drive Elementary School	Girls Wash Room tap 3 by Room 121	MUN123	Thursday, June 4, 2020	0.021	Exceeded	1.3000	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Boys Wash Room tap 1 by Mech. Room	MUN132	Thursday, June 4, 2020	0.006	Exceeded	0.0620	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Boys Wash Room tap 2 by Mech. Room	MUN133	Thursday, June 4, 2020	0.007	Exceeded	0.0430	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Boys Wash Room tap 3 by Mech. Room	MUN134	Thursday, June 4, 2020	0.010	Exceeded	0.4000	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Library Room tap	MUN135	Thursday, June 4, 2020	0.140	Exceeded	0.2600	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Class Room 101 tap	MUN136	Thursday, June 4, 2020	0.001	Passed	0.0120	Passed	
Beaver Bank-Monarch Drive Elementary School	Class Room 104 tap	MUN137	Thursday, June 4, 2020	0.002	Passed	0.0052	Passed	
Beaver Bank-Monarch Drive Elementary School	Staff Kitchen tap	MUN138	Thursday, June 4, 2020	0.003	Passed	0.6500	Passed	
Beaver Bank-Monarch Drive Elementary School	Staff Room Wash Room 1 tap	MUN139	Thursday, June 4, 2020	0.001	Passed	0.4300	Passed	
Beaver Bank-Monarch Drive Elementary School	Staff Room Wash Room 2 tap	MUN140	Thursday, June 4, 2020	0.003	Passed	0.4100	Passed	
Beaver Bank-Monarch Drive Elementary School	Fountain by Machine Shop Room	MUN141	Thursday, June 4, 2020	0.005	Passed	0.0820	Passed	
Beaver Bank-Monarch Drive Elementary School	Main Office Sick Room tap	MUN188	Thursday, June 4, 2020	0.009	Exceeded	0.0740	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Janitors Closet tap by Gym	MUN189	Thursday, June 4, 2020	0.001	Passed	0.0082	Passed	
Beaver Bank-Monarch Drive Elementary School	Fountain by Gym	MUN190	Thursday, June 4, 2020	0.002	Passed	0.0410	Passed	
Beaver Bank-Monarch Drive Elementary School	Girls Change Room tap	MUN191	Thursday, June 4, 2020	0.002	Passed	0.0056	Passed	
Beaver Bank-Monarch Drive Elementary School	Boys Change Room tap	MUN192	Thursday, June 4, 2020	0.004	Passed	0.0160	Passed	
Beaver Bank-Monarch Drive Elementary School	Music Room 108 tap	MUN193	Thursday, June 4, 2020	0.018	Exceeded	0.0180	Passed	Signage added to instruct handwashing only
Beaver Bank-Monarch Drive Elementary School	Canteen Room tap	MUN194	Thursday, June 4, 2020	0.004	Passed	0.0580	Passed	
Bedford South School	Class Room 1014 tap	MYW981	Thursday, June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Class Room 1013 tap Room 1013	MYW982	Thursday, June 25, 2020	0.003	Passed	0.2700	Passed	
Bedford South School	Gender Neutral Wash Room 1016 tap	MYW983	Thursday, June 25, 2020	0.004	Passed	0.2600	Passed	
Bedford South School	Class Room 1012 tap	MYW984	Thursday, June 25, 2020	-	Passed	0.1600	Passed	
Bedford South School	Class Room 1011 tap	MYW985	Thursday, June 25, 2020	0.001	Passed	0.0970	Passed	
Bedford South School	Class Room 1027 tap	MYW986	Thursday, June 25, 2020	-	Passed	0.1600	Passed	
Bedford South School	Class Room 1026 tap	MYW987	Thursday, June 25, 2020	-	Passed	0.1900	Passed	
Bedford South School	Class Room 1025 tap	MYW988	Thursday, June 25, 2020	-	Passed	0.1800	Passed	
Bedford South School	Class Room Wash Room 1029 tap	MYW989	Thursday, June 25, 2020	0.001	Passed	0.3400	Passed	
Bedford South School	Class Room 1021 tap	MYW990	Thursday, June 25, 2020	-	Passed	0.1700	Passed	
Bedford South School	Class Room 1034 tap	MYX068	Thursday, June 25, 2020	0.001	Passed	0.2600	Passed	
Bedford South School	Class Room 1033 tap	MYX069	Thursday, June 25, 2020	-	Passed	0.2300	Passed	
Bedford South School	Gender Neutral Wash Room 1036 tap	MYX070	Thursday, June 25, 2020	0.001	Passed	0.1600	Passed	
Bedford South School	Class Room 1032 tap	MYX071	Thursday, June 25, 2020	-	Passed	0.1500	Passed	
Bedford South School	Class Room 1031 tap	MYX072	Thursday, June 25, 2020	0.002	Passed	0.3100	Passed	
Bedford South School	Fountain by Room 1061	PYJ427	Monday, June 21, 2021	-	Passed	0.0500	Passed	
Bedford South School	Boys Locker Room 1060 tap 1	MYX074	Thursday, June 25, 2020	0.002	Passed	0.2000	Passed	
Bedford South School	Boys Locker Room 1060 tap 2	MYX075	Thursday, June 25, 2020	0.014	Exceeded	0.5600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bedford South School	Girls Locker Room 1057 tap 1	MYX076	Thursday, June 25, 2020	0.004	Passed	0.2500	Passed	
Bedford South School	Girls Locker Room 1057 tap 2	MYX077	Thursday, June 25, 2020	0.005	Passed	0.3100	Passed	
Bedford South School	Gym Office Wash Room tap	MYX141	Thursday, June 25, 2020	0.001	Passed	0.2700	Passed	
Bedford South School	Arts Room 1069 tap 1	MYX142	Thursday, June 25, 2020	-	Passed	0.0240	Passed	
Bedford South School	Arts Room 1069 tap 2	MYX143	Thursday, June 25, 2020	0.001	Passed	0.0500	Passed	
Bedford South School	Gender Neutral Wash Room 1068 tap	MYX144	Thursday, June 25, 2020	0.002	Passed	0.1600	Passed	
Bedford South School	Gender Neutral Wash Room 1067 tap	MYX145	Thursday, June 25, 2020	-	Passed	0.1300	Passed	
Bedford South School	Janitors Closet 1066 tap	MYX146	Thursday, June 25, 2020	-	Passed	0.0940	Passed	
Bedford South School	Storage Room 1079 tap	MYX147	Thursday, June 25, 2020	0.004	Passed	0.1500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Bedford South School	Cafeteria/Kitchen Room 1080 tap 1	MYX148	Thursday, June 25, 2020	0.001	Passed	0.2900	Passed	
Bedford South School	Cafeteria/Kitchen Room 1080 tap 2	MYX149	Thursday, June 25, 2020	0.004	Passed	0.1500	Passed	
Bedford South School	Cafeteria/Kitchen Room 1080 tap 3	MYX150	Thursday, June 25, 2020	-	Passed	0.3000	Passed	
Bedford South School	Cafeteria/Kitchen Room 1080 tap 4	MYX166	Thursday, June 25, 2020	0.001	Passed	0.0990	Passed	
Bedford South School	Health Room tap	MYX167	Thursday, June 25, 2020	-	Passed	0.1500	Passed	
Bedford South School	Main Office Wash Room 1081 tap	MYX168	Thursday, June 25, 2020	-	Passed	0.1100	Passed	
Bedford South School	Library Work Room 1081 tap	MYX169	Thursday, June 25, 2020	0.001	Passed	0.1700	Passed	
Bedford South School	Boys Wash Room 1043 tap 1	MYX170	Thursday, June 25, 2020	-	Passed	0.1100	Passed	
Bedford South School	Boys Wash Room 1043 tap 2	MYX171	Thursday, June 25, 2020	0.001	Passed	0.1100	Passed	
Bedford South School	Boys Wash Room 1043 tap 3	MYX172	Thursday, June 25, 2020	0.001	Passed	0.1300	Passed	
Bedford South School	Boys Wash Room 1043 tap 4	MYX173	Thursday, June 25, 2020	-	Passed	0.1200	Passed	
Bedford South School	Janitors Closet 1046 tap	MYX174	Thursday, June 25, 2020	-	Passed	0.0610	Passed	
Bedford South School	Gender Neutral Wash Room 1047 tap	MYX175	Thursday, June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Girls Wash Room 1048 tap 1	MYX191	Thursday, June 25, 2020	0.001	Passed	0.1400	Passed	
Bedford South School	Girls Wash Room 1048 tap 2	MYX192	Thursday, June 25, 2020	0.003	Passed	0.2900	Passed	
Bedford South School	Girls Wash Room 1048 tap 3	MYX193	Thursday, June 25, 2020	0.002	Passed	0.2000	Passed	
Bedford South School	Girls Wash Room 1048 tap 4	MYX194	Thursday, June 25, 2020	0.001	Passed	0.1400	Passed	
Bedford South School	Fountain by Room 1048	PYJ426	Friday, June 25, 2021	-	Passed	0.0150	Passed	Fountain replaced
Bedford South School	Class Room 2039 tap 1	MYX196	Thursday, June 25, 2020	-	Passed	0.1800	Passed	
Bedford South School	Class Room 2039 tap 2	MYX197	Thursday, June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Class Room 2038 tap	MYX198	Thursday, June 25, 2020	0.001	Passed	0.6700	Passed	
Bedford South School	Class Room 2037 tap	MYX199	Thursday, June 25, 2020	0.001	Passed	0.2700	Passed	
Bedford South School	Class Room 2036 tap 1	MYX200	Thursday, June 25, 2020	0.001	Passed	0.1600	Passed	
Bedford South School	Class Room 2036 tap 2	MYX221	Thursday, June 25, 2020	0.001	Passed	0.1900	Passed	
Bedford South School	Class Room 2029 tap 1	MYX222	Thursday, June 25, 2020	0.001	Passed	0.1400	Passed	
Bedford South School	Class Room 2029 tap 2	MYX223	Thursday, June 25, 2020	0.001	Passed	0.2500	Passed	
Bedford South School	Class Room 2029 tap 3	MYX224	Thursday, June 25, 2020	0.016	Exceeded	0.3400	Passed	
Bedford South School	Class Room 2029 tap 4	MYX225	Thursday, June 25, 2020	0.001	Passed	0.5300	Passed	
Bedford South School	Class Room 2028 tap 1	MYX226	Thursday, June 25, 2020	0.001	Passed	0.5300	Passed	
Bedford South School	Class Room 2028 tap 2	MYX227	Thursday, June 25, 2020	0.003	Passed	0.6000	Passed	
Bedford South School	Class Room 2028 tap 3	MYX228	Thursday, June 25, 2020	0.001	Passed	0.2000	Passed	
Bedford South School	Class Room 2028 tap 4	MYX229	Thursday, June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Class Room 2027 tap	MYX230	Thursday, June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Class Room 2026 tap	MYX242	Thursday, June 25, 2020	0.001	Passed	0.2600	Passed	
Bedford South School	Home Ec. Room 2012 tap 1	MYX243	Thursday, June 25, 2020	0.002	Passed	0.1700	Passed	
Bedford South School	Home Ec. Room 2012 tap 2	MYX244	Thursday, June 25, 2020	0.002	Passed	0.3300	Passed	
Bedford South School	Home Ec. Room 2012 tap 3	MYX245	Thursday, June 25, 2020	0.001	Passed	0.1300	Passed	
Bedford South School	Home Ec. Room 2012 tap 4	MYX246	Thursday, June 25, 2020	-	Passed	0.1100	Passed	
Bedford South School	Tech Ed Room 2071 tap	MYX247	Thursday, June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Staff Room Wash Room 2073 tap	MYX248	Thursday, June 25, 2020	-	Passed	0.0370	Passed	
Bedford South School	Staff Room 2075 tap	MYX249	Thursday, June 25, 2020	-	Passed	0.1600	Passed	
Bedford South School	Staff Room Wash Room 2074 tap	MYX250	Thursday, June 25, 2020	-	Passed	0.0290	Passed	
Bedford South School	Class Room 2049 tap	MYX251	Thursday, June 25, 2020	0.001	Passed	0.2200	Passed	
Bedford South School	Class Room 2048 tap	MYX290	Thursday, June 25, 2020	0.002	Passed	2.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Bedford South School	Class Room 2047 tap	MYX291	Thursday, June 25, 2020	-	Passed	0.3700	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Bedford South School	Class Room 2046 tap	MYX292	Thursday, June 25, 2020	-	Passed	0.1600	Passed	
Bedford South School	Janitors Closet 2064 tap	MYX294	Thursday, June 25, 2020	-	Passed	0.0620	Passed	
Bedford South School	Gender Neutral Wash Room 2065 tap	MYX295	Thursday, June 25, 2020	0.001	Passed	0.1800	Passed	
Bedford South School	Fountain by Room 2065	PYJ429	Monday, June 21, 2021	-	Passed	0.0150	Passed	Fountain replaced
Bedford South School	Girls Wash Room 2056 tap 1	MYX297	Thursday, June 25, 2020	0.005	Exceeded	0.3200	Passed	
Bedford South School	Girls Wash Room 2056 tap 2	MYX298	Thursday, June 25, 2020	0.002	Passed	0.2400	Passed	
Bedford South School	Girls Wash Room 2056 tap 3	MYX299	Thursday, June 25, 2020	0.003	Passed	0.3100	Passed	
Bedford South School	Girls Wash Room 2056 tap 4	MYX300	Thursday, June 25, 2020	0.002	Passed	0.2300	Passed	
Bedford South School	Boys Wash Room 2055 tap 1	MYX301	Thursday, June 25, 2020	0.008	Exceeded	0.4100	Passed	
Bedford South School	Boys Wash Room 2055 tap 2	MYX302	Thursday, June 25, 2020	0.008	Exceeded	0.4700	Passed	
Bedford South School	Boys Wash Room 2055 tap 3	MYX303	Thursday, June 25, 2020	0.079	Exceeded	1.8000	Passed	
Bedford South School	Boys Wash Room 2055 tap 4	MYX307	Thursday, June 25, 2020	0.013	Exceeded	0.3300	Passed	
Bedford South School	Fountain by Room 2029	PYJ428	Friday, June 25, 2021	-	Passed	0.0250	Passed	Fountain replaced
Beechville-Lakeside-Timberlea Junior Elementary Sc	Janitors Closet 1 tap	MUK838	Wednesday, June 3, 2020	0.005	Passed	0.0400	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 212 tap 1	MUK839	Wednesday, June 3, 2020	0.011	Exceeded	0.0490	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 212 tap 2	MUK840	Wednesday, June 3, 2020	0.100	Exceeded	0.0470	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 212 tap 3	MUK841	Wednesday, June 3, 2020	0.150	Exceeded	0.0940	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 212 tap 4	MUK842	Wednesday, June 3, 2020	0.100	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Fountain by Room 212	MUK843	Wednesday, June 3, 2020	0.020	Exceeded	0.3600	Passed	Fountain replaced
Beechville-Lakeside-Timberlea Junior Elementary Sc	Art Room 207 tap 1	MUK844	Wednesday, June 3, 2020	0.005	Passed	0.0400	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Art Room 207 tap 2	MUK845	Wednesday, June 3, 2020	0.073	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 216 tap 1	MUK846	Wednesday, June 3, 2020	0.050	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 216 tap 2	MUK847	Wednesday, June 3, 2020	0.022	Exceeded	0.0800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 216 tap 3	MUK850	Wednesday, June 3, 2020	0.050	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 216 tap 4	MUK851	Wednesday, June 3, 2020	0.130	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Fountain by Room 216	MUK852	Wednesday, June 3, 2020	0.004	Passed	0.1100	Passed	Fountain Replacement in progress
Beechville-Lakeside-Timberlea Junior Elementary Sc	Fountain by Staff Room	MUK853	Wednesday, June 3, 2020	-	Passed	0.3400	Passed	Fountain replaced
Beechville-Lakeside-Timberlea Junior Elementary Sc	Staff Room Gender Neutral Wash Room 1 tap	MUK854	Wednesday, June 3, 2020	0.001	Passed	0.0370	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Staff Room Gender Neutral Wash Room 2 tap	MUK855	Wednesday, June 3, 2020	0.002	Passed	0.0420	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Staff Room Kitchen tap	MUK856	Wednesday, June 3, 2020	0.016	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 104 tap	MUK857	Wednesday, June 3, 2020	0.001	Passed	0.2800	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Room 100 Gender Neutral Wash Room tap	MUK858	Wednesday, June 3, 2020	0.006	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 102 tap	MUK859	Wednesday, June 3, 2020	0.003	Passed	0.2100	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 101 tap	MUK860	Wednesday, June 3, 2020	0.001	Passed	0.4400	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Room 105 Kitchen tap	MUK861	Wednesday, June 3, 2020	0.070	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Cafeteria/Kitchen double compartment sink tap	MUK862	Wednesday, June 3, 2020	0.003	Passed	0.2500	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Cafeteria/Kitchen hand washing sink tap	MUK863	Wednesday, June 3, 2020	0.003	Passed	0.5000	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 107 tap 1	MUK864	Wednesday, June 3, 2020	0.014	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 107 tap 2	MUK865	Wednesday, June 3, 2020	0.010	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 107 tap 3	MUK866	Wednesday, June 3, 2020	0.044	Exceeded	0.0970	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Girls Wash Room 107 tap 4	MUK867	Wednesday, June 3, 2020	0.010	Exceeded	0.0800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 109 tap 1	MUK868	Wednesday, June 3, 2020	0.006	Exceeded	0.0930	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 109 tap 2	MUK869	Wednesday, June 3, 2020	0.007	Exceeded	0.0780	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 109 tap 3	MUK870	Wednesday, June 3, 2020	0.007	Exceeded	0.0930	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Boys Wash Room 109 tap 4	MUK871	Wednesday, June 3, 2020	0.006	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 111 tap	MUK872	Wednesday, June 3, 2020	0.026	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Room 132 Gender Neutral Wash Room tap	MUK873	Wednesday, June 3, 2020	0.013	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Room 133 Gender Neutral Wash Room tap	MUK874	Wednesday, June 3, 2020	0.014	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 113 tap	MUK875	Wednesday, June 3, 2020	0.003	Passed	0.1500	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 116 tap	MUK876	Wednesday, June 3, 2020	0.011	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 114 tap	MUK877	Wednesday, June 3, 2020	0.006	Exceeded	0.6200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 112 tap	MUK878	Wednesday, June 3, 2020	0.008	Exceeded	0.8600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Class Room 110 tap	MUK879	Wednesday, June 3, 2020	0.002	Passed	0.2300	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Room 131 Gender Neutral Wash Room tap	MUK880	Wednesday, June 3, 2020	0.021	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Janitors Closet tap by Room 131	MUK881	Wednesday, June 3, 2020	0.001	Passed	0.0260	Passed	
Beechville-Lakeside-Timberlea Junior Elementary Sc	Fountain by Janitors Closet	MUK882	Wednesday, June 3, 2020	0.001	Passed	0.4500	Passed	Fountain replaced.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Music Room 108 tap	MUK883	Wednesday, June 3, 2020	0.052	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Gym Gender Neutral Wash Room 1 tap	MUK884	Wednesday, June 3, 2020	0.010	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Gym Office Wash Room tap	MUK885	Wednesday, June 3, 2020	0.011	Exceeded	0.7200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Junior Elementary Sc	Gym Gender Neutral Wash Room 2 tap	MUK886	Wednesday, June 3, 2020	0.550	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Staff Room Kitchen tap	MUJ397	Wednesday, June 3, 2020	0.001	Passed	0.0760	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Staff Room Female Wash Room tap 1	MUJ398	Wednesday, June 3, 2020	0.004	Passed	0.1200	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Staff Room Female Wash Room tap 2	MUJ399	Wednesday, June 3, 2020	0.027	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Staff Room Male Wash Room tap	MUJ400	Wednesday, June 3, 2020	0.011	Exceeded	0.0800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Boys Wash Room tap 1 by Library	MUJ401	Wednesday, June 3, 2020	0.004	Passed	0.1600	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Boys Wash Room tap 2 by Library	MUJ402	Wednesday, June 3, 2020	0.010	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Boys Wash Room tap 3 by Library	MUJ403	Wednesday, June 3, 2020	0.016	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Janitors Closet tap by Library	MUJ404	Wednesday, June 3, 2020	0.001	Passed	0.0270	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Fountain by Janitors Closet	MUJ405	Wednesday, June 3, 2020	0.022	Exceeded	0.5600	Passed	Fountain remediated.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Girls Wash Room tap 1 by Room 203	MUJ406	Wednesday, June 3, 2020	0.007	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Girls Wash Room tap 21 by Room 203	MUJ407	Wednesday, June 3, 2020	0.010	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Girls Wash Room tap 3 by Room 203	MUJ408	Wednesday, June 3, 2020	0.003	Passed	0.2600	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Girls Wash Room tap 4 by Room 203	MUJ409	Wednesday, June 3, 2020	0.002	Passed	0.1400	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Cooking Room tap 1	NNS470	Thursday, September 3, 2020	0.001	Passed	0.0130	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Cooking Room tap 2	NNS471	Thursday, September 3, 2020	0.000	Passed	0.0130	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Sewing Room tap	MUJ412	Wednesday, June 3, 2020	0.014	Exceeded	0.5900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	French Room 200 tap	MUJ413	Wednesday, June 3, 2020	0.013	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Cafeteria/Kitchen hand washing sink tap	MUJ414	Wednesday, June 3, 2020	0.003	Passed	0.1700	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Cafeteria/Kitchen sink tap	NNS469	Thursday, September 3, 2020	0.000	Passed	0.0100	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Cafeteria/Kitchen double compartment sink tap	MUJ416	Wednesday, June 3, 2020	0.004	Passed	0.3500	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Boys Change Room tap 1	MUJ417	Wednesday, June 3, 2020	0.007	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Boys Change Room tap 2	MUJ418	Wednesday, June 3, 2020	0.003	Passed	0.1200	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Fountain by Room 105	MUJ419	Wednesday, June 3, 2020	0.005	Exceeded	0.1200	Passed	Fountain remediated.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Staff Wash Room tap by Room 105	MUJ420	Wednesday, June 3, 2020	0.001	Passed	0.0510	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Staff Wash Room tap by Room 104	MUJ421	Wednesday, June 3, 2020	0.001	Passed	0.0340	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Girls Change Room tap 1	MUJ422	Wednesday, June 3, 2020	0.070	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Girls Change Room tap 2	MUJ423	Wednesday, June 3, 2020	0.013	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Metal Room sink tap	MUJ424	Wednesday, June 3, 2020	0.007	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Beechville-Lakeside-Timberlea Senior Elementary Sc	Art Room multi tap sink tap 1	MUJ425	Wednesday, June 3, 2020	0.001	Passed	0.0610	Passed	
Beechville-Lakeside-Timberlea Senior Elementary Sc	Art Room multi tap sink tap 2	MUJ426	Wednesday, June 3, 2020	-	Passed	0.0580	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Beechville-Lakeside-Timberlea Senior Elementary School	Art Room multi tap sink tap 3	MUJ427	Wednesday, June 3, 2020	-	Passed	0.0540	Passed	
Beechville-Lakeside-Timberlea Senior Elementary School	Art Room multi tap sink tap 4	MUJ428	Wednesday, June 3, 2020	-	Passed	0.0470	Passed	
Beechville-Lakeside-Timberlea Senior Elementary School	Janitors Closet tap by Room 101	MUJ429	Wednesday, June 3, 2020	0.007	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bel Ayr Elementary School	Staff Room 120 Wash Room 1 tap	MXJ925	Thursday, June 18, 2020	0.007	Exceeded	0.0560	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bel Ayr Elementary School	Staff Room 120 Kitchen tap	MXJ926	Thursday, June 18, 2020	0.001	Passed	0.0540	Passed	
Bel Ayr Elementary School	Staff Room 120 Wash Room 2 tap	MXJ927	Thursday, June 18, 2020	0.001	Passed	0.0590	Passed	
Bel Ayr Elementary School	Fountain by Room 112	PXP046	Wednesday, June 23, 2021	0.001	Passed	0.1200	Passed	Fountain replaced
Bel Ayr Elementary School	Boys Wash Room tap 1 by Room 124	MXJ929	Thursday, June 18, 2020	0.007	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bel Ayr Elementary School	Boys Wash Room tap 2 by Room 124	MXJ930	Thursday, June 18, 2020	0.006	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bel Ayr Elementary School	Boys Wash Room tap 3 by Room 124	MXJ931	Thursday, June 18, 2020	0.002	Passed	0.0570	Passed	
Bel Ayr Elementary School	Janitors Closet 124 tap	MXJ932	Thursday, June 18, 2020	0.006	Exceeded	0.0570	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bel Ayr Elementary School	Girls Wash Room tap 1 by Room 124	MXJ933	Thursday, June 18, 2020	0.003	Passed	0.0840	Passed	
Bel Ayr Elementary School	Girls Wash Room tap 2 by Room 124	MXJ934	Thursday, June 18, 2020	0.007	Exceeded	0.0530	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bel Ayr Elementary School	Girls Wash Room tap 3 by Room 124	MXJ935	Thursday, June 18, 2020	0.003	Passed	0.0410	Passed	
Bel Ayr Elementary School	Learning Centre Wash Room tap	MXJ936	Thursday, June 18, 2020	0.001	Passed	0.0540	Passed	
Bel Ayr Elementary School	Girls Wash Room tap 1 by Room 122	MXJ937	Thursday, June 18, 2020	0.001	Passed	0.3200	Passed	
Bel Ayr Elementary School	Girls Wash Room tap 2 by Room 122	MXJ938	Thursday, June 18, 2020	-	Passed	0.0510	Passed	
Bel Ayr Elementary School	Boys Wash Room tap 1 by Room 122	MXJ939	Thursday, June 18, 2020	0.006	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bel Ayr Elementary School	Boys Wash Room tap 2 by Room 122	MXJ940	Thursday, June 18, 2020	0.002	Passed	0.0620	Passed	
Bel Ayr Elementary School	Boys Wash Room tap 3 by Room 122	MXJ941	Thursday, June 18, 2020	0.001	Passed	0.0510	Passed	
Bel Ayr Elementary School	Gym/Cafeteria tap	NLS536	Tuesday, August 25, 2020	0.004	Passed	0.0160	Passed	
Bel Ayr Elementary School	Fountain by Room 123	PXP054	Wednesday, June 23, 2021	0.003	Passed	0.0620	Passed	Fountain replaced
Bel Ayr Elementary School	Janitors Closet 123 tap	MXJ944	Thursday, June 18, 2020	0.002	Passed	0.1100	Passed	
Bel Ayr Elementary School	Main Office 118 tap 1	MXJ945	Thursday, June 18, 2020	0.003	Passed	0.1000	Passed	
Bel Ayr Elementary School	Main Office 118 tap 2	MXJ946	Thursday, June 18, 2020	0.002	Passed	0.0920	Passed	
Bell Park Academic Centre	Staff Room 218 tap	MYA895	Monday, June 22, 2020	0.002	Passed	0.2600	Passed	
Bell Park Academic Centre	Staff Room 218 Male Wash Room tap	MYA896	Monday, June 22, 2020	0.004	Passed	0.3200	Passed	
Bell Park Academic Centre	Staff Room 218 Female Wash Room tap	MYA897	Monday, June 22, 2020	0.002	Passed	0.2300	Passed	
Bell Park Academic Centre	Fountain by Room 218	MYA898	Monday, June 22, 2020	0.003	Passed	0.3400	Passed	
Bell Park Academic Centre	Girls Wash Room tap 1 by Room 206	MYA899	Monday, June 22, 2020	0.002	Passed	0.0650	Passed	
Bell Park Academic Centre	Girls Wash Room tap 2 by Room 206	MYA900	Monday, June 22, 2020	0.003	Passed	0.1400	Passed	
Bell Park Academic Centre	Girls Wash Room tap 3 by Room 206	MYA901	Monday, June 22, 2020	0.006	Exceeded	0.1400	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Fountain by Room 206	Qqmi254	Thursday, August 26, 2021	0.002	Passed	0.1200	Passed	Fountain replaced
Bell Park Academic Centre	Boys Wash Room tap 1 by Room 205	MYA903	Monday, June 22, 2020	0.010	Exceeded	0.3700	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Boys Wash Room tap 2 by Room 205	MYA904	Monday, June 22, 2020	0.013	Exceeded	0.4500	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Boys Wash Room tap 3 by Room 205	MYA910	Monday, June 22, 2020	0.010	Exceeded	0.4200	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Class Room 216 tap	MYA911	Monday, June 22, 2020	0.007	Exceeded	0.1800	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Janitors Closet 203	MYA912	Monday, June 22, 2020	0.001	Passed	0.1300	Passed	
Bell Park Academic Centre	Class Room 101 tap	MYA913	Monday, June 22, 2020	0.003	Passed	0.1800	Passed	
Bell Park Academic Centre	Fountain by Room 101	MYA914	Monday, June 22, 2020	0.001	Passed	0.2900	Passed	
Bell Park Academic Centre	Class Room 102 tap	MYA915	Monday, June 22, 2020	0.001	Passed	0.4500	Passed	
Bell Park Academic Centre	Class Room 102 Wash Room tap	MYA916	Monday, June 22, 2020	0.001	Passed	0.1700	Passed	
Bell Park Academic Centre	Class Room 101 Wash Room tap	MYA917	Monday, June 22, 2020	0.006	Exceeded	0.1400	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Class Room 103 Wash Room tap	MYA918	Monday, June 22, 2020	0.002	Passed	0.3000	Passed	
Bell Park Academic Centre	Staff Wash Room tap by Office	MYH195	Tuesday, June 23, 2020	0.001	Passed	0.1000	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Bell Park Academic Centre	Girls Wash Room tap 1 by Office	MYH196	Tuesday, June 23, 2020	0.017	Exceeded	0.4000	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Girls Wash Room tap 2 by Office	MYH197	Tuesday, June 23, 2020	0.017	Exceeded	0.3800	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Girls Wash Room tap 3 by Office	MYH198	Tuesday, June 23, 2020	0.027	Exceeded	0.3800	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Fountain by Room 105	QMI253	Thursday, August 26, 2021	0.004	Passed	0.0970	Passed	Fountain replaced
Bell Park Academic Centre	Boys Wash Room tap 1 by Office	MYH200	Tuesday, June 23, 2020	0.013	Exceeded	0.3000	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Boys Wash Room tap 2 by Office	MYH201	Tuesday, June 23, 2020	0.006	Exceeded	0.1600	Passed	Signage added to instruct handwashing only
Bell Park Academic Centre	Janitors Closet tap by Boys Wash Room	MYH202	Tuesday, June 23, 2020	0.001	Passed	0.0450	Passed	
Bell Park Academic Centre	Kitchen/Cafeteria hand washing tap	MYH203	Tuesday, June 23, 2020	0.002	Passed	0.5700	Passed	
Bell Park Academic Centre	Kitchen/Cafeteria triple compartment tap 1	MYH204	Tuesday, June 23, 2020	0.002	Passed	0.5200	Passed	
Bell Park Academic Centre	Kitchen/Cafeteria triple compartment tap 2	MYH205	Tuesday, June 23, 2020	0.001	Passed	0.1900	Passed	
Bell Park Academic Centre	Main Office tap	MYH206	Tuesday, June 23, 2020	0.001	Passed	0.6600	Passed	
BFEC - BPM	Gender Neutral Wash Room 138 tap	OCN147	Thursday, November 5, 2020	0.003	Passed	0.0890	Passed	
BFEC - BPM	Gender Neutral Wash Room 140 tap	OCN148	Thursday, November 5, 2020	0.002	Passed	0.0840	Passed	
BFEC - BPM	Gender Neutral Wash Room 143 tap	OAM998	Thursday, October 29, 2020	0.005	Passed	0.1700	Passed	
BFEC - BPM	Gender Neutral Wash Room 142 tap	OAM999	Thursday, October 29, 2020	0.005	Passed	0.1700	Passed	
BFEC - BPM	Gender Neutral Wash Room 141 tap	OAM000	Thursday, October 29, 2020	0.005	Passed	0.1600	Passed	
BFEC - BPM	Gender Neutral Wash Room 139 tap	OAM002	Thursday, October 29, 2020	0.005	Passed	0.1700	Passed	
BFEC - BPM	Class Room 136 tap 1	NZB923	Thursday, October 22, 2020	-	Passed	0.0250	Passed	
BFEC - BPM	Class Room 136 tap 2	NZB924	Thursday, October 22, 2020	-	Passed	0.0250	Passed	
BFEC - BPM	Class Room 136 tap 3	NZB925	Thursday, October 22, 2020	-	Passed	0.0250	Passed	
BFEC - BPM	Class Room 136 tap 4	NZB926	Thursday, October 22, 2020	-	Passed	0.0250	Passed	
BFEC - BPM	Gender Neutral Wash Room 144 tap	NZB927	Thursday, October 22, 2020	0.001	Passed	0.0450	Passed	
BFEC - BPM	Janitors Closet 137 tap	NZB931	Thursday, October 22, 2020	-	Passed	0.0180	Passed	
BFEC - BPM	Class Room 124 tap	NZB932	Thursday, October 22, 2020	-	Passed	0.0310	Passed	
BFEC - BPM	Fountain by Wash Rooms	NZB938	Thursday, October 22, 2020	0.001	Passed	0.1400	Passed	
BFEC - BPM	Staff Room 109 Kitchen tap	NZB939	Thursday, October 22, 2020	-	Passed	0.0290	Passed	
BFEC - BPM	Staff Wash Room 110 tap	NZB940	Thursday, October 22, 2020	0.001	Passed	0.0480	Passed	
BFEC - BPM	Staff Wash Room 111 tap	NZB941	Thursday, October 22, 2020	0.001	Passed	0.0470	Passed	
BFEC - BPM	Gender Neutral Wash Room 107 tap	NZB942	Thursday, October 22, 2020	0.001	Passed	0.0510	Passed	
BFEC (Dartmouth)	Staff Wash Room tap by Youth Centre	MYA741	Monday, June 22, 2020	0.021	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Youth Centre tap 1	MYA742	Monday, June 22, 2020	0.025	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Youth Centre tap 2	MYA743	Monday, June 22, 2020	0.019	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Youth Centre tap 3	MYA744	Monday, June 22, 2020	0.510	Exceeded	1.9000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Staff Room Male Wash Room tap	MYA745	Monday, June 22, 2020	0.026	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Staff Room Female Wash Room tap	MYA746	Monday, June 22, 2020	0.043	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Upstairs Boys Wash Room tap 1	MYA747	Monday, June 22, 2020	0.190	Exceeded	1.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Upstairs Boys Wash Room tap 2	MYA748	Monday, June 22, 2020	0.400	Exceeded	4.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Upstairs Boys Wash Room tap 3	MYA749	Monday, June 22, 2020	0.370	Exceeded	2.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Upstairs Boys Wash Room tap 4	MYA750	Monday, June 22, 2020	0.200	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Janitors Closet tap between Wash Rooms	MYA751	Monday, June 22, 2020	0.050	Exceeded	0.5100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Fountain Between Wash Rooms	MYA752	Monday, June 22, 2020	0.023	Exceeded	0.9100	Passed	Fountain to be decommissioned, remediated, and rete1sed. Other sources available
BFEC (Dartmouth)	Upstairs Girls Wash Room tap 1	MYA753	Monday, June 22, 2020	0.110	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Upstairs Girls Wash Room tap 2	MYA754	Monday, June 22, 2020	0.500	Exceeded	2.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Upstairs Girls Wash Room tap 3	MYA755	Monday, June 22, 2020	0.560	Exceeded	3.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Upstairs Girls Wash Room tap 4	MYA756	Monday, June 22, 2020	0.200	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
BFEC (Dartmouth)	Janitors Closet 12 tap	MYA757	Monday, June 22, 2020	0.055	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Downstairs Boys Wash Room tap 1	MYA758	Monday, June 22, 2020	0.063	Exceeded	0.6500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Downstairs Boys Wash Room tap 2	MYA759	Monday, June 22, 2020	0.320	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Downstairs Boys Wash Room tap 3	MYA760	Monday, June 22, 2020	0.150	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Downstairs Boys Wash Room tap 4	MYA762	Monday, June 22, 2020	1.800	Exceeded	3.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Fountain by Janitors Room	MYA763	Monday, June 22, 2020	0.001	Passed	0.3700	Passed	
BFEC (Dartmouth)	Janitors Closet tap	MYA764	Monday, June 22, 2020	0.003	Passed	0.0590	Passed	
BFEC (Dartmouth)	Downstairs Girls Wash Room tap 1	MYA765	Monday, June 22, 2020	0.220	Exceeded	4.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Downstairs Girls Wash Room tap 2	MYA766	Monday, June 22, 2020	0.370	Exceeded	4.7000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Downstairs Girls Wash Room tap 3	MYA767	Monday, June 22, 2020	0.048	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Downstairs Girls Wash Room tap 4	MYA768	Monday, June 22, 2020	0.039	Exceeded	0.8900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
BFEC (Dartmouth)	Class Room 17 tap	MYA769	Monday, June 22, 2020	0.008	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Principle Office Wash Room tap	MYR712	Wednesday, June 24, 2020	0.004	Passed	0.2300	Passed	
Bicentennial School	Office Wash Room 04 tap	MYR713	Wednesday, June 24, 2020	0.006	Exceeded	0.0520	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Janitors Closet tap by Room 18	MYR714	Wednesday, June 24, 2020	0.001	Passed	0.0330	Passed	
Bicentennial School	Boys Wash Room tap 1 by Library	MYR715	Wednesday, June 24, 2020	0.005	Passed	0.1800	Passed	
Bicentennial School	Boys Wash Room tap 2 by Library	MYR716	Wednesday, June 24, 2020	0.001	Passed	0.0300	Passed	
Bicentennial School	Boys Wash Room tap 3 by Library	MYR717	Wednesday, June 24, 2020	0.001	Passed	0.0330	Passed	
Bicentennial School	Boys Wash Room tap 4 by Library	MYR718	Wednesday, June 24, 2020	-	Passed	0.0310	Passed	
Bicentennial School	Boys Wash Room tap 5 by Library	MYR719	Wednesday, June 24, 2020	-	Passed	0.0320	Passed	
Bicentennial School	Boys Wash Room tap 6 by Library	MYR720	Wednesday, June 24, 2020	0.001	Passed	0.0360	Passed	
Bicentennial School	Boys Wash Room tap 7 by Library	MYR721	Wednesday, June 24, 2020	0.001	Passed	0.0310	Passed	
Bicentennial School	Boys Wash Room tap 8 by Library	MYR722	Wednesday, June 24, 2020	0.001	Passed	0.0350	Passed	
Bicentennial School	Staff Gender Neutral Wash Room tap by Library	MYR723	Wednesday, June 24, 2020	0.002	Passed	0.0610	Passed	
Bicentennial School	Fountain by Library	MYR724	Wednesday, June 24, 2020	0.002	Passed	0.4700	Passed	
Bicentennial School	Staff Gender Neutral Wash Room tap by Library	MYR725	Wednesday, June 24, 2020	0.001	Passed	0.0500	Passed	
Bicentennial School	Girls Wash Room tap 1 by Library	MYR726	Wednesday, June 24, 2020	0.012	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Girls Wash Room tap 2 by Library	MYR727	Wednesday, June 24, 2020	0.002	Passed	0.0580	Passed	
Bicentennial School	Girls Wash Room tap 3 by Library	MYR728	Wednesday, June 24, 2020	0.001	Passed	0.0310	Passed	
Bicentennial School	Girls Wash Room tap 4 by Library	MYR729	Wednesday, June 24, 2020	-	Passed	0.0240	Passed	
Bicentennial School	Girls Wash Room tap 5 by Library	MYR730	Wednesday, June 24, 2020	-	Passed	0.0220	Passed	
Bicentennial School	Girls Wash Room tap 6 by Library	MYR731	Wednesday, June 24, 2020	-	Passed	0.0190	Passed	
Bicentennial School	Girls Wash Room tap 7 by Library	MYR732	Wednesday, June 24, 2020	-	Passed	0.0160	Passed	
Bicentennial School	Girls Wash Room tap 8 by Library	MYR733	Wednesday, June 24, 2020	-	Passed	0.0200	Passed	
Bicentennial School	Art Room 19 tap	MYR734	Wednesday, June 24, 2020	0.002	Passed	0.1000	Passed	
Bicentennial School	Learning Centre Wash Room 1 tap	MYR735	Wednesday, June 24, 2020	0.002	Passed	0.3700	Passed	
Bicentennial School	Learning Centre Wash Room 2 tap	MYR736	Wednesday, June 24, 2020	0.002	Passed	0.3200	Passed	
Bicentennial School	Janitors Closet tap by Class Room 2	MYR737	Wednesday, June 24, 2020	-	Passed	0.0170	Passed	
Bicentennial School	Boys Wash Room tap 1 by Class Room 1	MYR738	Wednesday, June 24, 2020	0.001	Passed	0.0190	Passed	
Bicentennial School	Boys Wash Room tap 2 by Class Room 1	MYR739	Wednesday, June 24, 2020	0.075	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Gym Office Wash Room tap	MYR740	Wednesday, June 24, 2020	0.042	Exceeded	0.5800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Fountain by Gym Office	MYR741	Wednesday, June 24, 2020	-	Passed	0.4000	Passed	
Bicentennial School	Fountain by Gym Door	MYR742	Wednesday, June 24, 2020	0.004	Passed	0.5600	Passed	
Bicentennial School	Pre-primary Wash Room tap 1 by Staff Room	MYR743	Wednesday, June 24, 2020	0.001	Passed	0.0220	Passed	
Bicentennial School	Pre-primary Wash Room tap 2 by Staff Room	MYR744	Wednesday, June 24, 2020	0.013	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Bicentennial School	Pre-primary Wash Room tap 3 by Staff Room	MYR745	Wednesday, June 24, 2020	0.007	Exceeded	0.5600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Fountain by Staff Room	NMK042	Friday, August 28, 2020	0.002	Passed	0.0960	Passed	
Bicentennial School	Janitors Closet tap by Room 9	MYR747	Wednesday, June 24, 2020	0.001	Passed	0.0610	Passed	
Bicentennial School	Staff Room Kitchen tap	MYR748	Wednesday, June 24, 2020	-	Passed	0.2200	Passed	
Bicentennial School	Mimeograph Room tap	MYR749	Wednesday, June 24, 2020	-	Passed	0.0700	Passed	
Bicentennial School	Gender Neutral Wash Room tap by Staff Room	MYR750	Wednesday, June 24, 2020	0.001	Passed	0.0500	Passed	
Bicentennial School	Administrative Assistant Room tap	MYR751	Wednesday, June 24, 2020	0.003	Passed	0.2000	Passed	
Bicentennial School	Science Lab tap 1 Room 27	MYR752	Wednesday, June 24, 2020	0.180	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 2 Room 27	MYR753	Wednesday, June 24, 2020	0.074	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 3 Room 27	MYR754	Wednesday, June 24, 2020	0.120	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 4 Room 27	MYR755	Wednesday, June 24, 2020	0.052	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 5 Room 27	MYR756	Wednesday, June 24, 2020	0.023	Exceeded	0.8500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 6 Room 27	MYR757	Wednesday, June 24, 2020	0.035	Exceeded	0.9800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 7 Room 27	MYR758	Wednesday, June 24, 2020	0.079	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 8 Room 27	MYR759	Wednesday, June 24, 2020	0.073	Exceeded	0.7100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 9 Room 27	MYR760	Wednesday, June 24, 2020	0.008	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 10 Room 27	MYR761	Wednesday, June 24, 2020	0.009	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 11 Room 27	MYR762	Wednesday, June 24, 2020	0.014	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 12 Room 27	MYR763	Wednesday, June 24, 2020	0.007	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 13 Room 27	MYR764	Wednesday, June 24, 2020	0.004	Passed	0.1300	Passed	
Bicentennial School	Science Lab tap 14 Room 27	MYR765	Wednesday, June 24, 2020	0.004	Passed	0.1200	Passed	
Bicentennial School	Science Lab tap 15 Room 27	MYR766	Wednesday, June 24, 2020	0.007	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 16 Room 27	MYR767	Wednesday, June 24, 2020	0.013	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Science Lab tap 17 Room 27	MYR768	Wednesday, June 24, 2020	0.005	Passed	0.1400	Passed	
Bicentennial School	Science Lab tap 18 Room 27	MYR769	Wednesday, June 24, 2020	0.002	Passed	0.1000	Passed	
Bicentennial School	Science Lab tap 19 Room 27	MYR770	Wednesday, June 24, 2020	0.008	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Janitors Closet tap by Room 29	MYR771	Wednesday, June 24, 2020	0.001	Passed	0.0370	Passed	
Bicentennial School	Class Room 29 tap	MYR772	Wednesday, June 24, 2020	0.002	Passed	0.1700	Passed	
Bicentennial School	Fountain by Room 31	MYR773	Wednesday, June 24, 2020	0.001	Passed	0.0380	Passed	
Bicentennial School	Tech Ed sink tap	MYR774	Wednesday, June 24, 2020	0.002	Passed	0.0670	Passed	
Bicentennial School	Tech Ed Room fountain	MYR775	Wednesday, June 24, 2020	0.012	Exceeded	0.0980	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Class Room 30 tap	MYR776	Wednesday, June 24, 2020	0.008	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Boys Wash Room tap 1 by Room 30	MYR777	Wednesday, June 24, 2020	0.024	Exceeded	0.9700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Boys Wash Room tap 2 by Room 30	MYR778	Wednesday, June 24, 2020	0.022	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Boys Wash Room tap 3 by Room 30	MYR779	Wednesday, June 24, 2020	0.012	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Boys Wash Room tap 4 by Room 30	MYR780	Wednesday, June 24, 2020	0.001	Passed	0.0800	Passed	
Bicentennial School	Gender Neutral Wash Room tap by Room 29	MYR781	Wednesday, June 24, 2020	0.001	Passed	0.0280	Passed	
Bicentennial School	Gender Neutral Wash Room tap by Boys Wash Room	MYR782	Wednesday, June 24, 2020	0.001	Passed	0.1300	Passed	
Bicentennial School	Boys Wash Room tap 1 by Room 29	MYR783	Wednesday, June 24, 2020	0.038	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Boys Wash Room tap 2 by Room 29	MYR784	Wednesday, June 24, 2020	0.013	Exceeded	2.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Boys Wash Room tap 3 by Room 29	MYR785	Wednesday, June 24, 2020	0.002	Passed	0.2100	Passed	
Bicentennial School	Boys Wash Room tap 4 by Room 29	MYR786	Wednesday, June 24, 2020	0.025	Exceeded	4.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Bicentennial School	Fountain by Room 29	MYR787	Wednesday, June 24, 2020	-	Passed	0.5300	Passed	
Brookhouse Elementary School	Staff Room 111 Wash Room 1 tap	MWI326	Monday, June 15, 2020	0.016	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Staff Room 111 Kitchen tap	MWI327	Monday, June 15, 2020	0.001	Passed	0.0290	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Brookhouse Elementary School	Staff Room 111 Wash Room 2 tap	MWI328	Monday, June 15, 2020	-	Passed	0.0210	Passed	
Brookhouse Elementary School	Fountain by Room 205	MWI329	Monday, June 15, 2020	0.001	Passed	0.7400	Passed	
Brookhouse Elementary School	Fountain across from Room 205	NLJ906	Monday, August 24, 2020	0.002	Passed	0.0690	Passed	
Brookhouse Elementary School	Janitors Closet tap by Room 205	MWI331	Monday, June 15, 2020	0.001	Passed	0.0330	Passed	
Brookhouse Elementary School	Girls Wash Room 206 tap 1	MWI332	Monday, June 15, 2020	0.056	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Girls Wash Room 206 tap 2	MWI333	Monday, June 15, 2020	0.230	Exceeded	2.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Girls Wash Room 206 tap 3	MWI334	Monday, June 15, 2020	0.120	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Girls Wash Room 206 tap 4	MWI335	Monday, June 15, 2020	0.270	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Staff Wash Room 204 tap	MWI336	Monday, June 15, 2020	0.002	Passed	0.4700	Passed	
Brookhouse Elementary School	Fountain by Room 136	NLJ907	Monday, August 24, 2020	0.018	Exceeded	0.1000	Passed	New Fountain to be installed. Other sources available.
Brookhouse Elementary School	Janitors Closet tap by Room 136	MWI338	Monday, June 15, 2020	0.001	Passed	0.0400	Passed	
Brookhouse Elementary School	Boys Wash Room 136 tap 1	MWI339	Monday, June 15, 2020	0.022	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Boys Wash Room 136 tap 2	MWI340	Monday, June 15, 2020	0.005	Passed	0.1800	Passed	
Brookhouse Elementary School	Boys Wash Room 136 tap 3	MWI341	Monday, June 15, 2020	0.002	Passed	0.0590	Passed	
Brookhouse Elementary School	Learning Centre Wash Room tap	MWI342	Monday, June 15, 2020	0.009	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Gym Office Wash Room tap	MWI343	Monday, June 15, 2020	0.008	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Boys Wash Room tap 1 by Room 127	MWI344	Monday, June 15, 2020	0.003	Passed	0.0500	Passed	
Brookhouse Elementary School	Boys Wash Room tap 2 by Room 127	MWI345	Monday, June 15, 2020	0.003	Passed	0.0420	Passed	
Brookhouse Elementary School	Boys Wash Room tap 3 by Room 127	MWI348	Monday, June 15, 2020	0.002	Passed	0.0280	Passed	
Brookhouse Elementary School	Janitors Closet tap by Room 127	MWI349	Monday, June 15, 2020	0.004	Passed	0.0370	Passed	
Brookhouse Elementary School	Girls Wash Room tap 1 by Room 104	MWI350	Monday, June 15, 2020	-	Passed	0.0100	Passed	
Brookhouse Elementary School	Girls Wash Room tap 2 by Room 104	MWI351	Monday, June 15, 2020	0.006	Exceeded	0.0840	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Girls Wash Room tap 3 by Room 104	MWI352	Monday, June 15, 2020	-	Passed	0.0120	Passed	
Brookhouse Elementary School	Girls Wash Room 112 tap 1	MWI353	Monday, June 15, 2020	0.002	Passed	0.0300	Passed	
Brookhouse Elementary School	Girls Wash Room 112 tap 2	MWI354	Monday, June 15, 2020	0.001	Passed	0.0180	Passed	
Brookhouse Elementary School	Girls Wash Room 112 tap 3	MWI355	Monday, June 15, 2020	0.001	Passed	0.0130	Passed	
Brookhouse Elementary School	Girls Wash Room 112 tap 4	MWI356	Monday, June 15, 2020	0.001	Passed	0.0130	Passed	
Brookhouse Elementary School	Fountain by Room 112	MWI357	Monday, June 15, 2020	0.005	Passed	1.1000	Passed	
Brookhouse Elementary School	Boys Wash Room 125 tap 1	MWI390	Monday, June 15, 2020	0.014	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Boys Wash Room 125 tap 2	MWI391	Monday, June 15, 2020	0.012	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Boys Wash Room 125 tap 3	MWI392	Monday, June 15, 2020	0.014	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Brookhouse Elementary School	Fountain by Room 125	MWI393	Monday, June 15, 2020	0.001	Passed	0.6400	Passed	
Brookhouse Elementary School	Office Room 115 tap	NLJ908	Monday, August 24, 2020	0.000	Passed	0.0170	Passed	
Brookhouse Elementary School	Principal's Office Wash Room 116 tap	MWI395	Monday, June 15, 2020	0.003	Passed	0.0830	Passed	
Brookside Junior High School	Girls Wash Room tap 1	MUQ912	Thursday, June 4, 2020	0.012	Exceeded	0.4300	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Girls Wash Room tap 2	MUQ913	Thursday, June 4, 2020	0.026	Exceeded	0.4200	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Girls Wash Room tap 3	MUQ914	Thursday, June 4, 2020	0.011	Exceeded	0.5300	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Girls Wash Room tap 4	MUQ915	Thursday, June 4, 2020	0.030	Exceeded	0.5600	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Gender Neutral Wash Room tap	MUQ916	Thursday, June 4, 2020	0.037	Exceeded	0.6700	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Gender Neutral Wash Room tap	MUQ917	Thursday, June 4, 2020	0.005	Passed	0.3100	Passed	
Brookside Junior High School	Boys Wash Room tap 1	MUQ918	Thursday, June 4, 2020	0.019	Exceeded	0.5300	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Boys Wash Room tap 2	MUQ919	Thursday, June 4, 2020	0.033	Exceeded	0.4700	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Boys Wash Room tap 3	MUQ920	Thursday, June 4, 2020	0.083	Exceeded	0.6300	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Storage Room tap	MUQ921	Thursday, June 4, 2020	0.013	Exceeded	0.1200	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Kitchen/Cafe tap 1	MUQ922	Thursday, June 4, 2020	0.003	Passed	0.2200	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Brookside Junior High School	Kitchen/Cafe tap 2	MUQ923	Thursday, June 4, 2020	0.013	Exceeded	0.4600	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Kitchen/Cafe tap 3	MUQ924	Thursday, June 4, 2020	0.061	Exceeded	0.8300	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Boiler Room tap	MUQ925	Thursday, June 4, 2020	0.004	Passed	0.3000	Passed	
Brookside Junior High School	Janitors Closet tap	MUQ926	Thursday, June 4, 2020	0.240	Exceeded	2.7000	Exceeded	Signage added to instruct handwashing only
Brookside Junior High School	Principal's Office Wash Room tap	MUQ927	Thursday, June 4, 2020	0.007	Exceeded	0.6600	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Staff Room Kitchen tap	NAK447	Thursday, July 2, 2020	0.003	Passed	0.3100	Passed	
Brookside Junior High School	2nd Floor Staff Room tap 1	MUQ928	Thursday, June 4, 2020	0.012	Exceeded	0.6800	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Staff Room tap 2	MUQ929	Thursday, June 4, 2020	0.013	Exceeded	0.4900	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Girls Wash Room tap 1	MUQ931	Thursday, June 4, 2020	0.015	Exceeded	0.6500	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Girls Wash Room tap 2	MUQ932	Thursday, June 4, 2020	0.033	Exceeded	0.8900	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Girls Wash Room tap 3	MUQ933	Thursday, June 4, 2020	0.220	Exceeded	0.3100	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Janitors Closet tap	MUQ934	Thursday, June 4, 2020	0.026	Exceeded	0.5400	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Boys Wash Room tap 1	MUQ935	Thursday, June 4, 2020	0.016	Exceeded	0.6900	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Boys Wash Room tap 2	MUQ936	Thursday, June 4, 2020	0.012	Exceeded	0.4500	Passed	Signage added to instruct handwashing only
Brookside Junior High School	2nd Floor Boys Wash Room tap 3	NAK453	Thursday, July 2, 2020	0.019	Exceeded	0.2600	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Class Room 215 tap 1	PCW346	Thursday, March 18, 2021	0.012	Exceeded	0.7200	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Class Room 215 tap 2	PCW347	Thursday, March 18, 2021	0.009	Exceeded	0.3400	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Class Room 215 tap 3	PCW348	Thursday, March 18, 2021	0.012	Exceeded	0.3000	Passed	Signage added to instruct handwashing only
Brookside Junior High School	Class Room 215 tap 4	PCW249	Thursday, March 18, 2021	0.004	Passed	0.2800	Passed	
Brookside Junior High School	Class Room 215 tap 5	PCW350	Thursday, March 18, 2021	0.005	Passed	0.2700	Passed	
Brookside Junior High School	Fountain by Room 208	NAK454	Thursday, July 2, 2020	0.006	Exceeded	0.2800	Passed	New Fountain to be installed. Other sources available.
Brookside Junior High School	Fountain by Room 106	NAK455	Thursday, July 2, 2020	0.005	Passed	0.2100	Passed	
Burton Ettinger Elementary School	Class Room 218 tap	MRX345	Monday, May 25, 2020	0.003	Passed	0.0540	Passed	
Burton Ettinger Elementary School	Class Room 220 tap	MRX346	Monday, May 25, 2020	0.006	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Class Room 221 tap	MRX347	Monday, May 25, 2020	0.003	Passed	0.1600	Passed	
Burton Ettinger Elementary School	Class Room 222 tap	MRX348	Monday, May 25, 2020	0.021	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Class Room 223 tap	MRX349	Monday, May 25, 2020	0.004	Passed	0.2000	Passed	
Burton Ettinger Elementary School	Fountain by Room 224	QQC454	Monday, September 13, 2021	-	Passed	0.0430	Passed	Fountain replaced
Burton Ettinger Elementary School	Janitors Closet 224 tap	MRX351	Monday, May 25, 2020	0.006	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Staff Room 227 tap	NIU634	Wednesday, August 12, 2020	0.000	Passed	0.0140	Passed	
Burton Ettinger Elementary School	Janitors Closet 238 tap	MRX353	Monday, May 25, 2020	0.001	Passed	0.0160	Passed	
Burton Ettinger Elementary School	Gender Neutral Wash Room 231 tap	MRX354	Monday, May 25, 2020	0.002	Passed	0.1600	Passed	
Burton Ettinger Elementary School	Girls Wash Room 236 tap 1	MRX355	Monday, May 25, 2020	-	Passed	0.1700	Passed	
Burton Ettinger Elementary School	Girls Wash Room 236 tap 2	MRX356	Monday, May 25, 2020	-	Passed	0.0600	Passed	
Burton Ettinger Elementary School	Staff Female Wash Room 236 tap	MRX357	Monday, May 25, 2020	-	Passed	0.0076	Passed	
Burton Ettinger Elementary School	Fountain by Room 236	MRX358	Monday, May 25, 2020	-	Passed	0.5000	Passed	
Burton Ettinger Elementary School	Boys Wash Room 237 tap 1	MRX359	Monday, May 25, 2020	0.013	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Boys Wash Room 237 tap 2	MRX360	Monday, May 25, 2020	0.001	Passed	0.0120	Passed	
Burton Ettinger Elementary School	Staff Male Wash Room 237 tap	MRX361	Monday, May 25, 2020	-	Passed	0.0630	Passed	
Burton Ettinger Elementary School	Fountain by Office Room 101	NIU633	Wednesday, August 12, 2020	0.005	Passed	0.0440	Passed	
Burton Ettinger Elementary School	Staff Room 104 Wash Room tap 1	MRX363	Monday, May 25, 2020	0.005	Passed	0.0550	Passed	
Burton Ettinger Elementary School	Staff Room 104 Wash Room tap 2	MRX364	Monday, May 25, 2020	0.014	Exceeded	0.0690	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Staff Room 104 Kitchen tap	MRX365	Monday, May 25, 2020	0.008	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Girls Wash Room tap 1 by Room 108	MRX366	Monday, May 25, 2020	0.006	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Girls Wash Room tap 2 by Room 108	MRX367	Monday, May 25, 2020	0.002	Passed	0.0920	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Burton Ettinger Elementary School	Girls Wash Room tap 3 by Room 108	MRX368	Monday, May 25, 2020	0.010	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Staff Wash Room tap by Room 108	MRX369	Monday, May 25, 2020	0.002	Passed	0.0840	Passed	
Burton Ettinger Elementary School	Boys Wash Room tap 1 by Room 108	MRX370	Monday, May 25, 2020	0.002	Passed	0.0800	Passed	
Burton Ettinger Elementary School	Boys Wash Room tap 2 by Room 108	MRX371	Monday, May 25, 2020	0.020	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Boys Wash Room tap 3 by Room 108	MRX372	Monday, May 25, 2020	0.002	Passed	0.1200	Passed	
Burton Ettinger Elementary School	Janitors Closet tap by Room 102	MRX373	Monday, May 25, 2020	0.033	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Gym Girls Locker Room tap	MRX374	Monday, May 25, 2020	0.005	Passed	0.1100	Passed	
Burton Ettinger Elementary School	Gender Neutral Locker Room in Gym	MRX375	Monday, May 25, 2020	0.003	Passed	0.0850	Passed	
Burton Ettinger Elementary School	Kitchen Room 111 tap	MRX376	Monday, May 25, 2020	0.006	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Kitchen Room 111 double compartment sink	MRX377	Monday, May 25, 2020	0.001	Passed	0.1000	Passed	
Burton Ettinger Elementary School	Fountain by Room 112	QQC455	Monday, September 13, 2021	0.001	Passed	0.0260	Passed	Fountain replaced
Burton Ettinger Elementary School	Girls Wash Room tap 1 by Room 116	MRX379	Monday, May 25, 2020	0.001	Passed	0.3300	Passed	
Burton Ettinger Elementary School	Girls Wash Room tap 2 by Room 116	MRX380	Monday, May 25, 2020	-	Passed	0.0420	Passed	
Burton Ettinger Elementary School	Girls Wash Room tap 3 by Room 116	MRX381	Monday, May 25, 2020	-	Passed	0.2700	Passed	
Burton Ettinger Elementary School	Boys Wash Room 116 tap 1	MRX382	Monday, May 25, 2020	0.008	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Burton Ettinger Elementary School	Boys Wash Room 116 tap 2	MRX383	Monday, May 25, 2020	0.002	Passed	0.0140	Passed	
Caldwell Road Elementary School	Class Room Wash Room tap Room 1A	MQE455	Thursday, May 14, 2020	0.003	Passed	0.1900	Passed	
Caldwell Road Elementary School	Boys Wash Room tap 1 by Room 6	MQE456	Thursday, May 14, 2020	0.001	Passed	0.3200	Passed	
Caldwell Road Elementary School	Boys Wash Room tap 2 by Room 6	MQE457	Thursday, May 14, 2020	0.002	Passed	0.1700	Passed	
Caldwell Road Elementary School	Boys Wash Room tap 3 by Room 6	MQE458	Thursday, May 14, 2020	0.001	Passed	0.1000	Passed	
Caldwell Road Elementary School	Janitors Closet tap 1 by Room 6	MQE459	Thursday, May 14, 2020	0.001	Passed	0.0760	Passed	
Caldwell Road Elementary School	Fountain by Room 6	NLS565	Tuesday, August 25, 2020	0.001	Passed	0.0190	Passed	
Caldwell Road Elementary School	Girls Wash Room tap 1 by Room 6	MQE461	Thursday, May 14, 2020	0.003	Passed	0.1300	Passed	
Caldwell Road Elementary School	Girls Wash Room tap 2 by Room 6	MQE462	Thursday, May 14, 2020	0.002	Passed	0.0760	Passed	
Caldwell Road Elementary School	Girls Wash Room tap 3 by Room 6	MQE463	Thursday, May 14, 2020	0.001	Passed	0.0520	Passed	
Caldwell Road Elementary School	Learning Centre Wash Room tap by Room 7	MQE464	Thursday, May 14, 2020	0.002	Passed	0.1400	Passed	
Caldwell Road Elementary School	1st Floor Boys Wash Room tap 1	MQE465	Thursday, May 14, 2020	0.003	Passed	0.1900	Passed	
Caldwell Road Elementary School	1st Floor Boys Wash Room tap 2	MQE466	Thursday, May 14, 2020	0.001	Passed	0.0390	Passed	
Caldwell Road Elementary School	1st Floor Girls Wash Room tap 1	MQE467	Thursday, May 14, 2020	0.002	Passed	0.1500	Passed	
Caldwell Road Elementary School	1st Floor Girls Wash Room tap 2	MQE468	Thursday, May 14, 2020	0.049	Exceeded	0.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caldwell Road Elementary School	Fountain by main entrance	MQE469	Thursday, May 14, 2020	0.002	Passed	0.4800	Passed	
Caldwell Road Elementary School	2nd Floor Girls Wash Room tap	MQE470	Thursday, May 14, 2020	0.007	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caldwell Road Elementary School	2nd Floor Boys Wash Room tap	MQE471	Thursday, May 14, 2020	0.004	Passed	0.0960	Passed	
Caldwell Road Elementary School	Fountain by Room 208	MQE472	Thursday, May 14, 2020	0.002	Passed	0.2100	Passed	
Caldwell Road Elementary School	2nd Floor Janitors Closet tap by Room 208	MQE473	Thursday, May 14, 2020	0.002	Passed	0.0950	Passed	
Caldwell Road Elementary School	Music Room tap Room 122	NLS566	Tuesday, August 25, 2020	0.004	Passed	0.0170	Passed	
Caldwell Road Elementary School	1st Floor Staff Kitchen tap	MQE475	Thursday, May 14, 2020	-	Passed	0.0270	Passed	
Caldwell Road Elementary School	1st Floor Staff Wash Room 1 tap	MQE476	Thursday, May 14, 2020	-	Passed	0.0200	Passed	
Caldwell Road Elementary School	1st Floor Staff Wash Room 2 tap	MQE477	Thursday, May 14, 2020	-	Passed	0.0130	Passed	
Caledonia Junior High School	Class Room tap Room 108	MXU489	Thursday, June 18, 2020	0.026	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Boys Wash Room tap 1 by Room 108	MXU490	Thursday, June 18, 2020	0.002	Passed	0.2200	Passed	
Caledonia Junior High School	Boys Wash Room tap 2 by Room 108	MXU491	Thursday, June 18, 2020	0.012	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Boys Wash Room tap 3 by Room 108	MXU492	Thursday, June 18, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Janitors Closet tap between Wash Room's	MXU493	Thursday, June 18, 2020	0.001	Passed	0.0320	Passed	
Caledonia Junior High School	Girls Wash Room tap 1 by Room 108	MXU494	Thursday, June 18, 2020	0.092	Exceeded	0.6600	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Caledonia Junior High School	Girls Wash Room tap 2 by Room 108	MXU495	Thursday, June 18, 2020	0.005	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Girls Wash Room tap 3 by Room 108	MXU496	Thursday, June 18, 2020	0.004	Passed	0.4200	Passed	
Caledonia Junior High School	Girls Wash Room tap 4 by Room 108	MXU497	Thursday, June 18, 2020	0.003	Passed	0.3700	Passed	
Caledonia Junior High School	Girls Wash Room tap 5 by Room 108	MXU498	Thursday, June 18, 2020	0.019	Exceeded	0.6400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Class Room tap 1 Room 109	MXU506	Thursday, June 18, 2020	0.003	Passed	0.2100	Passed	
Caledonia Junior High School	Class Room tap 2 Room 109	MXU507	Thursday, June 18, 2020	0.130	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Staff Kitchen tap Room 110	NLU938	Monday, August 24, 2020	0.000	Passed	0.0520	Passed	
Caledonia Junior High School	Staff Wash Room1 tap Room 110	MXU509	Thursday, June 18, 2020	0.007	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Staff Wash Room2 tap Room 110	MXU510	Thursday, June 18, 2020	0.008	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Janitors Closet tap Room 112	MXU511	Thursday, June 18, 2020	0.001	Passed	0.0230	Passed	
Caledonia Junior High School	Class Room tap Room 104	MXU512	Thursday, June 18, 2020	0.063	Exceeded	0.6800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Gender Neutral Wash Room tap Room 115	MXU513	Thursday, June 18, 2020	0.013	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Fountain by Room 115	MXU514	Thursday, June 18, 2020	0.002	Passed	0.4900	Passed	
Caledonia Junior High School	Science Lab tap 1 Room 217	MXU515	Thursday, June 18, 2020	0.053	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 2 Room 217	MXU516	Thursday, June 18, 2020	0.068	Exceeded	0.6700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 3 Room 217	MXU517	Thursday, June 18, 2020	0.410	Exceeded	3.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 4 Room 217	MXU518	Thursday, June 18, 2020	0.270	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 5 Room 217	MXU519	Thursday, June 18, 2020	0.170	Exceeded	0.9900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 6 Room 217	MXU520	Thursday, June 18, 2020	0.004	Passed	0.0710	Passed	
Caledonia Junior High School	Science Lab tap 7 Room 217	MXU521	Thursday, June 18, 2020	1.200	Exceeded	8.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 8 Room 217	MXU522	Thursday, June 18, 2020	0.100	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 9 Room 217	MXU523	Thursday, June 18, 2020	0.074	Exceeded	0.8700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 10 Room 217	MXU524	Thursday, June 18, 2020	0.410	Exceeded	3.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 11 Room 217	MXU525	Thursday, June 18, 2020	0.270	Exceeded	0.9600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 12 Room 217	MXU526	Thursday, June 18, 2020	0.060	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 13 Room 217	MXU527	Thursday, June 18, 2020	0.230	Exceeded	0.9500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 14 Room 217	MXU528	Thursday, June 18, 2020	0.047	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Science Lab tap 15 Room 217	MXU529	Thursday, June 18, 2020	0.021	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Fountain by Science Lab	MXU530	Thursday, June 18, 2020	0.007	Exceeded	0.3200	Passed	
Caledonia Junior High School	Family Studies tap 1 Room 215	MXU531	Thursday, June 18, 2020	0.001	Passed	0.1700	Passed	
Caledonia Junior High School	Family Studies tap 2 Room 215	NMK130	Friday, August 28, 2020	0.001	Passed	0.0550	Passed	
Caledonia Junior High School	Family Studies tap 3 Room 215	NMK131	Friday, August 28, 2020	0.002	Passed	0.0440	Passed	
Caledonia Junior High School	Family Studies tap 4 Room 215	MXU534	Thursday, June 18, 2020	0.004	Passed	0.7900	Passed	
Caledonia Junior High School	Family Studies tap 5 Room 215	MXU535	Thursday, June 18, 2020	0.001	Passed	0.9300	Passed	
Caledonia Junior High School	Class Room tap 1 Room 207	MXU536	Thursday, June 18, 2020	0.007	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Class Room tap 2 Room 207	MXU537	Thursday, June 18, 2020	0.100	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Class Room tap 3 Room 207	MXU538	Thursday, June 18, 2020	0.005	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Girls Wash Room tap 1 by Room 207	MXU539	Thursday, June 18, 2020	0.012	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Girls Wash Room tap 2 by Room 207	MXU540	Thursday, June 18, 2020	0.009	Exceeded	0.1800	Passed	Faucet to be decommissioned, remediated, and retagged. Other sources available
Caledonia Junior High School	Girls Wash Room tap 3 by Room 207	MXU541	Thursday, June 18, 2020	0.005	Passed	0.1300	Passed	
Caledonia Junior High School	Janitors Closet tap between Wash Room's	MXU542	Thursday, June 18, 2020	0.023	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Boys Wash Room tap 1 by Room 207	MXU583	Thursday, June 18, 2020	0.042	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Boys Wash Room tap 2 by Room 207	MXU589	Thursday, June 18, 2020	0.014	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Boys Wash Room tap 3 by Room 207	MXU590	Thursday, June 18, 2020	0.036	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Caledonia Junior High School	Girls Wash Room tap 3 by Room 108	MYH020	Tuesday, June 23, 2020	0.006	Exceeded	0.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Caudle Park Elementary School	Fountain by Room 101	PYE704	Thursday, June 24, 2021	0.002	Passed	0.1800	Passed	Fountain replaced
Caudle Park Elementary School	1st Floor Boys Wash Room tap 1	MPX380	Wednesday, May 13, 2020	0.002	Passed	0.1100	Passed	
Caudle Park Elementary School	1st Floor Boys Wash Room tap 2	MPX381	Wednesday, May 13, 2020	0.001	Passed	0.0920	Passed	
Caudle Park Elementary School	1st Floor Janitors Closet tap	MPX382	Wednesday, May 13, 2020	-	Passed	0.0440	Passed	
Caudle Park Elementary School	1st Floor Staff Wash Room tap 1	MPX383	Wednesday, May 13, 2020	0.002	Passed	0.0300	Passed	
Caudle Park Elementary School	1st Floor Staff Wash Room tap 2	MPX384	Wednesday, May 13, 2020	0.002	Passed	0.0420	Passed	
Caudle Park Elementary School	1st Floor Girls Wash Room tap 1	MPX385	Wednesday, May 13, 2020	0.002	Passed	0.1500	Passed	
Caudle Park Elementary School	1st Floor Girls Wash Room tap 2	MPX386	Wednesday, May 13, 2020	0.001	Passed	0.1000	Passed	
Caudle Park Elementary School	1st Floor Girls Wash Room tap 3	MPX387	Wednesday, May 13, 2020	0.002	Passed	0.0990	Passed	
Caudle Park Elementary School	Main Office Wash Room tap	MPX388	Wednesday, May 13, 2020	-	Passed	0.1100	Passed	
Caudle Park Elementary School	2nd Floor Staff Room Kitchen tap	MPX389	Wednesday, May 13, 2020	0.001	Passed	0.1700	Passed	
Caudle Park Elementary School	Fountain by Room 202	PYE705	Thursday, June 24, 2021	0.003	Passed	0.0700	Passed	Fountain replaced
Caudle Park Elementary School	2nd Floor Boys Wash Room tap 1	NFZ879	Thursday, July 30, 2020	-	Passed	0.0580	Passed	
Caudle Park Elementary School	2nd Floor Boys Wash Room tap 2	MPX392	Wednesday, May 13, 2020	0.001	Passed	0.0730	Passed	
Caudle Park Elementary School	2nd Floor Boys Wash Room tap 3	MPX393	Wednesday, May 13, 2020	0.001	Passed	0.0840	Passed	
Caudle Park Elementary School	2nd Floor Boys Wash Room tap 4	MPX394	Wednesday, May 13, 2020	0.001	Passed	0.1500	Passed	
Caudle Park Elementary School	2nd Floor Janitors Closet tap	MPX395	Wednesday, May 13, 2020	-	Passed	0.0320	Passed	
Caudle Park Elementary School	2nd Floor Staff Room Wash Room tap	MPX396	Wednesday, May 13, 2020	0.001	Passed	0.2000	Passed	
Caudle Park Elementary School	2nd Floor Girls Wash Room tap 1	MPX397	Wednesday, May 13, 2020	0.003	Passed	0.1800	Passed	
Caudle Park Elementary School	2nd Floor Girls Wash Room tap 2	MPX398	Wednesday, May 13, 2020	0.001	Passed	0.0850	Passed	
Caudle Park Elementary School	2nd Floor Girls Wash Room tap 3	MPX399	Wednesday, May 13, 2020	0.001	Passed	0.0590	Passed	
Caudle Park Elementary School	2nd Floor Girls Wash Room tap 4	MPX400	Wednesday, May 13, 2020	0.001	Passed	0.0720	Passed	
Caudle Park Elementary School	Fountain by Room 303	PYE706	Thursday, June 24, 2021	0.002	Passed	0.1900	Passed	Fountain replaced
Caudle Park Elementary School	3rd Floor Boys Wash Room tap	MPX402	Wednesday, May 13, 2020	0.001	Passed	0.0950	Passed	
Caudle Park Elementary School	3rd Floor Girls Wash Room tap	MPX403	Wednesday, May 13, 2020	0.001	Passed	0.1800	Passed	
Caudle Park Elementary School	3rd Floor Janitors Closet tap	MPX404	Wednesday, May 13, 2020	-	Passed	0.0230	Passed	
Caudle Park Elementary School	Class Room tap Room 101	NFZ878	Thursday, July 30, 2020	0.001	Passed	0.0800	Passed	
Cavalier Drive School	Main Office Wash Room tap	MPQ776	Tuesday, May 12, 2020	0.003	Passed	0.0310	Passed	
Cavalier Drive School	Fountain by Room 102	MPQ777	Tuesday, May 12, 2020	0.011	Exceeded	0.0660	Passed	Fountain to be remediated
Cavalier Drive School	Wash Room by Room 102 tap 1	MPQ778	Tuesday, May 12, 2020	0.018	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Wash Room by Room 102 tap 2	MPQ779	Tuesday, May 12, 2020	0.016	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Learning Centre tap	MPQ780	Tuesday, May 12, 2020	0.004	Passed	0.0470	Passed	
Cavalier Drive School	Wash Room by Room 104 tap 1	MPQ781	Tuesday, May 12, 2020	0.010	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Wash Room by Room 104 tap 2	MPQ782	Tuesday, May 12, 2020	0.001	Passed	0.0340	Passed	
Cavalier Drive School	Class Room tap Room 108	MPQ783	Tuesday, May 12, 2020	0.004	Passed	0.0200	Passed	
Cavalier Drive School	Class Room tap Room 110	MPQ784	Tuesday, May 12, 2020	0.004	Passed	0.4400	Passed	
Cavalier Drive School	Class Room tap Room 111	MPQ785	Tuesday, May 12, 2020	0.032	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Fountain by Room 107	MPQ788	Tuesday, May 12, 2020	0.020	Exceeded	0.1400	Passed	Fountain Replacement in progress.
Cavalier Drive School	1st Floor Boys Wash Room tap 1	MPQ789	Tuesday, May 12, 2020	0.011	Exceeded	0.0980	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	1st Floor Boys Wash Room tap 2	MPQ790	Tuesday, May 12, 2020	0.006	Exceeded	0.0450	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	1st Floor Janitors Closet tap	MPQ791	Tuesday, May 12, 2020	0.001	Passed	0.0230	Passed	
Cavalier Drive School	1st Floor Girls Wash Room tap 1	MPQ792	Tuesday, May 12, 2020	0.018	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	1st Floor Girls Wash Room tap 2	MPQ793	Tuesday, May 12, 2020	0.090	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	1st Floor Girls Wash Room tap 3	MPQ794	Tuesday, May 12, 2020	0.089	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Staff Room Wash Room tap 1	MPQ795	Tuesday, May 12, 2020	0.014	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Cavalier Drive School	Staff Room Wash Room tap 2	MPQ796	Tuesday, May 12, 2020	0.002	Passed	0.0190	Passed	
Cavalier Drive School	Staff Room Kitchen tap	MPQ797	Tuesday, May 12, 2020	0.001	Passed	0.0410	Passed	
Cavalier Drive School	Gym Boys Wash Room tap	MPQ798	Tuesday, May 12, 2020	0.006	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Gym Girls Wash Room tap	MPQ799	Tuesday, May 12, 2020	0.009	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Fountain by Room 165	MPQ800	Tuesday, May 12, 2020	0.005	Passed	0.2300	Passed	
Cavalier Drive School	Kitchen tap by Room 167	MPQ801	Tuesday, May 12, 2020	0.007	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Class Room tap Room 156	MPQ802	Tuesday, May 12, 2020	0.180	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Class Room tap 1 Room 152	MPQ803	Tuesday, May 12, 2020	0.001	Passed	0.0170	Passed	
Cavalier Drive School	Class Room tap 2 Room 152	MPQ804	Tuesday, May 12, 2020	0.045	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Fountain by Room 209	MPQ805	Tuesday, May 12, 2020	0.003	Passed	0.1800	Passed	
Cavalier Drive School	2nd Floor Girls Wash Room tap 1	MPQ806	Tuesday, May 12, 2020	0.170	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	2nd Floor Girls Wash Room tap 2	MPQ807	Tuesday, May 12, 2020	0.055	Exceeded	0.0830	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	2nd Floor Girls Wash Room tap 3	MPQ810	Tuesday, May 12, 2020	0.110	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	2nd Floor Boys Wash Room tap 1	MPQ811	Tuesday, May 12, 2020	0.023	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	2nd Floor Boys Wash Room tap 2	MPQ812	Tuesday, May 12, 2020	0.011	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	2nd Floor Boys Wash Room tap 3	MPQ813	Tuesday, May 12, 2020	0.027	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	2nd Floor Janitors Closet tap	MPQ814	Tuesday, May 12, 2020	-	Passed	0.0058	Passed	
Cavalier Drive School	Class Room tap Room 205	MPQ815	Tuesday, May 12, 2020	0.003	Passed	0.0210	Passed	
Cavalier Drive School	Class Room tap Room 203	MPQ816	Tuesday, May 12, 2020	0.300	Exceeded	0.0340	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Class Room tap Room 201	MPQ817	Tuesday, May 12, 2020	0.003	Passed	0.2300	Passed	
Cavalier Drive School	Class Room tap Room 202	MPQ818	Tuesday, May 12, 2020	0.010	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Class Room tap Room 204	MPQ819	Tuesday, May 12, 2020	0.001	Passed	0.0210	Passed	
Cavalier Drive School	Class Room Wash Room tap Room 204	MPQ822	Tuesday, May 12, 2020	0.010	Exceeded	0.0760	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cavalier Drive School	Fountain by Room 204	MPQ823	Tuesday, May 12, 2020	0.026	Exceeded	0.1700	Passed	Fountain Replacement in progress.
Cavalier Drive School	Class Room tap Room 206	MPQ824	Tuesday, May 12, 2020	0.003	Passed	0.0150	Passed	
Cavalier Drive School	Class Room Wash Room tap Room 206	MPQ825	Tuesday, May 12, 2020	0.003	Passed	0.0680	Passed	
Central Spryfield Elementary School	Kitchen tap Room 104	NKX271	Friday, August 21, 2020	0.000	Passed	0.0060	Passed	
Central Spryfield Elementary School	Fountain by Room 104	MRC993	Wednesday, May 20, 2020	0.001	Passed	0.1300	Passed	
Central Spryfield Elementary School	Boys Wash Room tap 1 by Room 104	MRC994	Wednesday, May 20, 2020	0.021	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Boys Wash Room tap 2 by Room 104	MRC995	Wednesday, May 20, 2020	0.026	Exceeded	0.0470	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Boys Wash Room tap 3 by Room 104	MRC996	Wednesday, May 20, 2020	0.008	Exceeded	0.0480	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Girls Wash Room tap 1 by Room 104	MRC997	Wednesday, May 20, 2020	0.180	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Girls Wash Room tap 2 by Room 104	MRC998	Wednesday, May 20, 2020	0.016	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Girls Wash Room tap 3 by Room 104	MRC999	Wednesday, May 20, 2020	0.007	Exceeded	0.0650	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Janitors Closet tap Room 113	NKV272	Friday, August 21, 2020	0.000	Passed	0.0080	Passed	
Central Spryfield Elementary School	Kitchen tap 1 Room 116	NKX275	Friday, August 21, 2020	0.000	Passed	0.0100	Passed	
Central Spryfield Elementary School	Kitchen tap 2 Room 116	MRD002	Wednesday, May 20, 2020	0.003	Passed	0.3700	Passed	
Central Spryfield Elementary School	Staff Room Kitchen tap Room 112	NKX273	Friday, August 21, 2020	0.000	Passed	0.0060	Passed	
Central Spryfield Elementary School	Staff Wash Room tap 1 Room 112	MRD004	Wednesday, May 20, 2020	0.007	Exceeded	0.0430	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Staff Wash Room tap 2 Room 112	MRD005	Wednesday, May 20, 2020	0.008	Exceeded	0.0440	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Learning Centre tap Room 103	MRD006	Wednesday, May 20, 2020	0.001	Passed	0.0440	Passed	
Central Spryfield Elementary School	Learning Centre Wash Room tap Room 103	MRD007	Wednesday, May 20, 2020	0.010	Exceeded	0.0360	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Class Room tap Room 100C	MRD008	Wednesday, May 20, 2020	-	Passed	0.0600	Passed	
Central Spryfield Elementary School	Girls Wash Room tap 1 by Room 100C	MRD009	Wednesday, May 20, 2020	-	Passed	0.1000	Passed	
Central Spryfield Elementary School	Girls Wash Room tap 2 by Room 100C	MRD010	Wednesday, May 20, 2020	0.001	Passed	0.0990	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Central Spryfield Elementary School	Girls Wash Room tap 3 by Room 100C	MRD011	Wednesday, May 20, 2020	0.001	Passed	0.0600	Passed	
Central Spryfield Elementary School	Boys Wash Room tap 1 by caretaker Office	MRD012	Wednesday, May 20, 2020	0.002	Passed	0.0960	Passed	
Central Spryfield Elementary School	Boys Wash Room tap 2 by caretaker Office	MRD013	Wednesday, May 20, 2020	0.006	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Janitors Closet tap by caretaker Room	MRD014	Wednesday, May 20, 2020	0.001	Passed	0.0670	Passed	
Central Spryfield Elementary School	Fountain by Room 100B	MRD015	Wednesday, May 20, 2020	0.002	Passed	0.1300	Passed	
Central Spryfield Elementary School	Class Room tap Room 100B	MRD016	Wednesday, May 20, 2020	0.002	Passed	0.1700	Passed	
Central Spryfield Elementary School	Boys Wash Room tap 1 Room 214	MRD017	Wednesday, May 20, 2020	0.002	Passed	0.0440	Passed	
Central Spryfield Elementary School	Boys Wash Room tap 2 Room 214	MRD018	Wednesday, May 20, 2020	0.009	Exceeded	0.0430	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Boys Wash Room tap 3 Room 214	MRD019	Wednesday, May 20, 2020	0.008	Exceeded	0.0570	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Janitors Closet tap Room 212	MRD020	Wednesday, May 20, 2020	0.002	Passed	0.0520	Passed	
Central Spryfield Elementary School	Fountain by Room 212	MRD021	Wednesday, May 20, 2020	0.001	Passed	0.3600	Passed	
Central Spryfield Elementary School	Girls Wash Room tap 1 Room 215	MRD022	Wednesday, May 20, 2020	0.001	Passed	0.0410	Passed	
Central Spryfield Elementary School	Girls Wash Room tap 2 Room 215	MRD023	Wednesday, May 20, 2020	0.005	Exceeded	0.0380	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Girls Wash Room tap 3 Room 215	MRD024	Wednesday, May 20, 2020	0.001	Passed	0.0370	Passed	
Central Spryfield Elementary School	Guidance Kitchen tap Room 217	NKX274	Friday, August 21, 2020	0.001	Passed	0.0110	Passed	
Central Spryfield Elementary School	Guidance Wash Room tap Room 217	MRD026	Wednesday, May 20, 2020	0.007	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Central Spryfield Elementary School	Fountain by Room 200B	MRD027	Wednesday, May 20, 2020	0.004	Passed	0.1300	Passed	
Central Spryfield Elementary School	Class Room tap Room 200B	MRD028	Wednesday, May 20, 2020	0.003	Passed	0.0610	Passed	
Charles P. Allen High School	2008A-T1	MNX510	Friday, May 1, 2020	-	Passed	0.2800	Passed	
Charles P. Allen High School	FOUNTAIN BY 2008A	MNX511	Friday, May 1, 2020	-	Passed	0.5100	Passed	
Charles P. Allen High School	2029-T1	MNX512	Friday, May 1, 2020	-	Passed	0.5600	Passed	
Charles P. Allen High School	2029-T2	MNX513	Friday, May 1, 2020	-	Passed	0.4700	Passed	
Charles P. Allen High School	2029-T3	MNX514	Friday, May 1, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	2030-T1	MNX515	Friday, May 1, 2020	-	Passed	0.7500	Passed	
Charles P. Allen High School	2030-T2	MNX516	Friday, May 1, 2020	-	Passed	0.7000	Passed	
Charles P. Allen High School	2030-T3	MNX517	Friday, May 1, 2020	-	Passed	0.6800	Passed	
Charles P. Allen High School	FOUNTAIN BY 2028	MNX518	Friday, May 1, 2020	-	Passed	0.4800	Passed	
Charles P. Allen High School	2032	MNX519	Friday, May 1, 2020	-	Passed	0.3800	Passed	
Charles P. Allen High School	2031	MNX524	Friday, May 1, 2020	-	Passed	0.0790	Passed	
Charles P. Allen High School	2028	MNX525	Friday, May 1, 2020	-	Passed	0.6600	Passed	
Charles P. Allen High School	2044	MNX526	Friday, May 1, 2020	-	Passed	0.3600	Passed	
Charles P. Allen High School	2044B-T1	MNX527	Friday, May 1, 2020	-	Passed	0.2700	Passed	
Charles P. Allen High School	2044B-T2	MNX528	Friday, May 1, 2020	-	Passed	0.3100	Passed	
Charles P. Allen High School	2045-T1	MNX529	Friday, May 1, 2020	-	Passed	0.7400	Passed	
Charles P. Allen High School	2045-T2	MNX530	Friday, May 1, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	2045-T3	MNX531	Friday, May 1, 2020	-	Passed	0.7900	Passed	
Charles P. Allen High School	2046-T1	MNX532	Friday, May 1, 2020	-	Passed	0.9900	Passed	
Charles P. Allen High School	2046-T2	MNX533	Friday, May 1, 2020	-	Passed	0.6900	Passed	
Charles P. Allen High School	2046-T3	MNX541	Friday, May 1, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	2047	MNX542	Friday, May 1, 2020	-	Passed	0.3700	Passed	
Charles P. Allen High School	2048	MNX543	Friday, May 1, 2020	0.004	Passed	0.4400	Passed	
Charles P. Allen High School	FOUNTAIN BY 2049	MNX544	Friday, May 1, 2020	-	Passed	0.3000	Passed	
Charles P. Allen High School	Locker Room tap 1 Room 2068	MOE400	Monday, May 4, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Locker Room tap 2 Room 2068	MOE401	Monday, May 4, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Locker Room tap 1 Room 2067	MOE402	Monday, May 4, 2020	0.001	Passed	0.8400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Charles P. Allen High School	Locker Room tap 2 Room 2067	MOE403	Monday, May 4, 2020	-	Passed	0.8200	Passed	
Charles P. Allen High School	Locker Room tap 1 Room 2066	MOE404	Monday, May 4, 2020	0.003	Passed	0.8200	Passed	
Charles P. Allen High School	Locker Room tap 2 Room 2066	MOE405	Monday, May 4, 2020	0.001	Passed	0.4900	Passed	
Charles P. Allen High School	Locker Room tap 1 Room 2065	MOE406	Monday, May 4, 2020	-	Passed	0.5900	Passed	
Charles P. Allen High School	Locker Room tap 2 Room 2065	MOE407	Monday, May 4, 2020	-	Passed	0.5400	Passed	
Charles P. Allen High School	Fountain by Locker Room 2067	MPC109	Friday, May 8, 2020	-	Passed	0.3800	Passed	
Charles P. Allen High School	Fountain by Locker Room 2065	MPC110	Friday, May 8, 2020	-	Passed	0.4700	Passed	
Charles P. Allen High School	Learning studio tap Room 1002	MPM943	Monday, May 11, 2020	-	Passed	0.9300	Passed	
Charles P. Allen High School	Fountain by Room 1003	MPM944	Monday, May 11, 2020	-	Passed	0.5000	Passed	
Charles P. Allen High School	Wash Room tap Room 1005	MPM945	Monday, May 11, 2020	-	Passed	0.4600	Passed	
Charles P. Allen High School	Class Room tap Room 1004	MPM946	Monday, May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Fountain by Room 1015	MPM947	Monday, May 11, 2020	-	Passed	0.4300	Passed	
Charles P. Allen High School	Class Room tap Room 1015	MPM948	Monday, May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Class Room tap Room 1016	MPM949	Monday, May 11, 2020	-	Passed	0.8100	Passed	
Charles P. Allen High School	Class Room tap 1 Room 1024	MPM950	Monday, May 11, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room tap 2 Room 1024	MPM951	Monday, May 11, 2020	-	Passed	0.9400	Passed	
Charles P. Allen High School	Class Room tap 1 Room 1027	MPM952	Monday, May 11, 2020	-	Passed	0.0720	Passed	
Charles P. Allen High School	Class Room tap 2 Room 1027	MPM953	Monday, May 11, 2020	-	Passed	0.7400	Passed	
Charles P. Allen High School	Class Room tap Room 1026	MPM954	Monday, May 11, 2020	-	Passed	0.8300	Passed	
Charles P. Allen High School	Boys Wash Room tap 1 Room 1028	MPM955	Monday, May 11, 2020	-	Passed	0.8500	Passed	
Charles P. Allen High School	Boys Wash Room tap 2 Room 1028	MPM956	Monday, May 11, 2020	-	Passed	0.8400	Passed	
Charles P. Allen High School	Boys Wash Room tap 3 Room 1028	MPM957	Monday, May 11, 2020	-	Passed	0.8000	Passed	
Charles P. Allen High School	Janitors Closet tap Room 1031	MPM958	Monday, May 11, 2020	-	Passed	0.5400	Passed	
Charles P. Allen High School	Staff Wash Room tap Room 1030	MPM959	Monday, May 11, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Girls Wash Room tap 1 Room 1029	MPM960	Monday, May 11, 2020	-	Passed	0.5400	Passed	
Charles P. Allen High School	Girls Wash Room tap 2 Room 1029	MPM961	Monday, May 11, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	Girls Wash Room tap 3 Room 1029	MPM962	Monday, May 11, 2020	-	Passed	0.6000	Passed	
Charles P. Allen High School	Caretaker Room tap Room 1066	MPM964	Monday, May 11, 2020	-	Passed	0.4100	Passed	
Charles P. Allen High School	Janitors Closet tap Room 1065	MPM965	Monday, May 11, 2020	0.001	Passed	0.1300	Passed	
Charles P. Allen High School	Girls Wash Room tap 1 Room 1055	MPM966	Monday, May 11, 2020	0.002	Passed	0.4400	Passed	
Charles P. Allen High School	Girls Wash Room tap 2 Room 1055	MPM967	Monday, May 11, 2020	0.002	Passed	0.5500	Passed	
Charles P. Allen High School	Girls Wash Room tap 3 Room 1055	MPM968	Monday, May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Staff Wash Room tap Room 1056	MPM969	Monday, May 11, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Janitors Closet tap Room 1057	MPM970	Monday, May 11, 2020	0.001	Passed	0.3200	Passed	
Charles P. Allen High School	Boys Wash Room tap 1 Room 1054	MPM971	Monday, May 11, 2020	-	Passed	0.7200	Passed	
Charles P. Allen High School	Boys Wash Room tap 2 Room 1054	MPM972	Monday, May 11, 2020	-	Passed	0.6900	Passed	
Charles P. Allen High School	Boys Wash Room tap 3 Room 1054	MPM973	Monday, May 11, 2020	-	Passed	0.7700	Passed	
Charles P. Allen High School	Fountain by Room 1054	MPM974	Monday, May 11, 2020	-	Passed	0.4700	Passed	
Charles P. Allen High School	Staff Wash Room 1048	MPM975	Monday, May 11, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room tap Room 3004	MSA126	Monday, May 25, 2020	-	Passed	0.2100	Passed	
Charles P. Allen High School	Fountain by Room 3006	MSA127	Monday, May 25, 2020	-	Passed	0.6100	Passed	
Charles P. Allen High School	Class Room tap Room 3028	MSA128	Monday, May 25, 2020	-	Passed	0.8100	Passed	
Charles P. Allen High School	Fountain by Room 3028	MSA129	Monday, May 25, 2020	-	Passed	0.6300	Passed	
Charles P. Allen High School	Boys Wash Room tap 1 Room 3029	MSA130	Monday, May 25, 2020	-	Passed	0.4900	Passed	
Charles P. Allen High School	Boys Wash Room tap 2 Room 3029	MSA131	Monday, May 25, 2020	-	Passed	0.5200	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Charles P. Allen High School	Boys Wash Room tap 3 Room 3029	MSA132	Monday, May 25, 2020	-	Passed	0.5500	Passed	
Charles P. Allen High School	Janitors Closet tap Room 3032	MSA133	Monday, May 25, 2020	0.001	Passed	0.3800	Passed	
Charles P. Allen High School	Staff Wash Room tap Room 3031	MSA134	Monday, May 25, 2020	-	Passed	0.2600	Passed	
Charles P. Allen High School	Girls Wash Room tap 1 Room 3030	MSA135	Monday, May 25, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	Girls Wash Room tap 2 Room 3030	MSA136	Monday, May 25, 2020	-	Passed	0.5600	Passed	
Charles P. Allen High School	Girls Wash Room tap 3 Room 3030	MSA137	Monday, May 25, 2020	-	Passed	0.6500	Passed	
Charles P. Allen High School	Gender Neutral Wash Room tap Room 3059	MSA138	Monday, May 25, 2020	-	Passed	0.3800	Passed	
Charles P. Allen High School	Class Room tap 1 Room 3060	MSA139	Monday, May 25, 2020	-	Passed	0.8900	Passed	
Charles P. Allen High School	Class Room tap 2 Room 3060	MSA140	Monday, May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room tap 3 Room 3060	MSA141	Monday, May 25, 2020	-	Passed	0.5900	Passed	
Charles P. Allen High School	Mech. Room tap Room ST.9.1	MSA142	Monday, May 25, 2020	-	Passed	0.1100	Passed	
Charles P. Allen High School	Class Room tap Room 3061	MSA143	Monday, May 25, 2020	-	Passed	0.1500	Passed	
Charles P. Allen High School	Science Lab tap 1 Room 3062	MSA144	Monday, May 25, 2020	-	Passed	0.1700	Passed	
Charles P. Allen High School	Science Lab tap 2 Room 3062	MSA145	Monday, May 25, 2020	-	Passed	0.0970	Passed	
Charles P. Allen High School	Science Lab tap 3 Room 3062	MSA146	Monday, May 25, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Change Room tap Room 3052A	MSA147	Monday, May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room tap 1 Room 3051	MSA148	Monday, May 25, 2020	-	Passed	0.2200	Passed	
Charles P. Allen High School	Class Room tap 2 Room 3051	MSA149	Monday, May 25, 2020	-	Passed	0.9300	Passed	
Charles P. Allen High School	Class Room tap 3 Room 3051	MSA150	Monday, May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Class Room tap 4 Room 3051	MSA151	Monday, May 25, 2020	-	Passed	0.1100	Passed	
Charles P. Allen High School	Class Room tap 5 Room 3051	MSA152	Monday, May 25, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Class Room tap Room 3050	MSA153	Monday, May 25, 2020	-	Passed	0.1100	Passed	
Charles P. Allen High School	Class Room tap 1 Room 3049	MSA154	Monday, May 25, 2020	-	Passed	0.3600	Passed	
Charles P. Allen High School	Class Room tap 2 Room 3049	MSA155	Monday, May 25, 2020	-	Passed	0.1600	Passed	
Charles P. Allen High School	Fountain before Room 3046	MSA156	Monday, May 25, 2020	-	Passed	0.5000	Passed	
Charles P. Allen High School	Girls Wash Room tap 1 Room 3046	MSA157	Monday, May 25, 2020	-	Passed	0.7100	Passed	
Charles P. Allen High School	Girls Wash Room tap 2 Room 3046	MSA158	Monday, May 25, 2020	-	Passed	0.6200	Passed	
Charles P. Allen High School	Girls Wash Room tap 3 Room 3046	MSA159	Monday, May 25, 2020	-	Passed	0.6200	Passed	
Charles P. Allen High School	Staff Wash Room tap Room 3047	MSA160	Monday, May 25, 2020	-	Passed	0.6800	Passed	
Charles P. Allen High School	Chem Lab tap 1 Room 3044	MSA161	Monday, May 25, 2020	0.003	Passed	0.7500	Passed	
Charles P. Allen High School	Chem Lab tap 2 Room 3044	MSA162	Monday, May 25, 2020	-	Passed	0.5000	Passed	
Charles P. Allen High School	Chem Lab tap 3 Room 3044	MSA163	Monday, May 25, 2020	-	Passed	0.6400	Passed	
Charles P. Allen High School	Chem Lab tap 4 Room 3044	MSA164	Monday, May 25, 2020	-	Passed	0.6100	Passed	
Charles P. Allen High School	Multipurpose Lab tap 1 Room 3041	MSA165	Monday, May 25, 2020	-	Passed	0.8300	Passed	
Charles P. Allen High School	Multipurpose Lab tap 2 Room 3041	MSA166	Monday, May 25, 2020	-	Passed	0.8100	Passed	
Charles P. Allen High School	Multipurpose Lab tap 3 Room 3041	MSA167	Monday, May 25, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Multipurpose Lab tap 4 Room 3041	MSA168	Monday, May 25, 2020	-	Passed	0.3700	Passed	
Charles P. Allen High School	Multipurpose Lab tap 5 Room 3041	MSA169	Monday, May 25, 2020	-	Passed	1.2000	Passed	
Charles P. Allen High School	Multipurpose Lab tap 6 Room 3041	MSA170	Monday, May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Boys Wash Room tap 1 Room 3045	MSA171	Monday, May 25, 2020	-	Passed	0.9300	Passed	
Charles P. Allen High School	Boys Wash Room tap 2 Room 3045	MSA172	Monday, May 25, 2020	-	Passed	0.8300	Passed	
Charles P. Allen High School	Boys Wash Room tap 3 Room 3045	MSA173	Monday, May 25, 2020	-	Passed	1.0000	Passed	
Charles P. Allen High School	Chem Lab tap 1 Room 3044	MSA174	Monday, May 25, 2020	-	Passed	1.1000	Passed	
Charles P. Allen High School	Chem Lab tap 2 Room 3044	MSA175	Monday, May 25, 2020	-	Passed	0.7400	Passed	
Charles P. Allen High School	Chem Lab tap 3 Room 3044	MSA176	Monday, May 25, 2020	-	Passed	0.6100	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Charles P. Allen High School	Chem Lab tap 4 Room 3044	MSA177	Monday, May 25, 2020	-	Passed	0.8000	Passed	
Charles P. Allen High School	Chem Lab tap 5 Room 3044	MSA178	Monday, May 25, 2020	-	Passed	0.7900	Passed	
Charles P. Allen High School	Chem Lab tap 6 Room 3044	MSA179	Monday, May 25, 2020	-	Passed	0.6800	Passed	
Charles P. Allen High School	Chem Lab tap 7 Room 3044	MSA180	Monday, May 25, 2020	-	Passed	0.9900	Passed	
Charles P. Allen High School	Janitors Closet tap Room 3048	MSA181	Monday, May 25, 2020	-	Passed	0.2600	Passed	
Charles P. Allen High School	Multipurpose Lab tap 7 Room 3041	MSA182	Monday, May 25, 2020	-	Passed	0.1600	Passed	
Charles P. Allen High School	Multipurpose Lab tap 8 Room 3041	MSA183	Monday, May 25, 2020	-	Passed	0.2800	Passed	
Charles P. Allen High School	Cafeteria tap 1	MYH021	Tuesday, June 23, 2020	-	Passed	0.0380	Passed	
Charles P. Allen High School	Cafeteria tap 2	MYH022	Tuesday, June 23, 2020	-	Passed	0.0440	Passed	
Charles P. Allen High School	Music Room 1069 tap	NES631	Friday, July 24, 2020	-	Passed	0.0620	Passed	
Chebucto Heights Elementary School	Class Room tap 1 Room 212	NKX388	Friday, August 21, 2020	0.000	Passed	0.0100	Passed	
Chebucto Heights Elementary School	Class Room tap Room 212A	MQS752	Tuesday, May 19, 2020	0.058	Exceeded	1.9000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Chebucto Heights Elementary School	2nd Floor Girls Wash Room tap 1	MQS753	Tuesday, May 19, 2020	0.002	Passed	0.0910	Passed	
Chebucto Heights Elementary School	2nd Floor Girls Wash Room tap 2	MQS754	Tuesday, May 19, 2020	0.004	Passed	0.0700	Passed	
Chebucto Heights Elementary School	2nd Floor Girls Wash Room tap 3	MQS755	Tuesday, May 19, 2020	0.002	Passed	0.1500	Passed	
Chebucto Heights Elementary School	2nd Floor Girls Wash Room tap 4	MQS756	Tuesday, May 19, 2020	0.008	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Chebucto Heights Elementary School	2nd Floor Boys Wash Room tap 1	MQS757	Tuesday, May 19, 2020	0.003	Passed	0.0670	Passed	
Chebucto Heights Elementary School	2nd Floor Boys Wash Room tap 2	MQS758	Tuesday, May 19, 2020	0.003	Passed	0.0620	Passed	
Chebucto Heights Elementary School	2nd Floor Boys Wash Room tap 3	MQS759	Tuesday, May 19, 2020	0.001	Passed	0.0720	Passed	
Chebucto Heights Elementary School	2nd Floor Boys Wash Room tap 4	MQS760	Tuesday, May 19, 2020	0.002	Passed	0.0730	Passed	
Chebucto Heights Elementary School	Class Room tap Room 203	MQS761	Tuesday, May 19, 2020	0.003	Passed	0.0220	Passed	
Chebucto Heights Elementary School	Janitors Closet tap by Room 202	MQS762	Tuesday, May 19, 2020	0.001	Passed	0.0069	Passed	
Chebucto Heights Elementary School	Class Room tap Room 202	MQS763	Tuesday, May 19, 2020	0.002	Passed	0.0150	Passed	
Chebucto Heights Elementary School	Fountain between Room 220 and 217	MQS764	Tuesday, May 19, 2020	0.003	Passed	0.1300	Passed	
Chebucto Heights Elementary School	Class Room tap 1 Room 216	NKX389	Friday, August 21, 2020	0.004	Passed	0.0100	Passed	
Chebucto Heights Elementary School	Class Room tap 2 Room 216	MQS766	Tuesday, May 19, 2020	0.002	Passed	0.0900	Passed	
Chebucto Heights Elementary School	Class Room tap Room 213	MQS767	Tuesday, May 19, 2020	0.003	Passed	0.0780	Passed	
Chebucto Heights Elementary School	Boys Locker Room tap Room 152	MQS768	Tuesday, May 19, 2020	0.002	Passed	0.1200	Passed	
Chebucto Heights Elementary School	Janitors Closet tap Room 157	MQS769	Tuesday, May 19, 2020	0.002	Passed	0.1800	Passed	
Chebucto Heights Elementary School	Gym Office Wash Room tap	MQS770	Tuesday, May 19, 2020	0.049	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Chebucto Heights Elementary School	Girls Locker Room tap Room 147	MQS771	Tuesday, May 19, 2020	0.002	Passed	0.0960	Passed	
Chebucto Heights Elementary School	Fountain by Gym	MQS772	Tuesday, May 19, 2020	-	Passed	0.1500	Passed	
Chebucto Heights Elementary School	Janitors Closet tap by Gym	MQS773	Tuesday, May 19, 2020	0.001	Passed	0.1600	Passed	
Chebucto Heights Elementary School	Gym Kitchen tap	MQS774	Tuesday, May 19, 2020	0.016	Exceeded	0.7900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Chebucto Heights Elementary School	Girls Wash Room tap 1 Room 114	MQS775	Tuesday, May 19, 2020	-	Passed	0.0130	Passed	
Chebucto Heights Elementary School	Girls Wash Room tap 2 Room 114	MQS776	Tuesday, May 19, 2020	0.001	Passed	0.0180	Passed	
Chebucto Heights Elementary School	Girls Wash Room tap 3 Room 114	MQS777	Tuesday, May 19, 2020	0.002	Passed	0.0430	Passed	
Chebucto Heights Elementary School	Boys Wash Room tap 1 Room 115	MQS778	Tuesday, May 19, 2020	0.001	Passed	0.0028	Passed	
Chebucto Heights Elementary School	Boys Wash Room tap 2 Room 115	MQS779	Tuesday, May 19, 2020	-	Passed	0.0018	Passed	
Chebucto Heights Elementary School	Boys Wash Room tap 3 Room 115	MQS780	Tuesday, May 19, 2020	-	Passed	0.0025	Passed	
Chebucto Heights Elementary School	Boys Wash Room tap 4 Room 115	MQS781	Tuesday, May 19, 2020	0.001	Passed	0.0078	Passed	
Chebucto Heights Elementary School	Class Room tap Room 120	MQS782	Tuesday, May 19, 2020	0.002	Passed	0.0330	Passed	
Chebucto Heights Elementary School	Gender Neutral Wash Room tap Room 120	MQS783	Tuesday, May 19, 2020	0.006	Exceeded	0.0110	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Chebucto Heights Elementary School	Janitors Closet tap Room 121	MQS784	Tuesday, May 19, 2020	-	Passed	0.0057	Passed	
Chebucto Heights Elementary School	Class Room tap Room 124	NKX390	Friday, August 21, 2020	0.001	Passed	0.0040	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Chebucto Heights Elementary School	Class Room Wash Room tap Room 124	MQS786	Tuesday, May 19, 2020	0.001	Passed	0.0220	Passed	
Chebucto Heights Elementary School	Fountain by Room 132	MQS787	Tuesday, May 19, 2020	0.001	Passed	0.0340	Passed	
Chebucto Heights Elementary School	Staff Wash Room tap 1 Room 112	MQS788	Tuesday, May 19, 2020	0.001	Passed	0.0260	Passed	
Chebucto Heights Elementary School	Staff Wash Room tap 2 Room 112	MQS789	Tuesday, May 19, 2020	0.001	Passed	0.0240	Passed	
Chebucto Heights Elementary School	Staff Room Kitchen tap	MQS790	Tuesday, May 19, 2020	0.001	Passed	0.0240	Passed	
Chebucto Heights Elementary School	Break Room tap	MQS791	Tuesday, May 19, 2020	0.002	Passed	0.2700	Passed	
Chebucto Heights Elementary School	Health Room Wash Room tap Room 109	MQS792	Tuesday, May 19, 2020	0.002	Passed	0.1400	Passed	
Citadel High School	Bio Lab tap 1 Room 209	MTU825	Monday, June 1, 2020	-	Passed	0.0400	Passed	
Citadel High School	Bio Lab tap 2 Room 209	MTU826	Monday, June 1, 2020	-	Passed	0.0600	Passed	
Citadel High School	Bio Lab tap 3 Room 209	MTU827	Monday, June 1, 2020	-	Passed	0.0480	Passed	
Citadel High School	Bio Lab tap 4 Room 209	MTU828	Monday, June 1, 2020	-	Passed	0.0330	Passed	
Citadel High School	Bio Lab tap 5 Room 209	MTU829	Monday, June 1, 2020	-	Passed	0.0300	Passed	
Citadel High School	Science Lab tap 1 Room 210	MTU830	Monday, June 1, 2020	0.006	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Citadel High School	Science Lab tap 2 Room 210	MTU831	Monday, June 1, 2020	0.003	Passed	0.2400	Passed	
Citadel High School	Science Lab tap 3 Room 210	MTU832	Monday, June 1, 2020	0.002	Passed	0.1500	Passed	
Citadel High School	Science Lab tap 4 Room 210	MTU833	Monday, June 1, 2020	-	Passed	0.0320	Passed	
Citadel High School	Science Lab tap 5 Room 210	MTU834	Monday, June 1, 2020	-	Passed	0.0170	Passed	
Citadel High School	Physics Lab tap 1 Room 212	MTU839	Monday, June 1, 2020	0.002	Passed	0.2300	Passed	
Citadel High School	Physics Lab tap 2 Room 212	MTU840	Monday, June 1, 2020	0.002	Passed	0.1800	Passed	
Citadel High School	Physics Lab tap 3 Room 212	MTU841	Monday, June 1, 2020	0.002	Passed	0.1500	Passed	
Citadel High School	Physics Lab tap 4 Room 212	MTU842	Monday, June 1, 2020	-	Passed	0.0220	Passed	
Citadel High School	Physics Lab tap 5 Room 212	MTU843	Monday, June 1, 2020	-	Passed	0.0170	Passed	
Citadel High School	Physics Lab tap 1 Room 213	MTU844	Monday, June 1, 2020	0.001	Passed	0.0620	Passed	
Citadel High School	Physics Lab tap 2 Room 213	MTU845	Monday, June 1, 2020	-	Passed	0.0270	Passed	
Citadel High School	Physics Lab tap 3 Room 213	MTU846	Monday, June 1, 2020	-	Passed	0.0350	Passed	
Citadel High School	Physics Lab tap 4 Room 213	MTU847	Monday, June 1, 2020	0.001	Passed	0.0840	Passed	
Citadel High School	Physics Lab tap 5 Room 213	MTU848	Monday, June 1, 2020	-	Passed	0.0310	Passed	
Citadel High School	Boys Room tap 1	MTU855	Monday, June 1, 2020	0.001	Passed	0.0980	Passed	
Citadel High School	Boys Room tap 2	MTU856	Monday, June 1, 2020	0.001	Passed	0.0550	Passed	
Citadel High School	Boys Room tap 3	MTU857	Monday, June 1, 2020	0.001	Passed	0.0700	Passed	
Citadel High School	Boys Room tap 4	MTU858	Monday, June 1, 2020	-	Passed	0.0490	Passed	
Citadel High School	Boys Room tap 5	MTU859	Monday, June 1, 2020	0.001	Passed	0.0400	Passed	
Citadel High School	Staff Room tap 1	MTU860	Monday, June 1, 2020	0.001	Passed	0.0790	Passed	
Citadel High School	Staff Room tap 2	MTU861	Monday, June 1, 2020	-	Passed	0.0460	Passed	
Citadel High School	Girls Room tap 1	MTU862	Monday, June 1, 2020	-	Passed	0.0440	Passed	
Citadel High School	Girls Room tap 2	MTU863	Monday, June 1, 2020	0.001	Passed	0.0710	Passed	
Citadel High School	Girls Room tap 3	MTU864	Monday, June 1, 2020	0.001	Passed	0.1100	Passed	
Citadel High School	Girls Room tap 4	MTU868	Monday, June 1, 2020	0.001	Passed	0.0940	Passed	
Citadel High School	Girls Room tap 5	MTU869	Monday, June 1, 2020	0.001	Passed	0.0590	Passed	
Citadel High School	Class Room Wash Room tap Room 220	MTU870	Monday, June 1, 2020	-	Passed	0.0180	Passed	
Citadel High School	Library sink tap	MTU872	Monday, June 1, 2020	-	Passed	0.0930	Passed	
Citadel High School	Class Room tap by Room 221	MTU873	Monday, June 1, 2020	-	Passed	0.0910	Passed	
Citadel High School	Janitors Closet tap by Room 221	MTU874	Monday, June 1, 2020	-	Passed	0.0200	Passed	
Citadel High School	2nd Floor Fountain by elevator	MTU875	Monday, June 1, 2020	-	Passed	0.1400	Passed	
Citadel High School	1st Floor Fountain by elevator	MTU876	Monday, June 1, 2020	-	Passed	0.1600	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Citadel High School	Cafeteria/Kitchen tap 1	MTU877	Monday, June 1, 2020	0.001	Passed	0.1200	Passed	
Citadel High School	Cafeteria/Kitchen tap 2	MTU881	Monday, June 1, 2020	-	Passed	0.2000	Passed	
Citadel High School	Cafeteria/Kitchen tap 3	MTU882	Monday, June 1, 2020	-	Passed	0.0700	Passed	
Citadel High School	Cafeteria/Kitchen tap 4	MTU883	Monday, June 1, 2020	-	Passed	0.0530	Passed	
Citadel High School	Cafeteria/Kitchen tap 5	MTU884	Monday, June 1, 2020	-	Passed	0.0490	Passed	
Citadel High School	Fountain by Room 103	MTU885	Monday, June 1, 2020	-	Passed	0.1400	Passed	
Citadel High School	Fountain by Room 106	MTU886	Monday, June 1, 2020	-	Passed	0.2000	Passed	
Citadel High School	Boiler Room tap	MTU887	Monday, June 1, 2020	-	Passed	0.2400	Passed	
Citadel High School	1st Floor Boys Wash Room tap 1	MTU888	Monday, June 1, 2020	0.001	Passed	0.0930	Passed	
Citadel High School	1st Floor Boys Wash Room tap 2	MTU889	Monday, June 1, 2020	-	Passed	0.0470	Passed	
Citadel High School	1st Floor Boys Wash Room tap 3	MTU890	Monday, June 1, 2020	0.003	Passed	0.0760	Passed	
Citadel High School	1st Floor Boys Wash Room tap 4	MTU894	Monday, June 1, 2020	0.009	Exceeded	0.7900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Citadel High School	1st Floor Boys Wash Room tap 5	MTU895	Monday, June 1, 2020	-	Passed	0.0440	Passed	
Citadel High School	1st Floor Staff Room tap 1	MTU896	Monday, June 1, 2020	-	Passed	0.0720	Passed	
Citadel High School	1st Floor Staff Room tap 2	MTU897	Monday, June 1, 2020	-	Passed	0.0460	Passed	
Citadel High School	Janitors Closet tap by Staff Room	MTU898	Monday, June 1, 2020	-	Passed	0.1300	Passed	
Citadel High School	1st Floor Girls Wash Room tap 1 (by JC)	MTU899	Monday, June 1, 2020	0.002	Passed	0.1000	Passed	
Citadel High School	1st Floor Girls Wash Room tap 2 (by JC)	MTU900	Monday, June 1, 2020	0.003	Passed	0.3700	Passed	
Citadel High School	1st Floor Girls Wash Room tap 3 (by JC)	MTU901	Monday, June 1, 2020	0.001	Passed	0.1400	Passed	
Citadel High School	1st Floor Girls Wash Room tap 4 (by JC)	MTU902	Monday, June 1, 2020	0.001	Passed	0.0870	Passed	
Citadel High School	1st Floor Girls Wash Room tap 5 (by JC)	NDO549	Friday, July 17, 2020	0.001	Passed	0.0480	Passed	
Citadel High School	Tech Ed tap Room 115	MTU906	Monday, June 1, 2020	-	Passed	0.0170	Passed	
Citadel High School	Gender Neutral Wash Room tap Room 120	MTU907	Monday, June 1, 2020	-	Passed	0.0540	Passed	
Citadel High School	Class Room tap Room 120	MTU908	Monday, June 1, 2020	-	Passed	0.0660	Passed	
Citadel High School	Main Office tap 1	MTU909	Monday, June 1, 2020	-	Passed	0.0230	Passed	
Citadel High School	Main Office tap 2	MTU910	Monday, June 1, 2020	-	Passed	0.0190	Passed	
Citadel High School	Fountain by Girls Locker Room	QQK571	Tuesday, September 14, 2021	-	Passed	0.0470	Passed	Fountain replaced
Citadel High School	Girls Locker Room tap 1	MTU913	Monday, June 1, 2020	-	Passed	0.0510	Passed	
Citadel High School	Girls Locker Room tap 2	MTU914	Monday, June 1, 2020	0.007	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Citadel High School	Janitors Closet tap near Gym	MTU915	Monday, June 1, 2020	0.002	Passed	0.1700	Passed	
Citadel High School	Fountain by Boys Locker Room	QQK570	Tuesday, September 14, 2021	-	Passed	0.0370	Passed	Fountain replaced
Citadel High School	Boys Locker Room tap 1	MTU917	Monday, June 1, 2020	0.001	Passed	0.2600	Passed	
Citadel High School	Boys Locker Room tap 2 Room 153	MTU918	Monday, June 1, 2020	0.003	Passed	0.1200	Passed	
Citadel High School	1st Floor Staff Wash Room	MTU919	Monday, June 1, 2020	0.007	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Citadel High School	Recycling Room tap	MTU920	Monday, June 1, 2020	-	Passed	0.0590	Passed	
Citadel High School	Drama Room tap Room 122	MTU921	Monday, June 1, 2020	-	Passed	0.0230	Passed	
Citadel High School	Boys Wash Room tap 1 by Room 122	MTU922	Monday, June 1, 2020	0.001	Passed	0.0400	Passed	
Citadel High School	Boys Wash Room tap 2 by Room 122	MTU923	Monday, June 1, 2020	-	Passed	0.0310	Passed	
Citadel High School	Boys Wash Room tap 3 by Room 122	MTU924	Monday, June 1, 2020	-	Passed	0.0640	Passed	
Citadel High School	Boys Wash Room tap 4 by Room 122	MTU925	Monday, June 1, 2020	-	Passed	0.0380	Passed	
Citadel High School	Janitors Closet tap by Boys Wash Room	MTU926	Monday, June 1, 2020	-	Passed	0.0320	Passed	
Citadel High School	1st Floor Girls Wash Room tap 1	MTU927	Monday, June 1, 2020	-	Passed	0.0520	Passed	
Citadel High School	1st Floor Girls Wash Room tap 2	MTU928	Monday, June 1, 2020	-	Passed	0.0470	Passed	
Citadel High School	1st Floor Girls Wash Room tap 3	NDO548	Friday, July 17, 2020	-	Passed	0.0360	Passed	
Citadel High School	1st Floor Girls Wash Room tap 4	MTU930	Monday, June 1, 2020	0.002	Passed	0.0360	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Citadel High School	1st Floor Girls Wash Room tap 5	MTU931	Monday, June 1, 2020	0.002	Passed	0.0990	Passed	
Citadel High School	1st Floor Girls Wash Room tap 6	MTU932	Monday, June 1, 2020	0.001	Passed	0.0410	Passed	
Citadel High School	1st Floor Girls Wash Room tap 7	MTU933	Monday, June 1, 2020	0.001	Passed	0.0570	Passed	
Citadel High School	Class Room tap 1 Room 301	MTV128	Monday, June 1, 2020	-	Passed	0.0360	Passed	
Citadel High School	Class Room tap 2 Room 301	MTV129	Monday, June 1, 2020	-	Passed	0.0250	Passed	
Citadel High School	Class Room tap 1 Room 302	MTV130	Monday, June 1, 2020	-	Passed	0.1400	Passed	
Citadel High School	Class Room tap 2 Room 302	MTV131	Monday, June 1, 2020	-	Passed	0.1300	Passed	
Citadel High School	Fountain by Room 305	MTV132	Monday, June 1, 2020	-	Passed	0.1500	Passed	
Citadel High School	Fountain by Room 308	MTV133	Monday, June 1, 2020	-	Passed	0.2400	Passed	
Citadel High School	Class Room tap 2 Room 311	MTV135	Monday, June 1, 2020	0.001	Passed	0.1600	Passed	
Citadel High School	Class Room tap 3 Room 311	MTV136	Monday, June 1, 2020	0.001	Passed	0.0920	Passed	
Citadel High School	Class Room tap 4 Room 311	MTV137	Monday, June 1, 2020	-	Passed	0.0580	Passed	
Citadel High School	Class Room tap 5 Room 311	MTV155	Monday, June 1, 2020	0.001	Passed	0.0880	Passed	
Citadel High School	Class Room tap 1 Room 312	MTV156	Monday, June 1, 2020	0.001	Passed	0.1100	Passed	
Citadel High School	Class Room tap 2 Room 312	MTV157	Monday, June 1, 2020	0.001	Passed	0.0690	Passed	
Citadel High School	Class Room tap 3 Room 312	MTV158	Monday, June 1, 2020	-	Passed	0.0610	Passed	
Citadel High School	Class Room tap 4 Room 312	MTV159	Monday, June 1, 2020	-	Passed	0.0560	Passed	
Citadel High School	Class Room tap 5 Room 312	MTV215	Monday, June 1, 2020	0.001	Passed	0.1300	Passed	
Citadel High School	Class Room tap 1 Room 314	MTV160	Monday, June 1, 2020	0.001	Passed	0.0560	Passed	
Citadel High School	Class Room tap 2 Room 314	MTV161	Monday, June 1, 2020	-	Passed	0.0400	Passed	
Citadel High School	Class Room tap 3 Room 314	MTV162	Monday, June 1, 2020	0.001	Passed	0.0530	Passed	
Citadel High School	Class Room tap 4 Room 314	MTV163	Monday, June 1, 2020	0.001	Passed	0.0710	Passed	
Citadel High School	Class Room tap 5 Room 314	MTV164	Monday, June 1, 2020	-	Passed	0.0420	Passed	
Citadel High School	Class Room tap 6 Room 314	MTV165	Monday, June 1, 2020	-	Passed	0.0490	Passed	
Citadel High School	Class Room tap 7 Room 314	MTV166	Monday, June 1, 2020	-	Passed	0.0510	Passed	
Citadel High School	Class Room tap 8 Room 314	MTV167	Monday, June 1, 2020	-	Passed	0.0480	Passed	
Citadel High School	Class Room tap 9 Room 314	MTV168	Monday, June 1, 2020	-	Passed	0.0160	Passed	
Citadel High School	Class Room tap 10 Room 314	MTV169	Monday, June 1, 2020	-	Passed	0.0300	Passed	
Citadel High School	Class Room tap 1 Room 315	MTV170	Monday, June 1, 2020	0.001	Passed	0.1000	Passed	
Citadel High School	Class Room tap 2 Room 315	MTV171	Monday, June 1, 2020	-	Passed	0.0430	Passed	
Citadel High School	Class Room tap 3 Room 315	MTV172	Monday, June 1, 2020	0.001	Passed	0.0520	Passed	
Citadel High School	Class Room tap 4 Room 315	MTV173	Monday, June 1, 2020	-	Passed	0.0510	Passed	
Citadel High School	Class Room tap 5 Room 315	MTV174	Monday, June 1, 2020	-	Passed	0.0430	Passed	
Citadel High School	Class Room tap 6 Room 315	MTV188	Monday, June 1, 2020	-	Passed	0.0380	Passed	
Citadel High School	Class Room tap 7 Room 315	MTV189	Monday, June 1, 2020	-	Passed	0.0220	Passed	
Citadel High School	Class Room tap 8 Room 315	MTV190	Monday, June 1, 2020	-	Passed	0.0140	Passed	
Citadel High School	Class Room tap 9 Room 315	MTV191	Monday, June 1, 2020	-	Passed	0.0140	Passed	
Citadel High School	Boys Wash Room tap 1 Room 316	MTV192	Monday, June 1, 2020	-	Passed	0.0550	Passed	
Citadel High School	Boys Wash Room tap 2 Room 316	MTV193	Monday, June 1, 2020	-	Passed	0.0410	Passed	
Citadel High School	Boys Wash Room tap 3 Room 316	MTV194	Monday, June 1, 2020	0.001	Passed	0.0590	Passed	
Citadel High School	Boys Wash Room tap 4 Room 316	MTV195	Monday, June 1, 2020	0.002	Passed	0.3300	Passed	
Citadel High School	Boys Wash Room tap 5 Room 316	MTV196	Monday, June 1, 2020	0.001	Passed	0.1200	Passed	
Citadel High School	Girls Wash Room tap 1 by Room 316	MTV197	Monday, June 1, 2020	0.001	Passed	0.2400	Passed	
Citadel High School	Girls Wash Room tap 2 by Room 316	MTV198	Monday, June 1, 2020	0.001	Passed	0.1400	Passed	
Citadel High School	Girls Wash Room tap 3 by Room 316	MTV199	Monday, June 1, 2020	0.002	Passed	0.4400	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Citadel High School	Girls Wash Room tap 4 by Room 316	MTV200	Monday, June 1, 2020	0.001	Passed	0.3000	Passed	
Citadel High School	Girls Wash Room tap 5 by Room 316	MTV201	Monday, June 1, 2020	0.001	Passed	0.3000	Passed	
Citadel High School	3rd Floor Staff Room tap 1	MTV202	Monday, June 1, 2020	-	Passed	0.0410	Passed	
Citadel High School	3rd Floor Staff Room tap 2	MTV203	Monday, June 1, 2020	-	Passed	0.0770	Passed	
Citadel High School	3rd Floor Staff Room tap 3	MTV204	Monday, June 1, 2020	0.001	Passed	0.0700	Passed	
Citadel High School	Class Room tap 1 Room 321	MTV205	Monday, June 1, 2020	-	Passed	0.1100	Passed	
Citadel High School	Class Room tap 2 Room 321	MTV206	Monday, June 1, 2020	-	Passed	0.0410	Passed	
Citadel High School	Class Room tap 3 Room 321	MTV207	Monday, June 1, 2020	-	Passed	0.0380	Passed	
Citadel High School	Class Room tap 4 Room 321	MTV208	Monday, June 1, 2020	-	Passed	0.0310	Passed	
Citadel High School	Gender Neutral Wash Room tap by Room 321	MTV209	Monday, June 1, 2020	-	Passed	0.0410	Passed	
Citadel High School	Storage Room tap by Janitors Closet	MTV210	Monday, June 1, 2020	-	Passed	0.1800	Passed	
Citadel High School	3rd Floor Janitors Closet tap	MTV211	Monday, June 1, 2020	-	Passed	0.0330	Passed	
Citadel High School	2nd Floor teen health Room tap	MTV212	Monday, June 1, 2020	0.001	Passed	0.2100	Passed	
Citadel High School	Fountain by Room 203	MTV213	Monday, June 1, 2020	-	Passed	0.1300	Passed	
Citadel High School	Fountain by Room 206	MTV214	Monday, June 1, 2020	-	Passed	0.1100	Passed	
Creighton Park Elementary School	Class Room tap Room 107	MYR663	Wednesday, June 24, 2020	0.001	Passed	0.2800	Passed	
Creighton Park Elementary School	Girls Wash Room tap 1 Room 109	MYR664	Wednesday, June 24, 2020	0.005	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Girls Wash Room tap 2 Room 109	MYR665	Wednesday, June 24, 2020	0.001	Passed	0.0790	Passed	
Creighton Park Elementary School	Girls Wash Room tap 3 Room 109	MYR666	Wednesday, June 24, 2020	0.003	Passed	0.1800	Passed	
Creighton Park Elementary School	Girls Wash Room tap 4 Room 109	MYR667	Wednesday, June 24, 2020	0.002	Passed	0.1100	Passed	
Creighton Park Elementary School	Fountain by Room 110	MYR668	Wednesday, June 24, 2020	-	Passed	0.3300	Passed	
Creighton Park Elementary School	Boys Wash Room tap 1 Room 111	MYR669	Wednesday, June 24, 2020	0.015	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Janitors Closet tap in Boys Wash Room (111)	MYR670	Wednesday, June 24, 2020	0.029	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Boys Wash Room tap 2 Room 111	MYR671	Wednesday, June 24, 2020	0.009	Exceeded	0.0930	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Boys Wash Room tap 3 Room 111	MYR672	Wednesday, June 24, 2020	-	Passed	0.0080	Passed	
Creighton Park Elementary School	Janitors Closet tap in boiler Room	MYR673	Wednesday, June 24, 2020	0.001	Passed	0.0170	Passed	
Creighton Park Elementary School	Class Room tap Room 125	MYR674	Wednesday, June 24, 2020	0.017	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Class Room tap Room 126	MYR675	Wednesday, June 24, 2020	0.012	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Boys Wash Room tap 1 Room 204	MYR676	Wednesday, June 24, 2020	0.006	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Boys Wash Room tap 2 Room 204	MYR677	Wednesday, June 24, 2020	0.001	Passed	0.0150	Passed	
Creighton Park Elementary School	Janitors Closet tap Room 205	MYR678	Wednesday, June 24, 2020	0.016	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Girls Wash Room tap 1 Room 206	MYR679	Wednesday, June 24, 2020	0.006	Exceeded	0.0430	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Girls Wash Room tap 2 Room 206	MYR680	Wednesday, June 24, 2020	0.006	Exceeded	0.0750	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Class Room tap Room 208	MYR681	Wednesday, June 24, 2020	0.080	Exceeded	0.8800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Staff Wash Room tap Room 203	MYR682	Wednesday, June 24, 2020	0.009	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Fountain by Room 201	QTT462	Monday, September 27, 2021	0.000	Passed	0.000	Passed	Fountain replaced
Creighton Park Elementary School	Class Room tap Room 203	MYR684	Wednesday, June 24, 2020	0.016	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Boys Wash Room tap Room 122	MYR685	Wednesday, June 24, 2020	0.031	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Fountain by Room 121	MYR686	Wednesday, June 24, 2020	-	Passed	0.2400	Passed	
Creighton Park Elementary School	Janitors Closet tap Room 121	MYR687	Wednesday, June 24, 2020	0.005	Passed	0.0640	Passed	
Creighton Park Elementary School	Girls Wash Room tap Room 120	MYR705	Wednesday, June 24, 2020	-	Passed	0.0082	Passed	
Creighton Park Elementary School	Class Room Wash Room tap Room 101	MYR706	Wednesday, June 24, 2020	0.083	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Class Room Wash Room tap Room 102	MYR707	Wednesday, June 24, 2020	0.032	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Creighton Park Elementary School	Class Room Wash Room tap Room 103	MYR708	Wednesday, June 24, 2020	0.012	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Clayton Park Junior High School	Class Room tap Room 214	MRM447	Thursday, May 21, 2020	0.006	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Clayton Park Junior High School	Janitors Closet tap by Room 214	MRM448	Thursday, May 21, 2020	-	Passed	0.0580	Passed	
Clayton Park Junior High School	Boys Wash Room tap 1 by Room 200	MRM449	Thursday, May 21, 2020	-	Passed	0.0200	Passed	
Clayton Park Junior High School	Boys Wash Room tap 2 by Room 200	MRM450	Thursday, May 21, 2020	0.001	Passed	0.0390	Passed	
Clayton Park Junior High School	Boys Wash Room tap 3 by Room 200	MRM451	Thursday, May 21, 2020	0.006	Exceeded	0.0540	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Clayton Park Junior High School	Fountain by Room 200	MRM452	Thursday, May 21, 2020	0.001	Passed	0.3700	Passed	
Clayton Park Junior High School	Staff Wash Room tap by Room 200	MRM453	Thursday, May 21, 2020	-	Passed	0.0160	Passed	
Clayton Park Junior High School	Girls Wash Room tap 1 by Room 200	MRM454	Thursday, May 21, 2020	0.002	Passed	0.4200	Passed	
Clayton Park Junior High School	Girls Wash Room tap 2 by Room 200	MRM455	Thursday, May 21, 2020	0.001	Passed	0.3500	Passed	
Clayton Park Junior High School	Girls Wash Room tap 3 by Room 200	MRM456	Thursday, May 21, 2020	0.001	Passed	0.2400	Passed	
Clayton Park Junior High School	Family Studies tap 1 by Room 106	MRM464	Thursday, May 21, 2020	0.001	Passed	0.2900	Passed	
Clayton Park Junior High School	Family Studies tap 2 by Room 106	MRM465	Thursday, May 21, 2020	-	Passed	0.1800	Passed	
Clayton Park Junior High School	Family Studies tap 3 by Room 106	MRM466	Thursday, May 21, 2020	0.003	Passed	0.1300	Passed	
Clayton Park Junior High School	Family Studies tap 4 by Room 106	MRM467	Thursday, May 21, 2020	-	Passed	0.0410	Passed	
Clayton Park Junior High School	Family Studies tap 45by Room 106	MRM468	Thursday, May 21, 2020	-	Passed	0.0430	Passed	
Clayton Park Junior High School	Class Room tap Room 145	MRM469	Thursday, May 21, 2020	0.005	Passed	0.2200	Passed	
Clayton Park Junior High School	Conference Room Wash Room tap by Room 134	MRM470	Thursday, May 21, 2020	0.004	Passed	0.0950	Passed	
Clayton Park Junior High School	Conference Room Kitchen tap Room 134	NIU530	Wednesday, August 12, 2020	0.000	Passed	0.0160	Passed	
Clayton Park Junior High School	Conference Room Wash Room tap by Room 134	MRM472	Thursday, May 21, 2020	-	Passed	0.1100	Passed	
Clayton Park Junior High School	Boys Locker Room tap by Room 121	MRM473	Thursday, May 21, 2020	0.001	Passed	0.0370	Passed	
Clayton Park Junior High School	Fountain by Room 118	MRM474	Thursday, May 21, 2020	-	Passed	0.3000	Passed	Fountain Replacement in progress
Clayton Park Junior High School	Girls Locker Room tap by Room 114	MRM475	Thursday, May 21, 2020	0.011	Exceeded	0.8500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Clayton Park Junior High School	Boys Wash Room tap 1 by Room 100	MRM476	Thursday, May 21, 2020	-	Passed	0.0084	Passed	
Clayton Park Junior High School	Boys Wash Room tap 2 by Room 100	MRM477	Thursday, May 21, 2020	-	Passed	0.0140	Passed	
Clayton Park Junior High School	Boys Wash Room tap 3 by Room 100	MRM478	Thursday, May 21, 2020	0.002	Passed	0.0530	Passed	
Clayton Park Junior High School	Fountain by Room 100B	MRM479	Thursday, May 21, 2020	-	Passed	0.4000	Passed	
Clayton Park Junior High School	Janitors Closet tap by Room 100	MRM480	Thursday, May 21, 2020	-	Passed	0.0099	Passed	
Clayton Park Junior High School	Girls Wash Room tap 1 by Room 104	MRM481	Thursday, May 21, 2020	-	Passed	0.0600	Passed	
Clayton Park Junior High School	Girls Wash Room tap 2 by Room 104	MRM482	Thursday, May 21, 2020	-	Passed	0.0840	Passed	
Clayton Park Junior High School	Girls Wash Room tap 3 by Room 104	MRM483	Thursday, May 21, 2020	0.007	Exceeded	0.0680	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Clayton Park Junior High School	Staff Room tap Room 104	NIU531	Wednesday, August 12, 2020	0.002	Passed	0.0016	Passed	
Clayton Park Junior High School	Janitors Closet tap by Room 003	MRM485	Thursday, May 21, 2020	0.001	Passed	0.0650	Passed	
Clayton Park Junior High School	Band Room Closet Kitchen tap by Room 144	MRM486	Thursday, May 21, 2020	0.006	Exceeded	0.0720	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Clayton Park Junior High School	Band Room Kitchen tap by Room 144	MRM487	Thursday, May 21, 2020	0.006	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Clayton Park Junior High School	Class Room tap Room 023	MRM488	Thursday, May 21, 2020	-	Passed	0.0830	Passed	
Clayton Park Junior High School	Class Room tap Room 025	MRM489	Thursday, May 21, 2020	-	Passed	0.0470	Passed	
Clayton Park Junior High School	Principals Office Wash Room tap Room 117	MRM490	Thursday, May 21, 2020	0.001	Passed	0.0280	Passed	
Clayton Park Junior High School	Art Room tap by Gym	MRM491	Thursday, May 21, 2020	0.001	Passed	0.0730	Passed	
Colby Village Elementary School	Class Room tap Room 203	MWG569	Friday, June 12, 2020	0.008	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Boys Wash Room tap 1 by Room 203	MWG570	Friday, June 12, 2020	0.006	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Boys Wash Room tap 2 by Room 203	MWG571	Friday, June 12, 2020	0.004	Passed	0.1300	Passed	
Colby Village Elementary School	Boys Wash Room tap 3 by Room 203	MWG572	Friday, June 12, 2020	0.003	Passed	0.0270	Passed	
Colby Village Elementary School	Boys Wash Room tap 4 by Room 203	MWG573	Friday, June 12, 2020	0.003	Passed	0.0250	Passed	
Colby Village Elementary School	Janitors Closet tap by Gym	MWG574	Friday, June 12, 2020	0.001	Passed	0.0520	Passed	
Colby Village Elementary School	Fountain by Gym	NLV943	Wednesday, August 26, 2020	0.000	Passed	0.0250	Passed	
Colby Village Elementary School	Girls Wash Room tap 1 by Gym	MWG576	Friday, June 12, 2020	0.004	Passed	0.0660	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Colby Village Elementary School	Girls Wash Room tap 2 by Gym	MWG577	Friday, June 12, 2020	0.004	Passed	0.0640	Passed	
Colby Village Elementary School	Girls Wash Room tap 3 by Gym	MWG578	Friday, June 12, 2020	0.006	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Girls Wash Room tap 4 by Gym	MWG579	Friday, June 12, 2020	0.005	Passed	0.0670	Passed	
Colby Village Elementary School	Gender Neutral Wash Room tap Room 212	MWG580	Friday, June 12, 2020	0.004	Passed	0.0700	Passed	
Colby Village Elementary School	Gender Neutral Wash Room tap Room 211	MWG581	Friday, June 12, 2020	0.012	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Boys Wash Room tap 1 by Room 211	MWG582	Friday, June 12, 2020	0.007	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Boys Wash Room tap 2 by Room 211	MWG583	Friday, June 12, 2020	0.003	Passed	0.2600	Passed	
Colby Village Elementary School	Boys Wash Room tap 3 by Room 211	MWG584	Friday, June 12, 2020	0.008	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Boys Wash Room tap 4 by Room 211	MWG585	Friday, June 12, 2020	0.030	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Janitors Closet tap by Staff Room	MWG586	Friday, June 12, 2020	0.001	Passed	0.0470	Passed	
Colby Village Elementary School	Fountain by Staff Room	NLV942	Wednesday, August 26, 2020	0.000	Passed	0.0250	Passed	
Colby Village Elementary School	Girls Wash Room tap 1 by Staff Room	MWG588	Friday, June 12, 2020	0.330	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Girls Wash Room tap 2 by Staff Room	MWG589	Friday, June 12, 2020	0.290	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Girls Wash Room tap 3 by Staff Room	MWG590	Friday, June 12, 2020	0.160	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Girls Wash Room tap 4 by Staff Room	MWG591	Friday, June 12, 2020	0.450	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Staff Room Wash Room 1 tap	MWG592	Friday, June 12, 2020	0.007	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Colby Village Elementary School	Staff Room Kitchen tap	NLV941	Wednesday, August 26, 2020	0.003	Passed	0.0230	Passed	
Colby Village Elementary School	Staff Room Wash Room 2 tap	MWG594	Friday, June 12, 2020	0.025	Exceeded	0.0690	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Breakfast Room tap 1	NMD819	Thursday, August 27, 2020	0.000	Passed	0.0170	Passed	
Cole Harbour District High School	Breakfast Room tap 2	NMD822	Thursday, August 27, 2020	0.000	Passed	0.0120	Passed	
Cole Harbour District High School	Breakfast Room tap 3	MXH625	Wednesday, June 17, 2020	0.002	Passed	1.9000	Passed	
Cole Harbour District High School	Breakfast Room tap 4	NMD823	Thursday, August 27, 2020	0.000	Passed	0.0100	Passed	
Cole Harbour District High School	Breakfast Room handwashing tap	MXH627	Wednesday, June 17, 2020	-	Passed	1.6000	Passed	
Cole Harbour District High School	Fountain by Room 308	NMD818	Thursday, August 27, 2020	0.001	Passed	0.0580	Passed	New Fountain to be installed. Other sources available.
Cole Harbour District High School	Staff Wash Room tap by Room 308	MXH629	Wednesday, June 17, 2020	0.001	Passed	0.0660	Passed	
Cole Harbour District High School	Boys Wash Room tap 1 by Room 309	MXH630	Wednesday, June 17, 2020	0.004	Passed	0.2500	Passed	
Cole Harbour District High School	Boys Wash Room tap 2 by Room 309	MXH631	Wednesday, June 17, 2020	0.002	Passed	0.3400	Passed	
Cole Harbour District High School	Janitors Closet tap by Room 309	MXH632	Wednesday, June 17, 2020	0.001	Passed	0.1600	Passed	
Cole Harbour District High School	Fountain by Room 309	MXH633	Wednesday, June 17, 2020	0.001	Passed	0.0870	Passed	New Fountain to be installed. Other sources available.
Cole Harbour District High School	Girls Wash Room tap 1 by Room 309	MXH634	Wednesday, June 17, 2020	0.008	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Girls Wash Room tap 2 by Room 309	MXH635	Wednesday, June 17, 2020	0.003	Passed	0.2300	Passed	
Cole Harbour District High School	Server Room tap in library	MXH636	Wednesday, June 17, 2020	0.570	Exceeded	0.5900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Class Room tap Room 208	MXH637	Wednesday, June 17, 2020	0.001	Passed	0.5400	Passed	
Cole Harbour District High School	Learning Centre Wash Room tap	MXH638	Wednesday, June 17, 2020	0.001	Passed	1.2000	Passed	
Cole Harbour District High School	Learning Centre Kitchen tap	MXH639	Wednesday, June 17, 2020	0.001	Passed	0.5500	Passed	
Cole Harbour District High School	Gender Neutral Wash Room tap by learning Centre	MXH640	Wednesday, June 17, 2020	-	Passed	0.7000	Passed	
Cole Harbour District High School	Fountain by Room 208	MXH641	Wednesday, June 17, 2020	-	Passed	0.3200	Passed	New Fountain to be installed. Other sources available.
Cole Harbour District High School	Staff Wash Room tap by Room 208	MXH642	Wednesday, June 17, 2020	0.004	Passed	0.0710	Passed	
Cole Harbour District High School	Staff Room 208 tap	NMD824	Thursday, August 27, 2020	0.000	Passed	0.0150	Passed	
Cole Harbour District High School	Boys Wash Room tap 1 by cafeteria	MXH644	Wednesday, June 17, 2020	0.008	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Boys Wash Room tap 2 by cafeteria	MXH645	Wednesday, June 17, 2020	0.001	Passed	0.1100	Passed	
Cole Harbour District High School	Boys Wash Room tap 3 by cafeteria	MXH646	Wednesday, June 17, 2020	0.002	Passed	0.0950	Passed	
Cole Harbour District High School	Janitors Closet tap by Wash Room's	MXH647	Wednesday, June 17, 2020	0.001	Passed	0.0450	Passed	
Cole Harbour District High School	Girls Wash Room tap 1 by Janitors Closet	MXH648	Wednesday, June 17, 2020	0.005	Passed	0.1900	Passed	
Cole Harbour District High School	Girls Wash Room tap 2 by Janitors Closet	MXH649	Wednesday, June 17, 2020	0.002	Passed	0.1200	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Cole Harbour District High School	Girls Wash Room tap 3 by Janitors Closet	MXH650	Wednesday, June 17, 2020	0.010	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Student Services Gender Neutral Wash Room tap	MXH651	Wednesday, June 17, 2020	-	Passed	0.5600	Passed	
Cole Harbour District High School	Cafeteria/Kitchen handwashing tap	MXH652	Wednesday, June 17, 2020	-	Passed	0.4200	Passed	
Cole Harbour District High School	Cafeteria/Kitchen triple compartment sink tap	NMD825	Thursday, August 27, 2020	0.000	Passed	0.0150	Passed	
Cole Harbour District High School	Cafeteria/Kitchen single compartment sink tap	MXH654	Wednesday, June 17, 2020	0.001	Passed	0.3900	Passed	
Cole Harbour District High School	Male Locker Room tap 1	MXH655	Wednesday, June 17, 2020	0.011	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Male Locker Room tap 2	MXH656	Wednesday, June 17, 2020	-	Passed	0.7900	Passed	
Cole Harbour District High School	Male Locker Room tap 3	MXH657	Wednesday, June 17, 2020	0.001	Passed	0.7800	Passed	
Cole Harbour District High School	Male Locker Room tap 4	MXH658	Wednesday, June 17, 2020	-	Passed	0.8200	Passed	
Cole Harbour District High School	Student Services Gender Neutral Wash Room tap	MXH659	Wednesday, June 17, 2020	0.002	Passed	0.8000	Passed	
Cole Harbour District High School	Female Locker Room tap 1	MXH660	Wednesday, June 17, 2020	-	Passed	0.6200	Passed	
Cole Harbour District High School	Female Locker Room tap 2	MXH661	Wednesday, June 17, 2020	0.001	Passed	0.6200	Passed	
Cole Harbour District High School	Female Locker Room tap 3	MXH662	Wednesday, June 17, 2020	-	Passed	0.4900	Passed	
Cole Harbour District High School	Female Locker Room tap 4	MXH663	Wednesday, June 17, 2020	-	Passed	0.4100	Passed	
Cole Harbour District High School	Air handler Room tap	MXH664	Wednesday, June 17, 2020	-	Passed	0.3300	Passed	
Cole Harbour District High School	Fountain by Gym door	MXH665	Wednesday, June 17, 2020	-	Passed	0.7600	Passed	
Cole Harbour District High School	Fountain in Skilled Trades Room	MXH666	Wednesday, June 17, 2020	-	Passed	1.6000	Passed	New Fountain to be installed. Other sources available.
Cole Harbour District High School	Staff Wash Room tap in main Office	MXH667	Wednesday, June 17, 2020	0.001	Passed	0.3700	Passed	
Cole Harbour District High School	Janitors Closet tap in Mech. Room	MXH668	Wednesday, June 17, 2020	0.005	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 1 Room 120	MXH669	Wednesday, June 17, 2020	0.006	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 2 Room 120	MXH670	Wednesday, June 17, 2020	0.370	Exceeded	1.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 3 Room 120	MXH671	Wednesday, June 17, 2020	0.013	Exceeded	0.8500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 4 Room 120	MXH672	Wednesday, June 17, 2020	0.080	Exceeded	0.6500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 5 Room 120	MXH673	Wednesday, June 17, 2020	0.036	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 6 Room 120	MXH674	Wednesday, June 17, 2020	0.100	Exceeded	0.9400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 7 Room 120	MXH675	Wednesday, June 17, 2020	0.016	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 8 Room 120	MXH676	Wednesday, June 17, 2020	0.026	Exceeded	0.9200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Lab sink between Room 120 and 119	MXH677	Wednesday, June 17, 2020	0.014	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 1 Room 119	MXH678	Wednesday, June 17, 2020	0.007	Exceeded	0.5600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 2 Room 119	MXH679	Wednesday, June 17, 2020	0.066	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 3 Room 119	MXH680	Wednesday, June 17, 2020	0.220	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 4 Room 119	MXH681	Wednesday, June 17, 2020	0.120	Exceeded	0.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 5 Room 119	MXH682	Wednesday, June 17, 2020	0.067	Exceeded	0.7200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 6 Room 119	MXH683	Wednesday, June 17, 2020	0.007	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 7 Room 119	MXH684	Wednesday, June 17, 2020	0.030	Exceeded	0.8500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Class Room tap Room 118	NMD841	Thursday, August 27, 2020	0.000	Passed	0.0040	Passed	
Cole Harbour District High School	Girls Wash Room tap 1 by Room 108	MXH686	Wednesday, June 17, 2020	0.020	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Girls Wash Room tap 2 by Room 108	MXH687	Wednesday, June 17, 2020	0.004	Passed	0.1600	Passed	
Cole Harbour District High School	Staff Wash Room tap between Wash Rooms	MXH688	Wednesday, June 17, 2020	0.005	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Boys Wash Room tap 1 by Room 108	MXH689	Wednesday, June 17, 2020	0.002	Passed	0.0950	Passed	
Cole Harbour District High School	Boys Wash Room tap 2 by Room 108	MXH690	Wednesday, June 17, 2020	0.012	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Class Room tap Room 117	NMD829	Thursday, August 27, 2020	0.000	Passed	0.0260	Passed	
Cole Harbour District High School	Janitors Closet tap by Room 117	MXH692	Wednesday, June 17, 2020	0.028	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Fountain by Janitors Closet	PXP085	Wednesday, June 23, 2021	0.003	Passed	0.1400	Passed	New Fountain.
Cole Harbour District High School	Gender Neutral Wash Room tap Room 116	MXH694	Wednesday, June 17, 2020	0.003	Passed	0.3600	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Cole Harbour District High School	Class Room tap Room 116	NMD828	Thursday, August 27, 2020	0.006	Passed	0.0560	Passed	
Cole Harbour District High School	Science Lab tap 1 Room 115	MXH696	Wednesday, June 17, 2020	0.094	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 2 Room 115	MXH697	Wednesday, June 17, 2020	0.061	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 3 Room 115	MXH698	Wednesday, June 17, 2020	0.030	Exceeded	0.7900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 4 Room 115	MXH699	Wednesday, June 17, 2020	0.093	Exceeded	0.5600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 1 Room 114	MXH700	Wednesday, June 17, 2020	0.052	Exceeded	2.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 2 Room 114	MXH701	Wednesday, June 17, 2020	0.017	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 3 Room 114	MXH702	Wednesday, June 17, 2020	0.007	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 4 Room 114	MXH703	Wednesday, June 17, 2020	0.010	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 1 Room 113	MXH704	Wednesday, June 17, 2020	0.083	Exceeded	0.7500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 2 Room 113	MXH705	Wednesday, June 17, 2020	0.011	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Science Lab tap 3 Room 113	MXH706	Wednesday, June 17, 2020	1.100	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Janitors Closet tap Room 112	MXH707	Wednesday, June 17, 2020	0.015	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cole Harbour District High School	Class Room tap 1 Room 109	NMD826	Thursday, August 27, 2020	0.007	Passed	0.0460	Passed	
Cole Harbour District High School	Class Room tap 2 Room 109	NMD827	Thursday, August 27, 2020	0.007	Passed	0.0210	Passed	
Colonel John Stuart Elementary School	Fountain by fire panel	MWG652	Friday, June 12, 2020	0.003	Passed	0.5200	Passed	
Colonel John Stuart Elementary School	Wash Room by Gym	MWG653	Friday, June 12, 2020	0.001	Passed	0.1700	Passed	
Colonel John Stuart Elementary School	Bar sink tap Room 102	NMD726	Thursday, August 27, 2020	0.001	Passed	0.1700	Passed	
Colonel John Stuart Elementary School	Kitchen sink tap Room 102	MWG655	Friday, June 12, 2020	0.001	Passed	0.2900	Passed	
Colonel John Stuart Elementary School	Staff Room Wash Room 1 tap	MWG656	Friday, June 12, 2020	0.001	Passed	0.0510	Passed	
Colonel John Stuart Elementary School	Staff Room Wash Room 2 tap	MWG657	Friday, June 12, 2020	0.002	Passed	0.0840	Passed	
Colonel John Stuart Elementary School	Staff Room Kitchen sink	MWG658	Friday, June 12, 2020	0.005	Passed	0.1300	Passed	
Colonel John Stuart Elementary School	Laundry tub tap by Room 113	MWG659	Friday, June 12, 2020	0.001	Passed	0.1000	Passed	
Colonel John Stuart Elementary School	Girls Wash Room tap 1 by fountain	MWG660	Friday, June 12, 2020	0.004	Passed	0.0990	Passed	
Colonel John Stuart Elementary School	Girls Wash Room tap 2 by fountain	MWG661	Friday, June 12, 2020	0.004	Passed	0.0670	Passed	
Colonel John Stuart Elementary School	Girls Wash Room tap 3 by fountain	MWG662	Friday, June 12, 2020	0.003	Passed	0.0540	Passed	
Colonel John Stuart Elementary School	Girls Wash Room tap 4 by fountain	MWG663	Friday, June 12, 2020	0.004	Passed	0.0880	Passed	
Colonel John Stuart Elementary School	Fountain in between Wash Room's	MWG664	Friday, June 12, 2020	0.004	Passed	0.7300	Passed	
Colonel John Stuart Elementary School	Boys Wash Room tap 1 by fountain	MWG665	Friday, June 12, 2020	0.003	Passed	0.1700	Passed	
Colonel John Stuart Elementary School	Boys Wash Room tap 2 by fountain	MWG666	Friday, June 12, 2020	0.003	Passed	0.1100	Passed	
Colonel John Stuart Elementary School	Boys Wash Room tap 3 by fountain	MWG667	Friday, June 12, 2020	0.004	Passed	0.0930	Passed	
Colonel John Stuart Elementary School	Class Room tap Room 101	NMD725	Thursday, August 27, 2020	0.001	Passed	0.1600	Passed	
Cunard Junior High School	Boys Wash Room tap 1 Room 209	MRE108	Wednesday, May 20, 2020	0.002	Passed	0.1700	Passed	
Cunard Junior High School	Boys Wash Room tap 2 Room 209	MRE109	Wednesday, May 20, 2020	0.001	Passed	0.0900	Passed	
Cunard Junior High School	Boys Wash Room tap 3 Room 209	MRE110	Wednesday, May 20, 2020	0.001	Passed	0.0680	Passed	
Cunard Junior High School	Boys Wash Room tap 4 Room 209	MRE111	Wednesday, May 20, 2020	0.001	Passed	0.0630	Passed	
Cunard Junior High School	Janitors Closet tap Room 209	MRE112	Wednesday, May 20, 2020	-	Passed	0.0190	Passed	
Cunard Junior High School	Fountain by Room 211	MRE113	Wednesday, May 20, 2020	0.003	Passed	0.2600	Passed	
Cunard Junior High School	Girls Wash Room tap 1 Room 211	MRE114	Wednesday, May 20, 2020	-	Passed	0.0760	Passed	
Cunard Junior High School	Girls Wash Room tap 2 Room 211	MRE115	Wednesday, May 20, 2020	0.001	Passed	0.0470	Passed	
Cunard Junior High School	Girls Wash Room tap 3 Room 211	MRE116	Wednesday, May 20, 2020	-	Passed	0.0550	Passed	
Cunard Junior High School	Girls Wash Room tap 4 Room 211	MRE117	Wednesday, May 20, 2020	-	Passed	0.0390	Passed	
Cunard Junior High School	Family Studies tap 1 Room 212	MRE118	Wednesday, May 20, 2020	0.002	Passed	0.0450	Passed	
Cunard Junior High School	Family Studies tap 2 Room 212	MRE119	Wednesday, May 20, 2020	0.001	Passed	0.0530	Passed	
Cunard Junior High School	Family Studies tap 3 Room 212	MRE120	Wednesday, May 20, 2020	-	Passed	0.0140	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Cunard Junior High School	Guidance Room tap Room 215	MRE121	Wednesday, May 20, 2020	0.003	Passed	0.0520	Passed	
Cunard Junior High School	Gender Neutral Wash Room tap Room 216	MRE122	Wednesday, May 20, 2020	-	Passed	0.0300	Passed	
Cunard Junior High School	Staff Room tap Room 200	NKX299	Friday, August 14, 2020	0.000	Passed	0.0040	Passed	
Cunard Junior High School	Class Room tap Room 106	NKX298	Friday, August 14, 2020	0.000	Passed	0.0041	Passed	
Cunard Junior High School	Boys Wash Room tap 1 Room 107	MRE125	Wednesday, May 20, 2020	0.009	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cunard Junior High School	Boys Wash Room tap 2 Room 107	MRE126	Wednesday, May 20, 2020	0.001	Passed	0.0560	Passed	
Cunard Junior High School	Boys Wash Room tap 3 Room 107	MRE127	Wednesday, May 20, 2020	-	Passed	0.0220	Passed	
Cunard Junior High School	Boys Wash Room tap 4 Room 107	MRE136	Wednesday, May 20, 2020	0.001	Passed	0.0300	Passed	
Cunard Junior High School	Janitors Closet tap Room 108	MRE137	Wednesday, May 20, 2020	0.003	Passed	0.0810	Passed	
Cunard Junior High School	Fountain by Room 108	MRE138	Wednesday, May 20, 2020	-	Passed	0.0960	Passed	
Cunard Junior High School	Girls Wash Room tap 1 Room 109	MRE139	Wednesday, May 20, 2020	0.024	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cunard Junior High School	Girls Wash Room tap 2 Room 109	MRE140	Wednesday, May 20, 2020	0.003	Passed	0.0390	Passed	
Cunard Junior High School	Girls Wash Room tap 3 Room 109	MRE141	Wednesday, May 20, 2020	0.004	Passed	0.0350	Passed	
Cunard Junior High School	Girls Wash Room tap 4 Room 109	MRE142	Wednesday, May 20, 2020	0.006	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cunard Junior High School	Class Room tap Room 112	MRE143	Wednesday, May 20, 2020	0.018	Exceeded	0.9400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Cunard Junior High School	Class Room tap Room 113	MRE144	Wednesday, May 20, 2020	0.003	Passed	0.3200	Passed	
Cunard Junior High School	Main Office Wash Room tap	MRE145	Wednesday, May 20, 2020	-	Passed	0.0190	Passed	
Dartmouth High School	Main Office Wash Room tap	MYV801	Wednesday, June 24, 2020	-	Passed	0.1300	Passed	
Dartmouth High School	Fountain by Office	MYV802	Wednesday, June 24, 2020	-	Passed	0.3900	Passed	
Dartmouth High School	Gender Neutral Wash Room tap in health Centre	MYV803	Wednesday, June 24, 2020	0.001	Passed	0.9100	Passed	
Dartmouth High School	Fountain by health Centre	MYV804	Wednesday, June 24, 2020	-	Passed	0.0400	Passed	
Dartmouth High School	Boys Wash Room tap 1 before Gym	MYV805	Wednesday, June 24, 2020	0.001	Passed	0.0260	Passed	
Dartmouth High School	Boys Wash Room tap 2 before Gym	MYV806	Wednesday, June 24, 2020	0.001	Passed	0.0320	Passed	
Dartmouth High School	Girls Wash Room tap 1 before Gym	MYV807	Wednesday, June 24, 2020	0.002	Passed	0.0390	Passed	
Dartmouth High School	Girls Wash Room tap 1 before Gym	MYV808	Wednesday, June 24, 2020	0.001	Passed	0.0470	Passed	
Dartmouth High School	Girls Locker Room tap 1 Room 164	MYV809	Wednesday, June 24, 2020	0.001	Passed	0.0310	Passed	
Dartmouth High School	Girls Locker Room tap 2 Room 164	MYV810	Wednesday, June 24, 2020	0.001	Passed	0.0980	Passed	
Dartmouth High School	Gym Office Wash Room tap Room 162	MYV811	Wednesday, June 24, 2020	-	Passed	0.6300	Passed	
Dartmouth High School	Boys Locker Room tap 1 Room 166	MYV812	Wednesday, June 24, 2020	0.001	Passed	0.0160	Passed	
Dartmouth High School	Female Change Room tap 1 Room 165	MYV815	Wednesday, June 24, 2020	-	Passed	0.2900	Passed	
Dartmouth High School	Female Change Room tap 1 Room 165	MYV816	Wednesday, June 24, 2020	-	Passed	0.3600	Passed	
Dartmouth High School	Wash Room tap in water Room 170	MYV817	Wednesday, June 24, 2020	0.012	Exceeded	0.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Chem Lab tap 1 Room 106	MYV818	Wednesday, June 24, 2020	0.050	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Chem Lab tap 2 Room 106	MYV819	Wednesday, June 24, 2020	0.001	Passed	0.0280	Passed	
Dartmouth High School	Chem Lab tap 3 Room 106	MYV820	Wednesday, June 24, 2020	0.002	Passed	0.2800	Passed	
Dartmouth High School	Chem Lab tap 4 Room 106	MYV821	Wednesday, June 24, 2020	0.001	Passed	0.3800	Passed	
Dartmouth High School	Chem Lab tap 5 Room 106	MYV822	Wednesday, June 24, 2020	0.001	Passed	0.3900	Passed	
Dartmouth High School	Chem Lab tap 6 Room 106	MYV823	Wednesday, June 24, 2020	0.001	Passed	0.0890	Passed	
Dartmouth High School	Chem Lab tap 7 Room 106	MYV824	Wednesday, June 24, 2020	0.001	Passed	0.1700	Passed	
Dartmouth High School	Chem Lab tap 8 Room 106	MYV825	Wednesday, June 24, 2020	0.001	Passed	0.2500	Passed	
Dartmouth High School	Chem Lab tap 9 Room 106	MYV826	Wednesday, June 24, 2020	0.001	Passed	0.1700	Passed	
Dartmouth High School	Physics Lab tap 1 by Room 106	MYV827	Wednesday, June 24, 2020	0.007	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Physics Lab tap 2 by Room 106	MYV828	Wednesday, June 24, 2020	0.380	Exceeded	0.9700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Wash Room tap in physics Lab	MYV829	Wednesday, June 24, 2020	0.094	Exceeded	0.9700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Fountain near physics Lab	NMV158	Monday, August 31, 2020	0.000	Passed	0.0290	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Dartmouth High School	Boys Wash Room tap 1 near Room 106	MYV831	Wednesday, June 24, 2020	0.038	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Boys Wash Room tap 2 near Room 106	MYV832	Wednesday, June 24, 2020	0.550	Exceeded	3.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Boys Wash Room tap 3 near Room 106	MYV833	Wednesday, June 24, 2020	2.200	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Janitors Closet tap near Room 106	MYV834	Wednesday, June 24, 2020	0.001	Passed	0.0880	Passed	
Dartmouth High School	Girls Wash Room tap 1 near Room 106	MYV835	Wednesday, June 24, 2020	0.069	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Girls Wash Room tap 2 near Room 106	MYV836	Wednesday, June 24, 2020	0.073	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Girls Wash Room tap 3 near Room 106	MYV837	Wednesday, June 24, 2020	0.130	Exceeded	0.7200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Class Room tap Room 112	MYV838	Wednesday, June 24, 2020	1.700	Exceeded	18.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Class Room tap 1 Room 116	MYV839	Wednesday, June 24, 2020	0.280	Exceeded	0.6100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Class Room tap 2 Room 116	MYV840	Wednesday, June 24, 2020	0.005	Passed	0.1500	Passed	
Dartmouth High School	Class Room tap 3 Room 116	MYV841	Wednesday, June 24, 2020	0.140	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Class Room tap 4 Room 116	MYV842	Wednesday, June 24, 2020	0.043	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Fountain by Room 116	MYV843	Wednesday, June 24, 2020	-	Passed	0.5900	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Room 116	MYV844	Wednesday, June 24, 2020	0.002	Passed	1.6000	Passed	
Dartmouth High School	Girls Wash Room tap 2 by Room 116	MYV845	Wednesday, June 24, 2020	0.001	Passed	0.3100	Passed	
Dartmouth High School	Girls Wash Room tap 3 by Room 116	MYV846	Wednesday, June 24, 2020	0.001	Passed	0.1800	Passed	
Dartmouth High School	Girls Wash Room tap 4 by Room 116	MYV847	Wednesday, June 24, 2020	0.001	Passed	0.2100	Passed	
Dartmouth High School	Janitors Closet tap by Room 116	MYV848	Wednesday, June 24, 2020	-	Passed	1.1000	Passed	
Dartmouth High School	Boys Wash Room tap 1 by Room 116	MYV849	Wednesday, June 24, 2020	-	Passed	0.1900	Passed	
Dartmouth High School	Boys Wash Room tap 2 by Room 116	MYV850	Wednesday, June 24, 2020	0.013	Exceeded	0.7100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Boys Wash Room tap 3 by Room 116	MYV851	Wednesday, June 24, 2020	0.002	Passed	0.5300	Passed	
Dartmouth High School	Boys Wash Room tap 4 by Room 116	MYV852	Wednesday, June 24, 2020	0.003	Passed	0.1300	Passed	
Dartmouth High School	Learning Centre tap 1	MYV853	Wednesday, June 24, 2020	-	Passed	0.5600	Passed	
Dartmouth High School	Learning Centre tap 2	MYV854	Wednesday, June 24, 2020	-	Passed	0.4000	Passed	
Dartmouth High School	Boys Wash Room tap 1 after library	MYV855	Wednesday, June 24, 2020	0.001	Passed	0.0750	Passed	
Dartmouth High School	Boys Wash Room tap 2 after library	MYV856	Wednesday, June 24, 2020	-	Passed	0.1100	Passed	
Dartmouth High School	Fountain between Wash Room's	MYV857	Wednesday, June 24, 2020	-	Passed	0.9900	Passed	
Dartmouth High School	Girls Wash Room tap 1 after library	MYV858	Wednesday, June 24, 2020	0.001	Passed	0.0940	Passed	
Dartmouth High School	Girls Wash Room tap 2 after library	MYV859	Wednesday, June 24, 2020	0.001	Passed	0.2700	Passed	
Dartmouth High School	Music Room tap Room 125	MYV860	Wednesday, June 24, 2020	-	Passed	0.0620	Passed	
Dartmouth High School	Staff Room Wash Room 1 tap	MYV861	Wednesday, June 24, 2020	0.022	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Staff Room Wash Room 2 tap	MYV862	Wednesday, June 24, 2020	0.330	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Janitors Closet tap by Staff Room	MYV863	Wednesday, June 24, 2020	0.003	Passed	0.0820	Passed	
Dartmouth High School	Family Studies tap 1	QTB153	Friday, September 24, 2021	-	Passed	0.0840	Passed	Faucet remediated
Dartmouth High School	Family Studies tap 2	QTB154	Friday, September 24, 2021	-	Passed	0.0800	Passed	Faucet remediated
Dartmouth High School	Family Studies tap 3	QTB155	Friday, September 24, 2021	0.001	Passed	0.1000	Passed	Faucet remediated
Dartmouth High School	Family Studies tap 4	QTB156	Friday, September 24, 2021	0.001	0	0.0630	Exceeded	Faucet remediated
Dartmouth High School	Family Studies tap 5	QTB157	Friday, September 24, 2021	0.001	Passed	0.0750	Passed	Faucet remediated
Dartmouth High School	Class Room tap 2 Room 120	MYV870	Wednesday, June 24, 2020	0.001	Passed	0.1300	Passed	
Dartmouth High School	Class Room tap 2 Room 120	MYV871	Wednesday, June 24, 2020	0.001	Passed	0.1300	Passed	
Dartmouth High School	Tech Ed Room tap	MYV872	Wednesday, June 24, 2020	0.001	Passed	1.7000	Passed	
Dartmouth High School	Cafeteria/Kitchen tap 1	NMV159	Monday, August 31, 2020	0.000	Passed	0.0200	Passed	
Dartmouth High School	Cafeteria/Kitchen tap 2	NMV160	Monday, August 31, 2020	0.000	Passed	0.0220	Passed	
Dartmouth High School	Cafeteria/Kitchen tap 3	NMV161	Monday, August 31, 2020	0.000	Passed	0.0340	Passed	
Dartmouth High School	2nd Floor fountain before Room 251	MYV876	Wednesday, June 24, 2020	0.005	Exceeded	0.3500	Passed	New Fountain to be installed. Other sources available.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Dartmouth High School	tap in air handling Room 251	MYV877	Wednesday, June 24, 2020	0.034	Exceeded	0.0310	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Staff Wash Room sink tap before Room 213	MYV878	Wednesday, June 24, 2020	0.006	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Biology Lab tap 1 Room 213	MYV879	Wednesday, June 24, 2020	0.012	Exceeded	0.5100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Biology Lab tap 2 Room 213	MYV880	Wednesday, June 24, 2020	0.007	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Biology Lab tap 3 Room 213	MYV881	Wednesday, June 24, 2020	0.008	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Biology Lab tap 4 Room 213	MYV882	Wednesday, June 24, 2020	0.650	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Biology Lab tap 5 Room 213	MYV883	Wednesday, June 24, 2020	0.042	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Class Room tap Room 213A	MYV884	Wednesday, June 24, 2020	0.170	Exceeded	0.5400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Boys Wash Room tap 1 by Room 213	MYV885	Wednesday, June 24, 2020	0.012	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Boys Wash Room tap 2 by Room 213	MYV886	Wednesday, June 24, 2020	0.003	Passed	0.1100	Passed	
Dartmouth High School	Boys Wash Room tap 3 by Room 213	MYV887	Wednesday, June 24, 2020	0.002	Passed	0.1100	Passed	
Dartmouth High School	Janitors Closet tap by Room 213	MYV888	Wednesday, June 24, 2020	0.017	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Girls Wash Room tap 1 by Room 213	MYV889	Wednesday, June 24, 2020	0.009	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Girls Wash Room tap 2 by Room 213	MYV890	Wednesday, June 24, 2020	0.005	Passed	0.1200	Passed	
Dartmouth High School	Girls Wash Room tap 3 by Room 213	MYV891	Wednesday, June 24, 2020	0.004	Passed	0.1100	Passed	
Dartmouth High School	Girls Wash Room tap 4 by Room 213	MYV892	Wednesday, June 24, 2020	0.004	Passed	0.1100	Passed	
Dartmouth High School	Art Room tap Room 222	MYV893	Wednesday, June 24, 2020	0.013	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Class Room tap 1 Room 223	MYV894	Wednesday, June 24, 2020	0.002	Passed	0.2000	Passed	
Dartmouth High School	Class Room tap 2 Room 223	MYV895	Wednesday, June 24, 2020	0.001	Passed	0.4600	Passed	
Dartmouth High School	Music Storage tap Room 201	MYV896	Wednesday, June 24, 2020	0.460	Exceeded	3.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Fountain by Room 2017	MYV897	Wednesday, June 24, 2020	-	Passed	0.5800	Passed	
Dartmouth High School	Girls Wash Room tap 1 by Room 201	MYV898	Wednesday, June 24, 2020	0.001	Passed	0.3200	Passed	
Dartmouth High School	Girls Wash Room tap 2 by Room 201	MYV899	Wednesday, June 24, 2020	0.015	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Fountain by Room 201	MYV900	Wednesday, June 24, 2020	-	Passed	0.3400	Passed	
Dartmouth High School	Girls Wash Room tap 1 Near Room 201	MYV901	Wednesday, June 24, 2020	0.004	Passed	1.2000	Passed	
Dartmouth High School	Girls Wash Room tap 2 Near Room 201	MYV902	Wednesday, June 24, 2020	0.005	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Girls Wash Room tap 3 Near Room 201	MYV903	Wednesday, June 24, 2020	0.002	Passed	0.3300	Passed	
Dartmouth High School	Girls Wash Room tap 4 Near Room 201	MYV904	Wednesday, June 24, 2020	0.001	Passed	0.1500	Passed	
Dartmouth High School	Janitors Closet tap by Girls Wash Room	MYV905	Wednesday, June 24, 2020	0.006	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth High School	Boys Wash Room tap 1 before 2nd Floor Staff Room	MYV906	Wednesday, June 24, 2020	0.002	Passed	1.6000	Passed	
Dartmouth High School	Boys Wash Room tap 2 before 2nd Floor Staff Room	MYV907	Wednesday, June 24, 2020	0.001	Passed	0.6400	Passed	
Dartmouth High School	Boys Wash Room tap 3 before 2nd Floor Staff Room	MYV908	Wednesday, June 24, 2020	0.001	Passed	0.5100	Passed	
Dartmouth High School	Boys Wash Room tap 4 before 2nd Floor Staff Room	MYV909	Wednesday, June 24, 2020	0.001	Passed	0.5600	Passed	
Dartmouth High School	2nd Floor Staff Room tap 1	MYV910	Wednesday, June 24, 2020	-	Passed	0.1700	Passed	
Dartmouth High School	2nd Floor Staff Room tap 2	MYV911	Wednesday, June 24, 2020	0.002	Passed	0.1900	Passed	
Dartmouth High School	2nd Floor Staff Room tap 3	MYV912	Wednesday, June 24, 2020	0.001	Passed	0.1200	Passed	
Dartmouth High School	Boys Locker Room tap 2 Room 166	NAI301	Monday, June 29, 2020	-	Passed	0.2000	Passed	
Dartmouth High School	Gym Office Wash Room tap Room 161	NAI329	Monday, June 29, 2020	0.003	Passed	0.6500	Passed	
Dartmouth High School	Class Room tap 2 Room 120	NAI331	Monday, June 29, 2020	0.005	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Dartmouth Teachers Centre	Fountain by Meeting Room	QMI042	Wednesday, August 25, 2021	-	Passed	0.0370	Passed	Fountain replaced
Dartmouth Teachers Centre	Fountain by Basement Male Wash Room	QMI043	Wednesday, August 25, 2021	-	Passed	0.0520	Passed	Fountain replaced
Dartmouth South Academy	Main Office Wash Room tap	MYV778	Wednesday, June 24, 2020	-	Passed	0.5100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 140 tap	MYV779	Wednesday, June 24, 2020	-	Passed	0.0850	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 142 tap 1	MYV780	Wednesday, June 24, 2020	0.001	Passed	0.1100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 142 tap 2	MYV781	Wednesday, June 24, 2020	0.001	Passed	0.0940	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Dartmouth South Academy	Class Room 148 Wash Room tap 1	MYV782	Wednesday, June 24, 2020	-	Passed	0.0880	Passed	
Dartmouth South Academy	Class Room 148 Wash Room tap 2	MYV783	Wednesday, June 24, 2020	0.001	Passed	0.1200	Passed	
Dartmouth South Academy	Class Room 148 tap	MYV784	Wednesday, June 24, 2020	-	Passed	0.1600	Passed	
Dartmouth South Academy	Class Room 150 tap	MYV785	Wednesday, June 24, 2020	-	Passed	0.0480	Passed	
Dartmouth South Academy	Class Room 152 tap	MYV786	Wednesday, June 24, 2020	-	Passed	0.1200	Passed	
Dartmouth South Academy	Class Room 155 tap	MYV787	Wednesday, June 24, 2020	-	Passed	0.2400	Passed	
Dartmouth South Academy	Class Room 153 tap	MYV788	Wednesday, June 24, 2020	0.001	Passed	0.2400	Passed	
Dartmouth South Academy	Class Room 151 tap	MYV789	Wednesday, June 24, 2020	-	Passed	0.3400	Passed	
Dartmouth South Academy	Learning Centre Room 145 tap 1	MYV791	Wednesday, June 24, 2020	-	Passed	0.1200	Passed	
Dartmouth South Academy	Learning Centre Room 145 tap 2	MYV792	Wednesday, June 24, 2020	-	Passed	0.2000	Passed	
Dartmouth South Academy	Learning Centre Wash Room 145 tap	MYV793	Wednesday, June 24, 2020	-	Passed	0.0790	Passed	
Dartmouth South Academy	Janitors Closet Room 141 tap	MYV794	Wednesday, June 24, 2020	0.002	Passed	0.0890	Passed	
Dartmouth South Academy	Fountain by Room 135	MYV795	Wednesday, June 24, 2020	-	Passed	1.1000	Passed	
Dartmouth South Academy	Gym Change Room 133DB Wash Room tap	MYV797	Wednesday, June 24, 2020	0.001	Passed	0.2900	Passed	
Dartmouth South Academy	Gym Change Room 133DN tap	MYV798	Wednesday, June 24, 2020	0.001	Passed	0.1400	Passed	
Dartmouth South Academy	Gym Change Room 133 DA tap	MYV799	Wednesday, June 24, 2020	0.001	Passed	0.1800	Passed	
Dartmouth South Academy	Music Room 131 tap 1	MYV800	Wednesday, June 24, 2020	-	Passed	0.2000	Passed	
Dartmouth South Academy	Music Room 131 tap 2	NAI150	Monday, June 29, 2020	-	Passed	0.0830	Passed	
Dartmouth South Academy	Library Room 102 tap	NAI151	Monday, June 29, 2020	-	Passed	0.0840	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106E tap	NAI152	Monday, June 29, 2020	0.002	Passed	0.1100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106D tap	NAI153	Monday, June 29, 2020	-	Passed	0.0600	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106C tap	NAI154	Monday, June 29, 2020	0.001	Passed	0.0770	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106B tap	NAI155	Monday, June 29, 2020	-	Passed	0.0690	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 106A tap	NAI156	Monday, June 29, 2020	-	Passed	0.0520	Passed	
Dartmouth South Academy	Fountain by Room 110A	NAI157	Monday, June 29, 2020	-	Passed	1.8000	Passed	
Dartmouth South Academy	Tech Ed Room 108 tap	NAI158	Monday, June 29, 2020	-	Passed	0.1600	Passed	
Dartmouth South Academy	Janitors Closet Room 112 tap	NAI159	Monday, June 29, 2020	-	Passed	0.1400	Passed	
Dartmouth South Academy	Innovation Lab Room 114 tap	NAI163	Monday, June 29, 2020	-	Passed	1.6000	Passed	
Dartmouth South Academy	Youth Health Room 107 tap	NAI164	Monday, June 29, 2020	0.001	Passed	0.5200	Passed	
Dartmouth South Academy	Recycle Room 101A tap	NAI165	Monday, June 29, 2020	-	Passed	0.7400	Passed	
Dartmouth South Academy	Kitchen Room 103A tap 1	NAI166	Monday, June 29, 2020	-	Passed	0.6400	Passed	
Dartmouth South Academy	Kitchen Room 103A tap 2	NAI167	Monday, June 29, 2020	0.001	Passed	0.1800	Passed	
Dartmouth South Academy	Janitors Closet Room 103B tap	NAI168	Monday, June 29, 2020	-	Passed	0.3800	Passed	
Dartmouth South Academy	Staff Room 204 Kitchen tap	NAI169	Monday, June 29, 2020	-	Passed	0.0750	Passed	
Dartmouth South Academy	Staff Room Wash Room 204A tap	NAI170	Monday, June 29, 2020	0.002	Passed	0.1400	Passed	
Dartmouth South Academy	Staff Room Wash Room 204B tap	NAI171	Monday, June 29, 2020	0.001	Passed	0.0720	Passed	
Dartmouth South Academy	Fountain by Room 204	NAI172	Monday, June 29, 2020	-	Passed	1.3000	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206E tap	NAI174	Monday, June 29, 2020	0.001	Passed	0.0500	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206D tap	NAI175	Monday, June 29, 2020	0.002	Passed	0.0710	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206C tap	NAI176	Monday, June 29, 2020	0.001	Passed	0.1000	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206B tap	NAI177	Monday, June 29, 2020	0.001	Passed	0.0700	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 206A tap	NAI178	Monday, June 29, 2020	-	Passed	0.0800	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 1	NAI179	Monday, June 29, 2020	-	Passed	0.0900	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 2	NAI180	Monday, June 29, 2020	-	Passed	0.0870	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 3	NAI181	Monday, June 29, 2020	0.002	Passed	0.3900	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Dartmouth South Academy	Family Studies Room 208 tap 4	NAI182	Monday, June 29, 2020	-	Passed	0.7200	Passed	
Dartmouth South Academy	Family Studies Room 208 tap 5	NAI183	Monday, June 29, 2020	-	Passed	0.7700	Passed	
Dartmouth South Academy	Janitors Closet Room 214 tap	NAI190	Monday, June 29, 2020	-	Passed	0.2100	Passed	
Dartmouth South Academy	Art Room 230 tap 1	NAI191	Monday, June 29, 2020	0.002	Passed	0.1600	Passed	
Dartmouth South Academy	Art Room 230 tap 2	NAI192	Monday, June 29, 2020	0.001	Passed	0.1100	Passed	
Dartmouth South Academy	Art Room 230 tap 3	NAI193	Monday, June 29, 2020	-	Passed	0.8400	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 236 tap	NAI194	Monday, June 29, 2020	0.001	Passed	0.0700	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 238 tap 1	NAI195	Monday, June 29, 2020	0.001	Passed	0.1100	Passed	
Dartmouth South Academy	Gender Neutral Wash Room 238 tap 2	NAI196	Monday, June 29, 2020	0.001	Passed	0.2100	Passed	
Dartmouth South Academy	Class Room 244 tap	NAI197	Monday, June 29, 2020	-	Passed	0.3900	Passed	
Dartmouth South Academy	Class Room 251 tap	NAI199	Monday, June 29, 2020	-	Passed	0.4800	Passed	
Dartmouth South Academy	Class Room 247 tap	NAI200	Monday, June 29, 2020	0.002	Passed	1.2000	Passed	
Dartmouth South Academy	Class Room 245 tap	NAI206	Monday, June 29, 2020	-	Passed	0.4500	Passed	
Dartmouth South Academy	Class Room 241 tap	NAI207	Monday, June 29, 2020	-	Passed	0.0700	Passed	
Dartmouth South Academy	Learning Centre Wash Room 239 tap	NAI208	Monday, June 29, 2020	0.002	Passed	0.0530	Passed	
Dartmouth South Academy	Janitors Closet Room 231 tap	NAI209	Monday, June 29, 2020	-	Passed	0.0370	Passed	
Dartmouth South Academy	Fountain by Room 231	NAI210	Monday, June 29, 2020	-	Passed	1.5000	Passed	
Dartmouth South Academy	Class Room 149 tap	NAI211	Monday, June 29, 2020	-	Passed	0.2600	Passed	
Dartmouth South Academy	Gym Change Room 133DN tap	NAI212	Monday, June 29, 2020	-	Passed	1.2000	Passed	
Duc d'Anville Elementary School	Class Room tap Room 230	MRM311	Thursday, May 21, 2020	0.002	Passed	0.0670	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 1 by Room 230	MRM312	Thursday, May 21, 2020	-	Passed	0.0140	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 2 by Room 230	MRM313	Thursday, May 21, 2020	0.001	Passed	0.0170	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 3 by Room 230	MRM314	Thursday, May 21, 2020	0.001	Passed	0.0220	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 4 by Room 230	MRM315	Thursday, May 21, 2020	0.001	Passed	0.0250	Passed	
Duc d'Anville Elementary School	Caretaker Room tap in Boys Wash Room	MRM316	Thursday, May 21, 2020	0.067	Exceeded	0.0740	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Duc d'Anville Elementary School	Fountain by 2nd Floor Wash Rooms	NJI652	Friday, August 14, 2020	0.012	Exceeded	0.0470	Passed	Fountain Replacement in progress
Duc d'Anville Elementary School	Girls Wash Room tap 1 Room 250	MRM318	Thursday, May 21, 2020	0.001	Passed	0.0690	Passed	
Duc d'Anville Elementary School	Girls Wash Room tap 2 Room 250	MRM319	Thursday, May 21, 2020	-	Passed	0.0150	Passed	
Duc d'Anville Elementary School	Girls Wash Room tap 3 Room 250	MRM320	Thursday, May 21, 2020	-	Passed	0.0095	Passed	
Duc d'Anville Elementary School	Girls Wash Room tap 4 Room 250	MRM328	Thursday, May 21, 2020	-	Passed	0.0120	Passed	
Duc d'Anville Elementary School	Staff Room Wash Room tap Room 260	MRM329	Thursday, May 21, 2020	0.001	Passed	0.0480	Passed	
Duc d'Anville Elementary School	Staff Room Kitchen tap Room 260	MRM330	Thursday, May 21, 2020	-	Passed	0.0150	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 1 by Room 134	MRM331	Thursday, May 21, 2020	0.001	Passed	0.0780	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 2 by Room 134	MRM332	Thursday, May 21, 2020	-	Passed	0.0200	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 3 by Room 134	MRM333	Thursday, May 21, 2020	0.001	Passed	0.0140	Passed	
Duc d'Anville Elementary School	Gender Neutral Wash Room tap Room 146	MRM334	Thursday, May 21, 2020	0.008	Exceeded	0.0370	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Duc d'Anville Elementary School	Fountain by Room 146	MRM335	Thursday, May 21, 2020	0.001	Passed	0.0150	Passed	Fountain Replacement in progress
Duc d'Anville Elementary School	Girls Wash Room tap 1 Room 150	MRM336	Thursday, May 21, 2020	0.003	Passed	0.1200	Passed	
Duc d'Anville Elementary School	Girls Wash Room tap 2 Room 150	MRM337	Thursday, May 21, 2020	0.001	Passed	0.0096	Passed	
Duc d'Anville Elementary School	Girls Wash Room tap 3 Room 150	MRM339	Thursday, May 21, 2020	-	Passed	0.0150	Passed	
Duc d'Anville Elementary School	Resources Rm Wash Room tap Room 326	MRM340	Thursday, May 21, 2020	0.001	Passed	0.0200	Passed	
Duc d'Anville Elementary School	Janitors Closet tap by Room 326	MRM341	Thursday, May 21, 2020	0.001	Passed	0.0180	Passed	
Duc d'Anville Elementary School	Class Room tap Room 405	MRM342	Thursday, May 21, 2020	0.001	Passed	0.6000	Passed	
Duc d'Anville Elementary School	Gym Office 415 Wash Room tap	MRM343	Thursday, May 21, 2020	0.001	Passed	0.0400	Passed	
Duc d'Anville Elementary School	Janitors Closet tap by Room 415	MRM344	Thursday, May 21, 2020	0.001	Passed	0.0230	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Duc d'Anville Elementary School	Boys Wash Room tap 1 Room 421	MRM345	Thursday, May 21, 2020	0.001	Passed	0.0390	Passed	
Duc d'Anville Elementary School	Boys Wash Room tap 2 Room 421	MRM346	Thursday, May 21, 2020	0.001	Passed	0.0650	Passed	
Duc d'Anville Elementary School	Girls Wash Room tap 1 Room 425	MRM347	Thursday, May 21, 2020	-	Passed	0.0180	Passed	
Duc d'Anville Elementary School	Girls Wash Room tap 2 Room 425	MRM348	Thursday, May 21, 2020	0.001	Passed	0.0180	Passed	
Duc d'Anville Elementary School	Fountain by Room 320	NJI651	Friday, August 14, 2020	0.004	Passed	0.0470	Passed	Fountain Replacement in progress
Duc d'Anville Elementary School	Class Room Wash Room tap Room 312	MRM350	Thursday, May 21, 2020	0.004	Passed	0.0700	Passed	
Duc d'Anville Elementary School	Class Room Wash Room tap Room 311	MRM351	Thursday, May 21, 2020	0.001	Passed	0.0440	Passed	
Duc d'Anville Elementary School	Class Room Wash Room tap Room 306	MRM352	Thursday, May 21, 2020	0.003	Passed	0.0760	Passed	
Duc d'Anville Elementary School	Class Room Wash Room tap Room 307	MRM353	Thursday, May 21, 2020	0.001	Passed	0.0510	Passed	
Dutch Settlement Elementary School	Boys Wash Room 121 tap	MYZ477	Thursday, June 25, 2020	0.001	Passed	0.3800	Passed	
Dutch Settlement Elementary School	Janitors Closet 120 tap	MYZ478	Thursday, June 25, 2020	0.001	Passed	0.2300	Passed	
Dutch Settlement Elementary School	Girls Wash Room 119 tap 1	MYZ479	Thursday, June 25, 2020	0.002	Passed	0.5000	Passed	
Dutch Settlement Elementary School	Girls Wash Room 119 tap 2	MYZ480	Thursday, June 25, 2020	0.002	Passed	0.2600	Passed	
Dutch Settlement Elementary School	Staff Wash Room 112A tap	MYZ481	Thursday, June 25, 2020	0.003	Passed	0.2800	Passed	
Dutch Settlement Elementary School	Staff Kitchen 112 tap	MYZ482	Thursday, June 25, 2020	0.001	Passed	0.0990	Passed	
Dutch Settlement Elementary School	Class Room Wash Room 109 B tap	MYZ483	Thursday, June 25, 2020	0.001	Passed	0.2500	Passed	
Dutch Settlement Elementary School	Janitors Closet 104 tap	MYZ484	Thursday, June 25, 2020	0.001	Passed	0.0980	Passed	
Dutch Settlement Elementary School	Girls Wash Room 107 tap 1	PHC298	Thursday, April 8, 2021	-	Passed	0.0088	Passed	Faucet remediated.
Dutch Settlement Elementary School	Girls Wash Room 107 tap 2	MYZ510	Thursday, June 25, 2020	-	Passed	0.0570	Passed	
Dutch Settlement Elementary School	Boys Wash Room 105 tap 1	MYZ511	Thursday, June 25, 2020	0.001	Passed	0.0680	Passed	
Dutch Settlement Elementary School	Boys Wash Room 105 tap 2	MYZ512	Thursday, June 25, 2020	0.002	Passed	0.0540	Passed	
Dutch Settlement Elementary School	Kitchen 103 tap	MYZ513	Thursday, June 25, 2020	0.002	Passed	0.5800	Passed	
Dutch Settlement Elementary School	Class Room 102 Wash Room tap	MYZ514	Thursday, June 25, 2020	0.002	Passed	0.7000	Passed	
Dutch Settlement Elementary School	Gym Storage Room tap	PHC299	Thursday, April 8, 2021	-	Passed	0.0087	Passed	Faucet remediated.
Dutch Settlement Elementary School	Gym Office Wash Room tap	PHC300	Thursday, April 8, 2021	-	Exceeded	0.0210	Passed	Faucet remediated.
East St. Margaret's Elementary School	2nd Floor Boys Wash Room tap 1	MWH004	Friday, June 12, 2020	0.021	Exceeded	0.5500	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	2nd Floor Boys Wash Room tap 2	MWH005	Friday, June 12, 2020	0.032	Exceeded	0.8400	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	2nd Floor Girls Wash Room tap 1	MWH006	Friday, June 12, 2020	0.015	Exceeded	0.7400	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	2nd Floor Girls Wash Room tap 2	MWH007	Friday, June 12, 2020	0.032	Exceeded	2.4000	Exceeded	Signage added to instruct handwashing only
East St. Margaret's Elementary School	2nd Floor Girls Wash Room tap 3	MWH008	Friday, June 12, 2020	0.025	Exceeded	1.8000	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	2nd Floor Gender Neutral Wash Room 1 tap	MWH010	Friday, June 12, 2020	0.170	Exceeded	0.9000	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	2nd Floor Gender Neutral Wash Room 2 tap	MWH011	Friday, June 12, 2020	0.012	Exceeded	0.5700	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	1st Floor Girls Wash Room tap 1	MWH012	Friday, June 12, 2020	0.007	Exceeded	0.1800	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	1st Floor Girls Wash Room tap 2	MWH013	Friday, June 12, 2020	0.004	Passed	0.3600	Passed	
East St. Margaret's Elementary School	Class Room tap Room 11	MWH016	Friday, June 12, 2020	0.025	Exceeded	0.6600	Passed	Signage added to instruct handwashing only
East St. Margaret's Elementary School	Janitors Closet tap Room 5	MWH017	Friday, June 12, 2020	0.049	Exceeded	2.7000	Exceeded	Signage added to instruct handwashing only
Eastern Passage Education Centre	Class Room tap Room 1095	NCE082	Friday, July 10, 2020	-	Passed	0.0790	Passed	
Eastern Passage Education Centre	Class Room tap 1 Room 1091	NCE083	Friday, July 10, 2020	0.001	Passed	0.0710	Passed	
Eastern Passage Education Centre	Class Room tap 2 Room 1091	NCE084	Friday, July 10, 2020	0.001	Passed	0.0730	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 1	NCE085	Friday, July 10, 2020	0.001	Passed	28.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Science Lab Room 1086 tap 2	NCE086	Friday, July 10, 2020	-	Passed	0.6400	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 3	NCE087	Friday, July 10, 2020	-	Passed	0.2400	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 4	NCE088	Friday, July 10, 2020	-	Passed	0.5200	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 5	NCE089	Friday, July 10, 2020	-	Passed	0.1900	Passed	
Eastern Passage Education Centre	Science Lab Room 1086 tap 6	NCE090	Friday, July 10, 2020	0.001	Passed	8.7000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Eastern Passage Education Centre	Science Lab Room 1085 tap 1	NCE091	Friday, July 10, 2020	0.015	Exceeded	6.3000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Science Lab Room 1085 tap 2	NCE092	Friday, July 10, 2020	0.001	Passed	1.0000	Passed	
Eastern Passage Education Centre	Science Lab Room 1085 tap 3	NCE093	Friday, July 10, 2020	0.002	Passed	0.5200	Passed	
Eastern Passage Education Centre	Science Lab Room 1085 tap 4	NCE094	Friday, July 10, 2020	0.001	Passed	0.5300	Passed	
Eastern Passage Education Centre	Science Lab Room 1085 tap 5	NCE095	Friday, July 10, 2020	0.002	Passed	3.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Science Lab Room 1085 tap 6	NCE096	Friday, July 10, 2020	0.001	Passed	1.9000	Passed	
Eastern Passage Education Centre	Learning Centre Wash Room tap Room 1081	NCE097	Friday, July 10, 2020	0.002	Passed	0.2100	Passed	
Eastern Passage Education Centre	Learning Centre tap Room 1079	NCE098	Friday, July 10, 2020	-	Passed	0.3300	Passed	
Eastern Passage Education Centre	Class Room tap Room 1076	NCE099	Friday, July 10, 2020	-	Passed	2.3000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Class Room tap 1 Room 1072	NCE100	Friday, July 10, 2020	0.001	Passed	1.7000	Passed	
Eastern Passage Education Centre	Class Room tap 2 Room 1072	NCE101	Friday, July 10, 2020	0.001	Passed	3.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Janitors Closet tap Room 1100	NCE102	Friday, July 10, 2020	-	Passed	0.1900	Passed	
Eastern Passage Education Centre	Fountain by Room 1100	PXW842	Thursday, June 24, 2021	0.001	Passed	0.1980	Passed	Fountain replaced
Eastern Passage Education Centre	Gender Neutral Wash Room tap Room 1101	NCE104	Friday, July 10, 2020	0.001	Passed	2.7000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Music Room tap Room 1064	NMV188	Monday, August 31, 2020	0.001	Passed	0.0950	Passed	
Eastern Passage Education Centre	Art Room tap Room 1061	NCE106	Friday, July 10, 2020	0.001	Passed	0.5500	Passed	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 1	NCE107	Friday, July 10, 2020	0.001	Passed	0.3500	Passed	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 2	NCE108	Friday, July 10, 2020	0.002	Passed	0.3500	Passed	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 3	NCE109	Friday, July 10, 2020	0.001	Passed	0.2600	Passed	
Eastern Passage Education Centre	Girls Wash Room 1102 tap 4	NCE110	Friday, July 10, 2020	-	Passed	0.2300	Passed	
Eastern Passage Education Centre	Fountain by Room 1104	PXW482	Thursday, June 24, 2021	0.001	Passed	0.1900	Passed	Fountain replaced
Eastern Passage Education Centre	Male Wash Room 1103 tap 1	NCE112	Friday, July 10, 2020	0.002	Passed	0.1800	Passed	
Eastern Passage Education Centre	Male Wash Room 1103 tap 2	NCE113	Friday, July 10, 2020	0.001	Passed	0.1500	Passed	
Eastern Passage Education Centre	Male Wash Room 1103 tap 3	NCE114	Friday, July 10, 2020	0.002	Passed	0.3600	Passed	
Eastern Passage Education Centre	Male Wash Room 1103 tap 4	NCE115	Friday, July 10, 2020	0.001	Passed	0.2200	Passed	
Eastern Passage Education Centre	Fountain by Room 1056	NCE116	Friday, July 10, 2020	-	Passed	0.8600	Passed	
Eastern Passage Education Centre	Female Locker Room tap 1 Room 1043	NCE117	Friday, July 10, 2020	0.004	Passed	0.3400	Passed	
Eastern Passage Education Centre	Female Locker Room tap 2 Room 1043	NCE118	Friday, July 10, 2020	0.001	Passed	0.4800	Passed	
Eastern Passage Education Centre	Gym Office Wash Room tap Room 1046	NCE119	Friday, July 10, 2020	0.001	Passed	1.2000	Passed	
Eastern Passage Education Centre	Gym Office Wash Room tap Room 1048	NCE120	Friday, July 10, 2020	0.002	Passed	2.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Male Locker Room tap 1 Room 1050	NCE121	Friday, July 10, 2020	0.036	Exceeded	4.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Male Locker Room tap 2 Room 1050	NCE122	Friday, July 10, 2020	0.029	Exceeded	3.3000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Recycle Room tap Room 1038	NCE123	Friday, July 10, 2020	0.034	Exceeded	13.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Gender Neutral Wash Room tap Room 1037	NCE124	Friday, July 10, 2020	0.001	Passed	0.6600	Passed	
Eastern Passage Education Centre	Janitors Closet tap Room 1035	NCE125	Friday, July 10, 2020	0.002	Passed	0.5500	Passed	
Eastern Passage Education Centre	Gender Neutral Wash Room tap by Room 1029	NCE126	Friday, July 10, 2020	0.002	Passed	0.2300	Passed	
Eastern Passage Education Centre	Family Studies Room 1029 tap 1	NCE127	Friday, July 10, 2020	0.001	Passed	1.5000	Passed	
Eastern Passage Education Centre	Family Studies Room 1029 tap 2	NCE128	Friday, July 10, 2020	-	Passed	0.3400	Passed	
Eastern Passage Education Centre	Family Studies Room 1029 tap 3	NCE129	Friday, July 10, 2020	0.001	Passed	0.4400	Passed	
Eastern Passage Education Centre	Family Studies Room 1029 tap 4	NCE130	Friday, July 10, 2020	-	Passed	0.3200	Passed	
Eastern Passage Education Centre	Office Wash Room tap Room 1025	NCE131	Friday, July 10, 2020	-	Passed	0.1900	Passed	
Eastern Passage Education Centre	Fountain by Room 2036	PXW486	Thursday, June 24, 2021	0.001	Passed	0.1900	Passed	Fountain replaced
Eastern Passage Education Centre	Janitors Closet tap Room 2036	NCE133	Friday, July 10, 2020	-	Passed	0.1100	Passed	
Eastern Passage Education Centre	Tech ed Room 2029 tap	NCE134	Friday, July 10, 2020	-	Passed	3.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Staff Room Wash Room tap Room 2026	NCE135	Friday, July 10, 2020	0.001	Passed	0.4400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Eastern Passage Education Centre	Staff Room Wash Room tap Room 2027	NCE136	Friday, July 10, 2020	0.002	Passed	0.5500	Passed	
Eastern Passage Education Centre	Staff Room Kitchen tap Room 2025	NCE137	Friday, July 10, 2020	-	Passed	0.4600	Passed	
Eastern Passage Education Centre	Class Room tap Room 2065	NCE138	Friday, July 10, 2020	-	Passed	1.1000	Passed	
Eastern Passage Education Centre	Class Room tap 1 Room 2061	NCE139	Friday, July 10, 2020	0.005	Exceeded	11.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Class Room tap 2 Room 2061	NCE140	Friday, July 10, 2020	0.003	Passed	2.0000	Passed	
Eastern Passage Education Centre	Class Room tap Room 2058	NCE141	Friday, July 10, 2020	0.001	Passed	0.8500	Passed	
Eastern Passage Education Centre	Class Room tap 1 Room 2053	NCE142	Friday, July 10, 2020	-	Passed	5.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Class Room tap 2 Room 2053	NCE143	Friday, July 10, 2020	-	Passed	0.6900	Passed	
Eastern Passage Education Centre	Class Room tap Room 2050	NCE144	Friday, July 10, 2020	-	Passed	0.5300	Passed	
Eastern Passage Education Centre	Class Room tap 1 Room 2046	NCE145	Friday, July 10, 2020	0.001	Passed	4.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eastern Passage Education Centre	Class Room tap 2 Room 2046	NCE146	Friday, July 10, 2020	-	Passed	0.8700	Passed	
Eastern Passage Education Centre	Janitors Closet tap Room 2071	NCE147	Friday, July 10, 2020	0.001	Passed	0.1600	Passed	
Eastern Passage Education Centre	Fountain by Room 2072	NCE148	Friday, July 10, 2020	0.001	Passed	0.3800	Passed	
Eastern Passage Education Centre	Gender Neutral Wash Room tap Room 2072	NCE149	Friday, July 10, 2020	0.003	Passed	0.5100	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 1 by Room 2072	NCE150	Friday, July 10, 2020	0.001	Passed	0.3800	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 2 by Room 2072	NCE151	Friday, July 10, 2020	0.001	Passed	0.3600	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 2 by Room 2072	NCE152	Friday, July 10, 2020	0.001	Passed	0.4400	Passed	
Eastern Passage Education Centre	Boys Wash Room tap 3 by Room 2072	NCE153	Friday, July 10, 2020	0.002	Passed	0.3000	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 1 by Room 2074	NCE154	Friday, July 10, 2020	0.003	Passed	0.5600	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 2 by Room 2074	NCE155	Friday, July 10, 2020	0.004	Passed	0.6200	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 3 by Room 2074	NCE156	Friday, July 10, 2020	0.002	Passed	0.5100	Passed	
Eastern Passage Education Centre	Girls Wash Room tap 4 by Room 2074	NCE157	Friday, July 10, 2020	0.005	Passed	0.2000	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by Room 225	NAI278	Friday, June 26, 2020	0.005	Passed	0.1300	Passed	
Eastern Shore District High School	Girls Wash Room tap 2 by Room 225	NAI279	Friday, June 26, 2020	0.180	Exceeded	0.1900	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Janitors Closet tap by Room 225	NAI280	Friday, June 26, 2020	0.025	Exceeded	0.1500	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Fountain by Room 225	NAI281	Friday, June 26, 2020	0.031	Exceeded	0.1100	Passed	New Fountain to be installed. Other sources available.
Eastern Shore District High School	Boys Wash Room tap 1 by Room 224	NAI282	Friday, June 26, 2020	0.005	Exceeded	0.0600	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Boys Wash Room tap 2 by Room 224	NAI283	Friday, June 26, 2020	0.230	Exceeded	0.2400	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Class Room tap Room 220	NAI284	Friday, June 26, 2020	0.002	Passed	0.2400	Passed	
Eastern Shore District High School	Sci. Lab tap 1 Room 217	NAI285	Friday, June 26, 2020	0.025	Exceeded	0.1100	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 2 Room 217	NAI286	Friday, June 26, 2020	0.002	Passed	0.2600	Passed	
Eastern Shore District High School	Sci. Lab tap 3 Room 217	NAI287	Friday, June 26, 2020	0.019	Exceeded	0.5700	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 4 Room 217	NAI291	Friday, June 26, 2020	0.002	Passed	0.2600	Passed	
Eastern Shore District High School	Sci. Lab tap 5 Room 217	NAI292	Friday, June 26, 2020	0.004	Passed	0.3700	Passed	
Eastern Shore District High School	Sci. Lab tap 6 Room 217	NAI293	Friday, June 26, 2020	0.003	Passed	0.4000	Passed	
Eastern Shore District High School	Sci. Lab tap 1a Room 217	NAI294	Friday, June 26, 2020	0.023	Exceeded	0.3000	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 2a Room 217	NAI295	Friday, June 26, 2020	0.005	Exceeded	0.2600	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 3a Room 217	NAI296	Friday, June 26, 2020	0.015	Exceeded	0.3200	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 4a Room 217	NAI297	Friday, June 26, 2020	0.005	Passed	0.3000	Passed	
Eastern Shore District High School	Sci. Lab tap 5a Room 217	NAI298	Friday, June 26, 2020	0.012	Exceeded	0.4800	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 6a Room 217	NAI299	Friday, June 26, 2020	0.003	Passed	0.1100	Passed	
Eastern Shore District High School	Sci. Lab tap 1b Room 217	NAI300	Friday, June 26, 2020	0.006	Exceeded	0.4000	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 2b Room 217	NAI303	Friday, June 26, 2020	0.017	Exceeded	0.5100	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 3b Room 217	NAI304	Friday, June 26, 2020	0.120	Exceeded	0.3700	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 4b Room 217	NAI305	Friday, June 26, 2020	0.002	Passed	0.2800	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Eastern Shore District High School	Sci. Lab tap 5b Room 217	NAI306	Friday, June 26, 2020	0.014	Exceeded	0.4100	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 6b Room 217	NAI307	Friday, June 26, 2020	0.002	Passed	0.2300	Passed	
Eastern Shore District High School	Sci. Lab tap 1c Room 217	NAI308	Friday, June 26, 2020	0.010	Exceeded	0.5900	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 2c Room 217	NAI309	Friday, June 26, 2020	0.055	Exceeded	0.2000	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 3c Room 217	NAI310	Friday, June 26, 2020	0.004	Passed	0.4300	Passed	
Eastern Shore District High School	Sci. Lab tap 1 Room 219	NAI311	Friday, June 26, 2020	0.012	Exceeded	0.3500	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 2 Room 219	NAI312	Friday, June 26, 2020	0.041	Exceeded	4.6000	Exceeded	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 3 Room 219	NAI332	Friday, June 26, 2020	0.008	Exceeded	0.2400	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 4 Room 219	NAI333	Friday, June 26, 2020	0.023	Exceeded	2.0000	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 5 Room 219	NAI334	Friday, June 26, 2020	0.017	Exceeded	0.5800	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 6 Room 219	NAI335	Friday, June 26, 2020	0.006	Exceeded	0.0930	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Sci. Lab tap 1a Room 219	NAI336	Friday, June 26, 2020	0.011	Exceeded	0.2700	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Staff Wash Room tap 1 Room 201a	NAI337	Friday, June 26, 2020	0.009	Exceeded	0.0450	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Staff Wash Room tap 2 Room 201a	NAI338	Friday, June 26, 2020	0.005	Passed	0.0300	Passed	
Eastern Shore District High School	Class Room tap Room 201A	NAI339	Friday, June 26, 2020	0.006	Exceeded	0.3900	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Boys Wash Room tap 1 by Room 202	NAI340	Friday, June 26, 2020	0.009	Exceeded	0.1400	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Boys Wash Room tap 2 by Room 202	NAI341	Friday, June 26, 2020	0.011	Exceeded	0.1100	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Boys Wash Room tap 3 by Room 202	NAI347	Friday, June 26, 2020	0.059	Exceeded	0.1800	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Fountain by Boys Wash Room	NAI348	Friday, June 26, 2020	0.011	Exceeded	0.0550	Passed	New Fountain to be installed. Other sources available.
Eastern Shore District High School	Staff Wash Room tap by Janitors Closet	NAI349	Friday, June 26, 2020	0.011	Exceeded	0.0530	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Janitors Closet in Janitors sink Room	NAI350	Friday, June 26, 2020	0.001	Passed	0.0740	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by Room 201c	NAI351	Friday, June 26, 2020	0.210	Exceeded	0.1700	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Girls Wash Room tap 2 by Room 201c	NAI352	Friday, June 26, 2020	0.380	Exceeded	0.4600	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Girls Wash Room tap 3 by Room 201c	NAI353	Friday, June 26, 2020	0.670	Exceeded	0.4700	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Double compartment sink tap Room 212	NAI354	Friday, June 26, 2020	0.001	Passed	0.0910	Passed	
Eastern Shore District High School	Single compartment sink tap Room 212	NAI355	Friday, June 26, 2020	0.004	Passed	0.1700	Passed	
Eastern Shore District High School	Gender Neutral Wash Room tap Room 212	NAI356	Friday, June 26, 2020	0.019	Exceeded	0.1500	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Class Room tap Room 213	NAI360	Friday, June 26, 2020	0.060	Exceeded	0.6400	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Class Room tap Room 123b	NAI361	Friday, June 26, 2020	0.003	Passed	0.6200	Passed	
Eastern Shore District High School	Class Room tap Room 122	NAI362	Friday, June 26, 2020	0.005	Passed	0.1900	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by Janitors Closet Room C	NAI363	Friday, June 26, 2020	0.350	Exceeded	0.1100	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Girls Wash Room tap 2 by Janitors Closet Room C	NAI364	Friday, June 26, 2020	0.002	Passed	0.0890	Passed	
Eastern Shore District High School	Janitors Closet tap in Janitors Closet Room c	NAI365	Friday, June 26, 2020	0.057	Exceeded	0.1800	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Fountain by Janitors Room C	NAI366	Friday, June 26, 2020	0.043	Exceeded	0.7800	Passed	New Fountain to be installed. Other sources available.
Eastern Shore District High School	Boys Wash Room tap by Room 119a	NAI367	Friday, June 26, 2020	0.002	Passed	0.0490	Passed	
Eastern Shore District High School	Class Room tap Room 116	NAI368	Friday, June 26, 2020	0.003	Passed	0.1400	Passed	
Eastern Shore District High School	Gym Office Wash Room tap	NAI369	Friday, June 26, 2020	0.004	Passed	0.6700	Passed	
Eastern Shore District High School	Main Office Wash Room tap Room 1081	NAI372	Friday, June 26, 2020	0.021	Exceeded	0.4600	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Gender Neutral Wash Room 1 tap in youth Centre R	NAI373	Friday, June 26, 2020	0.001	Passed	0.5100	Passed	
Eastern Shore District High School	Gender Neutral Wash Room 2 tap in youth Centre R	NAI374	Friday, June 26, 2020	-	Passed	0.2900	Passed	
Eastern Shore District High School	Boys Wash Room tap 1 by fountain	NAI375	Friday, June 26, 2020	0.005	Passed	0.2600	Passed	
Eastern Shore District High School	Boys Wash Room tap 2 by fountain	NAI376	Friday, June 26, 2020	0.008	Exceeded	0.4100	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Boys Wash Room tap 3 by fountain	NAI377	Friday, June 26, 2020	0.006	Exceeded	0.2800	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Staff Wash Room tap by caretakers Office	NAI378	Friday, June 26, 2020	0.003	Passed	0.1500	Passed	
Eastern Shore District High School	Janitors Closet tap in caretakers Office	NAI379	Friday, June 26, 2020	-	Passed	0.0410	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Eastern Shore District High School	Fountain by Boys Wash Room	NAI380	Friday, June 26, 2020	0.002	Passed	0.1200	Passed	
Eastern Shore District High School	Girls Wash Room tap 1 by main Office	NAI381	Friday, June 26, 2020	0.008	Exceeded	0.6800	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Girls Wash Room tap 2 by main Office	NAI388	Friday, June 26, 2020	0.039	Exceeded	0.4300	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Girls Wash Room tap 3 by main Office	NAI389	Friday, June 26, 2020	0.007	Exceeded	0.4100	Passed	Signage added to instruct handwashing only
Eastern Shore District High School	Fountain by Girls Wash Room	NAI390	Friday, June 26, 2020	0.009	Exceeded	0.3100	Passed	New Fountain to be installed. Other sources available.
Eastern Shore District High School	Single compartment sink 1 tap Room 113	NAI391	Friday, June 26, 2020	0.001	Passed	0.0710	Passed	
Eastern Shore District High School	Single compartment sink 2 tap Room 113	NK1511	Wednesday, August 19, 2020	0.000	Passed	0.0360	Passed	
Eastern Shore District High School	Double compartment sink tap Room 113	NAI393	Friday, June 26, 2020	0.002	Passed	0.1900	Passed	
Ecole Beaufort (SIAM)	Class Room 217 tap	QH089	Thursday, August 5, 2021	-	Passed	0.0800	Passed	
Ecole Beaufort (SIAM)	Fountain by Room 204	QH090	Thursday, August 5, 2021	0.001	Passed	0.3000	Passed	
Ecole Beaufort (SIAM)	Janitors Closet 104 tap	QH091	Thursday, August 5, 2021	-	Passed	0.0440	Passed	
Ecole Beaufort (SIAM)	Girls Wash Room 105 tap 1	QH092	Thursday, August 5, 2021	-	Passed	0.0640	Passed	
Ecole Beaufort (SIAM)	Girls Wash Room 105 tap 2	QH093	Thursday, August 5, 2021	-	Passed	0.0420	Passed	
Ecole Beaufort (SIAM)	Girls Wash Room 105 tap 3	QH094	Thursday, August 5, 2021	-	Passed	0.0410	Passed	
Ecole Beaufort (SIAM)	Class Room 106 tap	QH095	Thursday, August 5, 2021	-	Passed	0.0620	Passed	
Ecole Beaufort (SIAM)	Gender Neutral Wash Room 110 tap	QH096	Thursday, August 5, 2021	-	Passed	0.0390	Passed	
Ecole Beaufort (SIAM)	Gender Neutral Wash Room 216 tap	QH097	Thursday, August 5, 2021	-	Passed	0.0580	Passed	
Ecole Beaufort (SIAM)	Class Room 212 Wash Room tap	QH098	Thursday, August 5, 2021	-	Passed	0.0710	Passed	
Ecole Beaufort (SIAM)	Staff Room Wash Room tap	QH099	Thursday, August 5, 2021	-	Passed	0.0520	Passed	
Ecole Beaufort (SIAM)	Fountain by Room 204	QH100	Thursday, August 5, 2021	0.001	Passed	0.2300	Passed	
Ecole Beaufort (SIAM)	Janitors Closet 204 tap	QH101	Thursday, August 5, 2021	-	Passed	0.0300	Passed	
Ecole Beaufort (SIAM)	Boys Wash Room tap 1	QH102	Thursday, August 5, 2021	0.002	Passed	0.2200	Passed	
Ecole Beaufort (SIAM)	Boys Wash Room tap 2	QH103	Thursday, August 5, 2021	0.001	Passed	0.3100	Passed	
Ecole Beaufort (SIAM)	Gender Neutral Wash Room 209	QH104	Thursday, August 5, 2021	0.001	Passed	0.2700	Passed	
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 1	QH105	Thursday, August 5, 2021	0.001	Passed	0.0570	Passed	
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 2	QH106	Thursday, August 5, 2021	-	Passed	0.0190	Passed	
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 3	QH107	Thursday, August 5, 2021	0.001	Passed	0.0180	Passed	
Ecole Beaufort (SIAM)	Basement Boys Wash Room tap 4	QH108	Thursday, August 5, 2021	-	Passed	0.0150	Passed	
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 1	QH109	Thursday, August 5, 2021	0.002	Passed	0.0570	Passed	
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 2	QH110	Thursday, August 5, 2021	0.002	Passed	0.0300	Passed	
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 3	QH111	Thursday, August 5, 2021	0.002	Passed	0.0240	Passed	
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 4	QH112	Thursday, August 5, 2021	0.001	Passed	0.0160	Passed	
Ecole Beaufort (SIAM)	Basement Girls Wash Room tap 5	QH113	Thursday, August 5, 2021	0.001	Passed	0.0120	Passed	
Ecole Beaufort (SIAM)	Basement Caretakers Office tap	QH114	Thursday, August 5, 2021	-	Passed	0.0160	Passed	
Ecole Beaufort (SIAM)	Hallway Sink by Room B203 tap	QH115	Thursday, August 5, 2021	0.001	Passed	0.0150	Passed	
Ecole Beaufort (SIAM)	Fountain by Room B203	QH116	Thursday, August 5, 2021	0.003	Passed	0.1900	Passed	
Ecole Beaufort (SIAM)	Gender Neutral Wash Room B203 tap	QH117	Thursday, August 5, 2021	-	Passed	0.0100	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 1 by fan Room	MQZ703	Wednesday, May 20, 2020	0.001	Passed	0.1100	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 2 by fan Room	MQZ704	Wednesday, May 20, 2020	0.001	Passed	0.0660	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 3 by fan Room	MQZ705	Wednesday, May 20, 2020	0.001	Passed	0.0670	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 4 by fan Room	MQZ706	Wednesday, May 20, 2020	0.001	Passed	0.0620	Passed	
Elizabeth Sutherland School	Janitors Closet tap by Room 7	MQZ707	Wednesday, May 20, 2020	0.002	Passed	0.0810	Passed	
Elizabeth Sutherland School	Fountain by Janitors Closet	MQZ708	Wednesday, May 20, 2020	0.001	Passed	0.4700	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 1 by Janitors Closet	MQZ709	Wednesday, May 20, 2020	0.002	Passed	0.0740	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 2 by Janitors Closet	MQZ710	Wednesday, May 20, 2020	0.009	Exceeded	0.0900	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Elizabeth Sutherland School	Boys Wash Room tap 3 by Janitors Closet	MQZ711	Wednesday, May 20, 2020	0.009	Exceeded	0.0630	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Boys Wash Room tap 4 by Janitors Closet	MQZ712	Wednesday, May 20, 2020	0.003	Passed	0.0590	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 1 by canteen	MQZ713	Wednesday, May 20, 2020	0.008	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Girls Wash Room tap 2 by canteen	MQZ714	Wednesday, May 20, 2020	0.006	Exceeded	0.0860	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Girls Wash Room tap 3 by canteen	MQZ715	Wednesday, May 20, 2020	0.001	Passed	0.0360	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 4 by canteen	MQZ716	Wednesday, May 20, 2020	0.007	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Janitors Closet tap by canteen	MQZ717	Wednesday, May 20, 2020	-	Passed	0.0140	Passed	
Elizabeth Sutherland School	Fountain by canteen	MQZ718	Wednesday, May 20, 2020	0.003	Passed	0.6100	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 1 next to canteen	MQZ719	Wednesday, May 20, 2020	0.011	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Boys Wash Room tap 2 next to canteen	MQZ720	Wednesday, May 20, 2020	0.052	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Boys Wash Room tap 3 next to canteen	MQZ721	Wednesday, May 20, 2020	0.012	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Boys Wash Room tap 4 next to canteen	MQZ722	Wednesday, May 20, 2020	0.005	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Caretaker Room tap	MQZ723	Wednesday, May 20, 2020	0.001	Passed	0.0690	Passed	
Elizabeth Sutherland School	Art Room Kitchen tap 1	MQZ724	Wednesday, May 20, 2020	0.020	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Art Room Kitchen tap 2	MQZ725	Wednesday, May 20, 2020	0.001	Passed	0.0330	Passed	
Elizabeth Sutherland School	Music Room Kitchen tap	NKX243	Friday, August 21, 2020	0.000	Passed	0.0190	Passed	
Elizabeth Sutherland School	Staff Room Wash Room tap 1	MQZ727	Wednesday, May 20, 2020	-	Passed	0.0170	Passed	
Elizabeth Sutherland School	Staff Room Wash Room tap 2	MQZ728	Wednesday, May 20, 2020	-	Passed	0.0170	Passed	
Elizabeth Sutherland School	Staff Room Wash Room tap 3	MQZ729	Wednesday, May 20, 2020	0.012	Exceeded	0.5900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Resource Centre Kitchen tap	NKX244	Friday, August 21, 2020	0.000	Passed	0.0170	Passed	
Elizabeth Sutherland School	Science Room island sink tap	MQZ733	Wednesday, May 20, 2020	0.014	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Girls Wash Room tap 1 by Gym	MQZ734	Wednesday, May 20, 2020	0.001	Passed	0.0820	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 2 by Gym	MQZ735	Wednesday, May 20, 2020	0.001	Passed	0.0860	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 3 by Gym	MQZ736	Wednesday, May 20, 2020	0.001	Passed	0.0890	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 4 by Gym	MQZ737	Wednesday, May 20, 2020	-	Passed	0.0790	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 6 by Gym	MQZ738	Wednesday, May 20, 2020	0.002	Passed	0.0840	Passed	
Elizabeth Sutherland School	Fountain by Gym	MQZ739	Wednesday, May 20, 2020	0.001	Passed	0.1900	Passed	
Elizabeth Sutherland School	Janitors Closet tap by Gym	MQZ740	Wednesday, May 20, 2020	0.002	Passed	0.0770	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 1 by Gym	MQZ741	Wednesday, May 20, 2020	0.005	Exceeded	0.0560	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Boys Wash Room tap 2 by Gym	MQZ742	Wednesday, May 20, 2020	0.003	Passed	0.0350	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 3 by Gym	MQZ743	Wednesday, May 20, 2020	0.001	Passed	0.0230	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 4 by Gym	MQZ744	Wednesday, May 20, 2020	0.004	Passed	0.0360	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 5 by Gym	MQZ745	Wednesday, May 20, 2020	0.001	Passed	0.0920	Passed	
Elizabeth Sutherland School	Boys Wash Room tap 6 by Gym	MQZ746	Wednesday, May 20, 2020	0.002	Passed	0.0240	Passed	
Elizabeth Sutherland School	Boys Locker Room tap 1	MQZ747	Wednesday, May 20, 2020	0.001	Passed	0.0970	Passed	
Elizabeth Sutherland School	Boys Locker Room tap 2	MQZ748	Wednesday, May 20, 2020	0.001	Passed	0.0560	Passed	
Elizabeth Sutherland School	Girls Locker Room tap 1	NKX242	Friday, August 21, 2020	0.000	Passed	0.0130	Passed	
Elizabeth Sutherland School	Girls Locker Room tap 2	MQZ750	Wednesday, May 20, 2020	0.001	Passed	0.0150	Passed	
Elizabeth Sutherland School	Girls Locker Room tap 3	MQZ751	Wednesday, May 20, 2020	0.004	Passed	0.0900	Passed	
Elizabeth Sutherland School	Fountain by main Office	MQZ758	Wednesday, May 20, 2020	-	Passed	0.2800	Passed	
Elizabeth Sutherland School	Food Lab tap 1	MQZ759	Wednesday, May 20, 2020	-	Passed	0.0980	Passed	
Elizabeth Sutherland School	Food Lab tap 2	MQZ760	Wednesday, May 20, 2020	-	Passed	0.0230	Passed	
Elizabeth Sutherland School	Food Lab tap 3	MQZ761	Wednesday, May 20, 2020	0.001	Passed	0.0940	Passed	
Elizabeth Sutherland School	Food Lab tap 4	MQZ762	Wednesday, May 20, 2020	0.002	Passed	0.0420	Passed	
Elizabeth Sutherland School	Health Room Wash Room tap	MQZ763	Wednesday, May 20, 2020	0.001	Passed	0.0300	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Elizabeth Sutherland School	Health Room Kitchen tap	MQZ764	Wednesday, May 20, 2020	-	Passed	0.0180	Passed	
Elizabeth Sutherland School	Science Room bath sink tap	MRV247	Friday, May 22, 2020	0.018	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Elizabeth Sutherland School	Science Room Closet sink tap	MRV248	Friday, May 22, 2020	0.002	Passed	0.0650	Passed	
Elizabeth Sutherland School	Girls Wash Room tap 5 by Gym	MRV249	Friday, May 22, 2020	-	Passed	0.0660	Passed	
Ellenvale Junior High School	Chem Lab tap 1 Room 208	MVH128	Tuesday, June 9, 2020	0.001	Passed	0.0400	Passed	
Ellenvale Junior High School	Chem Lab tap 2 Room 208	MVH129	Tuesday, June 9, 2020	-	Passed	0.0069	Passed	
Ellenvale Junior High School	Chem Lab tap 3 Room 208	MVH130	Tuesday, June 9, 2020	-	Passed	0.0140	Passed	
Ellenvale Junior High School	Chem Lab tap 4 Room 208	MVH131	Tuesday, June 9, 2020	0.002	Passed	0.1200	Passed	
Ellenvale Junior High School	Chem Lab tap 5 Room 208	MVH132	Tuesday, June 9, 2020	0.001	Passed	0.0280	Passed	
Ellenvale Junior High School	Fountain by back staircase	MVH133	Tuesday, June 9, 2020	-	Passed	0.3900	Passed	
Ellenvale Junior High School	Kitchen sink tap 1 Room 211	NLK026	Monday, August 24, 2020	0.002	Passed	0.0050	Passed	
Ellenvale Junior High School	Kitchen sink tap 2 Room 211	MVH135	Tuesday, June 9, 2020	0.005	Passed	0.2100	Passed	
Ellenvale Junior High School	Kitchen sink tap 3 Room 211	MVH136	Tuesday, June 9, 2020	0.003	Passed	0.2400	Passed	
Ellenvale Junior High School	Kitchen sink tap 4 Room 211	NLK027	Monday, August 24, 2020	0.000	Passed	0.0090	Passed	
Ellenvale Junior High School	Kitchen sink tap 5 Room 211	MVH138	Tuesday, June 9, 2020	0.002	Passed	0.4400	Passed	
Ellenvale Junior High School	Kitchen sink tap 6 Room 211	MVH139	Tuesday, June 9, 2020	0.003	Passed	0.4000	Passed	
Ellenvale Junior High School	Staff Wash Room by Room 212	MVH140	Tuesday, June 9, 2020	0.001	Passed	0.0890	Passed	
Ellenvale Junior High School	Class Room tap Room 219	NLK028	Monday, August 24, 2020	0.000	Passed	0.0160	Passed	
Ellenvale Junior High School	Fountain by 201	MVH142	Tuesday, June 9, 2020	0.002	Passed	0.0690	Passed	
Ellenvale Junior High School	Fountain by 219	MVH143	Tuesday, June 9, 2020	0.002	Passed	0.1500	Passed	
Ellenvale Junior High School	2nd Floor Girls Wash Room tap 1 by front staircase	MVH144	Tuesday, June 9, 2020	0.002	Passed	0.2800	Passed	
Ellenvale Junior High School	2nd Floor Girls Wash Room tap 2 by front staircase	MVH145	Tuesday, June 9, 2020	0.015	Exceeded	0.5300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	2nd Floor Girls Wash Room tap 3 by front staircase	MVH146	Tuesday, June 9, 2020	0.012	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	Janitors Closet tap by Girls Wash Room	MVH147	Tuesday, June 9, 2020	0.001	Passed	0.0910	Passed	
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 1 by Room 220	MVH148	Tuesday, June 9, 2020	0.005	Passed	0.2600	Passed	
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 2 by Room 220	MVH149	Tuesday, June 9, 2020	0.007	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 3 by Room 220	MVH150	Tuesday, June 9, 2020	0.003	Passed	0.3900	Passed	
Ellenvale Junior High School	2nd Floor Boys Wash Room tap 4 by Room 220	MVH151	Tuesday, June 9, 2020	0.011	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	Staff Wash Room inside Room 101	MVH152	Tuesday, June 9, 2020	0.016	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	Staff Kitchen sink tap Room 103	MVH153	Tuesday, June 9, 2020	0.002	Passed	0.2400	Passed	
Ellenvale Junior High School	Male Staff Wash Room tap Room 103	MVH154	Tuesday, June 9, 2020	0.008	Exceeded	0.7900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	Female Staff Wash Room tap Room 103	MVH155	Tuesday, June 9, 2020	0.004	Passed	0.0950	Passed	
Ellenvale Junior High School	Fountain by Room 103	MVH156	Tuesday, June 9, 2020	-	Passed	0.2700	Passed	
Ellenvale Junior High School	Janitors Closet tap by Room 105	MVH157	Tuesday, June 9, 2020	-	Passed	0.0270	Passed	
Ellenvale Junior High School	Class Room tap Room 105	NLK024	Monday, August 24, 2020	0.007	Exceeded	0.0520	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	Gender Neutral Wash Room tap Room 105	MVH159	Tuesday, June 9, 2020	0.003	Passed	0.0420	Passed	
Ellenvale Junior High School	Laundry tub tap Room 109	MVH160	Tuesday, June 9, 2020	-	Passed	0.0200	Passed	
Ellenvale Junior High School	Laundry tub tap Room 111	NLK023	Monday, August 24, 2020	0.001	Passed	0.0150	Passed	
Ellenvale Junior High School	Class Room tap Room 110	NLK025	Monday, August 24, 2020	0.001	Passed	0.0150	Passed	
Ellenvale Junior High School	Fountain by Room 110	MVH163	Tuesday, June 9, 2020	0.004	Passed	0.7000	Passed	
Ellenvale Junior High School	Class Room tap Room 112	MVH164	Tuesday, June 9, 2020	-	Passed	0.0500	Passed	
Ellenvale Junior High School	Gender Neutral Wash Room tap Room 118	MVH165	Tuesday, June 9, 2020	0.010	Exceeded	0.7200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	Gender Neutral Wash Room tap Room 119	MVH166	Tuesday, June 9, 2020	0.005	Exceeded	0.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	Fountain by Room 116	MVH167	Tuesday, June 9, 2020	0.001	Passed	0.1300	Passed	
Ellenvale Junior High School	1st Floor Girls Wash Room tap 1 by front staircase	MVH168	Tuesday, June 9, 2020	0.018	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Ellenvale Junior High School	1st Floor Girls Wash Room tap 2 by front staircase	MVH169	Tuesday, June 9, 2020	0.008	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	1st Floor Girls Wash Room tap 3 by front staircase	MVH170	Tuesday, June 9, 2020	0.005	Passed	0.2300	Passed	
Ellenvale Junior High School	1st Floor Girls Wash Room tap 4 by front staircase	MVH171	Tuesday, June 9, 2020	0.005	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	1st Floor Boys Wash Room tap 1 by Room 101	MVH172	Tuesday, June 9, 2020	0.010	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	1st Floor Boys Wash Room tap 2 by Room 101	MVH173	Tuesday, June 9, 2020	0.010	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	1st Floor Boys Wash Room tap 3 by Room 101	MVH174	Tuesday, June 9, 2020	0.012	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ellenvale Junior High School	1st Floor Boys Wash Room tap 4 by Room 101	MVH175	Tuesday, June 9, 2020	0.014	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Family Studies tap 1 Room 201	NLS532	Monday, August 24, 2020	0.001	Passed	0.0100	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 2 Room 201	MVH191	Tuesday, June 9, 2020	0.005	Passed	0.2500	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 3 Room 201	NLS533	Monday, August 24, 2020	0.001	Passed	0.0200	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 4 Room 201	NLS534	Monday, August 24, 2020	0.002	Passed	0.0190	Passed	
Eric Graves Memorial Junior High School	Family Studies tap 5 Room 201	NLS535	Monday, August 24, 2020	0.002	Passed	0.0210	Passed	
Eric Graves Memorial Junior High School	Fountain by Room 201	MVH196	Tuesday, June 9, 2020	0.001	Passed	0.4700	Passed	
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 202	MVH197	Tuesday, June 9, 2020	0.008	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Boys Wash Room tap 1 by Room 204	MVH198	Tuesday, June 9, 2020	0.044	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Boys Wash Room tap 2 by Room 204	MVH199	Tuesday, June 9, 2020	0.089	Exceeded	0.8600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Boys Wash Room tap 3 by Room 204	MVH200	Tuesday, June 9, 2020	0.018	Exceeded	0.5400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Boys Wash Room tap 4 by Room 204	MVH201	Tuesday, June 9, 2020	0.110	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Staff Wash Room by Room 208	MVH202	Tuesday, June 9, 2020	0.004	Passed	0.1300	Passed	
Eric Graves Memorial Junior High School	Fountain by Room 208	NLS531	Monday, August 24, 2020	0.000	Passed	0.0100	Passed	
Eric Graves Memorial Junior High School	Girls Wash Room tap 1 by Room 208	MVH204	Tuesday, June 9, 2020	0.330	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Girls Wash Room tap 2 by Room 208	MVH205	Tuesday, June 9, 2020	0.084	Exceeded	0.7200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Girls Wash Room tap 3 by Room 208	MVH206	Tuesday, June 9, 2020	0.110	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Girls Wash Room tap 4 by Room 208	MVH207	Tuesday, June 9, 2020	0.110	Exceeded	0.4400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Class Room tap Room 210	MVH208	Tuesday, June 9, 2020	0.003	Passed	0.0550	Passed	
Eric Graves Memorial Junior High School	Chem Lab tap 1 Room 210	MVH209	Tuesday, June 9, 2020	0.062	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Chem Lab tap 2 Room 210	MVH210	Tuesday, June 9, 2020	0.320	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Chem Lab tap 3 Room 210	MVH211	Tuesday, June 9, 2020	0.160	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Chem Lab tap 4 Room 210	MVH212	Tuesday, June 9, 2020	0.220	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Chem Lab tap 5 Room 210	MVH213	Tuesday, June 9, 2020	0.130	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 215	MVH214	Tuesday, June 9, 2020	0.002	Passed	0.0810	Passed	
Eric Graves Memorial Junior High School	Principal Wash Room tap Room 108	MVH215	Tuesday, June 9, 2020	0.006	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Staff Room 109 Kitchen tap	OUF800	Friday, February 5, 2021	0.002	Passed	0.0160	Passed	Faucet remediated
Eric Graves Memorial Junior High School	Staff mens Wash Room tap 1 Room 109	MVH217	Tuesday, June 9, 2020	0.094	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Staff mens Wash Room tap 2 Room 109	MVH218	Tuesday, June 9, 2020	0.004	Passed	0.0420	Passed	
Eric Graves Memorial Junior High School	Staff womens Wash Room tap 1 Room 109	MVH219	Tuesday, June 9, 2020	0.014	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Staff womens Wash Room tap 2 Room 109	NLS528	Monday, August 24, 2020	0.000	Passed	0.0080	Passed	
Eric Graves Memorial Junior High School	Class Room tap Room 110	NLS529	Monday, August 24, 2020	0.000	Passed	0.0050	Passed	
Eric Graves Memorial Junior High School	Wash Room tap Room 110	MVH222	Tuesday, June 9, 2020	0.004	Passed	0.4400	Passed	
Eric Graves Memorial Junior High School	Janitors Closet tap by Room 111	MVH223	Tuesday, June 9, 2020	0.003	Passed	0.1900	Passed	
Eric Graves Memorial Junior High School	Gender Neutral Wash Room tap Room 112	MVH224	Tuesday, June 9, 2020	0.035	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Class Room tap Room 112	NLS527	Monday, August 24, 2020	0.001	Passed	0.0070	Passed	
Eric Graves Memorial Junior High School	Gym Storage Room tap	MVH226	Tuesday, June 9, 2020	0.082	Exceeded	2.6000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Fountain by Gym	MVH227	Tuesday, June 9, 2020	0.001	Passed	0.5400	Passed	
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 1	MVH228	Tuesday, June 9, 2020	0.018	Exceeded	0.4400	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 2	MVH229	Tuesday, June 9, 2020	0.016	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 3	MVH230	Tuesday, June 9, 2020	0.018	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	1st Floor Girls Wash Room tap 4	MVH231	Tuesday, June 9, 2020	0.010	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 1	MVH232	Tuesday, June 9, 2020	0.020	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 2	MVH233	Tuesday, June 9, 2020	0.014	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 3	MVH234	Tuesday, June 9, 2020	0.024	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	1st Floor Boys Wash Room tap 4	MVH235	Tuesday, June 9, 2020	0.014	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Fountain by Room 202	MVH236	Tuesday, June 9, 2020	0.002	Passed	0.4700	Passed	
Eric Graves Memorial Junior High School	Tech Ed. tap	MVH237	Tuesday, June 9, 2020	0.031	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Resource Room tap Room 107	MVH238	Tuesday, June 9, 2020	0.240	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Eric Graves Memorial Junior High School	Class Room tap Room 105	NLS531	Monday, August 24, 2020	0.000	Passed	0.0090	Passed	
Eric Graves Memorial Junior High School	Class Room Wash Room tap Room 105	MVH240	Tuesday, June 9, 2020	0.008	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Heights Elementary School	VP Office Wash Room tap	MSG780	Tuesday, May 26, 2020	0.003	Passed	0.1200	Passed	
Fairview Heights Elementary School	VP Office Kitchen tap	MSG781	Tuesday, May 26, 2020	0.002	Passed	0.4400	Passed	
Fairview Heights Elementary School	Gender Neutral Wash Room tap Room P2	MSG782	Tuesday, May 26, 2020	0.001	Passed	0.1600	Passed	
Fairview Heights Elementary School	Kitchen tap Room P2	MSG783	Tuesday, May 26, 2020	0.002	Passed	0.0900	Passed	
Fairview Heights Elementary School	Boys Wash Room tap 1 by Gym	MSG784	Tuesday, May 26, 2020	0.001	Passed	0.0470	Passed	
Fairview Heights Elementary School	Boys Wash Room tap 2 by Gym	MSG785	Tuesday, May 26, 2020	0.001	Passed	0.0350	Passed	
Fairview Heights Elementary School	Boys Wash Room tap 3 by Gym	MSG786	Tuesday, May 26, 2020	-	Passed	0.0120	Passed	
Fairview Heights Elementary School	Janitors Closet tap by Gym	MSG787	Tuesday, May 26, 2020	0.001	Passed	0.0120	Passed	
Fairview Heights Elementary School	Girls Wash Room tap 1 by Gym	MSG788	Tuesday, May 26, 2020	-	Passed	0.0120	Passed	
Fairview Heights Elementary School	Girls Wash Room tap 2 by Gym	MSG789	Tuesday, May 26, 2020	0.001	Passed	0.0092	Passed	
Fairview Heights Elementary School	Girls Wash Room tap 3 by Gym	MSG790	Tuesday, May 26, 2020	-	Passed	0.0079	Passed	
Fairview Heights Elementary School	Fountain by Room 12	PXW639	Monday, June 21, 2021	0.003	Passed	0.1300	Passed	Fountain Replaced.
Fairview Heights Elementary School	Boys Wash Room tap 1 at bottom of stairs	MSG792	Tuesday, May 26, 2020	0.001	Passed	0.0700	Passed	
Fairview Heights Elementary School	Boys Wash Room tap 2 at bottom of stairs	MSG793	Tuesday, May 26, 2020	0.001	Passed	0.0150	Passed	
Fairview Heights Elementary School	Boys Wash Room tap 3 at bottom of stairs	MSG794	Tuesday, May 26, 2020	0.002	Passed	0.1800	Passed	
Fairview Heights Elementary School	Staff Wash Room tap	MSG795	Tuesday, May 26, 2020	0.001	Passed	0.0081	Passed	
Fairview Heights Elementary School	Girls Wash Room tap 1 by caretaker Room	MSG796	Tuesday, May 26, 2020	0.001	Passed	0.0240	Passed	
Fairview Heights Elementary School	Girls Wash Room tap 2 by caretaker Room	MSG797	Tuesday, May 26, 2020	-	Passed	0.0100	Passed	
Fairview Heights Elementary School	Girls Wash Room tap 3 by caretaker Room	MSG798	Tuesday, May 26, 2020	-	Passed	0.0077	Passed	
Fairview Heights Elementary School	Caretaker Room tap	MSG799	Tuesday, May 26, 2020	-	Passed	0.0120	Passed	
Fairview Heights Elementary School	Fountain by Room 6	MSG800	Tuesday, May 26, 2020	0.001	Passed	0.2400	Passed	Fountain Replacement in progress
Fairview Heights Elementary School - Annex	Janitors Closet / Boiler Room tap	MRM940	Thursday, May 21, 2020	-	Passed	0.0140	Passed	
Fairview Heights Elementary School - Annex	Work Room tap	MRM941	Thursday, May 21, 2020	-	Passed	0.0390	Passed	
Fairview Heights Elementary School - Annex	Staff Kitchen tap by Gym	MRM943	Thursday, May 21, 2020	-	Passed	0.1100	Passed	
Fairview Heights Elementary School - Annex	Boys Wash Room tap 1 by Gym	MRM944	Thursday, May 21, 2020	0.001	Passed	0.0840	Passed	
Fairview Heights Elementary School - Annex	Boys Wash Room tap 2 by Gym	MRM945	Thursday, May 21, 2020	0.001	Passed	0.1400	Passed	
Fairview Heights Elementary School - Annex	Boys Wash Room tap 3 by Gym	MRM946	Thursday, May 21, 2020	-	Passed	0.0490	Passed	
Fairview Heights Elementary School - Annex	Girls Wash Room tap 1 by Gym	MRM947	Thursday, May 21, 2020	0.001	Passed	0.0470	Passed	
Fairview Heights Elementary School - Annex	Girls Wash Room tap 2 by Gym	MRM948	Thursday, May 21, 2020	0.001	Passed	0.2800	Passed	
Fairview Heights Elementary School - Annex	Girls Wash Room tap 3 by Gym	MRM949	Thursday, May 21, 2020	0.004	Passed	0.2200	Passed	
Fairview Heights Elementary School - Annex	Girls Wash Room tap 4 by Gym	MRM978	Thursday, May 21, 2020	0.001	Passed	0.1200	Passed	
Fairview Heights Elementary School - Annex	Fountain by Room 3	PXW867	Thursday, June 24, 2021	0.004	Passed	0.1300	Passed	Fountain Replaced.
Fairview Heights Elementary School - Annex	Main Office Wash Room tap by Room 5	MRM982	Thursday, May 21, 2020	-	Passed	0.2900	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Fairview Heights Elementary School - Annex	Admin Room tap off the Gym	NFE692	Tuesday, July 7, 2020	0.004	Passed	0.1100	Passed	
Fairview Junior High School	Kitchen tap 1 Room 236	MRO180	Friday, May 22, 2020	0.001	Passed	0.0760	Passed	
Fairview Junior High School	Kitchen tap 2 Room 236	MRO181	Friday, May 22, 2020	0.002	Passed	0.2700	Passed	
Fairview Junior High School	Kitchen tap 3 Room 236	MRO182	Friday, May 22, 2020	-	Passed	0.1800	Passed	
Fairview Junior High School	Kitchen tap 4 Room 236	MRO183	Friday, May 22, 2020	0.002	Passed	0.1100	Passed	
Fairview Junior High School	Kitchen tap 5 Room 236	MRO184	Friday, May 22, 2020	0.001	Passed	0.0610	Passed	
Fairview Junior High School	Kitchen tap 1 Room 230	MRO185	Friday, May 22, 2020	0.004	Passed	0.0670	Passed	
Fairview Junior High School	Fountain by Room 230	MRO186	Friday, May 22, 2020	0.001	Passed	0.3300	Passed	Fountain Replacement in progress
Fairview Junior High School	Class Room tap Room 205	MRO187	Friday, May 22, 2020	0.002	Passed	0.6400	Passed	
Fairview Junior High School	Male Staff Wash Room tap by Room 208	MRO188	Friday, May 22, 2020	0.002	Passed	0.0510	Passed	
Fairview Junior High School	Female Staff Wash Room tap by Room 208	MRO189	Friday, May 22, 2020	0.002	Passed	0.0470	Passed	
Fairview Junior High School	Janitors Closet tap by Staff Wash Rooms	MRO190	Friday, May 22, 2020	0.003	Passed	0.0630	Passed	
Fairview Junior High School	Boys Wash Room tap 1 by Room 205	MRO191	Friday, May 22, 2020	0.001	Passed	0.0260	Passed	
Fairview Junior High School	Boys Wash Room tap 2 by Room 205	MRO192	Friday, May 22, 2020	0.001	Passed	0.0210	Passed	
Fairview Junior High School	Boys Wash Room tap 3 by Room 205	MRO193	Friday, May 22, 2020	0.001	Passed	0.0240	Passed	
Fairview Junior High School	Boys Wash Room tap 4 by Room 205	MRO194	Friday, May 22, 2020	0.002	Passed	0.0200	Passed	
Fairview Junior High School	Fountain by Room 205	MRO195	Friday, May 22, 2020	0.004	Passed	0.2800	Passed	
Fairview Junior High School	Girls Wash Room tap 1 by Room 205	MRO196	Friday, May 22, 2020	0.004	Passed	0.1300	Passed	
Fairview Junior High School	Girls Wash Room tap 2 by Room 205	MRO197	Friday, May 22, 2020	0.002	Passed	0.1500	Passed	
Fairview Junior High School	Girls Wash Room tap 3 by Room 205	MRO198	Friday, May 22, 2020	0.001	Passed	0.0990	Passed	
Fairview Junior High School	Girls Wash Room tap 4 by Room 205	MRO199	Friday, May 22, 2020	0.003	Passed	0.0540	Passed	
Fairview Junior High School	Art Room tap 1 Room 239	MRO200	Friday, May 22, 2020	0.003	Passed	0.1900	Passed	
Fairview Junior High School	Art Room tap 2 Room 239	MRO201	Friday, May 22, 2020	0.001	Passed	0.0180	Passed	
Fairview Junior High School	Janitors Closet tap by Room 239	MRO202	Friday, May 22, 2020	0.002	Passed	0.0270	Passed	
Fairview Junior High School	Girls Wash Room tap 1 by Room 228	MRO203	Friday, May 22, 2020	0.002	Passed	0.0140	Passed	
Fairview Junior High School	Girls Wash Room tap 2 by Room 228	MRO204	Friday, May 22, 2020	0.002	Passed	0.0210	Passed	
Fairview Junior High School	Girls Wash Room tap 3 by Room 228	MRO205	Friday, May 22, 2020	0.009	Exceeded	0.0280	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Gender Neutral Staff Wash Room tap by Room 228	MRO206	Friday, May 22, 2020	0.004	Passed	0.0720	Passed	
Fairview Junior High School	Gender Neutral Staff Wash Room tap by Room 230	MRO207	Friday, May 22, 2020	0.003	Passed	0.0370	Passed	
Fairview Junior High School	Boys Wash Room tap 1 by Room 230	MRO208	Friday, May 22, 2020	0.001	Passed	0.0140	Passed	
Fairview Junior High School	Boys Wash Room tap 2 by Room 230	MRO209	Friday, May 22, 2020	0.002	Passed	0.0380	Passed	
Fairview Junior High School	Boys Wash Room tap 3 by Room 230	MRO215	Friday, May 22, 2020	0.002	Passed	0.0150	Passed	
Fairview Junior High School	Kitchen tap 1 Room 246	MRO216	Friday, May 22, 2020	0.005	Passed	0.1500	Passed	
Fairview Junior High School	Kitchen tap 1 Room 247	MRO217	Friday, May 22, 2020	0.007	Exceeded	0.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Kitchen tap 1 Room 248	MRO218	Friday, May 22, 2020	0.550	Exceeded	6.6000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Kitchen tap 2 Room 248	MRO219	Friday, May 22, 2020	0.086	Exceeded	2.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Kitchen tap 3 Room 248	MRO220	Friday, May 22, 2020	0.009	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Janitors Closet tap Room 131	MRO221	Friday, May 22, 2020	0.002	Passed	0.1300	Passed	
Fairview Junior High School	Staff Wash Room tap in Office Room 137	MRO222	Friday, May 22, 2020	0.001	Passed	0.0820	Passed	
Fairview Junior High School	Staff Kitchen tap Room 144	MRO223	Friday, May 22, 2020	0.001	Passed	0.0210	Passed	
Fairview Junior High School	Staff Wash Room tap Room 144	MRO224	Friday, May 22, 2020	0.001	Passed	0.0150	Passed	
Fairview Junior High School	Staff Wash Room tap Room 144	MRO443	Friday, May 22, 2020	0.001	Passed	0.0200	Passed	
Fairview Junior High School	Gender Neutral Wash Room tap Room 140	MRO444	Friday, May 22, 2020	0.002	Passed	0.0150	Passed	
Fairview Junior High School	Learning Centre Wash Room tap	MRO445	Friday, May 22, 2020	0.001	Passed	0.0120	Passed	
Fairview Junior High School	Fountain by Learning Centre	MRO446	Friday, May 22, 2020	-	Passed	0.3400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Fairview Junior High School	Gender Neutral Wash Room tap by Room 110	MRO447	Friday, May 22, 2020	0.010	Exceeded	0.0540	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Staff Wash Room by Gender Neutral Wash Room	MRO448	Friday, May 22, 2020	0.001	Passed	0.0310	Passed	
Fairview Junior High School	Janitors Closet tap by Staff Wash Rooms	MRO449	Friday, May 22, 2020	0.002	Passed	0.0270	Passed	
Fairview Junior High School	Boys Wash Room tap 1 by Room 108	MRO450	Friday, May 22, 2020	0.001	Passed	0.0250	Passed	
Fairview Junior High School	Boys Wash Room tap 2 by Room 108	MRO451	Friday, May 22, 2020	0.001	Passed	0.0190	Passed	
Fairview Junior High School	Fountain by Room 107	NNS553	Thursday, September 3, 2020	0.002	Passed	0.0630	Passed	Fountain Replacement in progress
Fairview Junior High School	Girls Wash Room tap 1 by Room 107	MRO460	Friday, May 22, 2020	0.002	Passed	0.0360	Passed	
Fairview Junior High School	Girls Wash Room tap 2 by Room 107	MRO461	Friday, May 22, 2020	0.001	Passed	0.0200	Passed	
Fairview Junior High School	Girls Wash Room tap 3 by Room 107	MRO462	Friday, May 22, 2020	0.001	Passed	0.0190	Passed	
Fairview Junior High School	Girls Wash Room tap 4 by Room 107	MRO463	Friday, May 22, 2020	0.001	Passed	0.0200	Passed	
Fairview Junior High School	Class Room tap 1 Room 160	MRO464	Friday, May 22, 2020	0.002	Passed	0.2300	Passed	
Fairview Junior High School	Class Room tap 2 Room 160	MRO465	Friday, May 22, 2020	-	Passed	0.5400	Passed	
Fairview Junior High School	Boiler Room tap Room 014	MRO466	Friday, May 22, 2020	0.064	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Wood shop Room tap	MRO467	Friday, May 22, 2020	0.002	Passed	0.1800	Passed	
Fairview Junior High School	Computer Lab tap Room 012	MRO468	Friday, May 22, 2020	0.017	Exceeded	0.8700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Janitors Closet tap Room 009	MRO469	Friday, May 22, 2020	0.037	Exceeded	0.6300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Fairview Junior High School	Caretaker Room Wash Room tap Room 007	MRO471	Friday, May 22, 2020	-	Passed	0.0068	Passed	
Fairview Junior High School	Boys Locker Room tap 1 Room 006	MRO472	Friday, May 22, 2020	0.003	Passed	0.0720	Passed	
Fairview Junior High School	Boys Locker Room tap 2 Room 006	MRO473	Friday, May 22, 2020	0.001	Passed	0.0130	Passed	
Fairview Junior High School	Fountain by Boys Locker Room	MRO474	Friday, May 22, 2020	0.001	Passed	0.1800	Passed	Fountain Replacement in progress
Fairview Junior High School	Girls Locker Room tap 1 Room 005	MRO475	Friday, May 22, 2020	0.003	Passed	0.0076	Passed	
Fairview Junior High School	Girls Locker Room tap 2 Room 005	MRO476	Friday, May 22, 2020	0.001	Passed	0.0047	Passed	
Fairview Junior High School	Phys Ed Wash Room 013	MRO477	Friday, May 22, 2020	0.007	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 1	MUT708	Friday, June 5, 2020	0.002	Passed	0.0820	Passed	
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 2	MUT709	Friday, June 5, 2020	0.068	Exceeded	0.0960	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 3	MUT710	Friday, June 5, 2020	0.004	Passed	0.1300	Passed	
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 4	MUT711	Friday, June 5, 2020	0.003	Passed	0.1300	Passed	
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 5	MUT712	Friday, June 5, 2020	0.022	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 6	MUT713	Friday, June 5, 2020	0.022	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 7	MUT714	Friday, June 5, 2020	0.011	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 8	MUT715	Friday, June 5, 2020	0.003	Passed	0.1900	Passed	
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 9	MUT716	Friday, June 5, 2020	0.002	Passed	0.1500	Passed	
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 10	MUT717	Friday, June 5, 2020	0.002	Passed	0.1200	Passed	
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 11	MUT718	Friday, June 5, 2020	0.002	Passed	0.1200	Passed	
Five Bridges Junior High School	3rd Floor Chem Lab Room 300 tap 12	MUT719	Friday, June 5, 2020	0.015	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Chem Lab Storage Room 300A tap	MUT720	Friday, June 5, 2020	0.400	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Physics Lab Storage Room 303A tap	MUT721	Friday, June 5, 2020	0.026	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Physics Lab tap Room 303	MUT722	Friday, June 5, 2020	0.007	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Class Room tap Room 307	MUT723	Friday, June 5, 2020	0.005	Passed	0.0560	Passed	
Five Bridges Junior High School	3rd Floor Staff Wash Room 1 tap	MUT724	Friday, June 5, 2020	0.002	Passed	0.0770	Passed	
Five Bridges Junior High School	3rd Floor Staff Wash Room 2 tap	MUT725	Friday, June 5, 2020	0.002	Passed	0.1000	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 1	MUT726	Friday, June 5, 2020	0.002	Passed	0.1000	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 2	MUT727	Friday, June 5, 2020	0.004	Passed	0.0910	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 3	MUT728	Friday, June 5, 2020	0.003	Passed	0.0490	Passed	
Five Bridges Junior High School	3rd Floor Boys Wash Room tap 4	MUT729	Friday, June 5, 2020	0.002	Passed	0.1000	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Five Bridges Junior High School	Fountain by Wash Room's	MUT730	Friday, June 5, 2020	0.001	Passed	0.2600	Passed	
Five Bridges Junior High School	3rd Floor Janitors Closet tap	MUT731	Friday, June 5, 2020	0.001	Passed	0.1100	Passed	
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 1	MUT732	Friday, June 5, 2020	0.002	Passed	0.0770	Passed	
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 2	MUT733	Friday, June 5, 2020	0.001	Passed	0.0600	Passed	
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 3	MUT734	Friday, June 5, 2020	0.016	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 4	MUT735	Friday, June 5, 2020	0.012	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	3rd Floor Girls Wash Room tap 5	MUT736	Friday, June 5, 2020	0.003	Passed	0.0700	Passed	
Five Bridges Junior High School	Bio Lab Room 325 tap 1	MUT737	Friday, June 5, 2020	0.016	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Bio Lab Room 325 tap 2	MUT738	Friday, June 5, 2020	0.007	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Bio Lab Room 325 tap 3	MUT739	Friday, June 5, 2020	0.013	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	2nd Floor Girls LR tap 1	MUT740	Friday, June 5, 2020	0.002	Passed	0.0820	Passed	
Five Bridges Junior High School	2nd Floor Girls LR tap 2	MUT741	Friday, June 5, 2020	0.001	Passed	0.0760	Passed	
Five Bridges Junior High School	Gym Office Wash Room tap Room 209A	MUT742	Friday, June 5, 2020	0.033	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Gym Office Wash Room tap Room 211A	MUT743	Friday, June 5, 2020	2.400	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Boys LR tap Room 215	MUT744	Friday, June 5, 2020	-	Passed	0.0670	Passed	
Five Bridges Junior High School	Learning Centre tap Room 223	MUT745	Friday, June 5, 2020	0.001	Passed	0.0720	Passed	
Five Bridges Junior High School	Learning Centre Wash Room tap Room 227	MUT746	Friday, June 5, 2020	0.007	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Learning Centre Wash Room tap Room 225	MUT747	Friday, June 5, 2020	0.005	Passed	0.0470	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 1	MUT748	Friday, June 5, 2020	0.001	Passed	0.0530	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 2	MUT749	Friday, June 5, 2020	0.001	Passed	0.0670	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 3	MUT750	Friday, June 5, 2020	0.001	Passed	0.0420	Passed	
Five Bridges Junior High School	2nd Floor Boys Wash Room tap 4	MUT751	Friday, June 5, 2020	0.001	Passed	0.0370	Passed	
Five Bridges Junior High School	Fountain by Wash Room's	MUT752	Friday, June 5, 2020	0.001	Passed	0.2700	Passed	
Five Bridges Junior High School	Janitors Closet tap by Wash Room's	MUT753	Friday, June 5, 2020	0.001	Passed	0.1100	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 1	MUT754	Friday, June 5, 2020	0.003	Passed	0.0720	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 2	MUT755	Friday, June 5, 2020	0.001	Passed	0.0610	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 3	MUT756	Friday, June 5, 2020	0.004	Passed	0.0920	Passed	
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 4	MUT757	Friday, June 5, 2020	0.007	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	2nd Floor Girls Wash Room tap 5	MUT758	Friday, June 5, 2020	0.002	Passed	0.0610	Passed	
Five Bridges Junior High School	Main Office Wash Room tap	MUT759	Friday, June 5, 2020	0.002	Passed	0.1300	Passed	
Five Bridges Junior High School	1st Floor Boys Wash Room tap 1	MUT760	Friday, June 5, 2020	0.002	Passed	0.0720	Passed	
Five Bridges Junior High School	1st Floor Boys Wash Room tap 2	MUT761	Friday, June 5, 2020	0.001	Passed	0.0580	Passed	
Five Bridges Junior High School	1st Floor Boys Wash Room tap 3	MUT762	Friday, June 5, 2020	0.016	Exceeded	0.0580	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	Fountain by 1st Floor Wash Rooms	QQR057	Wednesday, September 15, 2021	-	Passed	0.0013	Passed	Fountain replaced
Five Bridges Junior High School	Janitors Closet tap by 1st Floor Wash Room's	MUT764	Friday, June 5, 2020	0.001	Passed	0.0290	Passed	
Five Bridges Junior High School	1st Floor Girls Wash Room tap 1	MUT765	Friday, June 5, 2020	0.002	Passed	0.0540	Passed	
Five Bridges Junior High School	1st Floor Girls Wash Room tap 2	MUT766	Friday, June 5, 2020	0.014	Exceeded	0.0600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Five Bridges Junior High School	1st Floor Girls Wash Room tap 3	MUT767	Friday, June 5, 2020	0.001	Passed	0.0480	Passed	
Five Bridges Junior High School	1st Floor Girls Wash Room tap 4	MUT788	Friday, June 5, 2020	0.001	Passed	0.0430	Passed	
Five Bridges Junior High School	Staff Male Wash Room tap Room 157	MUT789	Friday, June 5, 2020	0.001	Passed	0.0430	Passed	
Five Bridges Junior High School	Staff Female Wash Room tap Room 158	MUT790	Friday, June 5, 2020	0.001	Passed	0.0520	Passed	
Fleming Tower School	Fountain	FWG481	Tuesday, June 15, 2021	0.003	Passed	0.0840	Passed	Fountain replaced.
Fleming Tower School	Teachers Room tap	MNX824	Friday, May 1, 2020	0.003	Passed	0.1400	Passed	
Fleming Tower School	Girls Wash Room tap 1	OXM599	Wednesday, February 24, 2021	0.006	Exceeded	0.1000	Passed	Signage added to instruct handwashing only
Fleming Tower School	Girls Wash Room tap 2	OXM600	Wednesday, February 24, 2021	0.001	Passed	0.0220	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Fleming Tower School	Girls Wash Room tap 3	OXM601	Wednesday, February 24, 2021	-	Passed	0.0150	Passed	Tap remediated.
Fleming Tower School	Boys Wash Room tap 1	OXM596	Wednesday, February 24, 2021	0.001	Passed	0.1000	Passed	
Fleming Tower School	Boys Wash Room tap 2	OXM597	Wednesday, February 24, 2021	-	Passed	0.0200	Passed	
Fleming Tower School	Boys Wash Room tap 3	OXM598	Wednesday, February 24, 2021	-	Passed	0.0140	Passed	Tap remediated.
Fleming Tower School	Class Room tap Room 2	MOE426	Monday, May 4, 2020	0.002	Passed	0.1200	Passed	
Fleming Tower School	Teachers Wash Room tap	MOE427	Monday, May 4, 2020	0.002	Passed	0.1100	Passed	
Gaetz Brook Junior High School	Gender Neutral Wash Room tap Room 306	NAN920	Tuesday, June 30, 2020	0.002	Passed	0.1400	Passed	
Gaetz Brook Junior High School	Staff Room Kitchen tap	NAN921	Tuesday, June 30, 2020	0.002	Passed	0.1500	Passed	
Gaetz Brook Junior High School	Staff Room Wash Room 1 tap	NAN922	Tuesday, June 30, 2020	0.008	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Staff Room Wash Room 2 tap	NAN923	Tuesday, June 30, 2020	0.005	Passed	0.5900	Passed	
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 305	NAN924	Tuesday, June 30, 2020	0.009	Exceeded	0.4400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 305	NAN925	Tuesday, June 30, 2020	0.008	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Fountain by Girls Wash Room	NAN926	Tuesday, June 30, 2020	4.600	Exceeded	0.2800	Passed	New Fountain to be installed. Other sources available.
Gaetz Brook Junior High School	Janitors Closet tap by fountain	NAN927	Tuesday, June 30, 2020	0.004	Passed	0.1500	Passed	
Gaetz Brook Junior High School	Boys Wash Room tap 1 by Janitors Closet	NAN928	Tuesday, June 30, 2020	0.074	Exceeded	3.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Boys Wash Room tap 2 by Janitors Closet	NAN929	Tuesday, June 30, 2020	0.001	Passed	0.1400	Passed	
Gaetz Brook Junior High School	Ms. O'Connell Room tap	NAN930	Tuesday, June 30, 2020	0.110	Exceeded	2.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Sci Lab tap before Room 300	NAN931	Tuesday, June 30, 2020	0.054	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Class Room tap 1 Room 300	NAN932	Tuesday, June 30, 2020	1.400	Exceeded	1.9000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Class Room tap 2 Room 300	NAN933	Tuesday, June 30, 2020	0.024	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Class Room tap 3 Room 300	NAN934	Tuesday, June 30, 2020	0.013	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Class Room tap 4 Room 300	NAN935	Tuesday, June 30, 2020	0.039	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Class Room tap 5 Room 300	NAN936	Tuesday, June 30, 2020	0.110	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Laundry tub tap Room 203	NAN937	Tuesday, June 30, 2020	0.045	Exceeded	0.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 204	NAN938	Tuesday, June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 204	NAN939	Tuesday, June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	Fountain by Girls Wash Room	NAN940	Tuesday, June 30, 2020	0.001	Passed	0.1300	Passed	
Gaetz Brook Junior High School	Janitors Closet by fountain	NAN941	Tuesday, June 30, 2020	0.001	Passed	0.1300	Passed	
Gaetz Brook Junior High School	Boys Wash Room tap 1 by Janitors Closet	NAN942	Tuesday, June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	Boys Wash Room tap 2 by Janitors Closet	NAN943	Tuesday, June 30, 2020	0.086	Exceeded	0.5800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Guidance Room rap	NAN944	Tuesday, June 30, 2020	0.041	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Fountain in Boys Locker Room	NAN945	Tuesday, June 30, 2020	0.001	Passed	0.0990	Passed	
Gaetz Brook Junior High School	Boys Locker Room tap	NAN946	Tuesday, June 30, 2020	0.001	Passed	0.0900	Passed	
Gaetz Brook Junior High School	Girls Locker Room tap	NAN947	Tuesday, June 30, 2020	0.007	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Staff Wash Room in main Office	NAN948	Tuesday, June 30, 2020	0.006	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Girls Wash Room tap 1 by Room 105	NAN949	Tuesday, June 30, 2020	0.011	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Girls Wash Room tap 2 by Room 105	NAN950	Tuesday, June 30, 2020	0.002	Passed	0.1400	Passed	
Gaetz Brook Junior High School	Fountain by Girls Wash Room	NAN951	Tuesday, June 30, 2020	0.019	Exceeded	0.7300	Passed	New Fountain to be installed. Other sources available.
Gaetz Brook Junior High School	Janitors Closet by fountain	NAN952	Tuesday, June 30, 2020	0.001	Passed	0.1200	Passed	
Gaetz Brook Junior High School	Boys Wash Room tap 1 by Janitors Closet	NAN953	Tuesday, June 30, 2020	0.015	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Boys Wash Room tap 2 by Janitors Closet	NAN954	Tuesday, June 30, 2020	0.009	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Kitchen/Cafeteria tap 1	NAN955	Tuesday, June 30, 2020	0.011	Exceeded	0.7700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Kitchen/Cafeteria handwashing tap	NAN956	Tuesday, June 30, 2020	0.021	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Kitchen/Cafeteria Wash Room tap	NAN957	Tuesday, June 30, 2020	0.016	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Triple compartment sink tap 1 in Kitchen	NAN958	Tuesday, June 30, 2020	0.034	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Gaetz Brook Junior High School	Triple compartment sink tap 2 in Kitchen	NAN959	Tuesday, June 30, 2020	0.027	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Photo Room tap	NAN960	Tuesday, June 30, 2020	3.300	Exceeded	4.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Janitors Closet tap in art Room	NAN961	Tuesday, June 30, 2020	0.094	Exceeded	2.8000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Gaetz Brook Junior High School	Art Room tap	NAN962	Tuesday, June 30, 2020	0.150	Exceeded	6.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
George Bissett Elementary School	Girls Wash Room tap 1 by Room 207	MXK042	Thursday, June 18, 2020	-	Passed	0.3000	Passed	
George Bissett Elementary School	Girls Wash Room tap 2 by Room 207	MXK043	Thursday, June 18, 2020	0.001	Passed	0.1200	Passed	
George Bissett Elementary School	Janitors Closet by Girls Wash Room	MXK044	Thursday, June 18, 2020	-	Passed	0.0550	Passed	
George Bissett Elementary School	Boys Wash Room tap 1 Room 215	MXK045	Thursday, June 18, 2020	0.001	Passed	0.4800	Passed	
George Bissett Elementary School	Boys Wash Room tap 2 Room 215	MXK046	Thursday, June 18, 2020	0.001	Passed	0.2000	Passed	
George Bissett Elementary School	Fountain by Boys Wash Room	-	-	-	-	-	-	
George Bissett Elementary School	Staff Kitchen sink tap Room 221	MXK047	Thursday, June 18, 2020	0.002	Passed	0.2000	Passed	
George Bissett Elementary School	Staff Room Wash Room tap Room 221	MXK048	Thursday, June 18, 2020	-	Passed	0.0150	Passed	
George Bissett Elementary School	Kitchen sink tap by Office	MXK049	Thursday, June 18, 2020	0.007	Exceeded	0.0770	Passed	
George Bissett Elementary School	Girls Wash Room tap 1 Room 224	MXK050	Thursday, June 18, 2020	-	Passed	0.2500	Passed	
George Bissett Elementary School	Girls Wash Room tap 2 Room 224	MXK051	Thursday, June 18, 2020	0.003	Passed	0.1900	Passed	
George Bissett Elementary School	Girls Wash Room tap 3 Room 224	MXK052	Thursday, June 18, 2020	0.001	Passed	0.0460	Passed	
George Bissett Elementary School	Girls Wash Room tap 4 Room 224	MXK053	Thursday, June 18, 2020	-	Passed	0.0150	Passed	
George Bissett Elementary School	Fountain by Girls Wash Room	PXK671	Wednesday, June 23, 2021	0.005	Passed	0.0790	Passed	Fountain Replaced.
George Bissett Elementary School	Janitors Closet tap Room 226	MXK055	Thursday, June 18, 2020	0.002	Passed	0.1100	Passed	
George Bissett Elementary School	Boys Wash Room tap 1 Room 228	MXK056	Thursday, June 18, 2020	0.014	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
George Bissett Elementary School	Boys Wash Room tap 2 Room 228	MXK057	Thursday, June 18, 2020	-	Passed	0.3900	Passed	
George Bissett Elementary School	Boys Wash Room tap 3 Room 228	MXK058	Thursday, June 18, 2020	0.001	Passed	0.3600	Passed	
George Bissett Elementary School	Boys Wash Room tap 4 Room 228	MXK059	Thursday, June 18, 2020	-	Passed	0.2100	Passed	
George Bissett Elementary School	Girls Wash Room tap 1 Room 110	MXK060	Thursday, June 18, 2020	0.001	Passed	0.3700	Passed	
George Bissett Elementary School	Girls Wash Room tap 2 Room 110	MXK061	Thursday, June 18, 2020	-	Passed	0.3600	Passed	
George Bissett Elementary School	Girls Wash Room tap 3 Room 110	MXK062	Thursday, June 18, 2020	0.001	Passed	0.2100	Passed	
George Bissett Elementary School	Boys Wash Room tap 1 Room 114	MXK063	Thursday, June 18, 2020	0.001	Passed	0.3800	Passed	
George Bissett Elementary School	Boys Wash Room tap 2 Room 114	MXK064	Thursday, June 18, 2020	-	Passed	0.5100	Passed	
George Bissett Elementary School	Boys Wash Room tap 3 Room 114	MXK065	Thursday, June 18, 2020	-	Passed	0.4100	Passed	
George Bissett Elementary School	Boys Wash Room tap 4 Room 114	MXK066	Thursday, June 18, 2020	0.003	Passed	0.4500	Passed	
George Bissett Elementary School	Fountain by Room 109	PXK672	Wednesday, June 23, 2021	0.005	Passed	0.0840	Passed	Fountain Replaced.
Georges P. Vanier Junior High School	Principals Office Wash Room tap	MVG411	Tuesday, June 9, 2020	0.001	Passed	0.1800	Passed	
Georges P. Vanier Junior High School	Fountain by Main Office	MVG412	Tuesday, June 9, 2020	0.001	Passed	0.6700	Passed	
Georges P. Vanier Junior High School	Learning Centre tap Room 158	MVG413	Tuesday, June 9, 2020	0.002	Passed	1.0000	Passed	
Georges P. Vanier Junior High School	Science Lab tap 1 Room 161	MVG414	Tuesday, June 9, 2020	0.006	Exceeded	0.5800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 2 Room 161	MVG415	Tuesday, June 9, 2020	0.039	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 3 Room 161	MVG416	Tuesday, June 9, 2020	0.067	Exceeded	0.8400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 4 Room 161	MVG417	Tuesday, June 9, 2020	0.340	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Class Room tap Room 164	MVG418	Tuesday, June 9, 2020	0.004	Passed	0.8700	Passed	
Georges P. Vanier Junior High School	Class Room tap 1 Room 146	MVG419	Tuesday, June 9, 2020	0.004	Passed	0.6500	Passed	
Georges P. Vanier Junior High School	Class Room tap 2 Room 146	MVG420	Tuesday, June 9, 2020	0.001	Passed	0.3500	Passed	
Georges P. Vanier Junior High School	Class Room tap 3 Room 146	MVG421	Tuesday, June 9, 2020	-	Passed	0.0760	Passed	
Georges P. Vanier Junior High School	Cafeteria tap 1	MVG422	Tuesday, June 9, 2020	0.001	Passed	0.0790	Passed	
Georges P. Vanier Junior High School	Cafeteria tap 2	MVG423	Tuesday, June 9, 2020	0.004	Passed	0.1700	Passed	
Georges P. Vanier Junior High School	Fountain by Room 124	MVG424	Tuesday, June 9, 2020	0.002	Passed	0.0760	Passed	Fountain Replacement in progress



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Georges P. Vanier Junior High School	Girls Wash Room tap 1 Room 120	MVG425	Tuesday, June 9, 2020	0.011	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Girls Wash Room tap 2 Room 120	MVG426	Tuesday, June 9, 2020	0.007	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Girls Wash Room tap 3 Room 120	MVG427	Tuesday, June 9, 2020	0.017	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Fountain by Girls Wash Room	MVG428	Tuesday, June 9, 2020	0.002	Passed	1.2000	Passed	Fountain Replacement in progress
Georges P. Vanier Junior High School	Janitors Closet tap Room 124	MVG429	Tuesday, June 9, 2020	-	Passed	0.0500	Passed	
Georges P. Vanier Junior High School	Boys Wash Room tap 1 Room 116	MVG430	Tuesday, June 9, 2020	0.030	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Boys Wash Room tap 2 Room 116	MVG431	Tuesday, June 9, 2020	0.001	Passed	0.1600	Passed	
Georges P. Vanier Junior High School	Boys Wash Room tap 3 Room 116	MVG432	Tuesday, June 9, 2020	0.001	Passed	0.0570	Passed	
Georges P. Vanier Junior High School	Gym Office Wash Room tap Room 105	MVG433	Tuesday, June 9, 2020	0.006	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Gym Office Wash Room tap Room 106	MVG434	Tuesday, June 9, 2020	0.004	Passed	0.1700	Passed	
Georges P. Vanier Junior High School	Fountain by Room 240	MVG435	Tuesday, June 9, 2020	0.003	Passed	0.6500	Passed	Fountain Replacement in progress
Georges P. Vanier Junior High School	Science Lab tap 1 Room 241	MVG436	Tuesday, June 9, 2020	0.200	Exceeded	0.8900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 2 Room 241	MVG437	Tuesday, June 9, 2020	0.130	Exceeded	0.6200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 3 Room 241	MVG438	Tuesday, June 9, 2020	0.150	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 4 Room 241	MVG439	Tuesday, June 9, 2020	0.037	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 5 Room 241	MVG440	Tuesday, June 9, 2020	0.110	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Food Lab tap 1 Room 231	NND063	Tuesday, September 1, 2020	0.000	Passed	0.0200	Passed	
Georges P. Vanier Junior High School	Food Lab tap 2 Room 231	NND075	Tuesday, September 1, 2020	0.001	Passed	0.0300	Passed	
Georges P. Vanier Junior High School	Food Lab tap 3 Room 231	NND076	Tuesday, September 1, 2020	0.001	Passed	0.0310	Passed	
Georges P. Vanier Junior High School	Food Lab tap 4 Room 231	NND077	Tuesday, September 1, 2020	0.001	Passed	0.0350	Passed	
Georges P. Vanier Junior High School	Clothes Lab tap Room 224	MVG445	Tuesday, June 9, 2020	1.500	Exceeded	2.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 1 Room 220	MVG446	Tuesday, June 9, 2020	0.028	Exceeded	0.6400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 2 Room 220	MVG447	Tuesday, June 9, 2020	0.051	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 3 Room 220	MVG448	Tuesday, June 9, 2020	0.057	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Science Lab tap 4 Room 220	MVG449	Tuesday, June 9, 2020	0.008	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Girls Wash Room tap 1 Room 210	MVG450	Tuesday, June 9, 2020	0.160	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Girls Wash Room tap 2 Room 210	MVG451	Tuesday, June 9, 2020	0.042	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Girls Wash Room tap 3 Room 210	MVG452	Tuesday, June 9, 2020	0.011	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Girls Wash Room tap 4 Room 210	MVG453	Tuesday, June 9, 2020	0.009	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Janitors Closet tap Room 212	MVG454	Tuesday, June 9, 2020	0.005	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	2nd Floor Boys Wash Room tap 1	MVG455	Tuesday, June 9, 2020	0.019	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	2nd Floor Boys Wash Room tap 2	MVG456	Tuesday, June 9, 2020	0.002	Passed	0.0930	Passed	
Georges P. Vanier Junior High School	2nd Floor Boys Wash Room tap 3	MVG457	Tuesday, June 9, 2020	0.002	Passed	0.0680	Passed	
Georges P. Vanier Junior High School	Staff Wash Room tap 1 Room 216	MVG458	Tuesday, June 9, 2020	0.039	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Staff Wash Room tap 2 Room 216	MVG459	Tuesday, June 9, 2020	0.008	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Georges P. Vanier Junior High School	Fountain by Staff Room	NND078	Tuesday, September 1, 2020	0.000	Passed	0.0410	Passed	
Gorsebrook Junior High School	Boys Locker Room tap (1st Floor)	MSZ161	Thursday, May 28, 2020	0.006	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Gym Gender Neutral Wash Room tap	MSZ162	Thursday, May 28, 2020	0.002	Passed	0.1500	Passed	
Gorsebrook Junior High School	Gym Office tap	MSZ163	Thursday, May 28, 2020	0.002	Passed	0.1400	Passed	
Gorsebrook Junior High School	Girls Locker Room tap	MSZ164	Thursday, May 28, 2020	0.003	Passed	1.9000	Passed	
Gorsebrook Junior High School	Fountain by Gym	MSZ165	Thursday, May 28, 2020	0.004	Passed	0.2500	Passed	
Gorsebrook Junior High School	Gender Neutral Wash Room 1 tap by Room 3	MSZ166	Thursday, May 28, 2020	0.001	Passed	0.2500	Passed	
Gorsebrook Junior High School	Gender Neutral Wash Room 2 tap by Room 3	MSZ167	Thursday, May 28, 2020	0.004	Passed	0.2700	Passed	
Gorsebrook Junior High School	Art Room tap Room 3	MSZ168	Thursday, May 28, 2020	0.013	Exceeded	0.8700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	1st Floor Staff Wash Room tap	MSZ169	Thursday, May 28, 2020	-	Passed	0.0230	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Gorsebrook Junior High School	1st Floor Staff Room Kitchen tap	MSZ170	Thursday, May 28, 2020	-	Passed	0.0270	Passed	
Gorsebrook Junior High School	Class Room tap Room 12	MSZ171	Thursday, May 28, 2020	0.002	Passed	0.2100	Passed	
Gorsebrook Junior High School	Janitors Closet tap by Room 18	MSZ172	Thursday, May 28, 2020	0.001	Passed	0.0530	Passed	
Gorsebrook Junior High School	Male Staff Wash Room tap by Room 18	MSZ173	Thursday, May 28, 2020	0.002	Passed	0.0620	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 1 by Room 18	MSZ174	Thursday, May 28, 2020	0.001	Passed	0.2500	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 2 by Room 18	MSZ175	Thursday, May 28, 2020	0.004	Passed	0.1100	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 3 by Room 18	MSZ176	Thursday, May 28, 2020	0.004	Passed	0.2200	Passed	
Gorsebrook Junior High School	Boys Wash Room tap 4 by Room 18	MSZ177	Thursday, May 28, 2020	0.001	Passed	0.2500	Passed	
Gorsebrook Junior High School	Fountain by Room 16	NLJ875	Monday, August 24, 2020	0.000	Passed	0.0200	Passed	
Gorsebrook Junior High School	Female Staff Wash Room tap by Room 16	MSZ179	Thursday, May 28, 2020	0.003	Passed	0.2300	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 1 by Room 16	MSZ180	Thursday, May 28, 2020	0.002	Passed	0.1900	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 2 by Room 16	MSZ181	Thursday, May 28, 2020	0.004	Passed	0.0530	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 3 by Room 16	MSZ182	Thursday, May 28, 2020	0.002	Passed	0.3000	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 4 by Room 16	MSZ183	Thursday, May 28, 2020	0.001	Passed	0.0780	Passed	
Gorsebrook Junior High School	Girls Wash Room tap 5 by Room 16	MSZ184	Thursday, May 28, 2020	0.008	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Resource Room tap Room 11	MSZ185	Thursday, May 28, 2020	0.001	Passed	0.1000	Passed	
Gorsebrook Junior High School	Resource Room Wash Room tap 1 Room 11	MSZ186	Thursday, May 28, 2020	0.002	Passed	0.0490	Passed	
Gorsebrook Junior High School	Resource Room Wash Room tap 2 Room 11	MSZ187	Thursday, May 28, 2020	0.001	Passed	0.0530	Passed	
Gorsebrook Junior High School	Fountain by main Office	MSZ188	Thursday, May 28, 2020	-	Passed	0.3500	Passed	
Gorsebrook Junior High School	Basement Class Room tap Room 29	MSZ189	Thursday, May 28, 2020	0.006	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Basement Boys Wash Room tap 1	MSZ190	Thursday, May 28, 2020	0.008	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Basement Boys Wash Room tap 2	MSZ191	Thursday, May 28, 2020	0.011	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Basement Boys Wash Room tap 3	MSZ192	Thursday, May 28, 2020	0.069	Exceeded	4.7000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Basement Girls Wash Room tap 1	MSZ193	Thursday, May 28, 2020	0.003	Passed	0.2000	Passed	
Gorsebrook Junior High School	Basement Girls Wash Room tap 2	MSZ194	Thursday, May 28, 2020	0.005	Exceeded	0.7500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Basement Girls Wash Room tap 3	MSZ195	Thursday, May 28, 2020	0.005	Passed	0.1500	Passed	
Gorsebrook Junior High School	Basement food Lab tap 1	MSZ196	Thursday, May 28, 2020	0.001	Passed	0.0330	Passed	
Gorsebrook Junior High School	Basement food Lab tap 2	MSZ197	Thursday, May 28, 2020	0.002	Passed	0.0640	Passed	
Gorsebrook Junior High School	Basement food Lab tap 3	MSZ198	Thursday, May 28, 2020	0.001	Passed	0.0500	Passed	
Gorsebrook Junior High School	Basement food Lab tap 4	MSZ199	Thursday, May 28, 2020	-	Passed	0.0550	Passed	
Gorsebrook Junior High School	Storage Room tap Room 32	MUV531	Monday, June 8, 2020	0.018	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Gorsebrook Junior High School	Janitors Closet tap Room 30	MUV532	Monday, June 8, 2020	0.001	Passed	0.1300	Passed	
Gorsebrook Junior High School	Wood Work Rm tap Room 28 28	MUV533	Monday, June 8, 2020	-	Passed	0.2500	Passed	
Graham Creighton Junior High School	Admin Wash Room tap	MYA071	Monday, June 22, 2020	0.002	Passed	0.2800	Passed	
Graham Creighton Junior High School	Science Room tap Room 184	MYA072	Monday, June 22, 2020	-	Passed	1.3000	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 1 by Room 184	MYA073	Monday, June 22, 2020	-	Passed	0.1400	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 2 by Room 184	MYA074	Monday, June 22, 2020	-	Passed	0.1300	Passed	
Graham Creighton Junior High School	Janitors Closet tap	MYA075	Monday, June 22, 2020	0.004	Passed	1.2000	Passed	
Graham Creighton Junior High School	Fountain between Wash Room's	MYA076	Monday, June 22, 2020	0.004	Passed	1.5000	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 1 before Room 162	MYA077	Monday, June 22, 2020	0.001	Passed	0.1400	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 2 before Room 162	MYA078	Monday, June 22, 2020	0.001	Passed	0.1300	Passed	
Graham Creighton Junior High School	Learning Centre tap Room 162	MYA079	Monday, June 22, 2020	0.001	Passed	0.6000	Passed	
Graham Creighton Junior High School	Class Room tap Room 165	MYA080	Monday, June 22, 2020	-	Passed	0.2700	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 1 Room 112	MYA081	Monday, June 22, 2020	0.004	Passed	0.3100	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 2 Room 112	MYA082	Monday, June 22, 2020	0.001	Passed	0.2400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Graham Creighton Junior High School	Girls Wash Room tap 3 Room 112	MYA083	Monday, June 22, 2020	0.004	Passed	0.2200	Passed	
Graham Creighton Junior High School	Gender Neutral Wash Room tap Room 113	MYA084	Monday, June 22, 2020	0.002	Passed	0.1000	Passed	
Graham Creighton Junior High School	Fountain by Room 113	MYA085	Monday, June 22, 2020	-	Passed	0.1700	Passed	
Graham Creighton Junior High School	Janitors Closet tap between Wash Room's	MYA086	Monday, June 22, 2020	0.004	Passed	0.3100	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 1 by Room 113	MYA087	Monday, June 22, 2020	0.003	Passed	0.2400	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 2 by Room 113	MYA088	Monday, June 22, 2020	0.001	Passed	0.2200	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 3 by Room 113	MYA089	Monday, June 22, 2020	0.001	Passed	0.3600	Passed	
Graham Creighton Junior High School	Fountain by Boys Wash Room	MYA090	Monday, June 22, 2020	-	Passed	0.7800	Passed	
Graham Creighton Junior High School	Girls Locker Room tap 1	MYA091	Monday, June 22, 2020	-	Passed	0.3900	Passed	
Graham Creighton Junior High School	Girls Locker Room tap 2	MYA092	Monday, June 22, 2020	-	Passed	0.3300	Passed	
Graham Creighton Junior High School	Gym Office Wash Room tap	MYA093	Monday, June 22, 2020	-	Passed	0.1300	Passed	
Graham Creighton Junior High School	Boys Locker Room tap 1	MYA094	Monday, June 22, 2020	-	Passed	0.7100	Passed	
Graham Creighton Junior High School	Boys Locker Room tap 2	MYA095	Monday, June 22, 2020	0.001	Passed	0.3200	Passed	
Graham Creighton Junior High School	Community Area tap Room 134	MYA096	Monday, June 22, 2020	0.001	Passed	0.1600	Passed	
Graham Creighton Junior High School	Meeting Room tap by Room 134	MYA097	Monday, June 22, 2020	0.001	Passed	1.1000	Passed	
Graham Creighton Junior High School	Cafeteria tap 1 Room 121	MYA099	Monday, June 22, 2020	-	Passed	0.6700	Passed	
Graham Creighton Junior High School	Cafeteria tap 2 Room 121	MYA100	Monday, June 22, 2020	-	Passed	0.8000	Passed	
Graham Creighton Junior High School	Cafeteria tap 3 Room 121	MYA101	Monday, June 22, 2020	0.001	Passed	0.1500	Passed	
Graham Creighton Junior High School	Cafeteria tap 4 Room 121	MYA102	Monday, June 22, 2020	-	Passed	0.0350	Passed	
Graham Creighton Junior High School	2nd Floor fountain by Room 121	MYA103	Monday, June 22, 2020	0.001	Passed	1.4000	Passed	
Graham Creighton Junior High School	Art Room tap 1	MYA104	Monday, June 22, 2020	-	Passed	0.2800	Passed	
Graham Creighton Junior High School	Art Room tap 2	MYA105	Monday, June 22, 2020	0.001	Passed	0.1200	Passed	
Graham Creighton Junior High School	Tech Ed. Room tap	MYA106	Monday, June 22, 2020	0.003	Passed	0.2600	Passed	
Graham Creighton Junior High School	Staff Room Kitchen tap	MYA107	Monday, June 22, 2020	0.001	Passed	0.1800	Passed	
Graham Creighton Junior High School	Staff Room Wash Room tap	MYA108	Monday, June 22, 2020	-	Passed	0.2300	Passed	
Graham Creighton Junior High School	Library tap	MYA109	Monday, June 22, 2020	-	Passed	0.1700	Passed	
Graham Creighton Junior High School	Staff Wash Room tap in Gym	MYA110	Monday, June 22, 2020	0.001	Passed	0.1700	Passed	
Graham Creighton Junior High School	Fountain by Room 230	MYA111	Monday, June 22, 2020	-	Passed	0.2000	Passed	
Graham Creighton Junior High School	Staff Wash Room tap Room 230	MYA112	Monday, June 22, 2020	-	Passed	0.1900	Passed	
Graham Creighton Junior High School	2nd Floor Girls Wash Room tap 1	MYA113	Monday, June 22, 2020	-	Passed	0.1500	Passed	
Graham Creighton Junior High School	2nd Floor Girls Wash Room tap 2	MYA114	Monday, June 22, 2020	-	Passed	0.1600	Passed	
Graham Creighton Junior High School	Janitors Closet tap by Girls Wash Room	MYA115	Monday, June 22, 2020	-	Passed	0.3700	Passed	
Graham Creighton Junior High School	Fountain between Wash Room's	MYA116	Monday, June 22, 2020	-	Passed	0.7700	Passed	
Graham Creighton Junior High School	2nd Floor Boys Wash Room tap 1	MYA117	Monday, June 22, 2020	0.002	Passed	0.3300	Passed	
Graham Creighton Junior High School	2nd Floor Boys Wash Room tap 2	MYA118	Monday, June 22, 2020	-	Passed	0.1800	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 1 by Room 205	MYA119	Monday, June 22, 2020	-	Passed	0.1700	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 2 by Room 205	MYA120	Monday, June 22, 2020	0.001	Passed	0.1100	Passed	
Graham Creighton Junior High School	Girls Wash Room tap 3 by Room 205	MYA126	Monday, June 22, 2020	0.001	Passed	0.4300	Passed	
Graham Creighton Junior High School	Staff Wash Room tap Room 205	MYA127	Monday, June 22, 2020	0.001	Passed	0.0930	Passed	
Graham Creighton Junior High School	Fountain by Room 208	MYA128	Monday, June 22, 2020	-	Passed	1.0000	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 1 Room 208	MYA129	Monday, June 22, 2020	0.001	Passed	0.5200	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 2 Room 208	MYA130	Monday, June 22, 2020	0.001	Passed	0.1300	Passed	
Graham Creighton Junior High School	Boys Wash Room tap 3 Room 208	MYA131	Monday, June 22, 2020	0.001	Passed	0.2000	Passed	
Graham Creighton Junior High School	Janitors Closet tap by Room 208	MYA132	Monday, June 22, 2020	0.001	Passed	0.1100	Passed	
Graham Creighton Junior High School	Family Studies tap 1 Room 209	MYA133	Monday, June 22, 2020	0.001	Passed	0.2400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Graham Creighton Junior High School	Family Studies tap 2 Room 209	NKI307	Tuesday, August 18, 2020	0.000	Passed	1.1000	Passed	
Graham Creighton Junior High School	Family Studies tap 3 Room 209	MYA135	Monday, June 22, 2020	-	Passed	0.6700	Passed	
Graham Creighton Junior High School	Family Studies tap 4 Room 209	MYA136	Monday, June 22, 2020	0.004	Passed	1.2000	Passed	
Graham Creighton Junior High School	Janitors Closet tap before Room 121	NAM737	Tuesday, June 30, 2020	0.001	Passed	0.1100	Passed	
Grosvenor-Wentworth Park Elementary School	Staff Room tap	MUL565	Wednesday, June 3, 2020	0.002	Passed	0.0300	Passed	
Grosvenor-Wentworth Park Elementary School	Janitors Closet tap near Room 113	MUL566	Wednesday, June 3, 2020	0.001	Passed	0.0490	Passed	
Grosvenor-Wentworth Park Elementary School	Class Room tap by Room 113	MUL567	Wednesday, June 3, 2020	0.008	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Grosvenor-Wentworth Park Elementary School	Class Room tap Room 113	MUL568	Wednesday, June 3, 2020	0.001	Passed	0.0860	Passed	
Grosvenor-Wentworth Park Elementary School	Class Room tap before Room 122	MUL569	Wednesday, June 3, 2020	0.014	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 1 by Room 122	MUL570	Wednesday, June 3, 2020	-	Passed	0.0600	Passed	
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 2 by Room 122	MUL571	Wednesday, June 3, 2020	0.002	Passed	0.0860	Passed	
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 1 by Room 122	MUL573	Wednesday, June 3, 2020	0.001	Passed	0.0740	Passed	
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 2 by Room 122	MUL574	Wednesday, June 3, 2020	0.001	Passed	0.0890	Passed	
Grosvenor-Wentworth Park Elementary School	Fountain by Girls Wash Room	MUL575	Wednesday, June 3, 2020	-	Passed	0.7000	Passed	
Grosvenor-Wentworth Park Elementary School	Gym Office Wash Room tap	MUL576	Wednesday, June 3, 2020	0.004	Passed	0.0580	Passed	
Grosvenor-Wentworth Park Elementary School	Class Room tap Room 145	MUL577	Wednesday, June 3, 2020	0.001	Passed	0.1000	Passed	
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 1 by Room 145	MUL578	Wednesday, June 3, 2020	-	Passed	0.0420	Passed	
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 2 by Room 145	MUL579	Wednesday, June 3, 2020	0.001	Passed	0.0640	Passed	
Grosvenor-Wentworth Park Elementary School	Janitors Closet tap between Wash Room's	MUL580	Wednesday, June 3, 2020	0.002	Passed	0.0290	Passed	
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 1 after Room 145	MUL581	Wednesday, June 3, 2020	0.001	Passed	0.0450	Passed	
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 2 after Room 145	MUL582	Wednesday, June 3, 2020	0.001	Passed	0.0300	Passed	
Grosvenor-Wentworth Park Elementary School	Class Room tap Room 7	MUL583	Wednesday, June 3, 2020	0.002	Passed	0.1200	Passed	
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 1 by Room 7	MUL584	Wednesday, June 3, 2020	0.008	Exceeded	0.0590	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 2 by Room 7	MUL585	Wednesday, June 3, 2020	-	Passed	0.0210	Passed	
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 3 by Room 7	MUL586	Wednesday, June 3, 2020	-	Passed	0.0200	Passed	
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 4 by Room 7	MUL587	Wednesday, June 3, 2020	0.001	Passed	0.0560	Passed	
Grosvenor-Wentworth Park Elementary School	Girls Wash Room tap 5 by Room 7	MUL588	Wednesday, June 3, 2020	0.002	Passed	0.0300	Passed	
Grosvenor-Wentworth Park Elementary School	Fountain by Wash Room's	MUL589	Wednesday, June 3, 2020	-	Passed	0.2200	Passed	
Grosvenor-Wentworth Park Elementary School	Staff Wash Room tap	MUL590	Wednesday, June 3, 2020	0.005	Exceeded	0.0750	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 1 after Room 7	MUL591	Wednesday, June 3, 2020	-	Passed	0.0120	Passed	
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 2 after Room 7	MUL592	Wednesday, June 3, 2020	-	Passed	0.0060	Passed	
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 3 after Room 7	MUL593	Wednesday, June 3, 2020	-	Passed	0.0073	Passed	
Grosvenor-Wentworth Park Elementary School	Boys Wash Room tap 4 after Room 7	MUL594	Wednesday, June 3, 2020	-	Passed	0.0049	Passed	
Grosvenor-Wentworth Park Elementary School	Janitors Closet tap after Boys Wash Room	MUL595	Wednesday, June 3, 2020	0.001	Passed	0.0200	Passed	
Grosvenor-Wentworth Park Elementary School	Fountain by Janitors Closet	MUL596	Wednesday, June 3, 2020	-	Passed	0.1100	Passed	
Grosvenor-Wentworth Park PP	Staff Kitchen tap	NTW459	Thursday, October 1, 2020	0.003	Passed	0.0890	Passed	
Grosvenor-Wentworth Park PP	Wash Room tap 1	NTW460	Thursday, October 1, 2020	0.002	Passed	0.1010	Passed	
Grosvenor-Wentworth Park PP	Wash Room tap 2	NTW461	Thursday, October 1, 2020	0.003	Passed	0.0800	Passed	
Grosvenor-Wentworth Park PP	Wash Room tap 3	NTW462	Thursday, October 1, 2020	0.003	Passed	0.0680	Passed	
Grosvenor-Wentworth Park PP	Wash Room tap 4	NTW463	Thursday, October 1, 2020	0.005	Passed	0.0620	Passed	
Grosvenor-Wentworth Park PP	Gender Neutral Wash Room tap	NTW464	Thursday, October 1, 2020	0.003	Passed	0.0890	Passed	
Halifax Central Junior High School	1st Floor first aid Room tap	MTN563	Thursday, May 28, 2020	-	Passed	0.0300	Passed	
Halifax Central Junior High School	fountain before Boys Wash Room	MTN564	Thursday, May 28, 2020	-	Passed	0.2100	Passed	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 1	MTN565	Thursday, May 28, 2020	-	Passed	0.0220	Passed	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 2	MTN566	Thursday, May 28, 2020	-	Passed	0.0210	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Halifax Central Junior High School	1st Floor Boys Wash Room tap 3	MTN567	Thursday, May 28, 2020	-	Passed	0.0210	Passed	
Halifax Central Junior High School	1st Floor Boys Wash Room tap 4	MTN568	Thursday, May 28, 2020	-	Passed	0.0200	Passed	
Halifax Central Junior High School	Art Room tap Room 7	MTN569	Thursday, May 28, 2020	0.004	Passed	0.7800	Passed	
Halifax Central Junior High School	Woodshop sink tap	MTN570	Thursday, May 28, 2020	0.001	Passed	0.5000	Passed	
Halifax Central Junior High School	Girls Locker Room tap 1	MTN572	Thursday, May 28, 2020	-	Passed	0.0390	Passed	
Halifax Central Junior High School	Girls Locker Room tap 2	MTN587	Thursday, May 28, 2020	-	Passed	0.0390	Passed	
Halifax Central Junior High School	Boys Locker Room tap 1	MTN588	Thursday, May 28, 2020	-	Passed	0.0082	Passed	
Halifax Central Junior High School	Boys Locker Room tap 2	MTN589	Thursday, May 28, 2020	-	Passed	0.0078	Passed	
Halifax Central Junior High School	Gender Neutral Wash Room tap	MTN590	Thursday, May 28, 2020	-	Passed	0.0065	Passed	
Halifax Central Junior High School	Fountain by Room 4	MTN591	Thursday, May 28, 2020	0.003	Passed	0.1300	Passed	
Halifax Central Junior High School	Girls Wash Room tap 1 by Room 4	MTN592	Thursday, May 28, 2020	0.001	Passed	0.1600	Passed	
Halifax Central Junior High School	Girls Wash Room tap 2 by Room 4	MTN593	Thursday, May 28, 2020	0.001	Passed	0.0780	Passed	
Halifax Central Junior High School	Girls Wash Room tap 3 by Room 4	MTN594	Thursday, May 28, 2020	0.001	Passed	0.0450	Passed	
Halifax Central Junior High School	Girls Wash Room tap 4 by Room 4	MTN595	Thursday, May 28, 2020	-	Passed	0.0370	Passed	
Halifax Central Junior High School	Girls Wash Room tap 5 by Room 4	MTN596	Thursday, May 28, 2020	-	Passed	0.0320	Passed	
Halifax Central Junior High School	Staff Room tap	MTN601	Thursday, May 28, 2020	0.002	Passed	0.0480	Passed	
Halifax Central Junior High School	Class Room tap Room 17	MTN602	Thursday, May 28, 2020	-	Passed	0.0250	Passed	
Halifax Central Junior High School	Family Studies tap 1 Room 9	MTN603	Thursday, May 28, 2020	0.003	Passed	0.2900	Passed	
Halifax Central Junior High School	Family Studies tap 2 Room 9	MTN604	Thursday, May 28, 2020	0.001	Passed	0.1300	Passed	
Halifax Central Junior High School	Family Studies tap 3 Room 9	MTN605	Thursday, May 28, 2020	0.001	Passed	0.0640	Passed	
Halifax Central Junior High School	Girls Wash Room tap 1 by Room 9	MTN606	Thursday, May 28, 2020	0.001	Passed	0.1200	Passed	
Halifax Central Junior High School	Girls Wash Room tap 2 by Room 9	MTN607	Thursday, May 28, 2020	0.001	Passed	0.1200	Passed	
Halifax Central Junior High School	Girls Wash Room tap 3 by Room 9	MTN608	Thursday, May 28, 2020	0.001	Passed	0.0730	Passed	
Halifax Central Junior High School	Girls Wash Room tap 4 by Room 9	MTN609	Thursday, May 28, 2020	-	Passed	0.0200	Passed	
Halifax Central Junior High School	Girls Wash Room tap 5 by Room 9	MTN610	Thursday, May 28, 2020	-	Passed	0.0190	Passed	
Halifax Central Junior High School	Fountain by Room 9	MTN612	Thursday, May 28, 2020	-	Passed	0.0760	Passed	
Halifax Central Junior High School	Gender Neutral Wash Room tap Room 22	MTN613	Thursday, May 28, 2020	-	Passed	0.0130	Passed	
Halifax Central Junior High School	VP Office Wash Room tap	MTN614	Thursday, May 28, 2020	0.002	Passed	0.0800	Passed	
Halifax Central Junior High School	Boys Wash Room tap 1 by Office	MTN615	Thursday, May 28, 2020	-	Passed	0.0150	Passed	
Halifax Central Junior High School	Boys Wash Room tap 2 by Office	MTN616	Thursday, May 28, 2020	-	Passed	0.0140	Passed	
Halifax Central Junior High School	Boys Wash Room tap 3 by Office	MTN617	Thursday, May 28, 2020	-	Passed	0.0140	Passed	
Halifax Central Junior High School	Boys Wash Room tap 4 by Office	MTN618	Thursday, May 28, 2020	-	Passed	0.0140	Passed	
Halifax Central Junior High School	Chem Lab tap 1	MTN619	Thursday, May 28, 2020	0.001	Passed	0.0170	Passed	
Halifax Central Junior High School	Chem Lab tap 2	MTN620	Thursday, May 28, 2020	0.001	Passed	0.0120	Passed	
Halifax Central Junior High School	Upstairs fountain	MYZ617	Thursday, June 25, 2020	0.001	Passed	0.1800	Passed	
Halifax Central Junior High School	Storage Room in Gym tap (right back corner)	NFZ852	Thursday, July 30, 2020	0.003	Passed	0.0810	Passed	
Halifax West High School	Class Room tap 1 Room B329	MUJ165	Tuesday, June 2, 2020	0.007	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only..
Halifax West High School	Class Room tap 2 Room B329	MUJ166	Tuesday, June 2, 2020	-	Passed	0.0770	Passed	
Halifax West High School	Class Room tap Room B327	MUJ167	Tuesday, June 2, 2020	-	Passed	0.2000	Passed	
Halifax West High School	Class Room tap Room B322	MUJ168	Tuesday, June 2, 2020	-	Passed	0.8300	Passed	
Halifax West High School	Class Room tap Room B315	MUJ169	Tuesday, June 2, 2020	-	Passed	0.4200	Passed	
Halifax West High School	Class Room tap Room B317	MUJ170	Tuesday, June 2, 2020	-	Passed	0.1400	Passed	
Halifax West High School	Class Room tap Room B316	MUJ171	Tuesday, June 2, 2020	-	Passed	0.0310	Passed	
Halifax West High School	Fountain after Room B315	MUJ172	Tuesday, June 2, 2020	-	Passed	0.4600	Passed	
Halifax West High School	Class Room tap Room A354	MUJ173	Tuesday, June 2, 2020	0.001	Passed	0.7100	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Halifax West High School	Class Room tap 1 Room A353	MUJ174	Tuesday, June 2, 2020	-	Passed	0.3400	Passed	
Halifax West High School	Class Room tap 2 Room A353	MUJ175	Tuesday, June 2, 2020	-	Passed	0.1100	Passed	
Halifax West High School	Class Room tap 3 Room A353	MUJ176	Tuesday, June 2, 2020	-	Passed	0.3600	Passed	
Halifax West High School	Class Room tap 4 Room A353	MUJ177	Tuesday, June 2, 2020	-	Passed	0.6400	Passed	
Halifax West High School	Room A352 tap 1	MUJ178	Tuesday, June 2, 2020	0.004	Passed	0.3100	Passed	
Halifax West High School	Room A352 tap 2	MUJ179	Tuesday, June 2, 2020	0.034	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only. and retested. Other sources available
Halifax West High School	Room A352 tap 3	MUJ180	Tuesday, June 2, 2020	0.002	Passed	0.9800	Passed	
Halifax West High School	Room A352 tap 4	MUJ181	Tuesday, June 2, 2020	0.099	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Room A352 tap 5	MUJ182	Tuesday, June 2, 2020	0.001	Passed	0.8500	Passed	
Halifax West High School	Room A351 tap 1	MUJ183	Tuesday, June 2, 2020	-	Passed	0.9100	Passed	
Halifax West High School	Room A351 tap 2	MUJ184	Tuesday, June 2, 2020	0.016	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Room A351 tap 3	MUJ185	Tuesday, June 2, 2020	0.013	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Room A351 tap 4	MUJ186	Tuesday, June 2, 2020	-	Passed	0.7400	Passed	
Halifax West High School	Room A351 tap 5	MUJ187	Tuesday, June 2, 2020	0.002	Passed	0.1800	Passed	
Halifax West High School	Room A350 tap 3	MUJ190	Tuesday, June 2, 2020	0.002	Passed	0.1100	Passed	
Halifax West High School	Room A350 tap 4	MUJ191	Tuesday, June 2, 2020	0.006	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Room A350 tap 5	MUJ192	Tuesday, June 2, 2020	0.002	Passed	0.4200	Passed	
Halifax West High School	Gender Neutral Wash Room tap Room A332	MUJ193	Tuesday, June 2, 2020	-	Passed	0.0370	Passed	
Halifax West High School	Room A343 tap	MUJ194	Tuesday, June 2, 2020	0.008	Exceeded	0.4900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Room A340 tap 1	MUJ195	Tuesday, June 2, 2020	0.001	Passed	0.6000	Passed	
Halifax West High School	Room A340 tap 2	MUJ196	Tuesday, June 2, 2020	0.001	Passed	0.4300	Passed	
Halifax West High School	Room A340 tap 3	MUJ197	Tuesday, June 2, 2020	0.008	Exceeded	0.0200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Room A340 tap 4	MUJ198	Tuesday, June 2, 2020	0.002	Passed	0.5400	Passed	
Halifax West High School	Room A340 tap 5	MUJ199	Tuesday, June 2, 2020	0.006	Exceeded	0.0180	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Room C352 tap	MUJ200	Tuesday, June 2, 2020	0.026	Exceeded	0.0960	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Mech Room tap after Room C322H	MUJ201	Tuesday, June 2, 2020	0.067	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Fountain after Room C226	MUJ202	Tuesday, June 2, 2020	-	Passed	0.2100	Passed	Fountain replacement in progress
Halifax West High School	Dressing Room tap 1 Room B222	MUJ203	Tuesday, June 2, 2020	-	Passed	0.0720	Passed	
Halifax West High School	Dressing Room tap 2 Room B222	MUJ204	Tuesday, June 2, 2020	0.001	Passed	0.1600	Passed	
Halifax West High School	Tech ed. Room tap Room B214	MUJ205	Tuesday, June 2, 2020	0.001	Passed	0.2400	Passed	
Halifax West High School	Kitchen/Cafeteria tap 1 Room B202	MUJ206	Tuesday, June 2, 2020	0.002	Passed	0.3200	Passed	
Halifax West High School	Kitchen/Cafeteria tap 2 Room B202	MUJ207	Tuesday, June 2, 2020	0.001	Passed	0.4400	Passed	
Halifax West High School	Kitchen/Cafeteria tap 3 Room B202	MUJ208	Tuesday, June 2, 2020	0.001	Passed	0.1400	Passed	
Halifax West High School	Main Office Wash Room tap	MUJ209	Tuesday, June 2, 2020	-	Passed	0.1400	Passed	
Halifax West High School	Student Services tap	MUJ210	Tuesday, June 2, 2020	-	Passed	0.1500	Passed	
Halifax West High School	Fountain outside Gym	MUJ211	Tuesday, June 2, 2020	-	Passed	0.2400	Passed	
Halifax West High School	Gym Gender Neutral Wash Room tap	MUJ212	Tuesday, June 2, 2020	-	Passed	0.0350	Passed	
Halifax West High School	Fountain in Gym	MUJ213	Tuesday, June 2, 2020	-	Passed	0.0790	Passed	Fountain replacement in progress
Halifax West High School	Gym Office tap Room A267	MUJ214	Tuesday, June 2, 2020	0.001	Passed	0.2700	Passed	
Halifax West High School	Girls Locker Room 1 tap	MUJ215	Tuesday, June 2, 2020	0.001	Passed	0.4500	Passed	
Halifax West High School	Boys Locker Room 1 tap	MUJ216	Tuesday, June 2, 2020	-	Passed	0.1800	Passed	
Halifax West High School	Boys Locker Room 2 tap	MUJ217	Tuesday, June 2, 2020	-	Passed	0.3400	Passed	
Halifax West High School	Girls Locker Room 2 tap	MUJ218	Tuesday, June 2, 2020	0.002	Passed	0.2000	Passed	
Halifax West High School	Gym Office tap Room A264	MUJ219	Tuesday, June 2, 2020	-	Passed	0.4500	Passed	
Halifax West High School	Fountain by Room A224	MUJ220	Tuesday, June 2, 2020	-	Passed	0.3100	Passed	Fountain replacement in progress

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Halifax West High School	Boys Wash Room tap 1 Room A221	MUJ221	Tuesday, June 2, 2020	-	Passed	0.0740	Passed	
Halifax West High School	Boys Wash Room tap 2 Room A221	MUJ222	Tuesday, June 2, 2020	-	Passed	0.1100	Passed	
Halifax West High School	Boys Wash Room tap 3 Room A221	MUJ223	Tuesday, June 2, 2020	-	Passed	0.1500	Passed	
Halifax West High School	Boys Wash Room tap 4 Room A221	MUJ224	Tuesday, June 2, 2020	0.002	Passed	0.0910	Passed	
Halifax West High School	Janitors Closet tap by Room A221	MUJ225	Tuesday, June 2, 2020	-	Passed	0.0320	Passed	
Halifax West High School	Girls Wash Room tap 1 Room A224	MUJ290	Tuesday, June 2, 2020	0.001	Passed	0.1200	Passed	
Halifax West High School	Girls Wash Room tap 2 Room A224	MUJ291	Tuesday, June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room tap 3 Room A224	MUJ292	Tuesday, June 2, 2020	-	Passed	0.2100	Passed	
Halifax West High School	Girls Wash Room tap 4 Room A224	MUJ293	Tuesday, June 2, 2020	-	Passed	0.1600	Passed	
Halifax West High School	Class Room tap Room A225	MUJ294	Tuesday, June 2, 2020	-	Passed	0.4600	Passed	
Halifax West High School	Gender Neutral Wash Room tap 1 Room A226	MUJ295	Tuesday, June 2, 2020	-	Passed	0.1900	Passed	
Halifax West High School	Gender Neutral Wash Room tap 2 Room A226	MUJ296	Tuesday, June 2, 2020	0.001	Passed	0.1500	Passed	
Halifax West High School	Staff Wash Room tap Room A230	MUJ297	Tuesday, June 2, 2020	0.002	Passed	0.2300	Passed	
Halifax West High School	Girls Wash Room tap 1 Room A234	MUJ298	Tuesday, June 2, 2020	-	Passed	0.1300	Passed	
Halifax West High School	Girls Wash Room tap 2 Room A234	MUJ299	Tuesday, June 2, 2020	-	Passed	0.1300	Passed	
Halifax West High School	Girls Wash Room tap 3 Room A234	MUJ300	Tuesday, June 2, 2020	0.001	Passed	0.1300	Passed	
Halifax West High School	Girls Wash Room tap 4 Room A234	MUJ301	Tuesday, June 2, 2020	0.007	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Janitors Closet tap by Room A234	MUJ302	Tuesday, June 2, 2020	0.001	Passed	0.0570	Passed	
Halifax West High School	Boys Wash Room tap 1 Room A235	MUJ303	Tuesday, June 2, 2020	0.001	Passed	0.0720	Passed	
Halifax West High School	Boys Wash Room tap 2 Room A235	MUJ304	Tuesday, June 2, 2020	-	Passed	0.2600	Passed	
Halifax West High School	Boys Wash Room tap 3 Room A235	MUJ305	Tuesday, June 2, 2020	-	Passed	0.2500	Passed	
Halifax West High School	Boys Wash Room tap 4 Room A235	MUJ306	Tuesday, June 2, 2020	-	Passed	0.2600	Passed	
Halifax West High School	Fountain by Student Gov. Room	MUJ307	Tuesday, June 2, 2020	-	Passed	0.3500	Passed	Fountain replacement in progress
Halifax West High School	Mech. Room tap Room C135	MUJ308	Tuesday, June 2, 2020	0.001	Passed	0.0710	Passed	
Halifax West High School	Fountain by Room C133	MUJ309	Tuesday, June 2, 2020	-	Passed	0.1000	Passed	Fountain replacement in progress
Halifax West High School	Boys Wash Room tap 1 Room C161	MUJ310	Tuesday, June 2, 2020	0.001	Passed	0.1800	Passed	
Halifax West High School	Boys Wash Room tap 2 Room C161	MUJ311	Tuesday, June 2, 2020	-	Passed	0.2200	Passed	
Halifax West High School	Boys Wash Room tap 3 Room C161	MUJ312	Tuesday, June 2, 2020	0.001	Passed	0.1700	Passed	
Halifax West High School	Staff Wash Room tap Room C160	MUJ313	Tuesday, June 2, 2020	0.004	Passed	0.2200	Passed	
Halifax West High School	Girls Wash Room tap 1 Room C162	MUJ314	Tuesday, June 2, 2020	0.006	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Girls Wash Room tap 2 Room C162	MUJ315	Tuesday, June 2, 2020	-	Passed	0.2300	Passed	
Halifax West High School	Girls Wash Room tap 3 Room C162	MUJ316	Tuesday, June 2, 2020	-	Passed	0.1800	Passed	
Halifax West High School	Girls Wash Room tap 1 Room C172	MUJ317	Tuesday, June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room tap 2 Room C172	MUJ318	Tuesday, June 2, 2020	-	Passed	0.2200	Passed	
Halifax West High School	Girls Wash Room tap 3 Room C172	MUJ319	Tuesday, June 2, 2020	0.004	Passed	0.3700	Passed	
Halifax West High School	Staff Wash Room tap Room C170	MUJ320	Tuesday, June 2, 2020	-	Passed	0.0470	Passed	
Halifax West High School	Boys Wash Room tap 1 Room C171	MUJ321	Tuesday, June 2, 2020	0.010	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Halifax West High School	Boys Wash Room tap 2 Room C171	MUJ322	Tuesday, June 2, 2020	-	Passed	0.5000	Passed	
Halifax West High School	Boys Wash Room tap 3 Room C171	MUJ323	Tuesday, June 2, 2020	-	Passed	0.2100	Passed	
Halifax West High School	Fountain after Room C171	MUJ324	Tuesday, June 2, 2020	-	Passed	0.5500	Passed	Fountain replacement in progress
Halifax West High School	Gender Neutral Wash Room tap Room C152	MUJ325	Tuesday, June 2, 2020	0.001	Passed	0.1800	Passed	
Halifax West High School	Janitors Closet tap After Room C152	MUJ326	Tuesday, June 2, 2020	-	Passed	0.0370	Passed	
Halifax West High School	Girls Wash Room tap 1 Room A313	MUJ327	Tuesday, June 2, 2020	0.003	Passed	0.2500	Passed	
Halifax West High School	Girls Wash Room tap 2 Room A313	MUJ328	Tuesday, June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room tap 3 Room A313	MUJ329	Tuesday, June 2, 2020	-	Passed	0.1400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Halifax West High School	Gender Neutral Wash Room tap by Room A312	MUJ330	Tuesday, June 2, 2020	-	Passed	0.1800	Passed	
Halifax West High School	Boys Wash Room tap 1 Room A312	MUJ331	Tuesday, June 2, 2020	-	Passed	0.3500	Passed	
Halifax West High School	Boys Wash Room tap 2 Room A312	MUJ332	Tuesday, June 2, 2020	-	Passed	0.4200	Passed	
Halifax West High School	Boys Wash Room tap 3 Room A312	MUJ333	Tuesday, June 2, 2020	0.001	Passed	0.1900	Passed	
Halifax West High School	Fountain by Room A311	MUJ334	Tuesday, June 2, 2020	-	Passed	0.3500	Passed	Fountain replacement in progress
Halifax West High School	Chem Lab tap 1 Room A333	MUJ335	Tuesday, June 2, 2020	-	Passed	0.4000	Passed	
Halifax West High School	Chem Lab tap 2 Room A333	MUJ336	Tuesday, June 2, 2020	-	Passed	0.4500	Passed	
Halifax West High School	Chem Lab tap 3 Room A333	MUJ337	Tuesday, June 2, 2020	0.001	Passed	0.2500	Passed	
Halifax West High School	Chem Lab tap 4 Room A333	MUJ338	Tuesday, June 2, 2020	-	Passed	0.9900	Passed	
Halifax West High School	Chem Lab tap 5 Room A333	MUJ339	Tuesday, June 2, 2020	-	Passed	0.6300	Passed	
Halifax West High School	Chem Lab tap 6 Room A333	MUJ340	Tuesday, June 2, 2020	0.001	Passed	0.3800	Passed	
Halifax West High School	Chem Lab tap 7 Room A333	MUJ341	Tuesday, June 2, 2020	0.001	Passed	0.3900	Passed	
Halifax West High School	Chem Lab tap 8 Room A333	MUJ342	Tuesday, June 2, 2020	0.001	Passed	0.4300	Passed	
Halifax West High School	Chem Lab tap 9 Room A333	NAO728	Friday, July 3, 2020	-	Passed	0.5300	Passed	
Halifax West High School	Chem Lab tap 10 Room A333	MUJ343	Tuesday, June 2, 2020	0.001	Passed	0.3800	Passed	
Halifax West High School	Chem Lab tap 1 Room A329	MUJ344	Tuesday, June 2, 2020	0.001	Passed	0.3400	Passed	
Halifax West High School	Chem Lab tap 2 Room A329	MUJ345	Tuesday, June 2, 2020	0.001	Passed	0.1700	Passed	
Halifax West High School	Chem Lab tap 3 Room A329	MUJ346	Tuesday, June 2, 2020	-	Passed	0.4300	Passed	
Halifax West High School	Chem Lab tap 4 Room A329	MUJ347	Tuesday, June 2, 2020	0.001	Passed	0.3400	Passed	
Halifax West High School	Chem Lab tap 5 Room A329	MUJ348	Tuesday, June 2, 2020	0.002	Passed	0.3200	Passed	
Halifax West High School	Chem Lab tap 6 Room A329	MUJ349	Tuesday, June 2, 2020	-	Passed	0.5600	Passed	
Halifax West High School	Chem Lab tap 7 Room A329	MUJ350	Tuesday, June 2, 2020	-	Passed	0.4900	Passed	
Halifax West High School	Chem Lab tap 8 Room A329	MUJ351	Tuesday, June 2, 2020	0.001	Passed	0.3900	Passed	
Halifax West High School	Chem Lab tap 9 Room A329	MUJ352	Tuesday, June 2, 2020	-	Passed	0.3000	Passed	
Halifax West High School	Boys Wash Room tap 1 Room A326	MUJ353	Tuesday, June 2, 2020	0.004	Passed	0.1400	Passed	
Halifax West High School	Boys Wash Room tap 2 Room A326	MUJ354	Tuesday, June 2, 2020	-	Passed	0.3100	Passed	
Halifax West High School	Boys Wash Room tap 3 Room A326	MUJ355	Tuesday, June 2, 2020	-	Passed	0.2000	Passed	
Halifax West High School	Janitors Closet tap Room A324	MUJ356	Tuesday, June 2, 2020	0.001	Passed	0.0370	Passed	
Halifax West High School	Girls Wash Room tap 1 Room A325	MUJ357	Tuesday, June 2, 2020	-	Passed	0.1700	Passed	
Halifax West High School	Girls Wash Room tap 2 Room A325	MUJ358	Tuesday, June 2, 2020	-	Passed	0.1100	Passed	
Halifax West High School	Girls Wash Room tap 3 Room A325	MUJ363	Tuesday, June 2, 2020	0.003	Passed	0.1100	Passed	
Halifax West High School	Fountain after Girls Wash Room	MUJ364	Tuesday, June 2, 2020	-	Passed	0.4400	Passed	
Halifax West High School	Staff Wash Room tap Room A321	MUJ365	Tuesday, June 2, 2020	-	Passed	0.0830	Passed	
Halifax West High School	Biology Lab tap 1 Room A319	MUJ366	Tuesday, June 2, 2020	0.001	Passed	0.4500	Passed	
Halifax West High School	Biology Lab tap 2 Room A319	MUJ367	Tuesday, June 2, 2020	-	Passed	0.9300	Passed	
Halifax West High School	Biology Lab tap 3 Room A319	MUJ368	Tuesday, June 2, 2020	0.002	Passed	0.3300	Passed	
Halifax West High School	Biology Lab tap 4 Room A319	MUJ369	Tuesday, June 2, 2020	0.001	Passed	0.1000	Passed	
Halifax West High School	Biology Lab tap 5 Room A319	MUJ370	Tuesday, June 2, 2020	-	Passed	0.8500	Passed	
Halifax West High School	Biology Lab tap 6 Room A319	MUJ371	Tuesday, June 2, 2020	-	Passed	0.6000	Passed	
Halifax West High School	Biology Lab tap 7 Room A319	MUJ372	Tuesday, June 2, 2020	-	Passed	0.2000	Passed	
Halifax West High School	Biology Lab tap 1 Room A318	MUJ388	Tuesday, June 2, 2020	0.003	Passed	0.4300	Passed	
Halifax West High School	Biology Lab tap 2 Room A318	MUJ389	Tuesday, June 2, 2020	0.001	Passed	0.5300	Passed	
Halifax West High School	Biology Lab tap 3 Room A318	MUJ390	Tuesday, June 2, 2020	0.001	Passed	0.4300	Passed	
Halifax West High School	Biology Lab tap 4 Room A318	MUJ391	Tuesday, June 2, 2020	-	Passed	0.8500	Passed	
Halifax West High School	Biology Lab tap 5 Room A318	MUJ392	Tuesday, June 2, 2020	0.001	Passed	0.4100	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Halifax West High School	Class Room tap Room A317	MUJ393	Tuesday, June 2, 2020	-	Passed	0.1000	Passed	
Halifax West High School	Gender Neutral Wash Room tap Room A315	MUJ394	Tuesday, June 2, 2020	-	Passed	0.0660	Passed	
Halifax West High School	Fountain before Room A311	MUJ395	Tuesday, June 2, 2020	-	Passed	0.1500	Passed	Fountain replacement in progress
Halifax West High School	Janitors Closet tap Room A311	MUJ396	Tuesday, June 2, 2020	0.002	Passed	0.0800	Passed	
Halifax West High School	Fountain by Room C246	NAO727	Tuesday, June 2, 2020	-	Passed	0.4300	Passed	Fountain replacement in progress
Halifax West High School	Fountain by Room C240	NAO727	Friday, July 3, 2020	-	Passed	0.4300	Passed	Fountain replacement in progress
Halifax West High School	Fountain by Room C147	-	-	-	-	-	-	Fountain replacement in progress
Halifax West High School	Fountain by Room C126	-	-	-	-	-	-	Fountain replacement in progress
Halifax West High School	Fountain by Room B327	-	-	-	-	-	-	Fountain replacement in progress
Halifax West High School	Fountain by Room C346	-	-	-	-	-	-	Fountain replacement in progress
Halifax West High School	Fountain by Room A350	-	-	-	-	-	-	Fountain replacement in progress
Halifax West High School	Fountain by Bella Rosa Aud.	-	-	-	-	-	-	Fountain replacement in progress
Halifax West High School	Fountain by Room B210	-	-	-	-	-	-	Fountain replacement in progress
Hammonds Plains Consolidated School	Gender Neutral Wash Room tap Room 220	MTV690	Monday, June 1, 2020	-	Passed	0.0850	Passed	
Hammonds Plains Consolidated School	Class Room tap Room 219	MTV691	Monday, June 1, 2020	-	Passed	0.2700	Passed	
Hammonds Plains Consolidated School	Fountain Room 219	MTV692	Monday, June 1, 2020	-	Passed	0.1200	Passed	
Hammonds Plains Consolidated School	Cafeteria/Kitchen single compartment sink tap	MTV693	Monday, June 1, 2020	0.001	Passed	0.1900	Passed	
Hammonds Plains Consolidated School	Cafeteria/Kitchen double compartment sink tap	MTV694	Monday, June 1, 2020	-	Passed	0.0680	Passed	
Hammonds Plains Consolidated School	Cafeteria/Kitchen hand washing sink tap	MTV695	Monday, June 1, 2020	-	Passed	0.0460	Passed	
Hammonds Plains Consolidated School	Girls Wash Room tap 1 Room 225	MTV696	Monday, June 1, 2020	-	Passed	0.1300	Passed	
Hammonds Plains Consolidated School	Girls Wash Room tap 2 Room 225	MTV697	Monday, June 1, 2020	-	Passed	0.1500	Passed	
Hammonds Plains Consolidated School	Girls Wash Room tap 3 Room 225	MTV698	Monday, June 1, 2020	-	Passed	0.1100	Passed	
Hammonds Plains Consolidated School	Girls Wash Room tap 4 Room 225	MTV699	Monday, June 1, 2020	-	Passed	0.1300	Passed	
Hammonds Plains Consolidated School	Girls Wash Room tap 5 Room 225	MTV700	Monday, June 1, 2020	-	Passed	0.0850	Passed	
Hammonds Plains Consolidated School	Janitors Closet tap by Room 225	MTV701	Monday, June 1, 2020	-	Passed	0.0440	Passed	
Hammonds Plains Consolidated School	Fountain by Room 225	MTV702	Monday, June 1, 2020	-	Passed	0.0560	Passed	
Hammonds Plains Consolidated School	Boys Wash Room tap 1 by Room 228	MTV703	Monday, June 1, 2020	0.003	Passed	0.2800	Passed	
Hammonds Plains Consolidated School	Boys Wash Room tap 2 by Room 228	MTV704	Monday, June 1, 2020	0.002	Passed	0.2200	Passed	
Hammonds Plains Consolidated School	Boys Wash Room tap 3 by Room 228	MTV705	Monday, June 1, 2020	-	Passed	0.2300	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room tap Room 203C	MTV706	Monday, June 1, 2020	-	Passed	0.0210	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room tap Room 203B	MTV707	Monday, June 1, 2020	-	Passed	0.0220	Passed	
Hammonds Plains Consolidated School	Staff Room Kitchen sink Room 203	MTV708	Monday, June 1, 2020	-	Passed	0.0440	Passed	
Hammonds Plains Consolidated School	Fountain by Room 204	MTV709	Monday, June 1, 2020	0.004	Passed	0.1300	Passed	
Hammonds Plains Consolidated School	Class Room tap Room 209	MTV723	Monday, June 1, 2020	0.013	Exceeded	0.3300	Passed	
Hammonds Plains Consolidated School	Class Room tap Room 210	MTV724	Monday, June 1, 2020	0.003	Passed	0.1500	Passed	
Hammonds Plains Consolidated School	Class Room tap Room 211	NLV788	Wednesday, August 26, 2020	0.000	Passed	0.0040	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room tap Room 238	MTV726	Monday, June 1, 2020	-	Passed	0.0110	Passed	
Hammonds Plains Consolidated School	Staff Gender Neutral Wash Room tap Room 237	MTV727	Monday, June 1, 2020	-	Passed	0.0068	Passed	
Hammonds Plains Consolidated School	Gender Neutral Wash Room tap Room 242	MTV728	Monday, June 1, 2020	-	Passed	0.2300	Passed	
Hammonds Plains Consolidated School	Class Room tap Room 245	NLV789	Wednesday, August 26, 2020	0.000	Passed	0.0070	Passed	
Hammonds Plains Consolidated School	Gender Neutral Wash Room tap Room 245A	MTV730	Monday, June 1, 2020	-	Passed	0.0980	Passed	
Hammonds Plains Consolidated School	Gender Neutral Wash Room tap Room 246A	MTV731	Monday, June 1, 2020	0.002	Passed	0.2800	Passed	
Hammonds Plains Consolidated School	Class Room tap Room 246	NLV790	Wednesday, August 26, 2020	0.000	Passed	0.0080	Passed	
Hammonds Plains Consolidated School	Class Room tap Room 247	MTV733	Monday, June 1, 2020	-	Passed	0.3700	Passed	
Harbour View Elementary School	Fountain by Room 213	MYY066	Thursday, June 25, 2020	0.001	Passed	0.3800	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Harbour View Elementary School	Class Room tap Room 214	MYY067	Thursday, June 25, 2020	0.006	Exceeded	0.8900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Janitors Closet tap by rom 214	MYY068	Thursday, June 25, 2020	0.013	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Boys Wash Room tap 1	MYY069	Thursday, June 25, 2020	0.046	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Boys Wash Room tap 2	MYY070	Thursday, June 25, 2020	0.016	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Boys Wash Room tap 3	MYY071	Thursday, June 25, 2020	0.012	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Boys Wash Room tap 4	MYY072	Thursday, June 25, 2020	0.013	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Girls Wash Room tap 1	MYY073	Thursday, June 25, 2020	0.082	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Girls Wash Room tap 2	MYY074	Thursday, June 25, 2020	0.190	Exceeded	0.9800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Girls Wash Room tap 3	MYY075	Thursday, June 25, 2020	0.022	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Upstairs Girls Wash Room tap 4	MYY076	Thursday, June 25, 2020	0.007	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Fountain by Room 215	MYY077	Thursday, June 25, 2020	-	Passed	0.2900	Passed	
Harbour View Elementary School	Fountain by Room 204	MYY078	Thursday, June 25, 2020	0.003	Passed	0.1800	Passed	
Harbour View Elementary School	Janitors Closet tap by Room 204	MYY079	Thursday, June 25, 2020	-	Passed	0.0190	Passed	
Harbour View Elementary School	Fountain by Room 208	MYY080	Thursday, June 25, 2020	0.001	Passed	0.5400	Passed	
Harbour View Elementary School	Student services Wash Room tap	MYY081	Thursday, June 25, 2020	0.006	Exceeded	0.0590	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Wash Room tap in caretaker Room	MYY082	Thursday, June 25, 2020	0.001	Passed	0.0300	Passed	
Harbour View Elementary School	Fountain by Room 115	NMK142	Friday, August 28, 2020	0.001	Passed	0.0170	Passed	
Harbour View Elementary School	Boys Wash Room tap 1 by Room 115	MYY084	Thursday, June 25, 2020	0.012	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Boys Wash Room tap 2 by Room 115	MYY085	Thursday, June 25, 2020	0.011	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Boys Wash Room tap 3 by Room 115	MYY102	Thursday, June 25, 2020	0.080	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Boys Wash Room tap 4 by Room 115	MYY103	Thursday, June 25, 2020	0.029	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Learning Centre Wash Room tap	MYY104	Thursday, June 25, 2020	0.009	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Staff Wash Room by learning Centre	MYY105	Thursday, June 25, 2020	-	Passed	0.0510	Passed	
Harbour View Elementary School	Janitors Closet tap by Room 114	MYY106	Thursday, June 25, 2020	0.001	Passed	0.0370	Passed	
Harbour View Elementary School	Library Wash Room tap	MYY107	Thursday, June 25, 2020	0.012	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Staff Room Female Wash Room tap 1	MYY108	Thursday, June 25, 2020	0.061	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Staff Room Female Wash Room tap 2	MYY109	Thursday, June 25, 2020	0.005	Passed	0.2700	Passed	
Harbour View Elementary School	Staff Room tap 1	MYY110	Thursday, June 25, 2020	0.012	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Staff Room tap 2 Room 308	MYY111	Thursday, June 25, 2020	0.200	Exceeded	0.5900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Staff Room Male Wash Room tap 1	MYY112	Thursday, June 25, 2020	0.200	Exceeded	0.7600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Staff Room Male Wash Room tap 2	MYY113	Thursday, June 25, 2020	0.027	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Staff Wash Room tap in main Office	MYY114	Thursday, June 25, 2020	0.003	Passed	0.0970	Passed	
Harbour View Elementary School	Main Office Kitchen tap	MYY115	Thursday, June 25, 2020	0.002	Passed	0.1200	Passed	
Harbour View Elementary School	Staff Wash Room tap in main Office	MYY116	Thursday, June 25, 2020	0.065	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Gym Office tap	MYY117	Thursday, June 25, 2020	0.009	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Fountain by Gym doors	MYY118	Thursday, June 25, 2020	0.001	Passed	0.1800	Passed	
Harbour View Elementary School	Boys Wash Room tap 1 by Gym doors	MYY119	Thursday, June 25, 2020	0.059	Exceeded	0.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Boys Wash Room tap 2 by Gym doors	MYY120	Thursday, June 25, 2020	0.013	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Boys Wash Room tap 3 by Gym doors	MYY121	Thursday, June 25, 2020	0.014	Exceeded	0.4900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Girls Wash Room tap 1 by Gym doors	MYY122	Thursday, June 25, 2020	0.006	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Girls Wash Room tap 2 by Gym doors	MYY123	Thursday, June 25, 2020	0.003	Passed	0.1600	Passed	
Harbour View Elementary School	Girls Wash Room tap 3 by Gym doors	MYY124	Thursday, June 25, 2020	0.007	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harbour View Elementary School	Janitors Closet in supplies Room	MYY125	Thursday, June 25, 2020	0.004	Passed	0.4000	Passed	
Harbour View Elementary School	Breakfast Room tap 1	NMK143	Friday, August 28, 2020	0.000	Passed	0.0170	Passed	
Harbour View Elementary School	Breakfast Room tap 2	NMK144	Friday, August 28, 2020	0.000	Passed	0.0150	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Harbour View Elementary School	Fountain by Room 111	MYY128	Thursday, June 25, 2020	0.001	Passed	0.0550	Passed	
Harbour View Elementary School	Janitors Closet tap in boiler Room	MYY129	Thursday, June 25, 2020	0.008	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Gender Neutral Wash Room tap school counselor Room	MTA010	Thursday, May 28, 2020	0.006	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Staff Room Wash Room 1 tap	MTA011	Thursday, May 28, 2020	0.001	Passed	0.0800	Passed	
Harold T. Barrett Junior High School	Staff Room Wash Room 2 tap	MTA012	Thursday, May 28, 2020	0.001	Passed	0.0750	Passed	
Harold T. Barrett Junior High School	Staff Room Kitchen tap	MTA013	Thursday, May 28, 2020	0.001	Passed	0.0740	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 1 by Staff Room	MTA014	Thursday, May 28, 2020	0.002	Passed	0.4100	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 2 by Staff Room	MTA015	Thursday, May 28, 2020	0.001	Passed	0.1100	Passed	
Harold T. Barrett Junior High School	Fountain by Staff Room	MTA016	Thursday, May 28, 2020	-	Passed	1.6000	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 1 by Gym	MTA017	Thursday, May 28, 2020	0.002	Passed	1.4000	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 2 by Gym	MTA018	Thursday, May 28, 2020	0.001	Passed	0.3300	Passed	
Harold T. Barrett Junior High School	Cafeteria Kitchen tap 1	MTA019	Thursday, May 28, 2020	0.002	Passed	0.1200	Passed	
Harold T. Barrett Junior High School	Cafeteria Kitchen tap 2	MTA020	Thursday, May 28, 2020	0.001	Passed	0.0690	Passed	
Harold T. Barrett Junior High School	Cafeteria Kitchen tap 3	MTA021	Thursday, May 28, 2020	0.001	Passed	0.0560	Passed	
Harold T. Barrett Junior High School	Industrial arts Room tap by Elec. Room	MTA022	Thursday, May 28, 2020	0.002	Passed	0.1500	Passed	
Harold T. Barrett Junior High School	Family Studies tap 1	MTA023	Thursday, May 28, 2020	-	Passed	0.1600	Passed	
Harold T. Barrett Junior High School	Family Studies tap 2	MTA024	Thursday, May 28, 2020	0.001	Passed	0.4600	Passed	
Harold T. Barrett Junior High School	Janitors Closet tap by Mech. Room	MTA025	Thursday, May 28, 2020	-	Passed	0.0210	Passed	
Harold T. Barrett Junior High School	Gender Neutral Wash Room tap Room 107	MTA026	Thursday, May 28, 2020	0.011	Exceeded	0.8600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Class Room tap 1 Room 203	MTA027	Thursday, May 28, 2020	0.007	Exceeded	0.9400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Class Room tap 2 Room 203	MTA028	Thursday, May 28, 2020	0.001	Passed	0.4600	Passed	
Harold T. Barrett Junior High School	Class Room tap 3 Room 203	MTA029	Thursday, May 28, 2020	0.003	Passed	0.7200	Passed	
Harold T. Barrett Junior High School	Class Room tap 4 Room 203	MTA030	Thursday, May 28, 2020	0.009	Exceeded	1.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Girls Wash Room tap 1 by Room 205	MTA031	Thursday, May 28, 2020	0.023	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Girls Wash Room tap 2 by Room 205	MTA032	Thursday, May 28, 2020	0.012	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Janitors Closet tap by Room 205	MTA033	Thursday, May 28, 2020	0.001	Passed	0.2700	Passed	
Harold T. Barrett Junior High School	Fountain by Room 205	MTA034	Thursday, May 28, 2020	0.008	Exceeded	0.2000	Passed	New Fountain to be installed. Other sources available.
Harold T. Barrett Junior High School	Boys Wash Room tap 1 by Room 205	MTA035	Thursday, May 28, 2020	0.005	Passed	0.2400	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 2 by Room 205	MTA036	Thursday, May 28, 2020	0.002	Passed	0.1900	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 1 by Office	MTA037	Thursday, May 28, 2020	0.001	Passed	0.2800	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 2 by Office	MTA038	Thursday, May 28, 2020	0.001	Passed	0.2300	Passed	
Harold T. Barrett Junior High School	Boys Wash Room tap 3 by Office	MTA039	Thursday, May 28, 2020	0.001	Passed	0.2000	Passed	
Harold T. Barrett Junior High School	Fountain by Office	MTA040	Thursday, May 28, 2020	0.002	Passed	0.2800	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 1 by Office	MTA041	Thursday, May 28, 2020	0.028	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harold T. Barrett Junior High School	Girls Wash Room tap 2 by Office	MTA042	Thursday, May 28, 2020	0.001	Passed	0.1900	Passed	
Harold T. Barrett Junior High School	Girls Wash Room tap 3 by Office	MTA043	Thursday, May 28, 2020	0.001	Passed	0.2000	Passed	
Harrietsfield Elementary School	Staff Wash Room tap	MOV557	Wednesday, May 6, 2020	0.004	Passed	0.1900	Passed	
Harrietsfield Elementary School	Staff Room tap	MOV558	Wednesday, May 6, 2020	0.027	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Girls Wash Room tap 1	MOV559	Wednesday, May 6, 2020	0.005	Passed	0.0600	Passed	
Harrietsfield Elementary School	Girls Wash Room tap 2	MOV560	Wednesday, May 6, 2020	0.004	Passed	0.1100	Passed	
Harrietsfield Elementary School	Girls Wash Room tap 3	MOV561	Wednesday, May 6, 2020	0.011	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Girls Wash Room tap 4	MOV562	Wednesday, May 6, 2020	0.010	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Boys Wash Room tap 1	MOV563	Wednesday, May 6, 2020	0.002	Passed	0.4200	Passed	
Harrietsfield Elementary School	Boys Wash Room tap 2	MOV564	Wednesday, May 6, 2020	0.002	Passed	0.3100	Passed	
Harrietsfield Elementary School	Storage Room #4	MOV565	Wednesday, May 6, 2020	0.730	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Harrietsfield Elementary School	Staff Wash Room tap	MOV649	Wednesday, May 6, 2020	0.003	Passed	0.1800	Passed	
Harrietsfield Elementary School	Girls Wash Room tap 1	MOV650	Wednesday, May 6, 2020	0.018	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Girls Wash Room tap 2	MOV651	Wednesday, May 6, 2020	0.010	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Girls Wash Room tap 3	MOV652	Wednesday, May 6, 2020	0.012	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Boys Wash Room tap 1	MOV653	Wednesday, May 6, 2020	0.003	Passed	0.3500	Passed	
Harrietsfield Elementary School	Boys Wash Room tap 2	MOV654	Wednesday, May 6, 2020	0.006	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Boys Wash Room tap 3	MOV655	Wednesday, May 6, 2020	0.008	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harrietsfield Elementary School	Janitors Closet tap	MOV656	Wednesday, May 6, 2020	0.004	Passed	0.1800	Passed	
Harrietsfield Elementary School	Boys Wash Room tap 2	MRV010	Friday, May 22, 2020	0.004	Passed	0.2600	Passed	
Harrietsfield Elementary School	2nd Floor fountain	MRV011	Friday, May 22, 2020	0.001	Passed	0.0520	Passed	
Harrietsfield Elementary School	1st Floor fountain	MRV012	Friday, May 22, 2020	0.011	Exceeded	0.0950	Passed	New Fountain to be installed. Other sources available.
Harry R. Hamilton Elementary School	Sink tap Room by Room 212	MUU017	Friday, June 5, 2020	-	Passed	0.0210	Passed	
Harry R. Hamilton Elementary School	Fountain by Room 207	PUQ476	Wednesday, June 9, 2021	0.001	Passed	0.0410	Passed	Fountain replaced
Harry R. Hamilton Elementary School	2nd Floor Girls Wash Room tap 1	MUU019	Friday, June 5, 2020	0.015	Exceeded	0.0500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	2nd Floor Girls Wash Room tap 2	MUU020	Friday, June 5, 2020	0.008	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	2nd Floor Girls Wash Room tap	MUU021	Friday, June 5, 2020	0.031	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	2nd Floor Boys Wash Room tap 1	MUU022	Friday, June 5, 2020	0.003	Passed	0.0570	Passed	
Harry R. Hamilton Elementary School	2nd Floor Boys Wash Room tap 2	MUU023	Friday, June 5, 2020	0.015	Exceeded	0.0550	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	2nd Floor Boys Wash Room tap 3	MUU024	Friday, June 5, 2020	0.001	Passed	0.0330	Passed	
Harry R. Hamilton Elementary School	Fountain by 2nd Floor Wash Rooms	PUQ475	Wednesday, June 9, 2021	0.001	Passed	0.0440	Passed	Fountain replaced
Harry R. Hamilton Elementary School	Staff Room Wash Room tap	MUU025	Friday, June 5, 2020	-	Passed	0.0200	Passed	
Harry R. Hamilton Elementary School	Staff Room Kitchen sink tap	MUU026	Friday, June 5, 2020	-	Passed	0.0210	Passed	
Harry R. Hamilton Elementary School	Staff Room Wash Room tap	MUU027	Friday, June 5, 2020	0.001	Passed	0.0330	Passed	
Harry R. Hamilton Elementary School	Gender Neutral Wash Room tap inside Room 103	MUU028	Friday, June 5, 2020	0.001	Passed	0.0940	Passed	
Harry R. Hamilton Elementary School	Gender Neutral Wash Room tap inside Room 104	MUU029	Friday, June 5, 2020	0.002	Passed	0.0730	Passed	
Harry R. Hamilton Elementary School	Class Room tap Room 104	MUU030	Friday, June 5, 2020	0.002	Passed	0.0970	Passed	
Harry R. Hamilton Elementary School	Sink tap Room by Room 110	MUU031	Friday, June 5, 2020	0.004	Passed	0.1500	Passed	
Harry R. Hamilton Elementary School	Fountain by Boys Wash Room	PUQ474	Wednesday, June 9, 2021	0.038	Exceeded	0.2100	Passed	Fountain replacement in progress
Harry R. Hamilton Elementary School	Gym Office tap	MUU033	Friday, June 5, 2020	0.170	Exceeded	0.8900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	Fountain by Gym doors	PUQ473	Wednesday, June 9, 2021	0.004	Passed	0.0550	Passed	Fountain replaced
Harry R. Hamilton Elementary School	1st Floor Girls Wash Room tap 1	MUU035	Friday, June 5, 2020	0.100	Exceeded	0.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	1st Floor Girls Wash Room tap 2	MUU036	Friday, June 5, 2020	0.014	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	1st Floor Girls Wash Room tap 3	MUU037	Friday, June 5, 2020	0.022	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	1st Floor Boys Wash Room tap 1	MUU038	Friday, June 5, 2020	0.073	Exceeded	0.0680	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	1st Floor Boys Wash Room tap 2	MUU039	Friday, June 5, 2020	0.025	Exceeded	0.0950	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Harry R. Hamilton Elementary School	1st Floor Boys Wash Room tap 3	MUU040	Friday, June 5, 2020	0.031	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Class Room tap Room 26	MYY206	Thursday, June 25, 2020	0.002	Passed	0.7700	Passed	
Hawthorn Elementary School	Class Room tap Room 21	MYY207	Thursday, June 25, 2020	0.003	Passed	0.2400	Passed	
Hawthorn Elementary School	Fountain by Room 19	MYY208	Thursday, June 25, 2020	0.001	Passed	0.1700	Passed	
Hawthorn Elementary School	Boys Wash Room tap 1 by Room 20	MYY209	Thursday, June 25, 2020	0.002	Passed	0.1000	Passed	
Hawthorn Elementary School	Boys Wash Room tap 2 by Room 20	MYY210	Thursday, June 25, 2020	0.004	Passed	0.2700	Passed	
Hawthorn Elementary School	Boys Wash Room tap 3 by Room 20	MYY211	Thursday, June 25, 2020	0.012	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Boys Wash Room tap 4 by Room 20	MYY212	Thursday, June 25, 2020	0.017	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Janitors Closet tap by Gender Neutral Wash Room	MYY213	Thursday, June 25, 2020	0.001	Passed	0.0950	Passed	
Hawthorn Elementary School	Gender Neutral Wash Room tap	MYY214	Thursday, June 25, 2020	0.001	Passed	0.0720	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Hawthorn Elementary School	Girls Wash Room tap 1 by Room 28	MYY215	Thursday, June 25, 2020	0.006	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Girls Wash Room tap 2 by Room 28	MYY216	Thursday, June 25, 2020	0.005	Passed	0.2000	Passed	
Hawthorn Elementary School	Girls Wash Room tap 3 by Room 28	MYY217	Thursday, June 25, 2020	0.011	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Girls Wash Room tap 4 by Room 28	MYY218	Thursday, June 25, 2020	0.013	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Class Room tap Room 15	MYY219	Thursday, June 25, 2020	0.002	Passed	0.1700	Passed	
Hawthorn Elementary School	Staff Room Female Wash Room tap 1	MYY220	Thursday, June 25, 2020	0.004	Passed	0.2600	Passed	
Hawthorn Elementary School	Staff Room Female Wash Room tap 2	MYY221	Thursday, June 25, 2020	0.001	Passed	0.0750	Passed	
Hawthorn Elementary School	Staff Room Male Wash Room tap	MYY222	Thursday, June 25, 2020	0.084	Exceeded	0.6200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Staff Room Kitchen tap	MYY223	Thursday, June 25, 2020	0.004	Passed	0.0790	Passed	
Hawthorn Elementary School	Class Room tap Room 13	MYY224	Thursday, June 25, 2020	0.006	Exceeded	0.7500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Class Room tap Room 11	MYY225	Thursday, June 25, 2020	0.004	Passed	0.5100	Passed	
Hawthorn Elementary School	Fountain by Boys Wash Room	NMK075	Friday, August 28, 2020	0.000	Passed	0.0050	Passed	
Hawthorn Elementary School	Class Room tap Room 12	MYY230	Thursday, June 25, 2020	0.022	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Boys Wash Room tap 1 by Room 12	MYY231	Thursday, June 25, 2020	0.032	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Boys Wash Room tap 2 by Room 12	MYY232	Thursday, June 25, 2020	0.007	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Boys Wash Room tap 3 by Room 12	MYY233	Thursday, June 25, 2020	0.020	Exceeded	0.6300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Janitors Closet tap by Room 12	MYY234	Thursday, June 25, 2020	0.004	Passed	0.1200	Passed	
Hawthorn Elementary School	Girls Wash Room tap 1 by Room 17	MYY235	Thursday, June 25, 2020	0.009	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Girls Wash Room tap 2 by Room 17	MYY236	Thursday, June 25, 2020	0.007	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Girls Wash Room tap 3 by Room 17	MYY237	Thursday, June 25, 2020	0.008	Exceeded	0.6300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Girls Wash Room tap 4 by Room 17	MYY238	Thursday, June 25, 2020	0.062	Exceeded	0.9200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Class Room tap Room 7	MYY239	Thursday, June 25, 2020	0.004	Passed	0.4100	Passed	
Hawthorn Elementary School	Staff Wash Room tap by Room 7	MYY240	Thursday, June 25, 2020	0.003	Passed	0.3500	Passed	
Hawthorn Elementary School	Girls Wash Room tap 1 by Staff Wash Room	MYY241	Thursday, June 25, 2020	0.005	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Girls Wash Room tap 2 by Staff Wash Room	MYY242	Thursday, June 25, 2020	0.024	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Girls Wash Room tap 3 by Staff Wash Room	MYY243	Thursday, June 25, 2020	0.004	Passed	0.2400	Passed	
Hawthorn Elementary School	Class Room tap by Room 6	MYY244	Thursday, June 25, 2020	0.012	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Lab sink tap by Room 6	MYY245	Thursday, June 25, 2020	0.012	Exceeded	0.0360	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Boys Wash Room tap 1 near Room 6	MYY246	Thursday, June 25, 2020	0.016	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hawthorn Elementary School	Boys Wash Room tap 2 near Room 6	MYY247	Thursday, June 25, 2020	0.004	Passed	0.1800	Passed	
Hawthorn Elementary School	Boys Wash Room tap 3 near Room 6	MYY248	Thursday, June 25, 2020	0.002	Passed	0.0560	Passed	
Hawthorn Elementary School	Janitors Closet tap in sink Room	MYY249	Thursday, June 25, 2020	0.001	Passed	0.0550	Passed	
Hawthorn Elementary School	Caretaker Room tap	MYY250	Thursday, June 25, 2020	0.002	Passed	0.3700	Passed	
Hawthorn Elementary School	Pre-primary Room Kitchen tap	NMK075	Friday, August 28, 2020	0.000		0.0280	Passed	
Hawthorn Elementary School	Fountain by Music Room	NMK076	Friday, August 28, 2020	0.002		0.0260	Passed	
Herring Cove Junior High School	Boys Wash Room tap 1 by Room 321	MQS625	Tuesday, May 19, 2020	0.003	Passed	0.2900	Passed	
Herring Cove Junior High School	Boys Wash Room tap 2 by Room 321	MQS626	Tuesday, May 19, 2020	0.001	Passed	0.2200	Passed	
Herring Cove Junior High School	Fountain by Room 324	MQS627	Tuesday, May 19, 2020	0.004	Passed	4.1000	Exceeded	New Fountain to be installed. Other sources available.
Herring Cove Junior High School	Girls Wash Room tap 1 by Room 326	MQS628	Tuesday, May 19, 2020	0.003	Passed	0.0430	Passed	
Herring Cove Junior High School	Girls Wash Room tap 2 by Room 326	MQS629	Tuesday, May 19, 2020	0.001	Passed	0.0140	Passed	
Herring Cove Junior High School	Girls Wash Room tap 3 by Room 326	MQS630	Tuesday, May 19, 2020	0.001	Passed	0.0120	Passed	
Herring Cove Junior High School	Class Room 327 tap	MQS631	Tuesday, May 19, 2020	0.003	Passed	0.0500	Passed	
Herring Cove Junior High School	Class Room 328 tap	MQS632	Tuesday, May 19, 2020	-	Passed	0.0110	Passed	
Herring Cove Junior High School	Class Room 326 tap	MQS633	Tuesday, May 19, 2020	0.023	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Janitors Closet 324 tap	MQS634	Tuesday, May 19, 2020	0.019	Exceeded	0.0630	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Herring Cove Junior High School	Fountain by Room 224	MQS639	Tuesday, May 19, 2020	0.001	Passed	0.0990	Passed	
Herring Cove Junior High School	Janitors Closet 224 tap	MQS640	Tuesday, May 19, 2020	0.021	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Boys Wash Room tap 1 by Room 228	MQS641	Tuesday, May 19, 2020	0.029	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Boys Wash Room tap 2 by Room 228	MQS642	Tuesday, May 19, 2020	0.001	Passed	0.0810	Passed	
Herring Cove Junior High School	Gender Neutral Wash Room 229 tap	MQS643	Tuesday, May 19, 2020	0.003	Passed	0.2200	Passed	
Herring Cove Junior High School	Girls Wash Room tap 1 by Room 232	MQS644	Tuesday, May 19, 2020	0.002	Passed	0.3200	Passed	
Herring Cove Junior High School	Girls Wash Room tap 2 by Room 232	MQS645	Tuesday, May 19, 2020	0.002	Passed	0.2300	Passed	
Herring Cove Junior High School	Staff Room 210 tap	NNS687	Thursday, September 3, 2020	0.001	Passed	0.0140	Passed	
Herring Cove Junior High School	Class Room 214 tap	MQS647	Tuesday, May 19, 2020	0.001	Passed	0.1000	Passed	
Herring Cove Junior High School	Photocopy Room tap	MQS648	Tuesday, May 19, 2020	0.590	Exceeded	0.6400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Family Studies 114 tap 1	MQS649	Tuesday, May 19, 2020	0.001	Passed	0.0700	Passed	
Herring Cove Junior High School	Family Studies 114 tap 2	NNS689	Thursday, September 3, 2020	0.002	Passed	0.0340	Passed	
Herring Cove Junior High School	Family Studies 114 tap 3	MQS651	Tuesday, May 19, 2020	0.004	Passed	0.2700	Passed	
Herring Cove Junior High School	Family Studies 114 tap 4	NNS691	Thursday, September 3, 2020	0.001	Passed	0.0260	Passed	
Herring Cove Junior High School	Class Room 115 tap	NNS692	Thursday, September 3, 2020	0.001	Passed	0.0270	Passed	
Herring Cove Junior High School	Basement Boys Wash Room tap 1	MQS654	Tuesday, May 19, 2020	0.015	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Basement Boys Wash Room tap 2	MQS655	Tuesday, May 19, 2020	0.005	Passed	0.2700	Passed	
Herring Cove Junior High School	Janitors Closet 131 tap	MQS656	Tuesday, May 19, 2020	0.010	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Fountain by Room 131	MQS657	Tuesday, May 19, 2020	0.001	Passed	0.1200	Passed	
Herring Cove Junior High School	Basement Girls Wash Room tap 1	MQS658	Tuesday, May 19, 2020	0.006	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Basement Girls Wash Room tap 2	MQS710	Tuesday, May 19, 2020	0.001	Passed	0.2400	Passed	
Herring Cove Junior High School	Basement Girls Wash Room tap 3	MQS711	Tuesday, May 19, 2020	0.003	Passed	0.2000	Passed	
Herring Cove Junior High School	Music Room 113 tap	MQS712	Tuesday, May 19, 2020	0.900	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Class Room 117 tap	MQS713	Tuesday, May 19, 2020	0.038	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Herring Cove Junior High School	Gym Kitchen Wash Sink tap	MRV313	Friday, May 22, 2020	0.000		0.0220	Passed	
Herring Cove Junior High School	Gym Kitchen Sink 1 tap	MRV314	Friday, May 22, 2020	0.000		0.0280	Passed	
Herring Cove Junior High School	Gym Kitchen Sink 2 tap	MRV315	Friday, May 22, 2020	0.000		0.0290	Passed	
Highland Park Junior High School	Fountain by Room 400	MSH470	Tuesday, May 26, 2020	-	Passed	0.0150	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 1	MSH471	Tuesday, May 26, 2020	-	Passed	0.4300	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 2	MSH472	Tuesday, May 26, 2020	-	Passed	0.0470	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 3	MSH473	Tuesday, May 26, 2020	-	Passed	0.0400	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 4	MSH474	Tuesday, May 26, 2020	-	Passed	0.0290	Passed	
Highland Park Junior High School	Family Studies Room 400 tap 5	MSH475	Tuesday, May 26, 2020	-	Passed	0.0150	Passed	
Highland Park Junior High School	Staff Room 401 tap	MSH476	Tuesday, May 26, 2020	-	Passed	0.0160	Passed	
Highland Park Junior High School	4th Floor Boys Wash Room tap 1	MSH477	Tuesday, May 26, 2020	0.002	Passed	0.0140	Passed	
Highland Park Junior High School	4th Floor Boys Wash Room tap 2	MSH478	Tuesday, May 26, 2020	0.001	Passed	0.0140	Passed	
Highland Park Junior High School	4th Floor Boys Wash Room tap 3	MSH479	Tuesday, May 26, 2020	0.001	Passed	0.0150	Passed	
Highland Park Junior High School	4th Floor Boys Wash Room tap 4	MSH480	Tuesday, May 26, 2020	0.002	Passed	0.0210	Passed	
Highland Park Junior High School	4th Floor Janitors Closet tap	MSH481	Tuesday, May 26, 2020	0.001	Passed	0.0120	Passed	
Highland Park Junior High School	4th Floor Girls Wash Room tap 1	NFE702	Monday, July 27, 2020	0.001	Passed	0.0390	Passed	
Highland Park Junior High School	4th Floor Girls Wash Room tap 2	MSH483	Tuesday, May 26, 2020	0.001	Passed	0.0410	Passed	
Highland Park Junior High School	4th Floor Girls Wash Room tap 3	MSH484	Tuesday, May 26, 2020	-	Passed	0.0280	Passed	
Highland Park Junior High School	4th Floor Girls Wash Room tap 4	MSH485	Tuesday, May 26, 2020	-	Passed	0.0270	Passed	
Highland Park Junior High School	Class Room 407 tap	MSH486	Tuesday, May 26, 2020	0.003	Passed	0.4400	Passed	
Highland Park Junior High School	Class Room 409 tap	MSH487	Tuesday, May 26, 2020	0.003	Passed	0.3300	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Highland Park Junior High School	Class Room 301 tap	MSH488	Tuesday, May 26, 2020	0.001	Passed	0.0910	Passed	
Highland Park Junior High School	Class Room 300 tap	MSH489	Tuesday, May 26, 2020	-	Passed	0.0540	Passed	
Highland Park Junior High School	Teachers Room 204 tap	MSH490	Tuesday, May 26, 2020	-	Passed	0.0530	Passed	
Highland Park Junior High School	Staff Room 204 Wash Room 1 tap	MSH491	Tuesday, May 26, 2020	-	Passed	0.0170	Passed	
Highland Park Junior High School	Staff Wash 204 Was Room 2 tap	NFE719	Monday, July 27, 2020	-	Passed	0.0048	Passed	
Highland Park Junior High School	Fountain by Room 204	QNH267	Tuesday, August 31, 2021	0.001	Passed	0.0170	Passed	Fountain replaced
Highland Park Junior High School	Principals Office 202 Wash Room tap	MSH494	Tuesday, May 26, 2020	-	Passed	0.0130	Passed	
Highland Park Junior High School	Gender Neutral Wash Room 200 tap	MSH495	Tuesday, May 26, 2020	-	Passed	0.0170	Passed	
Highland Park Junior High School	Class Room 203 tap	MSH496	Tuesday, May 26, 2020	0.001	Passed	0.0350	Passed	
Highland Park Junior High School	Caretakers Office 205 tap	MSH497	Tuesday, May 26, 2020	0.002	Passed	0.0089	Passed	
Highland Park Junior High School	Fountain by Gym	QNH268	Tuesday, August 31, 2021	0.001	Passed	0.0350	Passed	Fountain replaced
Highland Park Junior High School	Phys Ed Office tap	MSP301	Wednesday, May 27, 2020	0.002	Passed	0.0320	Passed	
Highland Park Junior High School	Boiler Room tap	MSP302	Wednesday, May 27, 2020	-	Passed	0.0190	Passed	
Hillside Park Elementary School	1st Floor Boys Wash Room tap 1	MPX259	Wednesday, May 13, 2020	0.330	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	1st Floor Boys Wash Room tap 2	MPX260	Wednesday, May 13, 2020	0.020	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	1st Floor Boys Wash Room tap 3	MPX261	Wednesday, May 13, 2020	0.002	Passed	0.0480	Passed	
Hillside Park Elementary School	1st Floor Janitors Closet tap	MPX262	Wednesday, May 13, 2020	0.003	Passed	0.1100	Passed	
Hillside Park Elementary School	1st Floor Girls Wash Room tap 1	MPX263	Wednesday, May 13, 2020	0.046	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	1st Floor Girls Wash Room tap 2	MPX264	Wednesday, May 13, 2020	0.020	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	1st Floor Girls Wash Room tap 3	MPX265	Wednesday, May 13, 2020	0.340	Exceeded	0.6300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Fountain by 1st Floor Electrical Room	-	-	-	-	-	-	Fountain Replacement in progress
Hillside Park Elementary School	Class Room tap Room 108	MPX266	Wednesday, May 13, 2020	0.008	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Learning Centre tap Room 109	NJG766	Friday, August 14, 2020	0.001	Passed	0.0190	Passed	
Hillside Park Elementary School	Class Room tap Room 110	MPX268	Wednesday, May 13, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Fountain by Room 204	MPX269	Wednesday, May 13, 2020	0.003	Passed	0.4700	Passed	Fountain Replacement in progress
Hillside Park Elementary School	Class Room tap Room 207	MPX270	Wednesday, May 13, 2020	0.002	Passed	0.1300	Passed	
Hillside Park Elementary School	Class Room tap Room 206	MPX271	Wednesday, May 13, 2020	0.006	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Staff Room Kitchen tap Room 203	MPX272	Wednesday, May 13, 2020	-	Passed	0.0360	Passed	
Hillside Park Elementary School	Staff Room Female Wash Room tap Room 203	MPX273	Wednesday, May 13, 2020	0.024	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Staff Room Male Wash Room tap Room 203	MPX274	Wednesday, May 13, 2020	0.002	Passed	0.0500	Passed	
Hillside Park Elementary School	Class Room tap Room 220	MPX275	Wednesday, May 13, 2020	0.005	Passed	0.4500	Passed	
Hillside Park Elementary School	2nd Floor music Room tap	MPX276	Wednesday, May 13, 2020	0.042	Exceeded	0.7200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Gym Office Wash Room tap	MPX277	Wednesday, May 13, 2020	0.057	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	2nd Floor Kitchen tap	MPX278	Wednesday, May 13, 2020	0.020	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	2nd Floor Boys Wash Room tap	MPX279	Wednesday, May 13, 2020	0.003	Passed	0.2100	Passed	
Hillside Park Elementary School	Fountain by Room 220	NJG767	Friday, August 14, 2020	0.003	Passed	0.1300	Passed	Fountain Replacement in progress
Hillside Park Elementary School	2nd Floor Girls Wash Room tap	MPX281	Wednesday, May 13, 2020	0.056	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	2nd Floor Janitors Closet tap	MPX282	Wednesday, May 13, 2020	0.007	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Library Room tap Room 218	MPX283	Wednesday, May 13, 2020	0.210	Exceeded	0.9300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	Fountain by 3rd Floor Girls Wash Room	NJG768	Friday, August 14, 2020	0.001	Passed	0.0190	Passed	Fountain Replacement in progress
Hillside Park Elementary School	3rd Floor Girls Wash Room tap 1	MPX285	Wednesday, May 13, 2020	0.007	Exceeded	0.0680	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	3rd Floor Girls Wash Room tap 2	MPX286	Wednesday, May 13, 2020	0.012	Exceeded	0.0520	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	3rd Floor Girls Wash Room tap 3	MPX287	Wednesday, May 13, 2020	0.026	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	3rd Floor Janitors Closet tap	MPX288	Wednesday, May 13, 2020	0.006	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	3rd Floor Boys Wash Room tap 1	MQK117	Friday, May 15, 2020	0.041	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Hillside Park Elementary School	3rd Floor Boys Wash Room tap 2	MQK118	Friday, May 15, 2020	0.047	Exceeded	0.0600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Hillside Park Elementary School	3rd Floor Boys Wash Room tap 3	MQK119	Friday, May 15, 2020	0.012	Exceeded	0.0410	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Holland Road Elementary School	Class Room tap Room 172	MWI032	Monday, June 15, 2020	0.001	Passed	0.2500	Passed	
Holland Road Elementary School	Class Room tap Room 171	MWI033	Monday, June 15, 2020	0.001	Passed	0.0770	Passed	
Holland Road Elementary School	Class Room tap Room 170	MWI034	Monday, June 15, 2020	0.001	Passed	0.0700	Passed	
Holland Road Elementary School	Primary Wash Room tap Room 169	MWI035	Monday, June 15, 2020	-	Passed	0.0680	Passed	
Holland Road Elementary School	Fountain by Room 170	MWI036	Monday, June 15, 2020	-	Passed	0.3700	Passed	Fountain Replacement in progress
Holland Road Elementary School	Boys Wash Room tap Room 172	MWI037	Monday, June 15, 2020	-	Passed	0.0760	Passed	
Holland Road Elementary School	Girls Wash Room tap 1 Room 173	MWI038	Monday, June 15, 2020	0.004	Passed	0.0890	Passed	
Holland Road Elementary School	Girls Wash Room tap 2 Room 173	MWI039	Monday, June 15, 2020	-	Passed	0.0660	Passed	
Holland Road Elementary School	Class Room tap Room 123	MWI040	Monday, June 15, 2020	0.001	Passed	0.0950	Passed	
Holland Road Elementary School	Class Room Wash Room tap Room 123	MWI041	Monday, June 15, 2020	0.001	Passed	0.1900	Passed	
Holland Road Elementary School	Janitors Closet tap by Room 123	MWI042	Monday, June 15, 2020	0.002	Passed	0.1300	Passed	
Holland Road Elementary School	Class Room Wash Room tap Room 126	MWI043	Monday, June 15, 2020	0.001	Passed	0.1700	Passed	
Holland Road Elementary School	Class Room tap Room 126	MWI044	Monday, June 15, 2020	-	Passed	0.0340	Passed	
Holland Road Elementary School	Class Room tap Room 122	MWI045	Monday, June 15, 2020	0.003	Passed	0.2500	Passed	
Holland Road Elementary School	Class Room tap Room 128	MWI046	Monday, June 15, 2020	0.001	Passed	0.1700	Passed	
Holland Road Elementary School	Music Room tap Room 130	MWI047	Monday, June 15, 2020	0.003	Passed	0.0970	Passed	
Holland Road Elementary School	Class Room Wash Room tap Room 136	MWI048	Monday, June 15, 2020	0.001	Passed	0.1600	Passed	
Holland Road Elementary School	Boys Wash Room tap 1 by Room 136	MWI049	Monday, June 15, 2020	-	Passed	0.0790	Passed	
Holland Road Elementary School	Boys Wash Room tap 2 by Room 136	MWI050	Monday, June 15, 2020	0.001	Passed	0.0990	Passed	
Holland Road Elementary School	Mech. Room tap by Library	MWI051	Monday, June 15, 2020	0.002	Passed	0.1000	Passed	
Holland Road Elementary School	Fountain by Library	MWI052	Monday, June 15, 2020	0.002	Passed	0.1400	Passed	Fountain Replacement in progress
Holland Road Elementary School	Girls Wash Room tap 1 by main Office	MWI053	Monday, June 15, 2020	-	Passed	0.0440	Passed	
Holland Road Elementary School	Girls Wash Room tap 2 by main Office	MWI054	Monday, June 15, 2020	0.002	Passed	0.0660	Passed	
Holland Road Elementary School	Girls Wash Room tap 3 by main Office	MWI055	Monday, June 15, 2020	0.001	Passed	0.0240	Passed	
Holland Road Elementary School	Staff Room Wash Room 1 tap	MWI056	Monday, June 15, 2020	0.002	Passed	0.2200	Passed	
Holland Road Elementary School	Staff Room Wash Room 2 tap	MWI057	Monday, June 15, 2020	-	Passed	0.2400	Passed	
Holland Road Elementary School	Staff Room Kitchen tap	MWI058	Monday, June 15, 2020	0.002	Passed	0.1800	Passed	
Holland Road Elementary School	Kitchen tap 1 Room 145	MWI059	Monday, June 15, 2020	0.005	Passed	0.1200	Passed	
Holland Road Elementary School	Kitchen tap 2 Room 145	MWI060	Monday, June 15, 2020	0.001	Passed	0.1000	Passed	
Holland Road Elementary School	Boys Locker Room tap Room 172	MWI061	Monday, June 15, 2020	0.006	Exceeded	0.0780	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Holland Road Elementary School	Gym Office Wash Room tap Room 149	MWI062	Monday, June 15, 2020	0.007	Exceeded	0.0780	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Holland Road Elementary School	Girls Locker Room tap by Room 149	MWI063	Monday, June 15, 2020	0.002	Passed	0.0850	Passed	
Holland Road Elementary School	Fountain by Gym	MWI064	Monday, June 15, 2020	0.001	Passed	0.2500	Passed	Fountain Replacement in progress
Holland Road Elementary School	Class Room tap Room 131	MYZ639	Thursday, June 25, 2020	0.016	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Humber Park Elementary School	Janitors Closet tap Room 33	MXK117	Thursday, June 18, 2020	0.005	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Humber Park Elementary School	Girls Gym change Room tap	MXK118	Thursday, June 18, 2020	0.014	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Humber Park Elementary School	Boys Gym change Room tap	MXK119	Thursday, June 18, 2020	0.007	Exceeded	0.5900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Humber Park Elementary School	Fountain by Gym door	MXK120	Thursday, June 18, 2020	0.002	Passed	0.1500	Passed	
Humber Park Elementary School	Boys Wash Room tap 1 Room 8	MXK121	Thursday, June 18, 2020	0.015	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Humber Park Elementary School	Boys Wash Room tap 2 Room 8	MXK122	Thursday, June 18, 2020	0.006	Exceeded	0.0920	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Humber Park Elementary School	Boys Wash Room tap 3 Room 8	MXK123	Thursday, June 18, 2020	0.004	Passed	0.0580	Passed	
Humber Park Elementary School	Boys Wash Room tap 4 Room 8	MXK124	Thursday, June 18, 2020	-	Passed	0.0260	Passed	
Humber Park Elementary School	Janitors Closet tap Room 9	MXK125	Thursday, June 18, 2020	0.001	Passed	0.0100	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Humber Park Elementary School	Fountain by Boys Wash Room (Rm 8)	MXK126	Thursday, June 18, 2020	0.004	Passed	0.0390	Passed	
Humber Park Elementary School	Fountain by Girls Wash Room (Rm 7)	MXK129	Thursday, June 18, 2020	0.002	Passed	0.0360	Passed	
Humber Park Elementary School	Girls Wash Room tap 1 Room 7	MXK130	Thursday, June 18, 2020	0.003	Passed	0.0580	Passed	
Humber Park Elementary School	Girls Wash Room tap 2 Room 7	MXK131	Thursday, June 18, 2020	0.002	Passed	0.0350	Passed	
Humber Park Elementary School	Girls Wash Room tap 3 Room 7	MXK132	Thursday, June 18, 2020	0.001	Passed	0.0140	Passed	
Humber Park Elementary School	Girls Wash Room tap 4 Room 7	MXK133	Thursday, June 18, 2020	-	Passed	0.0110	Passed	
Humber Park Elementary School	Staff Room Wash Room 1 tap Room 26	MXK134	Thursday, June 18, 2020	0.001	Passed	0.0140	Passed	
Humber Park Elementary School	Staff Room Kitchen tap	MXK135	Thursday, June 18, 2020	-	Passed	0.0071	Passed	
Humber Park Elementary School	Staff Room Wash Room 2 tap by Room 26	MXK136	Thursday, June 18, 2020	0.002	Passed	0.2100	Passed	
Ian Forsyth Elementary School	Janitors Closet tap Room 206	MWI424	Monday, June 15, 2020	0.037	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Staff Room Wash Room tap Room 204	MWI425	Monday, June 15, 2020	0.006	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	VP Office tap 2 Room 202	MWI427	Monday, June 15, 2020	0.005	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 1 Room 142	MWI428	Monday, June 15, 2020	0.013	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 2 Room 142	MWI429	Monday, June 15, 2020	0.005	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 3 Room 142	MWI430	Monday, June 15, 2020	0.007	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 4 Room 142	MWI431	Monday, June 15, 2020	0.036	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Janitors Closet tap Room 141	MWI432	Monday, June 15, 2020	0.002	Passed	0.1800	Passed	
Ian Forsyth Elementary School	Boys Wash Room tap 1 Room 139	MWI434	Monday, June 15, 2020	0.006	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Boys Wash Room tap 2 Room 139	MWI435	Monday, June 15, 2020	0.001	Passed	0.0600	Passed	
Ian Forsyth Elementary School	Boys Wash Room tap 3 Room 139	MWI436	Monday, June 15, 2020	0.002	Passed	0.0690	Passed	
Ian Forsyth Elementary School	Boys Wash Room tap 4 Room 139	MWI437	Monday, June 15, 2020	0.003	Passed	0.1200	Passed	
Ian Forsyth Elementary School	Class Room tap Room 129	MWI438	Monday, June 15, 2020	0.004	Passed	0.5400	Passed	
Ian Forsyth Elementary School	VP Office tap Room 202	NBS099	Tuesday, July 7, 2020	0.082	Exceeded	0.6700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Staff Room tap Room 103	NDP116	Thursday, July 16, 2020	0.042	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Staff Room Wash Room tap Room 103	NDP117	Thursday, July 16, 2020	0.025	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Sick Room tap Room 104	NDP118	Thursday, July 16, 2020	0.020	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Fountain by sick Room	NDP119	Thursday, July 16, 2020	0.026	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Gym Kitchen tap	NDP120	Thursday, July 16, 2020	0.110	Exceeded	0.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Boys Wash Room tap 1 by Room 111	NDP121	Thursday, July 16, 2020	0.190	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Boys Wash Room tap 2 by Room 111	NDP122	Thursday, July 16, 2020	0.100	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Boys Wash Room tap 3 by Room 111	NDP123	Thursday, July 16, 2020	0.150	Exceeded	0.7700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Janitors Closet tap Room 108	NDP124	Thursday, July 16, 2020	0.041	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 1 by Room 106	NDP125	Thursday, July 16, 2020	0.008	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 2 by Room 106	NDP171	Thursday, July 16, 2020	0.022	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 3 by Room 106	NDP172	Thursday, July 16, 2020	0.170	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 1 by Room 123	NDP173	Thursday, July 16, 2020	0.078	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 2 by Room 123	NDP174	Thursday, July 16, 2020	0.015	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 3 by Room 123	NDP175	Thursday, July 16, 2020	0.006	Exceeded	0.0660	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Boys Wash Room tap 1 by Room 125	NDP176	Thursday, July 16, 2020	0.021	Exceeded	0.0810	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Boys Wash Room tap 2 by Room 125	NDP177	Thursday, July 16, 2020	0.012	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Boys Wash Room tap 3 by Room 125	NDP178	Thursday, July 16, 2020	0.110	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Girls Wash Room tap 4 by Room 123	NDP179	Thursday, July 16, 2020	0.022	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Main Office tap	NDP180	Thursday, July 16, 2020	0.250	Exceeded	0.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Main Office Wash Room tap	NDP229	Thursday, July 16, 2020	0.340	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ian Forsyth Elementary School	Janitors Closet tap Room 127	NDP230	Thursday, July 16, 2020	0.069	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Ian Forsyth Elementary School	Fountain by Room 140	NDP231	Thursday, July 16, 2020	0.110	Exceeded	0.6900	Passed	New Fountain to be installed. Other sources available.
Ian Forsyth Elementary School	Fountain by Room 130	NDP232	Thursday, July 16, 2020	0.021	Exceeded	1.5000	Passed	New Fountain to be installed. Other sources available.
Ian Forsyth Elementary School	Fountain by Room 126	NDP233	Thursday, July 16, 2020	0.001	Passed	0.7000	Passed	
Ian Forsyth Elementary School	Fountain on 2nd Floor	NDP234	Thursday, July 16, 2020	0.001	Passed	0.9200	Passed	
Inglis Street Elementary School	Caretaker Room Wash Room tap Room 312	MTA096	Thursday, May 28, 2020	0.001	Passed	0.0950	Passed	
Inglis Street Elementary School	YMCA Room Wash Room tap Room 311	MTA097	Thursday, May 28, 2020	-	Passed	0.0360	Passed	
Inglis Street Elementary School	Fountain by Room 311	MTA098	Thursday, May 28, 2020	0.001	Passed	0.5800	Passed	
Inglis Street Elementary School	Janitors Closet tap Room 307	MTA099	Thursday, May 28, 2020	0.001	Passed	0.0740	Passed	
Inglis Street Elementary School	Girls Wash Room tap 1 Room 308	MTA100	Thursday, May 28, 2020	0.002	Passed	0.1600	Passed	
Inglis Street Elementary School	Girls Wash Room tap 2 Room 308	MTA101	Thursday, May 28, 2020	0.001	Passed	0.0730	Passed	
Inglis Street Elementary School	Girls Wash Room tap 3 Room 308	MTA102	Thursday, May 28, 2020	0.001	Passed	0.0400	Passed	
Inglis Street Elementary School	Class Room tap Room 305	NLK012	Monday, August 24, 2020	0.000	Passed	0.0050	Passed	
Inglis Street Elementary School	Class Room tap Room 302	MTA104	Thursday, May 28, 2020	0.002	Passed	0.2000	Passed	
Inglis Street Elementary School	Boys Wash Room tap 1 Room 301	MTA105	Thursday, May 28, 2020	0.001	Passed	0.0470	Passed	
Inglis Street Elementary School	Boys Wash Room tap 2 Room 301	MTA106	Thursday, May 28, 2020	0.003	Passed	0.0780	Passed	
Inglis Street Elementary School	Boys Wash Room tap 3 Room 301	MTA107	Thursday, May 28, 2020	0.005	Exceeded	0.0970	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Inglis Street Elementary School	Principals Office Wash Room tap Room 209	MTA108	Thursday, May 28, 2020	-	Passed	0.0220	Passed	
Inglis Street Elementary School	Fountain by Room 209	MTA109	Thursday, May 28, 2020	0.003	Passed	1.1000	Passed	
Inglis Street Elementary School	Staff Room tap Room 208	NLK011	Monday, August 24, 2020	0.001	Passed	0.0050	Passed	
Inglis Street Elementary School	Class Room Wash Room tap Room 206	MTA111	Thursday, May 28, 2020	-	Passed	0.0061	Passed	
Inglis Street Elementary School	Girls Wash Room tap 1 Room 205	MTA112	Thursday, May 28, 2020	-	Passed	0.0120	Passed	
Inglis Street Elementary School	Girls Wash Room tap 2 Room 205	MTA113	Thursday, May 28, 2020	-	Passed	0.0063	Passed	
Inglis Street Elementary School	Girls Wash Room tap 3 Room 205	MTA114	Thursday, May 28, 2020	-	Passed	0.0054	Passed	
Inglis Street Elementary School	Janitors Closet tap Room 204	MTA115	Thursday, May 28, 2020	0.001	Passed	0.1500	Passed	
Inglis Street Elementary School	Boys Wash Room tap 1 Room 200	MTA116	Thursday, May 28, 2020	0.002	Passed	0.2100	Passed	
Inglis Street Elementary School	Boys Wash Room tap 2 Room 200	MTA117	Thursday, May 28, 2020	0.001	Passed	0.0130	Passed	
Inglis Street Elementary School	Boys Wash Room tap 3 Room 200	MTA118	Thursday, May 28, 2020	0.002	Passed	0.0410	Passed	
Inglis Street Elementary School	Boys Wash Room tap 4 Room 200	MTA119	Thursday, May 28, 2020	0.002	Passed	0.1300	Passed	
Inglis Street Elementary School	Fountain by Gym	NLK013	Monday, August 24, 2020	0.002	Passed	0.1500	Passed	
Inglis Street Elementary School	Gym Office Wash Room tap	MTA121	Thursday, May 28, 2020	0.002	Passed	0.1200	Passed	
Inglis Street Elementary School	Basement Janitors Closet tap	MTA122	Thursday, May 28, 2020	0.001	Passed	0.2600	Passed	
Inglis Street Elementary School	Class Room tap Room 112	MTA123	Thursday, May 28, 2020	-	Passed	0.0210	Passed	
Inglis Street Elementary School	Gender Neutral Wash Room tap 1	MTA124	Thursday, May 28, 2020	0.001	Passed	0.0240	Passed	
Inglis Street Elementary School	Gender Neutral Wash Room tap 2 by Room 325	MTA125	Thursday, May 28, 2020	-	Passed	0.0200	Passed	
Inglis Street Elementary School	Basement Boiler Room tap	MUV553	Monday, June 8, 2020	0.002	Passed	0.1300	Passed	
Inglis Street Elementary School	Basement Class Room	MUV554	Monday, June 8, 2020	0.001	Passed	0.0490	Passed	
Inglis Street Elementary School	Basement Fountain	QKE731	Monday, August 16, 2021	0.001	Passed	0.0440	Passed	Fountain replaced
Island View High School	Gender Neutral Wash Room tap Room 304H.1	MYZ388	Thursday, June 25, 2020	0.001	Passed	0.0700	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304G	MZD660	Thursday, June 25, 2020	0.003	Passed	0.6300	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304F	MZD661	Thursday, June 25, 2020	0.007	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Gender Neutral Wash Room tap Room 304E	MZD662	Thursday, June 25, 2020	0.001	Passed	0.1100	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304D	MZD663	Thursday, June 25, 2020	0.006	Exceeded	0.9400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Gender Neutral Wash Room tap Room 304C	MZD664	Thursday, June 25, 2020	0.005	Passed	0.8500	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304B	MZD665	Thursday, June 25, 2020	0.001	Passed	0.1900	Passed	
Island View High School	Gender Neutral Wash Room tap Room 304A	MZD666	Thursday, June 25, 2020	0.004	Passed	0.3800	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Island View High School	Janitors Closet tap Room 208B.1	MZD667	Thursday, June 25, 2020	-	Passed	0.3800	Passed	
Island View High School	Class Room tap 1 Room 327.1	MZD668	Thursday, June 25, 2020	-	Passed	0.1900	Passed	
Island View High School	Class Room tap 2 Room 327.1	MZD669	Thursday, June 25, 2020	0.001	Passed	2.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Fountain by Room 327.1	MZD670	Thursday, June 25, 2020	-	Passed	0.3000	Passed	
Island View High School	Life Sci. Lab tap 1 Room 315.1	MZD671	Thursday, June 25, 2020	0.007	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Life Sci. Lab tap 2 Room 315.1	MZD672	Thursday, June 25, 2020	0.001	Passed	0.0960	Passed	
Island View High School	Life Sci. Lab tap 3 Room 315.1	MZD673	Thursday, June 25, 2020	0.004	Passed	0.4400	Passed	
Island View High School	Life Sci. Lab tap 4 Room 315.1	MZD674	Thursday, June 25, 2020	0.001	Passed	0.2800	Passed	
Island View High School	Life Sci. Lab tap 5 Room 315.1	MZD675	Thursday, June 25, 2020	-	Passed	1.1000	Passed	
Island View High School	Life Sci. Lab tap 6 Room 315.1	MZD676	Thursday, June 25, 2020	0.008	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Life Sci. Lab tap 7 Room 315.1	MZD677	Thursday, June 25, 2020	-	Passed	0.1900	Passed	
Island View High School	Assistive care Wash Room tap	MZD678	Thursday, June 25, 2020	0.008	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Class Room tap Room 311A	MZD679	Thursday, June 25, 2020	0.002	Passed	0.4900	Passed	
Island View High School	Chem Lab tap 1 Room 309	MZD680	Thursday, June 25, 2020	-	Passed	0.0340	Passed	
Island View High School	Chem Lab tap 2 Room 309	MZD681	Thursday, June 25, 2020	0.001	Passed	0.0730	Passed	
Island View High School	Chem Lab tap 3 Room 309	MZD682	Thursday, June 25, 2020	0.007	Exceeded	0.4900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Chem Lab tap 4 Room 309	MZD683	Thursday, June 25, 2020	-	Passed	0.0660	Passed	
Island View High School	Chem Lab tap 5 Room 309	MZD684	Thursday, June 25, 2020	0.001	Passed	0.0810	Passed	
Island View High School	Chem Lab tap 6 Room 309	MZD685	Thursday, June 25, 2020	0.001	Passed	0.0570	Passed	
Island View High School	Chem Lab tap 7 Room 309	MZD686	Thursday, June 25, 2020	-	Passed	0.4900	Passed	
Island View High School	Chem Lab tap 8 Room 309	MZD687	Thursday, June 25, 2020	0.001	Passed	0.0300	Passed	
Island View High School	Chem Lab tap 9 Room 309	MZD688	Thursday, June 25, 2020	0.001	Passed	0.4200	Passed	
Island View High School	Staff Room tap 1 Room 305	MZD689	Thursday, June 25, 2020	-	Passed	0.0310	Passed	
Island View High School	Staff Room tap 2 Room 305	MZD690	Thursday, June 25, 2020	0.001	Passed	0.7000	Passed	
Island View High School	Gender Neutral Wash Room tap Room 303	MZD691	Thursday, June 25, 2020	-	Passed	0.0720	Passed	
Island View High School	Gender Neutral Wash Room tap 1 Room 206H	MZD692	Thursday, June 25, 2020	0.003	Passed	0.6100	Passed	
Island View High School	Gender Neutral Wash Room tap 1 Room 206G	MZD693	Thursday, June 25, 2020	0.002	Passed	0.2600	Passed	
Island View High School	Gender Neutral Wash Room tap 1 Room 206F	MZD694	Thursday, June 25, 2020	0.019	Exceeded	3.6000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Gender Neutral Wash Room tap 1 Room 206E	MZD695	Thursday, June 25, 2020	0.004	Passed	0.9300	Passed	
Island View High School	Gender Neutral Wash Room tap 1 Room 206D	MZD696	Thursday, June 25, 2020	0.004	Passed	0.3000	Passed	
Island View High School	Gender Neutral Wash Room tap 1 Room 206C	MZD697	Thursday, June 25, 2020	0.001	Passed	0.1200	Passed	
Island View High School	Gender Neutral Wash Room tap 1 Room 206B	MZD698	Thursday, June 25, 2020	0.001	Passed	0.1500	Passed	
Island View High School	Gender Neutral Wash Room tap 1 Room 206A	MZD699	Thursday, June 25, 2020	0.001	Passed	0.1400	Passed	
Island View High School	Janitors Closet tap Room 208B.1	MZD700	Thursday, June 25, 2020	-	Passed	0.0600	Passed	
Island View High School	Class Room tap 1 Room 225	MZD701	Thursday, June 25, 2020	-	Passed	0.1100	Passed	
Island View High School	Class Room tap 2 Room 225	MZD702	Thursday, June 25, 2020	0.004	Passed	0.8400	Passed	
Island View High School	Class Room tap 1 Room 227	MZD703	Thursday, June 25, 2020	-	Passed	0.2600	Passed	
Island View High School	Class Room tap 2 Room 227	MZD704	Thursday, June 25, 2020	0.002	Passed	0.5700	Passed	
Island View High School	Class Room tap Room 213	MZD705	Thursday, June 25, 2020	0.001	Passed	0.2200	Passed	
Island View High School	Nutrition Lab tap 1 Room 211	NNC994	Tuesday, September 1, 2020	0.000	Passed	0.1700	Passed	
Island View High School	Nutrition Lab tap 2 Room 211	MZD707	Thursday, June 25, 2020	-	Passed	0.1800	Passed	
Island View High School	Nutrition Lab tap 3 Room 211	MZD708	Thursday, June 25, 2020	-	Passed	0.1200	Passed	
Island View High School	Nutrition Lab tap 4 Room 211	MZD709	Thursday, June 25, 2020	-	Passed	0.0910	Passed	
Island View High School	Nutrition Lab tap 5 Room 211	MZD710	Thursday, June 25, 2020	0.002	Passed	0.5000	Passed	
Island View High School	Nutrition Lab tap 6 Room 211	NNC995	Tuesday, September 1, 2020	0.000	Passed	0.0190	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Island View High School	Fountain by Room 211	MZD712	Thursday, June 25, 2020	-	Passed	0.3700	Passed	
Island View High School	Main Office Wash Room tap Room 1081	MZD713	Thursday, June 25, 2020	-	Passed	0.0600	Passed	
Island View High School	Gym Gender Neutral Wash Room 1 tap	MZD714	Thursday, June 25, 2020	0.009	Exceeded	1.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Gym Gender Neutral Wash Room 2 tap	MZD715	Thursday, June 25, 2020	0.006	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Gender Neutral Wash Room tap Room 106I.1	MZD716	Friday, June 26, 2020	-	Passed	0.0520	Passed	
Island View High School	Gender Neutral Wash Room tap 1 by Room 106F.1	MZD717	Friday, June 26, 2020	-	Passed	0.1200	Passed	
Island View High School	Gender Neutral Wash Room tap 2 by Room 106F.1	MZD718	Friday, June 26, 2020	0.001	Passed	0.2000	Passed	
Island View High School	Gender Neutral Wash Room tap Room 106B.1	MZD719	Friday, June 26, 2020	0.001	Passed	2.3000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Janitors Closet tap Room 112A.1	MZD720	Friday, June 26, 2020	0.007	Exceeded	0.0690	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Kitchen tap 1 Room 112	MZD721	Friday, June 26, 2020	-	Passed	0.1100	Passed	
Island View High School	Kitchen tap 2 Room 112	MZD722	Friday, June 26, 2020	-	Passed	0.0900	Passed	
Island View High School	Kitchen tap 3 Room 112	MZD723	Friday, June 26, 2020	-	Passed	0.1200	Passed	
Island View High School	Janitors Closet tap Room 114	MZD724	Friday, June 26, 2020	0.001	Passed	0.2900	Passed	
Island View High School	Music Room tap Room 118	MZD725	Friday, June 26, 2020	0.001	Passed	0.7100	Passed	
Island View High School	Art Room tap 1 Room 117	MZD726	Friday, June 26, 2020	-	Passed	0.2500	Passed	
Island View High School	Art Room tap 2 Room 117	MZD727	Friday, June 26, 2020	-	Passed	0.1600	Passed	
Island View High School	Media Room tap Room 111B.1	MZD728	Friday, June 26, 2020	0.003	Passed	0.1300	Passed	
Island View High School	Fountain by Room 111	MZD729	Friday, June 26, 2020	-	Passed	0.4100	Passed	
Island View High School	Production Room tap Room 107	MZD730	Friday, June 26, 2020	0.001	Passed	0.5200	Passed	
Island View High School	Recycle Room tap Room 105	MZD731	Friday, June 26, 2020	0.001	Passed	1.1000	Passed	
Island View High School	Science Lab tap 1 Room 103	MZD855	Friday, June 26, 2020	-	Passed	1.5000	Passed	
Island View High School	Science Lab tap 2 Room 103	MZD856	Friday, June 26, 2020	-	Passed	0.4100	Passed	
Island View High School	Science Lab tap 3 Room 103	MZD857	Friday, June 26, 2020	-	Passed	0.0570	Passed	
Island View High School	Science Lab tap 4 Room 103	NAM732	Tuesday, June 30, 2020	0.002	Passed	0.0240	Passed	
Island View High School	Science Lab tap 5 Room 103	NAM733	Tuesday, June 30, 2020	0.012	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Island View High School	Science Lab tap 6 Room 103	NAM734	Tuesday, June 30, 2020	0.002	Passed	0.0620	Passed	
Island View High School	Science Lab tap 7 Room 103	NAM735	Tuesday, June 30, 2020	0.002	Passed	0.1500	Passed	
John MacNeil Elementary School	Staff Room Kitchen sink tap	NMK080	Friday, August 28, 2020	0.000	Passed	0.0020	Passed	
John MacNeil Elementary School	Staff Room Wash Room 1 tap	MYA977	Monday, June 22, 2020	0.002	Passed	0.0170	Passed	
John MacNeil Elementary School	Staff Room Wash Room 2 tap	MYA978	Monday, June 22, 2020	-	Passed	0.0240	Passed	
John MacNeil Elementary School	Learning Centre tap Room 1	MYA979	Monday, June 22, 2020	0.001	Passed	0.0300	Passed	
John MacNeil Elementary School	Fountain by Room 1	MYA980	Monday, June 22, 2020	-	Passed	0.3300	Passed	
John MacNeil Elementary School	Boys Wash Room tap 1 by resource Room	MYA981	Monday, June 22, 2020	0.072	Exceeded	0.9100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John MacNeil Elementary School	Boys Wash Room tap 2 by resource Room	MYA982	Monday, June 22, 2020	0.010	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John MacNeil Elementary School	Janitors Closet tap by resource Room	MYA983	Monday, June 22, 2020	-	Passed	0.0150	Passed	
John MacNeil Elementary School	Girls Wash Room tap 1 by resource Room	MYA984	Monday, June 22, 2020	0.002	Passed	0.1900	Passed	
John MacNeil Elementary School	Girls Wash Room tap 2 by resource Room	MYA985	Monday, June 22, 2020	-	Passed	0.1100	Passed	
John MacNeil Elementary School	Girls Wash Room tap 3 by resource Room	MYA986	Monday, June 22, 2020	0.004	Passed	0.1100	Passed	
John MacNeil Elementary School	Girls Wash Room tap 1	MYA987	Monday, June 22, 2020	0.120	Exceeded	0.6800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John MacNeil Elementary School	Girls Wash Room tap 2	MYA988	Monday, June 22, 2020	0.020	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John MacNeil Elementary School	Girls Wash Room tap 3	MYA989	Monday, June 22, 2020	0.002	Passed	0.0290	Passed	
John MacNeil Elementary School	Girls Wash Room tap 4	MYA990	Monday, June 22, 2020	0.001	Passed	0.0230	Passed	
John MacNeil Elementary School	Boys Wash Room tap 1	MYA991	Monday, June 22, 2020	0.110	Exceeded	2.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John MacNeil Elementary School	Boys Wash Room tap 2	MYA992	Monday, June 22, 2020	0.005	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John MacNeil Elementary School	Boys Wash Room tap 3	MYA993	Monday, June 22, 2020	0.002	Passed	0.0330	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
John MacNeil Elementary School	Cafeteria/Kitchen tap in Gym	MYA994	Monday, June 22, 2020	0.110	Exceeded	0.7700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Gender Neutral Wash Room tap by upstairs Girls Wash Room	MYR793	Wednesday, June 24, 2020	0.008	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 1 by breakfast/lunch Room	MYR794	Wednesday, June 24, 2020	0.016	Exceeded	0.6600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 2 by breakfast/lunch Room	MYR795	Wednesday, June 24, 2020	0.077	Exceeded	0.5900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 3 by breakfast/lunch Room	MYR796	Wednesday, June 24, 2020	0.040	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 4 by breakfast/lunch Room	MYR797	Wednesday, June 24, 2020	0.130	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Staff Wash Room by Girls Wash Room	MYR798	Wednesday, June 24, 2020	0.040	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Janitors Closet tap in caretaker supplies Room	MYR799	Wednesday, June 24, 2020	0.001	Passed	0.0230	Passed	
John Martin Junior High School	Learning Centre Wash Room tap	MYR800	Wednesday, June 24, 2020	0.041	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 1 by learning Centre	MYR801	Wednesday, June 24, 2020	2.200	Exceeded	53.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 2 by learning Centre	MYR802	Wednesday, June 24, 2020	0.067	Exceeded	4.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 3 by learning Centre	MYR803	Wednesday, June 24, 2020	0.060	Exceeded	6.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Fountain by learning Centre Room	MYR804	Wednesday, June 24, 2020	0.003	Passed	0.5400	Passed	
John Martin Junior High School	Fountain by Room 213	NMV097	Monday, August 31, 2020	0.001	Passed	0.2100	Passed	
John Martin Junior High School	Boys Wash Room tap 1 by Staff Wash Room	MYR806	Wednesday, June 24, 2020	0.190	Exceeded	2.8000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 2 by Staff Wash Room	MYR807	Wednesday, June 24, 2020	0.062	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 3 by Staff Wash Room	MYR808	Wednesday, June 24, 2020	0.690	Exceeded	3.3000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Staff Wash Room by Caretaker Room	MYR809	Wednesday, June 24, 2020	0.022	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Janitors Closet inside caretaker Room	MYR810	Wednesday, June 24, 2020	0.001	Passed	0.0140	Passed	
John Martin Junior High School	Gender Neutral Wash Room by Girls Wash Room	MYR811	Wednesday, June 24, 2020	0.023	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 1 by Gender Neutral Wash Room	MYR812	Wednesday, June 24, 2020	0.340	Exceeded	0.9300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 2 by Gender Neutral Wash Room	MYR813	Wednesday, June 24, 2020	0.290	Exceeded	2.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 3 by Gender Neutral Wash Room	MYR814	Wednesday, June 24, 2020	0.390	Exceeded	5.6000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Fountain by caretaker supplies Room	NMV097	Monday, August 31, 2020	0.003	Passed	0.0350	Passed	
John Martin Junior High School	Fountain by Room 203	NMV100	Monday, August 31, 2020	0.007	Exceeded	0.1100	Passed	New Fountain to be installed. Other sources available.
John Martin Junior High School	Kitchen sink in breakfast Room	NMV101	Monday, August 31, 2020	0.000	Passed	0.0030	Passed	
John Martin Junior High School	Class Room tap Room 203	MYR818	Wednesday, June 24, 2020	0.048	Exceeded	0.5100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Kitchen/Cafeteria tap 1 after Room 203	MYR819	Wednesday, June 24, 2020	0.005	Passed	0.1500	Passed	
John Martin Junior High School	Kitchen/Cafeteria tap 2 after Room 203	MYR820	Wednesday, June 24, 2020	0.002	Passed	0.0130	Passed	
John Martin Junior High School	Staff Wash Room tap by caretaker supplies Room	MYR821	Wednesday, June 24, 2020	0.032	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Fountain by back Gym doors	MYR822	Wednesday, June 24, 2020	0.003	Passed	1.7000	Passed	
John Martin Junior High School	Staff Wash Room tap in teachers Wash Room	MYR823	Wednesday, June 24, 2020	0.014	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Janitors Closet tap in caretaker supplies Room	MYR824	Wednesday, June 24, 2020	0.001	Passed	0.0230	Passed	
John Martin Junior High School	Gym Office Wash Room tap	MYR825	Wednesday, June 24, 2020	0.047	Exceeded	0.7800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 1 in Gym	MYR826	Wednesday, June 24, 2020	0.044	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 2 in Gym	MYR827	Wednesday, June 24, 2020	0.020	Exceeded	0.3900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 3 in Gym	MYR828	Wednesday, June 24, 2020	0.020	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Girls Wash Room tap 4 in Gym	MYR829	Wednesday, June 24, 2020	0.011	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 1 in Gym	MYR830	Wednesday, June 24, 2020	0.032	Exceeded	0.0950	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 2 in Gym	MYR831	Wednesday, June 24, 2020	-	Passed	0.0058	Passed	
John Martin Junior High School	Boys Wash Room tap 3 in Gym	MYR832	Wednesday, June 24, 2020	0.024	Exceeded	0.0480	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Boys Wash Room tap 4 in Gym	MYR833	Wednesday, June 24, 2020	0.010	Exceeded	0.0210	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Staff shower Room tap in Gym	MYR834	Wednesday, June 24, 2020	0.090	Exceeded	1.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Janitors Closet tap by boiler Room	MYR835	Wednesday, June 24, 2020	0.002	Passed	0.0390	Passed	
John Martin Junior High School	Janitors Closet tap in tech ed. Room	MYR836	Wednesday, June 24, 2020	0.008	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
John Martin Junior High School	Gender Neutral Wash Room tap in tech ed. Room	MYR837	Wednesday, June 24, 2020	0.032	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Kitchen/Cafeteria Double compartment sink tap	NMV102	Monday, August 31, 2020	0.000	Passed	0.0029	Passed	
John Martin Junior High School	hand washing sink tap in family Studies Room	NMV103	Monday, August 31, 2020	0.003	Passed	0.0900	Passed	
John Martin Junior High School	Family Studies Room tap 1	NMV104	Monday, August 31, 2020	0.000	Passed	0.0220	Passed	
John Martin Junior High School	Family Studies Room tap 2	NMV105	Monday, August 31, 2020	0.000	Passed	0.0230	Passed	
John Martin Junior High School	Family Studies Room tap 3	NMV106	Monday, August 31, 2020	0.000	Passed	0.0140	Passed	
John Martin Junior High School	Family Studies Room tap 4	NMV107	Monday, August 31, 2020	0.000	Passed	0.0280	Passed	
John Martin Junior High School	Family Studies Room tap 5	NMV108	Monday, August 31, 2020	0.000	Passed	0.0270	Passed	
John Martin Junior High School	Games Room tap	NMV109	Monday, August 31, 2020	0.010	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Office Staff Wash Room tap	MYR846	Wednesday, June 24, 2020	0.054	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 1 tap 1	MYR847	Wednesday, June 24, 2020	0.160	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 1 tap 3	MYR848	Wednesday, June 24, 2020	0.200	Exceeded	2.3000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 1 tap 4	MYR849	Wednesday, June 24, 2020	0.360	Exceeded	0.8100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 1 tap 5	MYR850	Wednesday, June 24, 2020	0.140	Exceeded	2.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 1 tap 6	MYR851	Wednesday, June 24, 2020	1.000	Exceeded	3.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 2 tap 1	MYR856	Wednesday, June 24, 2020	0.340	Exceeded	2.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 2 tap 2	MYR857	Wednesday, June 24, 2020	1.500	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 2 tap 3	MYR858	Wednesday, June 24, 2020	0.440	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 2 tap 4	MYR859	Wednesday, June 24, 2020	0.750	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 2 tap 5	MYR860	Wednesday, June 24, 2020	1.100	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 2 tap 6	MYR861	Wednesday, June 24, 2020	0.140	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab #3 tap 1	MYR862	Wednesday, June 24, 2020	0.580	Exceeded	0.8400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab #3 tap 2	MYR863	Wednesday, June 24, 2020	1.200	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab #3 tap 3	MYR864	Wednesday, June 24, 2020	0.650	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab #3 tap 4	MYR865	Wednesday, June 24, 2020	3.400	Exceeded	0.6700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab #3 tap 5	MYR866	Wednesday, June 24, 2020	3.500	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab #3 tap 6	MYR867	Wednesday, June 24, 2020	3.900	Exceeded	1.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Lab sink in science Lab tap 1	MYR868	Wednesday, June 24, 2020	3.400	Exceeded	0.9100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Handwashing sink in science Lab	MYR869	Wednesday, June 24, 2020	0.039	Exceeded	0.5800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John Martin Junior High School	Science Lab 1 tap 2	NAI288	Monday, June 29, 2020	0.380	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John W. MacLeod Elementary School	Class Room tap Room 10	MNX927	Friday, May 1, 2020	0.001	Passed	0.1300	Passed	
John W. MacLeod Elementary School	Class Room tap Room 9	MNX928	Friday, May 1, 2020	-	Passed	0.0079	Passed	
John W. MacLeod Elementary School	Class Room tap Room 8	MNX929	Friday, May 1, 2020	0.004	Passed	0.0630	Passed	
John W. MacLeod Elementary School	Class Room tap Room 13	MNX930	Friday, May 1, 2020	0.010	Exceeded	0.0640	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John W. MacLeod Elementary School	Fountain by Room 13	QQC450	Monday, September 13, 2021	-	Passed	0.0019	Passed	Fountain replaced
John W. MacLeod Elementary School	Fountain by Room 18	QQC453	Monday, September 13, 2021	-	Passed	-	Passed	Fountain replaced
John W. MacLeod Elementary School	Fountain by Room 3	QQC451	Monday, September 13, 2021	-	Passed	-	Passed	Fountain replaced
John W. MacLeod Elementary School	Room 22 tap 1	MNY246	Friday, May 1, 2020	0.002	Passed	0.2200	Passed	
John W. MacLeod Elementary School	Room 22 tap 2	MNY247	Friday, May 1, 2020	0.001	Passed	0.0980	Passed	
John W. MacLeod Elementary School	Room 22 tap 3	MNY248	Friday, May 1, 2020	0.004	Passed	0.2700	Passed	
John W. MacLeod Elementary School	Room 22 tap 4	MNY249	Friday, May 1, 2020	0.005	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
John W. MacLeod Elementary School	Fountain by Room 22	QQC452	Monday, September 13, 2021	-	Passed	-	Passed	Fountain replaced
John W. MacLeod Elementary School	Room 27 tap 1	MNY251	Friday, May 1, 2020	0.001	Passed	0.1100	Passed	
John W. MacLeod Elementary School	Room 27 tap 2	MNY252	Friday, May 1, 2020	-	Passed	0.0950	Passed	
John W. MacLeod Elementary School	Room 27 tap 3	MNY253	Friday, May 1, 2020	-	Passed	0.0670	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
John W. MacLeod Elementary School	Room 27 tap 4	MNY254	Friday, May 1, 2020	-	Passed	0.0680	Passed	
John W. MacLeod Elementary School	Room 29 tap 1	MNY255	Friday, May 1, 2020	0.002	Passed	0.0290	Passed	
John W. MacLeod Elementary School	Room 29 tap 2	MNY256	Friday, May 1, 2020	0.001	Passed	0.0230	Passed	
John W. MacLeod Elementary School	Room 29 tap 3	MNY257	Friday, May 1, 2020	-	Passed	0.0150	Passed	
John W. MacLeod Elementary School	Room 29 tap 4	MNY258	Friday, May 1, 2020	0.001	Passed	0.0190	Passed	
John W. MacLeod Elementary School	Room 32 tap	MNY259	Friday, May 1, 2020	0.002	Passed	0.1200	Passed	
John W. MacLeod Elementary School	Room 38 tap	MNY260	Friday, May 1, 2020	0.001	Passed	0.1100	Passed	
John W. MacLeod Elementary School	Room 4 tap 1	MNY261	Friday, May 1, 2020	0.001	Passed	0.1100	Passed	
John W. MacLeod Elementary School	Room 4 tap 2	MNY262	Friday, May 1, 2020	0.001	Passed	0.1200	Passed	
John W. MacLeod Elementary School	Class Room tap Room 34	MSP473	Wednesday, May 27, 2020	0.001	Passed	0.0170	Passed	
Joseph Giles Elementary School	Boys Wash Room tap 1 by Room 11	MVV982	Thursday, June 11, 2020	0.004	Passed	0.1400	Passed	
Joseph Giles Elementary School	Boys Wash Room tap 2 by Room 11	MVV983	Thursday, June 11, 2020	0.004	Passed	0.1300	Passed	
Joseph Giles Elementary School	Boys Wash Room tap 3 by Room 11	MVV984	Thursday, June 11, 2020	0.002	Passed	0.1800	Passed	
Joseph Giles Elementary School	Class Room tap Room 3	MVV985	Thursday, June 11, 2020	0.004	Passed	0.1100	Passed	
Joseph Giles Elementary School	Class Room Wash Room tap Room 3	MVV986	Thursday, June 11, 2020	0.001	Passed	0.0360	Passed	
Joseph Giles Elementary School	Fountain by teachers Room	MVV987	Thursday, June 11, 2020	0.002	Passed	0.2000	Passed	
Joseph Giles Elementary School	Wash Room tap in teachers lounge	MVV988	Thursday, June 11, 2020	0.001	Passed	0.0260	Passed	
Joseph Giles Elementary School	Kitchen tap in teachers lounge	MVV989	Thursday, June 11, 2020	0.002	Passed	0.0140	Passed	
Joseph Giles Elementary School	Janitors Closet tap by Girls Wash Room	MVV990	Thursday, June 11, 2020	-	Passed	0.0380	Passed	
Joseph Giles Elementary School	Girls Wash Room tap 1 by teachers lounge	MVV991	Thursday, June 11, 2020	0.003	Passed	0.1800	Passed	
Joseph Giles Elementary School	Girls Wash Room tap 2 by teachers lounge	MVV992	Thursday, June 11, 2020	0.003	Passed	0.1800	Passed	
Joseph Giles Elementary School	Girls Wash Room tap 3 by teachers lounge	MVV993	Thursday, June 11, 2020	0.003	Passed	0.1500	Passed	
Joseph Giles Elementary School	Class Room tap in Room 29	MVV994	Thursday, June 11, 2020	0.029	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Joseph Giles Elementary School	Wash Room tap in Boys shower Room	MVV995	Thursday, June 11, 2020	0.006	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Joseph Giles Elementary School	Janitors Closet tap in Boys shower Room	MVV996	Thursday, June 11, 2020	0.004	Passed	0.1100	Passed	
Joseph Giles Elementary School	Fountain by Boys Locker Room	PXP041	Wednesday, June 23, 2021	-	Passed	0.0290	Passed	New Fountain.
Joseph Giles Elementary School	Wash Room tap in Girls Locker Room	MVV998	Thursday, June 11, 2020	0.002	Passed	0.2500	Passed	
Joseph Giles Elementary School	Fountain by Girls Locker Room	MVV999	Thursday, June 11, 2020	0.005	Passed	0.2700	Passed	
Joseph Howe Elementary School	2nd Floor Boys Wash Room tap 1	MTP738	Friday, May 29, 2020	0.001	Passed	0.0640	Passed	
Joseph Howe Elementary School	2nd Floor Boys Wash Room tap 2	MTP739	Friday, May 29, 2020	0.001	Passed	0.0380	Passed	
Joseph Howe Elementary School	2nd Floor Boys Wash Room tap 3	MTP740	Friday, May 29, 2020	-	Passed	0.0280	Passed	
Joseph Howe Elementary School	2nd Floor Janitors Closet tap	MTP741	Friday, May 29, 2020	-	Passed	0.0088	Passed	
Joseph Howe Elementary School	2nd Floor fountain by Girls Wash Room	MTP742	Friday, May 29, 2020	0.026	Exceeded	1.8000	Passed	New Fountain to be installed. Other sources available.
Joseph Howe Elementary School	2nd Floor Girls Wash Room tap 1	MTP743	Friday, May 29, 2020	-	Passed	0.0100	Passed	
Joseph Howe Elementary School	2nd Floor Girls Wash Room tap 2	MTP744	Friday, May 29, 2020	-	Passed	0.0140	Passed	
Joseph Howe Elementary School	2nd Floor Girls Wash Room tap 3	MTP745	Friday, May 29, 2020	-	Passed	0.0130	Passed	
Joseph Howe Elementary School	2nd Floor Girls Wash Room tap 4	MTP746	Friday, May 29, 2020	-	Passed	0.0190	Passed	
Joseph Howe Elementary School	2nd Floor Girls Wash Room tap 5	MTP747	Friday, May 29, 2020	-	Passed	0.0210	Passed	
Joseph Howe Elementary School	2nd Floor Staff Room Wash Room 1 tap	MTP757	Friday, May 29, 2020	-	Passed	0.0031	Passed	
Joseph Howe Elementary School	2nd Floor Staff Room Wash Room 2 tap	MTP758	Friday, May 29, 2020	-	Passed	0.0039	Passed	
Joseph Howe Elementary School	Staff Room Kitchen tap	MTP759	Friday, May 29, 2020	-	Passed	0.0036	Passed	
Joseph Howe Elementary School	1st Floor Boys Wash Room tap 1	MTP760	Friday, May 29, 2020	-	Passed	0.0110	Passed	
Joseph Howe Elementary School	1st Floor Boys Wash Room tap 2	MTP761	Friday, May 29, 2020	-	Passed	0.0180	Passed	
Joseph Howe Elementary School	1st Floor Boys Wash Room tap 3	MTP762	Friday, May 29, 2020	0.001	Passed	0.0430	Passed	
Joseph Howe Elementary School	1st Floor Boys Wash Room tap 4	MTP763	Friday, May 29, 2020	0.001	Passed	0.0600	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Joseph Howe Elementary School	1st Floor Janitors Closet tap	MTP764	Friday, May 29, 2020	0.009	Exceeded	0.5600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Joseph Howe Elementary School	1st Floor fountain by Janitors Closet	MTP765	Friday, May 29, 2020	0.001	Passed	0.1900	Passed	
Joseph Howe Elementary School	1st Floor Girls Wash Room tap 1	MTP766	Friday, May 29, 2020	-	Passed	0.0130	Passed	
Joseph Howe Elementary School	1st Floor Girls Wash Room tap 2	MTP770	Friday, May 29, 2020	0.004	Passed	0.1800	Passed	
Joseph Howe Elementary School	1st Floor Girls Wash Room tap 3	MTP771	Friday, May 29, 2020	-	Passed	0.0140	Passed	
Joseph Howe Elementary School	1st Floor Girls Wash Room tap 4	MTP772	Friday, May 29, 2020	0.001	Passed	0.0690	Passed	
Joseph Howe Elementary School	1st Floor Class Room Wash Room tap	MTP773	Friday, May 29, 2020	0.010	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Joseph Howe Elementary School	Gender Neutral Wash Room tap (Kitchen)	MTP774	Friday, May 29, 2020	-	Passed	0.0480	Passed	
Joseph Howe Elementary School	Pre primary 2nd Floor fountain	MTP775	Friday, May 29, 2020	0.003	Passed	0.0620	Passed	
Joseph Howe Elementary School	2nd Floor Pre primary Laundry/Wash Room tap 1	MTP776	Friday, May 29, 2020	-	Passed	0.0190	Passed	
Joseph Howe Elementary School	2nd Floor Pre primary Laundry/Wash Room tap 2	MTP777	Friday, May 29, 2020	-	Passed	0.0160	Passed	
Joseph Howe Elementary School	2nd Floor Pre primary Laundry/Wash Room tap 3	MTP778	Friday, May 29, 2020	-	Passed	0.0140	Passed	
Joseph Howe Elementary School	Boys Wash Room tap 1 Basement by Gym	MTP779	Friday, May 29, 2020	0.270	Exceeded	1.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Joseph Howe Elementary School	Boys Wash Room tap 1 Basement by Gym	MTP781	Friday, May 29, 2020	0.003	Passed	0.0910	Passed	
Joseph Howe Elementary School	Basement fountain near caretakers Room	NMD863	Thursday, August 27, 2020	0.000	Passed	0.0080	Passed	
Joseph Howe Elementary School	Basement Janitors Closet tap	MTP783	Friday, May 29, 2020	-	Passed	0.0490	Passed	
Joseph Howe Elementary School	Caretakers Room tap by Room 138	MTP784	Friday, May 29, 2020	0.002	Passed	0.0510	Passed	
Joseph Howe Elementary School	Girls Wash Room tap 1 Room 138	MTP785	Friday, May 29, 2020	-	Passed	0.0190	Passed	
Joseph Howe Elementary School	Girls Wash Room tap 2 Room 138	MTP786	Friday, May 29, 2020	0.001	Passed	0.0260	Passed	
Joseph Howe Elementary School	Breakfast club Room tap (Basement)	MTP787	Friday, May 29, 2020	0.001	Passed	0.0290	Passed	
Joseph Howe Elementary School	Gender Neutral Gym Wash Room tap 1	MTP788	Friday, May 29, 2020	0.002	Passed	0.0770	Passed	
Joseph Howe Elementary School	Gender Neutral Gym Wash Room tap 2	MTP789	Friday, May 29, 2020	-	Passed	0.0140	Passed	
Joseph Howe Elementary School	Gender Neutral Gym Wash Room tap 3	MTP790	Friday, May 29, 2020	-	Passed	0.0120	Passed	
Joseph Howe Elementary School	Gender Neutral Gym Wash Room tap 4	MTP793	Friday, May 29, 2020	-	Passed	0.0110	Passed	
Kingswood Elementary School	Fountain by Room 242	NLV853	Wednesday, August 26, 2020	0.005	Passed	0.0080	Passed	
Kingswood Elementary School	Janitors Closet tap Room 233	MUU155	Friday, June 5, 2020	-	Passed	0.0380	Passed	
Kingswood Elementary School	Girls Wash Room tap 1 by Room 233	MUU156	Friday, June 5, 2020	0.260	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Girls Wash Room tap 2 by Room 233	MUU157	Friday, June 5, 2020	0.230	Exceeded	0.8400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Boys Wash Room tap 1 by Room 232	MUU158	Friday, June 5, 2020	0.031	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Boys Wash Room tap 2 by Room 232	MUU159	Friday, June 5, 2020	0.020	Exceeded	0.0660	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Gender Neutral Wash Room tap Room 232	MUU160	Friday, June 5, 2020	0.001	Passed	0.0600	Passed	
Kingswood Elementary School	Boys Wash Room tap 1 by Room 225	MUU161	Friday, June 5, 2020	0.002	Passed	0.0500	Passed	
Kingswood Elementary School	Boys Wash Room tap 2 by Room 225	MUU162	Friday, June 5, 2020	0.003	Passed	0.0910	Passed	
Kingswood Elementary School	Girls Wash Room tap 1 by Room 224	MUU163	Friday, June 5, 2020	0.001	Passed	0.1900	Passed	
Kingswood Elementary School	Girls Wash Room tap 2 by Room 224	MUU164	Friday, June 5, 2020	0.002	Passed	0.1900	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 224	MUU165	Friday, June 5, 2020	-	Passed	0.0077	Passed	
Kingswood Elementary School	Fountain by Room 204	MUU166	Friday, June 5, 2020	0.002	Passed	0.2700	Passed	
Kingswood Elementary School	Laundry tub tap Room 240	MUU167	Friday, June 5, 2020	-	Passed	0.0380	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 20	MUU168	Friday, June 5, 2020	0.004	Passed	0.1300	Passed	
Kingswood Elementary School	Class Room tap Room 210	MUU169	Friday, June 5, 2020	-	Passed	0.0350	Passed	
Kingswood Elementary School	Class Room tap Room 112	MUU170	Friday, June 5, 2020	0.001	Passed	0.5000	Passed	
Kingswood Elementary School	Class Room tap Room 113	MUU171	Friday, June 5, 2020	-	Passed	0.3900	Passed	
Kingswood Elementary School	fountain by Room 184	MUU172	Friday, June 5, 2020	0.002	Passed	0.8600	Passed	
Kingswood Elementary School	Class Room tap Room 117	MUU173	Friday, June 5, 2020	-	Passed	0.3900	Passed	
Kingswood Elementary School	Class Room tap Room 118	MUU174	Friday, June 5, 2020	-	Passed	0.5000	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Kingswood Elementary School	Class Room tap Room 120	MUU175	Friday, June 5, 2020	-	Passed	0.4700	Passed	
Kingswood Elementary School	Class Room tap Room 119	MUU176	Friday, June 5, 2020	-	Passed	0.3600	Passed	
Kingswood Elementary School	Class Room tap Room 116	MUU177	Friday, June 5, 2020	0.002	Passed	0.6800	Passed	
Kingswood Elementary School	Class Room tap 1 Room 115	MUU178	Friday, June 5, 2020	-	Passed	0.0680	Passed	
Kingswood Elementary School	Class Room tap 2 Room 115	MUU179	Friday, June 5, 2020	-	Passed	0.5600	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 114	MUU180	Friday, June 5, 2020	0.002	Passed	0.0600	Passed	
Kingswood Elementary School	Boys Wash Room tap 1 by Room 114	MUU181	Friday, June 5, 2020	0.047	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Boys Wash Room tap 2 by Room 114	MUU182	Friday, June 5, 2020	0.035	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Girls Wash Room tap 1 by Room 167	MUU183	Friday, June 5, 2020	0.073	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Girls Wash Room tap 2 by Room 167	MUU184	Friday, June 5, 2020	0.009	Exceeded	0.0720	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Gender Neutral Wash Room tap Room 165	MUU185	Friday, June 5, 2020	0.001	Passed	0.0660	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 166	MUU186	Friday, June 5, 2020	0.015	Exceeded	0.0370	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Class Room tap Room 167	MUU187	Friday, June 5, 2020	-	Passed	0.0300	Passed	
Kingswood Elementary School	Class Room tap Room 110	MUU188	Friday, June 5, 2020	-	Passed	0.0410	Passed	
Kingswood Elementary School	Staff Wash Room tap Room 180 (main Office)	MUU189	Friday, June 5, 2020	-	Passed	0.0380	Passed	
Kingswood Elementary School	Library Kitchen tap Room 107	MUU190	Friday, June 5, 2020	0.001	Passed	0.1100	Passed	
Kingswood Elementary School	Boys Wash Room tap 1 by Room 106	MUU191	Friday, June 5, 2020	0.003	Passed	0.3100	Passed	
Kingswood Elementary School	Boys Wash Room tap 2 by Room 106	MUU192	Friday, June 5, 2020	0.023	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Girls Wash Room tap 1 by Room 183	MUU193	Friday, June 5, 2020	0.001	Passed	0.0340	Passed	
Kingswood Elementary School	Girls Wash Room tap 2 by Room 183	MUU194	Friday, June 5, 2020	0.003	Passed	0.1100	Passed	
Kingswood Elementary School	Class Room tap Room 102	MUU195	Friday, June 5, 2020	-	Passed	0.2500	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 187	MUU196	Friday, June 5, 2020	-	Passed	0.0870	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 124	MUU197	Friday, June 5, 2020	0.001	Passed	0.0360	Passed	
Kingswood Elementary School	Class Room tap Room 101	MUU198	Friday, June 5, 2020	-	Passed	0.0430	Passed	
Kingswood Elementary School	Class Room tap Room 103	MUU199	Friday, June 5, 2020	-	Passed	0.2400	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 121	MUU200	Friday, June 5, 2020	-	Passed	0.0390	Passed	
Kingswood Elementary School	Gender Neutral Wash Room tap Room 186	MUU201	Friday, June 5, 2020	0.020	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Kingswood Elementary School	Class Room tap Room 104	MUU202	Friday, June 5, 2020	-	Passed	0.0590	Passed	
Kingswood Elementary School	Fountain by Room 104	MUU203	Friday, June 5, 2020	0.002	Passed	0.6800	Passed	
Kingswood Elementary School	Music Room tap Room 105	MUU204	Friday, June 5, 2020	0.004	Passed	0.0640	Passed	
Kingswood Elementary School	Laundry tub tap Room 138	MUU205	Friday, June 5, 2020	0.001	Passed	0.0980	Passed	
Kingswood Elementary School	Cafeteria/Kitchen handwashing tap	MUU206	Friday, June 5, 2020	-	Passed	0.5200	Passed	
Kingswood Elementary School	Cafeteria/Kitchen single compartment sink tap	MUU207	Friday, June 5, 2020	0.002	Passed	0.4900	Passed	
Kingswood Elementary School	Cafeteria/Kitchen handwashing tap	MUU208	Friday, June 5, 2020	0.005	Exceeded	0.7500	Passed	
Kingswood Elementary School	Cafeteria/Kitchen Triple compartment sink tap 1	MUU209	Friday, June 5, 2020	-	Passed	0.4900	Passed	
Kingswood Elementary School	Cafeteria/Kitchen Triple compartment sink tap 2	MUU210	Friday, June 5, 2020	0.001	Passed	0.0850	Passed	
Kingswood Elementary School	Cafeteria/Kitchen single compartment sink tap	NLV864	Wednesday, August 26, 2020	0.001	Passed	0.0550	Passed	
Kingswood Elementary School	Cafeteria/stage Kitchen tap 1	MUU212	Friday, June 5, 2020	-	Passed	0.0440	Passed	
Kingswood Elementary School	Cafeteria/stage Kitchen tap 2	MUU213	Friday, June 5, 2020	0.005	Passed	0.5100	Passed	
Kingswood Elementary School	Janitors Closet tap Room 142	MUU214	Friday, June 5, 2020	-	Passed	0.0310	Passed	
Kingswood Elementary School	Fountain in Gym by Room 144	MUU215	Friday, June 5, 2020	-	Passed	0.4400	Passed	
Kingswood Elementary School	Boys change Room tap Room 144	MUU216	Friday, June 5, 2020	0.001	Passed	0.1600	Passed	
Kingswood Elementary School	Girls Change Room tap Room 150	MUU217	Friday, June 5, 2020	0.002	Passed	0.0740	Passed	
Kingswood Elementary School	Gym Office Wash Room tap Room 146	MUU218	Friday, June 5, 2020	0.001	Passed	0.0850	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 306	MUW210	Monday, June 8, 2020	-	Passed	0.4600	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
LeMarchant-St. Thomas Elementary School	Class Room tap Room 308	MUW211	Monday, June 8, 2020	0.001	Passed	0.0820	Passed	
LeMarchant-St. Thomas Elementary School	Assist care Wash Room tap	MUW212	Monday, June 8, 2020	-	Passed	0.1800	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 314	MUW213	Monday, June 8, 2020	0.001	Passed	0.1500	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 316	MUW214	Monday, June 8, 2020	0.001	Passed	0.1600	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 318	MUW215	Monday, June 8, 2020	-	Passed	0.2800	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 322	MUW216	Monday, June 8, 2020	0.001	Passed	0.0700	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 326	MUW217	Monday, June 8, 2020	0.002	Passed	0.1800	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 325	MUW218	Monday, June 8, 2020	-	Passed	0.2100	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 323	MUW219	Monday, June 8, 2020	-	Passed	0.2300	Passed	
LeMarchant-St. Thomas Elementary School	3rd Floor Wash Room sink tap 1	MUW220	Monday, June 8, 2020	0.002	Passed	0.6300	Passed	
LeMarchant-St. Thomas Elementary School	3rd Floor Wash Room sink tap 2	MUW221	Monday, June 8, 2020	0.005	Passed	0.6000	Passed	
LeMarchant-St. Thomas Elementary School	3rd Floor Wash Room sink tap 3	NAM731	Tuesday, June 30, 2020	0.001	Passed	0.5000	Passed	
LeMarchant-St. Thomas Elementary School	3rd Floor Wash Room sink tap 4	MUW223	Monday, June 8, 2020	0.002	Passed	0.6200	Passed	
LeMarchant-St. Thomas Elementary School	Fountain by Wash Room	MUW224	Monday, June 8, 2020	-	Passed	0.3700	Passed	
LeMarchant-St. Thomas Elementary School	Fountain by Janitors Closet	MUW225	Monday, June 8, 2020	-	Passed	0.3200	Passed	
LeMarchant-St. Thomas Elementary School	Janitors Closet tap by Room 301	MUW226	Monday, June 8, 2020	-	Passed	0.4700	Passed	
LeMarchant-St. Thomas Elementary School	Class Room tap Room 301	MUW227	Monday, June 8, 2020	-	Passed	0.1000	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 302 tap	MUW228	Monday, June 8, 2020	-	Passed	0.0380	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 206 tap 1	MUW229	Monday, June 8, 2020	-	Passed	0.2300	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 206 tap 2	MUW230	Monday, June 8, 2020	0.001	Passed	0.5600	Passed	
LeMarchant-St. Thomas Elementary School	Fountain 1	MUW231	Monday, June 8, 2020	-	Passed	0.7900	Passed	
LeMarchant-St. Thomas Elementary School	Fountain 2	MUW232	Monday, June 8, 2020	-	Passed	0.6600	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 216 tap	MUW233	Monday, June 8, 2020	-	Passed	0.3400	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 218 tap	NAM730	Tuesday, June 30, 2020	-	Passed	0.0820	Passed	
LeMarchant-St. Thomas Elementary School	Fountain 1	MUW235	Monday, June 8, 2020	-	Passed	0.3100	Passed	
LeMarchant-St. Thomas Elementary School	Fountain 2	MUW236	Monday, June 8, 2020	-	Passed	0.3100	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 220 tap	MUW237	Monday, June 8, 2020	-	Passed	0.3900	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 222 tap	MUW238	Monday, June 8, 2020	-	Passed	0.5200	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 226 tap	MUW239	Monday, June 8, 2020	0.004	Passed	0.2700	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 225 tap	MUW240	Monday, June 8, 2020	-	Passed	0.2700	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 221 tap	MUW241	Monday, June 8, 2020	-	Passed	0.1600	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 213 tap	MUW242	Monday, June 8, 2020	-	Passed	0.3000	Passed	
LeMarchant-St. Thomas Elementary School	2nd Floor Wash Room tap 1	NAM729	Tuesday, June 30, 2020	-	Passed	0.4200	Passed	
LeMarchant-St. Thomas Elementary School	2nd Floor Wash Room tap 2	MUW244	Monday, June 8, 2020	0.002	Passed	0.7000	Passed	
LeMarchant-St. Thomas Elementary School	2nd Floor Wash Room tap 3	MUW245	Monday, June 8, 2020	0.002	Passed	0.6600	Passed	
LeMarchant-St. Thomas Elementary School	2nd Floor Wash Room tap 4	MUW246	Monday, June 8, 2020	0.001	Passed	0.6300	Passed	
LeMarchant-St. Thomas Elementary School	Janitors Closet 209 tap	MUW247	Monday, June 8, 2020	-	Passed	0.3400	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 202 tap	MUW248	Monday, June 8, 2020	-	Passed	0.1900	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 204 tap	MUW249	Monday, June 8, 2020	-	Passed	0.6800	Passed	
LeMarchant-St. Thomas Elementary School	Main Office 102 Wash Room tap	MUW250	Monday, June 8, 2020	-	Passed	0.4900	Passed	
LeMarchant-St. Thomas Elementary School	Fountain 1 by Room 110	MUW251	Monday, June 8, 2020	-	Passed	0.0710	Passed	
LeMarchant-St. Thomas Elementary School	Fountain 2 by Room 114	MUW252	Monday, June 8, 2020	-	Passed	0.1000	Passed	
LeMarchant-St. Thomas Elementary School	Gender Neutral Wash Room 114 tap	NAM728	Tuesday, June 30, 2020	0.001	Passed	0.0940	Passed	
LeMarchant-St. Thomas Elementary School	Room 114 Kitchen sink tap	MUW254	Monday, June 8, 2020	0.001	Passed	0.9500	Passed	
LeMarchant-St. Thomas Elementary School	Gender Neutral Wash Room 116 tap	MUW255	Monday, June 8, 2020	-	Passed	0.2500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
LeMarchant-St. Thomas Elementary School	Room 116 Kitchen sink tap	MUW256	Monday, June 8, 2020	-	Passed	0.2200	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 122 Gender Neutral Wash Room tap	MUW257	Monday, June 8, 2020	0.001	Passed	0.4900	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 122 tap	MUW258	Monday, June 8, 2020	0.001	Passed	0.3900	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 124 tap	MUW259	Monday, June 8, 2020	-	Passed	0.6500	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 124 Gender Neutral Wash Room tap	MUW260	Monday, June 8, 2020	-	Passed	0.3500	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 126 Gender Neutral Wash Room tap	MUW261	Monday, June 8, 2020	-	Passed	0.4800	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 126 tap	MUW262	Monday, June 8, 2020	-	Passed	0.3600	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 125 tap	MUW263	Monday, June 8, 2020	-	Passed	0.2700	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 125 Gender Neutral Wash Room tap	MUW264	Monday, June 8, 2020	-	Passed	0.4700	Passed	
LeMarchant-St. Thomas Elementary School	Janitors Closet 121 tap	MUW265	Monday, June 8, 2020	-	Passed	0.2000	Passed	
LeMarchant-St. Thomas Elementary School	Gym Gender Neutral Wash Room 119B tap	MUW266	Monday, June 8, 2020	-	Passed	0.1600	Passed	
LeMarchant-St. Thomas Elementary School	Gym Staff Wash Room tap	MUW267	Monday, June 8, 2020	-	Passed	1.2000	Passed	
LeMarchant-St. Thomas Elementary School	Main Floor Gender Neutral Wash Room tap 1	MUW268	Monday, June 8, 2020	0.003	Passed	0.6000	Passed	
LeMarchant-St. Thomas Elementary School	Main Floor Gender Neutral Wash Room tap 2	MUW269	Monday, June 8, 2020	0.001	Passed	0.6100	Passed	
LeMarchant-St. Thomas Elementary School	Main Floor Gender Neutral Wash Room tap 3	NAM727	Tuesday, June 30, 2020	-	Passed	0.4600	Passed	
LeMarchant-St. Thomas Elementary School	Main Floor Gender Neutral Wash Room tap 4	MUW271	Monday, June 8, 2020	0.001	Passed	0.6700	Passed	
LeMarchant-St. Thomas Elementary School	Stage tap 1	MUW272	Monday, June 8, 2020	-	Passed	0.1500	Passed	
LeMarchant-St. Thomas Elementary School	Stage tap 2	MUW273	Monday, June 8, 2020	-	Passed	0.0560	Passed	
LeMarchant-St. Thomas Elementary School	Music Room tap	MUW274	Monday, June 8, 2020	-	Passed	1.1000	Passed	
LeMarchant-St. Thomas Elementary School	Room 109 Laundry tub tap	MUW275	Monday, June 8, 2020	-	Passed	0.4200	Passed	
LeMarchant-St. Thomas Elementary School	Class Room 129 tap	MUW276	Monday, June 8, 2020	-	Passed	0.1200	Passed	
LeMarchant-St. Thomas Elementary School	Cafeteria/Kitchen double compartment tap	MUW277	Monday, June 8, 2020	-	Passed	0.1600	Passed	
LeMarchant-St. Thomas Elementary School	Cafeteria/Kitchen hand washing tap	MUW278	Monday, June 8, 2020	0.001	Passed	0.2700	Passed	
LeMarchant-St. Thomas Elementary School	Cafeteria/Kitchen Janitors Closet tap	MUW279	Monday, June 8, 2020	0.001	Passed	0.6900	Passed	
LeMarchant-St. Thomas Elementary School	Cafeteria/Kitchen single compartment tap	MUW280	Monday, June 8, 2020	-	Passed	0.3900	Passed	
LeMarchant-St. Thomas Elementary School	Laundry tub tap in Boiler Room (outside)	MUW281	Monday, June 8, 2020	0.001	Passed	0.6600	Passed	
Leslie Thomas Junior High School	3rd Floor Boys Wash Room tap 1	MOP577	Tuesday, May 5, 2020	0.003	Passed	0.1100	Passed	
Leslie Thomas Junior High School	3rd Floor Boys Wash Room tap 2	MOP578	Tuesday, May 5, 2020	0.003	Passed	0.0930	Passed	
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 1	MOP579	Tuesday, May 5, 2020	0.004	Passed	0.0900	Passed	
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 2	MOP580	Tuesday, May 5, 2020	0.002	Passed	0.0810	Passed	
Leslie Thomas Junior High School	3rd Floor Girls Wash Room tap 3	MOP581	Tuesday, May 5, 2020	0.015	Exceeded	0.0800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	3rd Floor fountain by Room 3D	MOP582	Tuesday, May 5, 2020	0.001	Passed	0.5900	Passed	
Leslie Thomas Junior High School	Class Room tap Room 308	MOP583	Tuesday, May 5, 2020	0.006	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	Class Room Wash Room 1 tap Room 308	MOP584	Tuesday, May 5, 2020	0.003	Passed	0.0780	Passed	
Leslie Thomas Junior High School	Class Room Wash Room 2 tap Room 308	MOP585	Tuesday, May 5, 2020	0.002	Passed	0.0700	Passed	
Leslie Thomas Junior High School	Class Room tap Room 3D	MOP586	Tuesday, May 5, 2020	0.002	Passed	0.0670	Passed	
Leslie Thomas Junior High School	2nd Floor Boys Wash Room tap 1	MOP587	Tuesday, May 5, 2020	0.025	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	2nd Floor Boys Wash Room tap 2	MOP588	Tuesday, May 5, 2020	0.006	Exceeded	0.0770	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	2nd Floor Girls Wash Room tap 1	MOP589	Tuesday, May 5, 2020	0.017	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	2nd Floor Girls Wash Room tap 2	MOP590	Tuesday, May 5, 2020	0.002	Passed	0.0860	Passed	
Leslie Thomas Junior High School	Fountain in Room 2A	NJH081	Friday, August 14, 2020	0.006	Exceeded	0.0890	Passed	New Fountain to be installed. Other sources available.
Leslie Thomas Junior High School	Janitors Closet tap Room 2A	MOP592	Tuesday, May 5, 2020	0.001	Passed	0.0500	Passed	
Leslie Thomas Junior High School	Main Office Wash Room tap	MOP593	Tuesday, May 5, 2020	0.009	Exceeded	0.0940	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	2nd Floor café tap	MOP594	Tuesday, May 5, 2020	0.003	Passed	0.3900	Passed	
Leslie Thomas Junior High School	1st Floor Class Room tap Room 113	MOP595	Tuesday, May 5, 2020	0.002	Passed	0.2600	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Leslie Thomas Junior High School	1st Floor Class Room tap 1 Room 111	MOP596	Tuesday, May 5, 2020	0.001	Passed	0.3800	Passed	
Leslie Thomas Junior High School	1st Floor Class Room tap 2 Room 111	MOP597	Tuesday, May 5, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	Class Room tap Room 110	MOP598	Tuesday, May 5, 2020	0.002	Passed	0.8000	Passed	
Leslie Thomas Junior High School	Class Room tap Room 108	MOP599	Tuesday, May 5, 2020	0.071	Exceeded	0.8900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	Class Room tap Room 109	MOP600	Tuesday, May 5, 2020	0.002	Passed	0.0760	Passed	
Leslie Thomas Junior High School	Class Room tap Room 107	MOP601	Tuesday, May 5, 2020	0.059	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	Class Room tap Room 106	MOP602	Tuesday, May 5, 2020	0.038	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	1st Floor Boys Wash Room tap 1	MOP603	Tuesday, May 5, 2020	0.012	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	1st Floor Boys Wash Room tap 2	MOP604	Tuesday, May 5, 2020	0.005	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	Janitors Closet tap Room 1B	MOP605	Tuesday, May 5, 2020	0.003	Passed	0.0730	Passed	
Leslie Thomas Junior High School	1st Floor fountain by Room 1B	MOP606	Tuesday, May 5, 2020	0.001	Passed	0.7000	Passed	
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 1	MOP607	Tuesday, May 5, 2020	0.006	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 2	MOP608	Tuesday, May 5, 2020	0.001	Passed	0.0760	Passed	
Leslie Thomas Junior High School	1st Floor Girls Wash Room tap 3	MOP609	Tuesday, May 5, 2020	0.002	Passed	0.0820	Passed	
Lockview High School	Class Room tap Room A108	NBQ671	Wednesday, July 8, 2020	0.007	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap 1 Room A112	NBQ672	Wednesday, July 8, 2020	0.003	Passed	0.9500	Passed	
Lockview High School	Class Room tap 2 Room A112	NBQ673	Wednesday, July 8, 2020	0.013	Exceeded	0.0470	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Staff Wash Room tap Room C105	NBQ674	Wednesday, July 8, 2020	0.016	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Staff Wash Room tap Room C106	NBQ675	Wednesday, July 8, 2020	0.005	Passed	0.0720	Passed	
Lockview High School	Staff Room tap by Room C106	NBQ676	Wednesday, July 8, 2020	0.002	Passed	0.0940	Passed	
Lockview High School	Library support Room tap Room C117	NBQ677	Wednesday, July 8, 2020	0.036	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Library support Wash Room tap Room C117	NBQ678	Wednesday, July 8, 2020	0.012	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room tap 1 by section A	NBQ679	Wednesday, July 8, 2020	0.013	Exceeded	0.0700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room tap 2 by section A	NBQ680	Wednesday, July 8, 2020	0.019	Exceeded	0.0650	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room tap 3 by section A	NBQ681	Wednesday, July 8, 2020	0.028	Exceeded	0.0570	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room tap 4 by section A	NBQ682	Wednesday, July 8, 2020	0.037	Exceeded	0.0650	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Fountain by Room B101	-	-	-	-	-	-	Fountain remediation in progress
Lockview High School	Science Lab tap 1 Room B101	NBQ683	Wednesday, July 8, 2020	0.001	Passed	0.7100	Passed	
Lockview High School	Science Lab tap 2 Room B101	NBQ684	Wednesday, July 8, 2020	0.008	Exceeded	0.9200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab tap 3 Room B101	NBQ685	Wednesday, July 8, 2020	0.005	Passed	1.3000	Passed	
Lockview High School	Science Lab tap 4 Room B101	NBQ686	Wednesday, July 8, 2020	0.005	Passed	0.7600	Passed	
Lockview High School	Science Lab tap 5 Room B101	NBQ687	Wednesday, July 8, 2020	0.001	Passed	1.7000	Passed	
Lockview High School	Science Lab tap 6 Room B101	NBQ688	Wednesday, July 8, 2020	0.001	Passed	1.4000	Passed	
Lockview High School	Science Lab tap 7 Room B101	NBQ689	Wednesday, July 8, 2020	0.001	Passed	1.1000	Passed	
Lockview High School	Science Lab tap 8 Room B101	NBQ690	Wednesday, July 8, 2020	0.001	Passed	1.0000	Passed	
Lockview High School	Science Lab tap 9 Room B101	NBQ691	Wednesday, July 8, 2020	0.007	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab tap 10 Room B101	NBQ692	Wednesday, July 8, 2020	0.018	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab tap 11 Room B101	NBQ693	Wednesday, July 8, 2020	0.004	Passed	0.8900	Passed	
Lockview High School	Science Lab tap 12 Room B101	NBQ694	Wednesday, July 8, 2020	0.001	Passed	2.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab tap 13 Room B101	NBQ695	Wednesday, July 8, 2020	0.004	Passed	1.2000	Passed	
Lockview High School	Science Lab tap 14 Room B101	NBQ696	Wednesday, July 8, 2020	0.002	Passed	1.6000	Passed	
Lockview High School	Science Lab tap 15 Room B101	NBQ697	Wednesday, July 8, 2020	0.007	Exceeded	0.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab tap 16 Room B101	NBQ698	Wednesday, July 8, 2020	0.004	Passed	0.9600	Passed	
Lockview High School	Science Lab tap 17 Room B101	NBQ699	Wednesday, July 8, 2020	0.011	Exceeded	0.8700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab tap 18 Room B101	NBQ700	Wednesday, July 8, 2020	0.081	Exceeded	0.9300	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Lockview High School	Science Lab Room B102 tap 1	NBQ701	Wednesday, July 8, 2020	0.006	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 2	NBQ702	Wednesday, July 8, 2020	0.005	Exceeded	0.7900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 3	NBQ703	Wednesday, July 8, 2020	0.009	Exceeded	0.5800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 4	NBQ704	Wednesday, July 8, 2020	0.004	Passed	1.6000	Passed	
Lockview High School	Science Lab Room B102 tap 5	NBQ705	Wednesday, July 8, 2020	0.006	Exceeded	0.7700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 6	NBQ706	Wednesday, July 8, 2020	0.001	Passed	1.7000	Passed	
Lockview High School	Science Lab Room B102 tap 7	NBQ707	Wednesday, July 8, 2020	0.008	Exceeded	0.6500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 8	NBQ708	Wednesday, July 8, 2020	0.014	Exceeded	0.6800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 9	NBQ709	Wednesday, July 8, 2020	0.006	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 10	NBQ710	Wednesday, July 8, 2020	0.009	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 11	NBQ711	Wednesday, July 8, 2020	0.008	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Science Lab Room B102 tap 12	NBQ712	Wednesday, July 8, 2020	0.002	Passed	1.2000	Passed	
Lockview High School	Science Lab Room B102 tap 13	NBQ713	Wednesday, July 8, 2020	0.004	Passed	0.8200	Passed	
Lockview High School	Science Lab Room B102 tap 14	NBQ714	Wednesday, July 8, 2020	0.003	Passed	1.8000	Passed	
Lockview High School	Science Lab Room B102 tap 15	NBQ715	Wednesday, July 8, 2020	0.003	Passed	0.5600	Passed	
Lockview High School	Science Lab Room B102 tap 16	NBQ716	Wednesday, July 8, 2020	0.002	Passed	1.6000	Passed	
Lockview High School	Science Lab Room B102 tap 17	NBQ717	Wednesday, July 8, 2020	0.001	Passed	0.6400	Passed	
Lockview High School	Science Lab Room B102 tap 18	NBQ718	Wednesday, July 8, 2020	0.005	Passed	1.6000	Passed	
Lockview High School	Integrated Science Lab Room B104 tap 1	NBQ719	Wednesday, July 8, 2020	0.400	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B104 tap 2	NBQ720	Wednesday, July 8, 2020	0.012	Exceeded	5.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B104 tap 3	NBQ721	Wednesday, July 8, 2020	0.009	Exceeded	0.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B104 tap 4	NBQ722	Wednesday, July 8, 2020	0.017	Exceeded	0.0530	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B104 tap 5	NBQ723	Wednesday, July 8, 2020	0.014	Exceeded	0.0570	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B105 tap 1	NBQ724	Wednesday, July 8, 2020	0.013	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B105 tap 2	NBQ725	Wednesday, July 8, 2020	0.081	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B105 tap 3	NBQ726	Wednesday, July 8, 2020	0.021	Exceeded	0.0890	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B105 tap 4	NBQ727	Wednesday, July 8, 2020	0.015	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Prep Room tap Room B107	NBQ728	Wednesday, July 8, 2020	0.030	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B106 tap 1	NBQ729	Wednesday, July 8, 2020	0.016	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B106 tap 2	NBQ730	Wednesday, July 8, 2020	0.017	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B106 tap 3	NBQ731	Wednesday, July 8, 2020	0.033	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Bio Lab Room B106 tap 4	NBQ732	Wednesday, July 8, 2020	0.012	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B109 tap 1	NBQ733	Wednesday, July 8, 2020	0.010	Exceeded	0.0790	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B109 tap 2	NBQ734	Wednesday, July 8, 2020	0.016	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B109 tap 3	NBQ735	Wednesday, July 8, 2020	0.044	Exceeded	0.0570	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B109 tap 4	NBQ736	Wednesday, July 8, 2020	0.017	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Integrated Science Lab Room B109 tap 5	NBQ737	Wednesday, July 8, 2020	0.039	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Physics Lab Room 110 tap 1	NBQ738	Wednesday, July 8, 2020	0.084	Exceeded	4.4000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Physics Lab Room 110 tap 2	NBQ739	Wednesday, July 8, 2020	0.005	Passed	0.4100	Passed	
Lockview High School	Prep Room tap Room B112	NBQ740	Wednesday, July 8, 2020	0.045	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Physics Lab Room B111 tap 1	NBQ741	Wednesday, July 8, 2020	0.049	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Physics Lab Room B111 tap 2	NBQ742	Wednesday, July 8, 2020	0.006	Exceeded	0.0730	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Janitors Closet tap Room C137	NBQ743	Wednesday, July 8, 2020	0.006	Exceeded	0.0970	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Female Wash Room by Room B113 tap 1	NBQ744	Wednesday, July 8, 2020	0.004	Passed	0.0950	Passed	
Lockview High School	Female Wash Room by Room B113 tap 2	NBQ745	Wednesday, July 8, 2020	0.002	Passed	0.0830	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Lockview High School	Female Wash Room by Room B113 tap 3	NBQ746	Wednesday, July 8, 2020	0.001	Passed	0.0670	Passed	
Lockview High School	Female Wash Room by Room B113 tap 4	NBQ747	Wednesday, July 8, 2020	0.008	Exceeded	0.0990	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room Wash Room tap Room D109	NBQ748	Wednesday, July 8, 2020	0.039	Exceeded	0.1700	Passed	
Lockview High School	Class Room tap Room D109	NBQ749	Wednesday, July 8, 2020	0.002	Passed	0.1600	Passed	
Lockview High School	Class Room tap 1 Room D103	NBQ750	Wednesday, July 8, 2020	0.004	Passed	2.0000	Passed	
Lockview High School	Class Room tap 2 Room D103	NBQ751	Wednesday, July 8, 2020	0.010	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room Wash Room tap Room D106B	NBQ752	Wednesday, July 8, 2020	0.010	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Fountain by Room B113	NBQ753	Wednesday, July 8, 2020	-	Passed	1.8000	Passed	
Lockview High School	Health Room tap Room C122	NCK025	Monday, July 13, 2020	0.006	Exceeded	0.0650	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Office Wash Room tap Room D128	NCK026	Monday, July 13, 2020	-	Passed	0.0760	Passed	
Lockview High School	Office Kitchen tap Room D125	NCK027	Monday, July 13, 2020	0.004	Passed	0.4000	Passed	
Lockview High School	Office Wash Room tap Room D116	NCK028	Monday, July 13, 2020	0.011	Exceeded	0.0840	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Office Wash Room tap Room D115	NCK029	Monday, July 13, 2020	0.002	Passed	0.2500	Passed	
Lockview High School	Production Room F131 tap 1	NCK030	Monday, July 13, 2020	0.004	Passed	0.6500	Passed	
Lockview High School	Production Room F131 tap 2	NCK031	Monday, July 13, 2020	0.013	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Fountain by Room F127	NCK032	Monday, July 13, 2020	0.014	Exceeded	1.1000	Passed	Fountain replacement in progress
Lockview High School	Gender Neutral Wash Room tap 1 by Room F127	NCK033	Monday, July 13, 2020	0.033	Exceeded	0.0830	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Gender Neutral Wash Room tap 2 by Room F127	NCK034	Monday, July 13, 2020	0.015	Exceeded	0.0540	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Gender Neutral Wash Room tap 3 by Room F128	NCK055	Monday, July 13, 2020	0.015	Exceeded	0.0560	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Gender Neutral Wash Room tap 4 by Room F128	NCK056	Monday, July 13, 2020	0.042	Exceeded	0.0500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Gender Neutral Wash Room tap Room F127	NCK057	Monday, July 13, 2020	0.001	Passed	0.0660	Passed	
Lockview High School	Kitchen tap 1 Room F102	NCK058	Monday, July 13, 2020	0.002	Passed	0.2000	Passed	
Lockview High School	Kitchen tap 2 Room F102	NCK059	Monday, July 13, 2020	0.009	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Kitchen tap 3 Room F102	NCK060	Monday, July 13, 2020	0.001	Passed	0.3300	Passed	
Lockview High School	Kitchen tap 4 Room F102	NCK061	Monday, July 13, 2020	-	Passed	0.2800	Passed	
Lockview High School	Music Room tap Room F122	NCK062	Monday, July 13, 2020	0.002	Passed	0.8100	Passed	
Lockview High School	Janitors Closet tap Room F117	NCK063	Monday, July 13, 2020	0.002	Passed	0.0600	Passed	
Lockview High School	Janitors Closet tap Room F121	NCK064	Monday, July 13, 2020	0.002	Passed	0.0810	Passed	
Lockview High School	Janitors Closet tap Room F121	NCK095	Monday, July 13, 2020	0.098	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Home Ec. tap 1 Room F113	NND091	Tuesday, September 1, 2020	0.000	Passed	0.0110	Passed	
Lockview High School	Home Ec. tap 2 Room F113	NND092	Tuesday, September 1, 2020	0.000	Passed	0.0120	Passed	
Lockview High School	Home Ec. tap 3 Room F113	NCK098	Monday, July 13, 2020	0.003	Passed	0.2200	Passed	
Lockview High School	Home Ec. tap 4 Room F113	NND093	Tuesday, September 1, 2020	0.000	Passed	0.0086	Passed	
Lockview High School	Home Ec. Prep tap Room F111	NND094	Tuesday, September 1, 2020	0.000	Passed	0.0068	Passed	
Lockview High School	Art Room tap 1 F110	NCK101	Monday, July 13, 2020	0.013	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Art Room tap 2 F110	NCK102	Monday, July 13, 2020	0.025	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Art Room tap 1 F109	NCK103	Monday, July 13, 2020	0.010	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Art Room tap 2 F109	NCK104	Monday, July 13, 2020	0.075	Exceeded	0.7600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Fountain by Gym	NCK190	Monday, July 13, 2020	-	Passed	0.4700	Passed	
Lockview High School	Female Wash Room tap 1 F Pod	NCK191	Monday, July 13, 2020	0.003	Passed	0.0710	Passed	
Lockview High School	Female Wash Room tap 2 F Pod	NCK192	Monday, July 13, 2020	0.007	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Female Wash Room tap 3 F Pod	NCK193	Monday, July 13, 2020	0.002	Passed	0.0780	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room tap 1 F Pod	NCK194	Monday, July 13, 2020	0.002	Passed	0.0680	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room tap 2 F Pod	NCK195	Monday, July 13, 2020	0.007	Exceeded	0.0660	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room tap 3 F Pod	NCK196	Monday, July 13, 2020	0.003	Passed	0.0630	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Lockview High School	Fountain by Room F101	NCK197	Monday, July 13, 2020	-	Passed	1.3000	Passed	
Lockview High School	Student council Room tap RoomF101	NCK198	Monday, July 13, 2020	0.007	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Boys Locker Room tap 1 Room E115	NCK199	Monday, July 13, 2020	0.002	Passed	0.1300	Passed	
Lockview High School	Boys Locker Room tap 2 Room E115	NCK246	Monday, July 13, 2020	0.003	Passed	0.1500	Passed	
Lockview High School	Boys Locker Room tap Room E114	NCK247	Monday, July 13, 2020	0.009	Exceeded	0.4400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Girls Locker Room tap 1 Room E110	NCK248	Monday, July 13, 2020	0.007	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Girls Locker Room tap 2 Room E110	NCK249	Monday, July 13, 2020	0.006	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Girls Locker Room tap 1 Room E111	NCK250	Monday, July 13, 2020	0.002	Passed	0.1100	Passed	
Lockview High School	Girls Locker Room tap 2 Room E111	NCK251	Monday, July 13, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Multipurpose Room Wash Room tap 1 Room E109	NCK252	Monday, July 13, 2020	0.003	Passed	0.3600	Passed	
Lockview High School	Multipurpose Room Wash Room tap 2 Room E109	NCK253	Monday, July 13, 2020	0.022	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Tech ed Room tap 1 Room C214	NCK254	Monday, July 13, 2020	0.007	Exceeded	0.9200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Tech ed Room tap 2 Room C214	NCK255	Monday, July 13, 2020	0.026	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap Room C216	NCK328	Monday, July 13, 2020	0.001	Passed	2.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Fountain by Room C216	-	-	-	-	-	-	Fountain remediation in progress
Lockview High School	Class Room tap 1 Room A209	NCK329	Monday, July 13, 2020	0.005	Passed	1.2000	Passed	
Lockview High School	Class Room tap 2 Room A209	NCK330	Monday, July 13, 2020	0.039	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap 1 Room A205	NCK331	Monday, July 13, 2020	0.022	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap 2 Room A205	NCK332	Monday, July 13, 2020	0.005	Passed	1.2000	Passed	
Lockview High School	Fountain by Room B201	-	-	-	-	-	-	Fountain remediation in progress
Lockview High School	Class Room tap 1 Room B202	NCK333	Monday, July 13, 2020	0.013	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap 2 Room B202	NCK334	Monday, July 13, 2020	0.001	Passed	1.0000	Passed	
Lockview High School	Class Room tap 1 Room B207	NCK335	Monday, July 13, 2020	0.026	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap 2 Room B207	NCK336	Monday, July 13, 2020	0.071	Exceeded	0.0840	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Janitors Closet tap Room B214	NCK337	Monday, July 13, 2020	0.002	Passed	0.1900	Passed	
Lockview High School	Gender Neutral Wash Room tap Room C219	NCK338	Monday, July 13, 2020	0.120	Exceeded	0.5900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Gender Neutral Wash Room tap Room C202	NCK339	Monday, July 13, 2020	0.007	Exceeded	0.0720	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room by Room C202 tap 1	NCK340	Monday, July 13, 2020	0.010	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room by Room C202 tap 2	NCK341	Monday, July 13, 2020	0.006	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room by Room C202 tap 3	NCK342	Monday, July 13, 2020	0.005	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room by Room C202 tap 4	NCK343	Monday, July 13, 2020	0.007	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Male Wash Room by Room C202 tap 5	NCK344	Monday, July 13, 2020	0.025	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Female Wash Room by Room C202 tap 1	NCK345	Monday, July 13, 2020	0.004	Passed	0.1200	Passed	
Lockview High School	Female Wash Room by Room C202 tap 2	NCK346	Monday, July 13, 2020	0.003	Passed	0.1000	Passed	
Lockview High School	Female Wash Room by Room C202 tap 3	NCK347	Monday, July 13, 2020	0.006	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Female Wash Room by Room C202 tap 4	NCK365	Monday, July 13, 2020	0.006	Exceeded	0.0820	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Female Wash Room by Room C202 tap 5	NCK366	Monday, July 13, 2020	0.004	Passed	0.0670	Passed	
Lockview High School	Female Wash Room by Room C202 tap 6	NCK367	Monday, July 13, 2020	0.003	Passed	0.0810	Passed	
Lockview High School	Class Room tap 1 Room D207	NCK368	Monday, July 13, 2020	0.006	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap 2 Room D207	NCK369	Monday, July 13, 2020	0.023	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Lockview High School	Class Room tap Room D203	NCK370	Monday, July 13, 2020	0.008	Exceeded	1.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Madeline Symonds Middle School	Class Room tap Room 1095	NAO960	Friday, July 3, 2020	-	Passed	0.3300	Passed	
Madeline Symonds Middle School	Class Room tap 1 Room 1091	NAO961	Friday, July 3, 2020	-	Passed	0.5000	Passed	
Madeline Symonds Middle School	Class Room tap 2 Room 1091	NAO962	Friday, July 3, 2020	0.001	Passed	0.2000	Passed	
Madeline Symonds Middle School	Science Lab tap 1 Room 1086	NAO963	Friday, July 3, 2020	0.002	Passed	0.3000	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Madeline Symonds Middle School	Science Lab tap 2 Room 1086	NAO964	Friday, July 3, 2020	-	Passed	0.6000	Passed	
Madeline Symonds Middle School	Science Lab tap 3 Room 1086	NAO965	Friday, July 3, 2020	-	Passed	0.6600	Passed	
Madeline Symonds Middle School	Science Lab tap 4 Room 1086	NAO966	Friday, July 3, 2020	-	Passed	0.9600	Passed	
Madeline Symonds Middle School	Science Lab tap 5 Room 1086	NAO967	Friday, July 3, 2020	-	Passed	0.5200	Passed	
Madeline Symonds Middle School	Science Lab tap 6 Room 1086	NAO968	Friday, July 3, 2020	0.002	Passed	0.8000	Passed	
Madeline Symonds Middle School	Science Lab tap 1 Room 1085	NAO969	Friday, July 3, 2020	-	Passed	0.7700	Passed	
Madeline Symonds Middle School	Science Lab tap 2 Room 1085	NAO970	Friday, July 3, 2020	0.001	Passed	0.1900	Passed	
Madeline Symonds Middle School	Science Lab tap 3 Room 1085	NAO971	Friday, July 3, 2020	0.001	Passed	0.7400	Passed	
Madeline Symonds Middle School	Science Lab tap 4 Room 1085	NAO972	Friday, July 3, 2020	0.001	Passed	0.3500	Passed	
Madeline Symonds Middle School	Science Lab tap 5 Room 1085	NAO973	Friday, July 3, 2020	-	Passed	0.5700	Passed	
Madeline Symonds Middle School	Science Lab tap 6 Room 1085	NAO974	Friday, July 3, 2020	0.002	Passed	0.6300	Passed	
Madeline Symonds Middle School	Learning Centre Wash Room tap Room 1081	NAO975	Friday, July 3, 2020	0.004	Passed	0.3000	Passed	
Madeline Symonds Middle School	Learning Centre tap Room 1079	NAO976	Friday, July 3, 2020	-	Passed	0.3300	Passed	
Madeline Symonds Middle School	Class Room tap Room 1076	NAO977	Friday, July 3, 2020	-	Passed	0.4000	Passed	
Madeline Symonds Middle School	Class Room tap 1 Room 1072	NAO978	Friday, July 3, 2020	-	Passed	0.8500	Passed	
Madeline Symonds Middle School	Class Room tap 2 Room 1072	NAO979	Friday, July 3, 2020	-	Passed	0.2900	Passed	
Madeline Symonds Middle School	Janitors Closet tap Room 1100	NAO980	Friday, July 3, 2020	0.001	Passed	0.0760	Passed	
Madeline Symonds Middle School	Fountain by Room 1101	NAO981	Friday, July 3, 2020	0.001	Passed	0.5000	Passed	
Madeline Symonds Middle School	Fountain by Room 1104	NXK281	Thursday, October 15, 2020	-	Passed	0.2600	Passed	
Madeline Symonds Middle School	Gender Neutral Wash Room tap Room 1101	NAO982	Friday, July 3, 2020	0.001	Passed	0.1100	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 1 by Room 1095	NAO983	Friday, July 3, 2020	0.001	Passed	0.1200	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 2 by Room 1095	NAO984	Friday, July 3, 2020	0.001	Passed	0.1500	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 3 by Room 1095	NAO985	Friday, July 3, 2020	0.001	Passed	0.1600	Passed	
Madeline Symonds Middle School	Boys Wash Room tap 4 by Room 1095	NAO986	Friday, July 3, 2020	0.001	Passed	0.2400	Passed	
Madeline Symonds Middle School	Art Room 1061 tap	NAO988	Friday, July 3, 2020	0.002	Passed	0.1000	Passed	
Madeline Symonds Middle School	Fountain by Room 1056	NXK285	Thursday, October 15, 2020	-	Passed	0.0840	Passed	
Madeline Symonds Middle School	Girls Locker Room tap 1 Room 1043	NAO989	Friday, July 3, 2020	0.001	Passed	0.2100	Passed	
Madeline Symonds Middle School	Girls Locker Room tap 2 Room 1043	NAO990	Friday, July 3, 2020	0.001	Passed	0.1900	Passed	
Madeline Symonds Middle School	Gym Office Wash Room tap Room 1046	NAO991	Friday, July 3, 2020	-	Passed	0.3200	Passed	
Madeline Symonds Middle School	Gym Office Wash Room tap Room 1048	NAO992	Friday, July 3, 2020	-	Passed	0.3100	Passed	
Madeline Symonds Middle School	Male Locker Room tap 1 Room 1050	NAO993	Friday, July 3, 2020	0.001	Passed	0.4300	Passed	
Madeline Symonds Middle School	Male Locker Room tap 2 Room 1050	NAO994	Friday, July 3, 2020	0.001	Passed	0.4200	Passed	
Madeline Symonds Middle School	Female Wash Room tap Room 1036	NAO995	Friday, July 3, 2020	0.002	Passed	0.0850	Passed	
Madeline Symonds Middle School	Janitors Closet tap Room 1035	NAO996	Friday, July 3, 2020	0.001	Passed	0.0370	Passed	
Madeline Symonds Middle School	Male Wash Room tap Room 1037	NAO997	Friday, July 3, 2020	0.001	Passed	0.1600	Passed	
Madeline Symonds Middle School	Family Studies tap 1 Room 1029	NAO998	Friday, July 3, 2020	-	Passed	0.2500	Passed	
Madeline Symonds Middle School	Family Studies tap 2 Room 1029	NAO999	Friday, July 3, 2020	0.001	Passed	0.0910	Passed	
Madeline Symonds Middle School	Family Studies tap 3 Room 1029	NAP000	Friday, July 3, 2020	-	Passed	0.0960	Passed	
Madeline Symonds Middle School	Family Studies tap 4 Room 1029	NAP001	Friday, July 3, 2020	-	Passed	0.0860	Passed	
Madeline Symonds Middle School	Office Wash Room tap Room 1035	NAP002	Friday, July 3, 2020	-	Passed	0.0690	Passed	
Madeline Symonds Middle School	Class Room tap Room 2065	NAP003	Friday, July 3, 2020	-	Passed	0.2500	Passed	
Madeline Symonds Middle School	Class Room tap 1 Room 2061	NXK287	Thursday, October 15, 2020	-	Passed	0.1900	Passed	Remediation has been completed
Madeline Symonds Middle School	Class Room tap 2 Room 2061	NAP005	Friday, July 3, 2020	0.001	Passed	0.8100	Passed	
Madeline Symonds Middle School	Class Room tap Room 2058	NAP006	Friday, July 3, 2020	-	Passed	0.6300	Passed	
Madeline Symonds Middle School	Class Room tap 1 Room 2053	NAP007	Friday, July 3, 2020	0.004	Passed	0.6800	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Madeline Symonds Middle School	Class Room tap 2 Room 2053	NAP008	Friday, July 3, 2020	-	Passed	0.1500	Passed	
Madeline Symonds Middle School	Class Room tap Room 2050	NAP009	Friday, July 3, 2020	-	Passed	0.2400	Passed	
Madeline Symonds Middle School	Class Room tap 1 Room 2046	NAP010	Friday, July 3, 2020	0.001	Passed	0.5300	Passed	
Madeline Symonds Middle School	Class Room tap 2 Room 2046	NAP011	Friday, July 3, 2020	0.002	Passed	0.2700	Passed	
Madeline Symonds Middle School	Female Wash Room tap 1 by Room 2046	NAP012	Friday, July 3, 2020	0.001	Passed	0.4400	Passed	
Madeline Symonds Middle School	Female Wash Room tap 2 by Room 2046	NAP013	Friday, July 3, 2020	-	Passed	0.1900	Passed	
Madeline Symonds Middle School	Female Wash Room tap 3 by Room 2046	NAP014	Friday, July 3, 2020	0.001	Passed	0.2100	Passed	
Madeline Symonds Middle School	Female Wash Room tap 4 by Room 2046	NAP015	Friday, July 3, 2020	0.001	Passed	0.2600	Passed	
Madeline Symonds Middle School	Janitors Closet tap Room 2071	NAP016	Friday, July 3, 2020	0.001	Passed	0.0690	Passed	
Madeline Symonds Middle School	Gender Neutral Wash Room tap Room 2072	NAP017	Friday, July 3, 2020	0.001	Passed	0.1000	Passed	
Madeline Symonds Middle School	Fountain by Room 2072	NXK283	Thursday, October 15, 2020	-	Passed	0.0240	Passed	Fountain replacement in progress
Madeline Symonds Middle School	Male Wash Room tap 1 by Room 2072	NAP018	Friday, July 3, 2020	0.001	Passed	0.1900	Passed	
Madeline Symonds Middle School	Male Wash Room tap 2 by Room 2072	NAP019	Friday, July 3, 2020	0.001	Passed	0.1500	Passed	
Madeline Symonds Middle School	Male Wash Room tap 3 by Room 2072	NAP020	Friday, July 3, 2020	0.001	Passed	0.1600	Passed	
Madeline Symonds Middle School	Male Wash Room tap 4 by Room 2072	NAP021	Friday, July 3, 2020	0.017	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Madeline Symonds Middle School	Janitors Closet tap Room 2036	NAP022	Friday, July 3, 2020	0.003	Passed	0.1700	Passed	
Madeline Symonds Middle School	Fountain by Room 2037	NXK284	Thursday, October 15, 2020	-	Passed	0.0850	Passed	Fountain replacement in progress
Madeline Symonds Middle School	Fountain by Room 2038	NXK282	Thursday, October 15, 2020	0.001	Passed	0.0650	Passed	
Madeline Symonds Middle School	Tech Ed Room 2039 tap	NAP023	Friday, July 3, 2020	-	Passed	0.3900	Passed	
Madeline Symonds Middle School	Staff Room Wash Room 2026 tap	NAP024	Friday, July 3, 2020	-	Passed	0.2100	Passed	
Madeline Symonds Middle School	Staff Room Wash Room 2027 tap	NAP025	Friday, July 3, 2020	0.001	Passed	0.2200	Passed	
Madeline Symonds Middle School	Staff Room 2025 Kitchen tap	NAP026	Friday, July 3, 2020	0.001	Passed	0.1200	Passed	
Marine Drive Academy	Awaiting results from NSTIR	NEW SCHOOL	Tuesday, September 1, 2020					
Michael Wallace Elementary School	Gender Neutral Wash Room tap Room 29B	MXV210	Thursday, June 18, 2020	0.012	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Michael Wallace Elementary School	Fountain by Room 29B	NLJ974	Monday, August 24, 2020	0.001	Passed	0.0310	Passed	
Michael Wallace Elementary School	Caretakers Office tap after Room 29B	MXV212	Thursday, June 18, 2020	0.001	Passed	0.0460	Passed	
Michael Wallace Elementary School	Girls Wash Room tap 1 near Room 29B	MXV213	Thursday, June 18, 2020	0.001	Passed	0.0590	Passed	
Michael Wallace Elementary School	Girls Wash Room tap 2 near Room 29B	MXV214	Thursday, June 18, 2020	0.001	Passed	0.0320	Passed	
Michael Wallace Elementary School	Girls Wash Room tap 3 near Room 29B	MXV215	Thursday, June 18, 2020	-	Passed	0.0160	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 1	MXV216	Thursday, June 18, 2020	0.001	Passed	0.2200	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 2	MXV217	Thursday, June 18, 2020	0.001	Passed	0.0380	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 3	MXV218	Thursday, June 18, 2020	0.001	Passed	0.0190	Passed	
Michael Wallace Elementary School	2nd Floor Gender Neutral Wash Room tap Room 2A	MXV219	Thursday, June 18, 2020	0.006	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Michael Wallace Elementary School	2nd Floor fountain between Wash Room's	NLJ976	Monday, August 24, 2020	0.001	Passed	0.0170	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 1 Room 11	MXV221	Thursday, June 18, 2020	0.001	Passed	0.0660	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 2 Room 11	MXV222	Thursday, June 18, 2020	-	Passed	0.0160	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 3 Room 11	MXV223	Thursday, June 18, 2020	-	Passed	0.0100	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 4 Room 11	MXV224	Thursday, June 18, 2020	-	Passed	0.0100	Passed	
Michael Wallace Elementary School	Boys Wash Room tap 5 Room 11	MXV225	Thursday, June 18, 2020	0.001	Passed	0.0880	Passed	
Michael Wallace Elementary School	Girls Wash Room tap 1 Room 17	MXV226	Thursday, June 18, 2020	0.011	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Michael Wallace Elementary School	Girls Wash Room tap 2 Room 17	MXV227	Thursday, June 18, 2020	0.002	Passed	0.0380	Passed	
Michael Wallace Elementary School	Girls Wash Room tap 3 Room 17	MXV228	Thursday, June 18, 2020	0.001	Passed	0.0130	Passed	
Michael Wallace Elementary School	Girls Wash Room tap 4 Room 17	MXV229	Thursday, June 18, 2020	0.017	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Michael Wallace Elementary School	Girls Wash Room tap 5 Room 17	MXV230	Thursday, June 18, 2020	0.002	Passed	0.0300	Passed	
Michael Wallace Elementary School	Fountain by Room 17	MXV231	Thursday, June 18, 2020	0.028	Exceeded	0.2700	Passed	New Fountain to be installed. Other sources available.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Michael Wallace Elementary School	Main Office Gender Neutral Wash Room tap	MXV232	Thursday, June 18, 2020	0.012	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood Elementary School	Girls Wash Room tap 1 by fan Room	MSZ955	Thursday, May 28, 2020	-	Passed	0.0440	Passed	
Millwood Elementary School	Girls Wash Room tap 2 by fan Room	MSZ956	Thursday, May 28, 2020	-	Passed	0.0320	Passed	
Millwood Elementary School	Girls Wash Room tap 3 by fan Room	MSZ957	Thursday, May 28, 2020	-	Passed	0.0500	Passed	
Millwood Elementary School	Boys Wash Room tap 1 by fan Room	MSZ958	Thursday, May 28, 2020	-	Passed	0.0071	Passed	
Millwood Elementary School	Boys Wash Room tap 2 by fan Room	MSZ959	Thursday, May 28, 2020	-	Passed	0.0062	Passed	
Millwood Elementary School	Boys Wash Room tap 3 by fan Room	MSZ960	Thursday, May 28, 2020	-	Passed	0.0065	Passed	
Millwood Elementary School	Janitors Closet tap by Room 202	MSZ961	Thursday, May 28, 2020	-	Passed	0.0056	Passed	
Millwood Elementary School	Fountain by Room 202	MSZ962	Thursday, May 28, 2020	0.001	Passed	0.0740	Passed	
Millwood Elementary School	Girls Wash Room tap 1 by elevator	MSZ963	Thursday, May 28, 2020	-	Passed	0.0070	Passed	
Millwood Elementary School	Girls Wash Room tap 2 by elevator	MSZ964	Thursday, May 28, 2020	-	Passed	0.0091	Passed	
Millwood Elementary School	Girls Wash Room tap 3 by elevator	MSZ965	Thursday, May 28, 2020	-	Passed	0.0072	Passed	
Millwood Elementary School	Boys Wash Room tap 1 by elevator	MSZ966	Thursday, May 28, 2020	-	Passed	0.0076	Passed	
Millwood Elementary School	Boys Wash Room tap 2 by elevator	MSZ967	Thursday, May 28, 2020	-	Passed	0.0064	Passed	
Millwood Elementary School	Boys Wash Room tap 3 by elevator	MSZ968	Thursday, May 28, 2020	-	Passed	0.0055	Passed	
Millwood Elementary School	Caretaker Room tap by elec. Rm	MSZ969	Thursday, May 28, 2020	-	Passed	0.0032	Passed	
Millwood Elementary School	fountain by Room 135	MSZ970	Thursday, May 28, 2020	0.004	Passed	0.3100	Passed	
Millwood Elementary School	Class Room tap Room 135	MSZ971	Thursday, May 28, 2020	-	Passed	0.0071	Passed	
Millwood Elementary School	Gender Neutral Wash Room tap Room 135	MSZ972	Thursday, May 28, 2020	-	Passed	0.0060	Passed	
Millwood Elementary School	Gender Neutral Wash Room tap Room 132	MSZ973	Thursday, May 28, 2020	0.001	Passed	0.0570	Passed	
Millwood Elementary School	Class Room tap Room 132	MSZ974	Thursday, May 28, 2020	-	Passed	0.0065	Passed	
Millwood Elementary School	Class Room tap Room 128	MSZ975	Thursday, May 28, 2020	-	Passed	0.0067	Passed	
Millwood Elementary School	Class Room tap Room 127	MSZ976	Thursday, May 28, 2020	-	Passed	0.0067	Passed	
Millwood Elementary School	Class Room tap Room 123	MSZ977	Thursday, May 28, 2020	-	Passed	0.0059	Passed	
Millwood Elementary School	Class Room Wash Room tap Room 123	MSZ978	Thursday, May 28, 2020	0.001	Passed	0.0940	Passed	
Millwood Elementary School	Class Room tap Room 122	MSZ979	Thursday, May 28, 2020	-	Passed	0.0098	Passed	
Millwood Elementary School	Class Room tap by Room 122	MSZ980	Thursday, May 28, 2020	0.001	Passed	0.0076	Passed	
Millwood Elementary School	Staff Room Kitchen tap	MSZ981	Thursday, May 28, 2020	-	Passed	0.0100	Passed	
Millwood Elementary School	Staff Room Wash Room 1 tap	MSZ982	Thursday, May 28, 2020	-	Passed	0.0075	Passed	
Millwood Elementary School	Staff Room Wash Room 2 tap	MSZ983	Thursday, May 28, 2020	-	Passed	0.0064	Passed	
Millwood Elementary School	Office hand wash tap	MSZ984	Thursday, May 28, 2020	0.001	Passed	0.0150	Passed	
Millwood Elementary School	Girls Locker Room tap	MSZ985	Thursday, May 28, 2020	0.004	Passed	0.2600	Passed	
Millwood Elementary School	Gym Office Wash Room tap	MSZ986	Thursday, May 28, 2020	0.001	Passed	0.0220	Passed	
Millwood Elementary School	Boys Locker Room tap	MSZ987	Thursday, May 28, 2020	0.033	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood Elementary School	Kitchen - Kitchen tap	MSZ988	Thursday, May 28, 2020	-	Passed	0.0090	Passed	
Millwood High School	Janitors Closet tap Room 241	MTN671	Friday, May 29, 2020	0.001	Passed	0.0250	Passed	
Millwood High School	Boys Wash Room tap 1 Room 204	MTN672	Friday, May 29, 2020	0.001	Passed	0.0200	Passed	
Millwood High School	Boys Wash Room tap 2 Room 204	MTN673	Friday, May 29, 2020	0.001	Passed	0.0250	Passed	
Millwood High School	Boys Wash Room tap 3 Room 204	MTN674	Friday, May 29, 2020	0.001	Passed	0.0260	Passed	
Millwood High School	Boys Wash Room tap 4 Room 204	MTN675	Friday, May 29, 2020	0.004	Passed	0.0330	Passed	
Millwood High School	Boys Wash Room tap 5 Room 204	MTN676	Friday, May 29, 2020	-	Passed	0.0800	Passed	
Millwood High School	Boys Wash Room tap 6 Room 204	MTN677	Friday, May 29, 2020	0.001	Passed	0.0190	Passed	
Millwood High School	Girls Wash Room tap 1 Room 205	MTN678	Friday, May 29, 2020	0.035	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Girls Wash Room tap 2 Room 205	MTN679	Friday, May 29, 2020	0.002	Passed	0.1000	Passed	
Millwood High School	Girls Wash Room tap 3 Room 205	MTN680	Friday, May 29, 2020	0.001	Passed	0.1100	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Millwood High School	Girls Wash Room tap 4 Room 205	MTN681	Friday, May 29, 2020	-	Passed	0.0790	Passed	
Millwood High School	Girls Wash Room tap 5 Room 205	MTN682	Friday, May 29, 2020	0.005	Passed	0.2000	Passed	
Millwood High School	Girls Wash Room tap 6 Room 205	MTN683	Friday, May 29, 2020	0.003	Passed	0.0400	Passed	
Millwood High School	Fountain by Room 206	MTN684	Friday, May 29, 2020	0.001	Passed	0.2400	Passed	
Millwood High School	Gender Neutral Wash Room tap Room 202	MTN685	Friday, May 29, 2020	0.003	Passed	0.5800	Passed	
Millwood High School	Class Room tap Room 202	MTN686	Friday, May 29, 2020	0.002	Passed	0.0520	Passed	
Millwood High School	Class Room tap Room 240	MTN687	Friday, May 29, 2020	0.001	Passed	0.0280	Passed	
Millwood High School	Class Room tap Room 229	MTN688	Friday, May 29, 2020	0.006	Exceeded	0.8600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Physics Lab tap 1 Room 226	MTN689	Friday, May 29, 2020	0.003	Passed	0.1800	Passed	
Millwood High School	Physics Lab tap 2 Room 226	MTN690	Friday, May 29, 2020	0.020	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Physics Lab Storage tap Room 231	MTN691	Friday, May 29, 2020	0.004	Passed	0.0570	Passed	
Millwood High School	Art Room tap 1 Room 223	MTN692	Friday, May 29, 2020	-	Passed	0.1200	Passed	
Millwood High School	Art Room tap 2 Room 223	MTN693	Friday, May 29, 2020	0.001	Passed	0.0500	Passed	
Millwood High School	Science Room tap 1 Room 222	MTN694	Friday, May 29, 2020	0.012	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Science Room tap 2 Room 222	MTN695	Friday, May 29, 2020	0.001	Passed	0.0510	Passed	
Millwood High School	Chem Lab tap 1 Room 220	MTN696	Friday, May 29, 2020	0.001	Passed	0.0310	Passed	
Millwood High School	Chem Lab tap 2 Room 220	MTN697	Friday, May 29, 2020	0.002	Passed	0.0630	Passed	
Millwood High School	Chem Lab tap 3 Room 220	MTN698	Friday, May 29, 2020	0.001	Passed	0.0330	Passed	
Millwood High School	Chem Lab tap 4 Room 220	MTN699	Friday, May 29, 2020	-	Passed	0.0120	Passed	
Millwood High School	Chem Lab tap 5 Room 220	MTN700	Friday, May 29, 2020	0.001	Passed	0.0490	Passed	
Millwood High School	Science Room tap 1 Room 215	MTN704	Friday, May 29, 2020	0.010	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Science Room tap 2 Room 215	MTN705	Friday, May 29, 2020	0.002	Passed	0.8400	Passed	
Millwood High School	Science Room tap 3 Room 215	MTN706	Friday, May 29, 2020	0.006	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Science Room tap 1 Room 216	MTN707	Friday, May 29, 2020	0.006	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Gender Neutral Wash Room by Room 202	MTN708	Friday, May 29, 2020	0.007	Exceeded	0.0530	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Main Office Gender Neutral Wash Room tap 1	MTN709	Friday, May 29, 2020	0.007	Exceeded	0.0410	Passed	
Millwood High School	Main Office Gender Neutral Wash Room tap 2	MTN710	Friday, May 29, 2020	-	Passed	0.0310	Passed	
Millwood High School	Main Office Gender Neutral Wash Room tap 3	MTN711	Friday, May 29, 2020	0.004	Passed	0.0380	Passed	
Millwood High School	Class Room tap Room 109	MTN712	Friday, May 29, 2020	0.002	Passed	0.0500	Passed	
Millwood High School	Kitchen sink tap Room 117	MTN713	Friday, May 29, 2020	0.008	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Cafeteria Kitchen triple compartment sink tap	MTN714	Friday, May 29, 2020	0.001	Passed	0.0440	Passed	
Millwood High School	Fountain by Girls Wash Room	MTN715	Friday, May 29, 2020	0.001	Passed	0.1600	Passed	
Millwood High School	Girls Wash Room tap 1 Room 120	MTN716	Friday, May 29, 2020	0.021	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Girls Wash Room tap 2 Room 120	MTN717	Friday, May 29, 2020	0.003	Passed	0.0540	Passed	
Millwood High School	Girls Wash Room tap 3 Room 120	MTN718	Friday, May 29, 2020	0.001	Passed	0.0570	Passed	
Millwood High School	Girls Wash Room tap 4 Room 120	MTN719	Friday, May 29, 2020	0.002	Passed	0.0540	Passed	
Millwood High School	Girls Wash Room tap 5 Room 120	MTN720	Friday, May 29, 2020	0.010	Exceeded	0.0840	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Millwood High School	Girls Wash Room tap 6 Room 120	MTN721	Friday, May 29, 2020	0.001	Passed	0.0260	Passed	
Millwood High School	Boys Wash Room tap 1 Room 119	MTN722	Friday, May 29, 2020	0.003	Passed	0.0970	Passed	
Millwood High School	Boys Wash Room tap 2 Room 119	MTN723	Friday, May 29, 2020	-	Passed	0.0240	Passed	
Millwood High School	Boys Wash Room tap 3 Room 119	MTN728	Friday, May 29, 2020	0.002	Passed	0.0800	Passed	
Millwood High School	Janitors Closet tap Room 123	MTN729	Friday, May 29, 2020	-	Passed	0.0190	Passed	
Millwood High School	Laundry tub tap Room 129	MTN730	Friday, May 29, 2020	0.004	Passed	0.0760	Passed	
Millwood High School	Girls Locker Room tap 1 Room 150	MTN731	Friday, May 29, 2020	0.001	Passed	0.0330	Passed	
Millwood High School	Girls Locker Room tap 2 Room 150	MTN732	Friday, May 29, 2020	0.001	Passed	0.0350	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Millwood High School	Girls Locker Room tap 3 Room 150	MTN733	Friday, May 29, 2020	0.001	Passed	0.0400	Passed	
Millwood High School	Fountain in Girls Locker Room 150	MTN734	Friday, May 29, 2020	0.004	Passed	0.0540	Passed	
Millwood High School	Gym Office Wash Room tap Room 151	MTN735	Friday, May 29, 2020	0.002	Passed	0.0970	Passed	
Millwood High School	Gender Neutral Wash Room tap Room 152	MTN736	Friday, May 29, 2020	0.002	Passed	0.0360	Passed	
Millwood High School	Boys Locker Room tap 1 Room 153	MTN737	Friday, May 29, 2020	-	Passed	0.0390	Passed	
Millwood High School	Boys Locker Room tap 2 Room 153	MTN738	Friday, May 29, 2020	-	Passed	0.0410	Passed	
Mount Edward Elementary School	Staff Room tap	MUW070	Monday, June 8, 2020	0.001	Passed	0.0640	Passed	
Mount Edward Elementary School	Staff Room Wash Room tap	MUW071	Monday, June 8, 2020	0.003	Passed	0.0400	Passed	
Mount Edward Elementary School	Class Room tap Room 8	MUW072	Monday, June 8, 2020	0.003	Passed	0.2300	Passed	
Mount Edward Elementary School	Kitchen sink tap in canteen in Gym	NLO084	Tuesday, August 25, 2020	0.001	Passed	0.0180	Passed	
Mount Edward Elementary School	Boys Wash Room tap 1 by Gym	MUW074	Monday, June 8, 2020	0.009	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Mount Edward Elementary School	Boys Wash Room tap 2 by Gym	MUW075	Monday, June 8, 2020	0.002	Passed	0.0840	Passed	
Mount Edward Elementary School	Boys Wash Room tap 3 by Gym	MUW076	Monday, June 8, 2020	0.003	Passed	0.0570	Passed	
Mount Edward Elementary School	Gender Neutral Wash Room tap by Boys Wash Room	MUW077	Monday, June 8, 2020	0.008	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Mount Edward Elementary School	Janitors Closet tap by Girls Wash Room	MUW078	Monday, June 8, 2020	0.002	Passed	0.5400	Passed	
Mount Edward Elementary School	Girls Wash Room tap 1 by Janitors Closet	MUW079	Monday, June 8, 2020	0.002	Passed	0.2500	Passed	
Mount Edward Elementary School	Girls Wash Room tap 2 by Janitors Closet	MUW086	Monday, June 8, 2020	0.005	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Mount Edward Elementary School	Girls Wash Room tap 3 by Janitors Closet	MUW087	Monday, June 8, 2020	0.001	Passed	0.0840	Passed	
Mount Edward Elementary School	Fountain by Staff Room	MUW088	Monday, June 8, 2020	0.001	Passed	0.2200	Passed	
Mount Edward Elementary School	Girls Wash Room tap 1 by Office	MUW089	Monday, June 8, 2020	0.006	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Mount Edward Elementary School	Girls Wash Room tap 2 by Office	MUW090	Monday, June 8, 2020	0.002	Passed	0.2300	Passed	
Mount Edward Elementary School	Boys Wash Room tap 1 by Office	MUW091	Monday, June 8, 2020	0.006	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Mount Edward Elementary School	Boys Wash Room tap 2 by Office	MUW092	Monday, June 8, 2020	0.005	Passed	0.3300	Passed	
Mount Edward Elementary School	Boys Wash Room tap 3 by Office	MUW093	Monday, June 8, 2020	0.022	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Mount Edward Elementary School	Fountain by Janitors Closet	MUW094	Monday, June 8, 2020	0.001	Passed	0.2000	Passed	
Mount Edward Elementary School	Janitors Closet tap by fountain	MUW095	Monday, June 8, 2020	0.001	Passed	0.0560	Passed	
Mount Edward Elementary School	Low sink in main Office	MUW126	Monday, June 8, 2020	0.002	Passed	0.1300	Passed	
Mount Edward Elementary School	Staff Wash Room in principals Office	MUW127	Monday, June 8, 2020	0.010	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Rural High School	General science tap 1 Room 2205	MVW073	Thursday, June 11, 2020	-	Passed	0.0400	Passed	
Musquodoboit Rural High School	General science tap 2 Room 2205	MVW074	Thursday, June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	General science tap 3 Room 2205	MVW075	Thursday, June 11, 2020	0.002	Passed	0.0480	Passed	
Musquodoboit Rural High School	General science tap 4 Room 2205	MVW076	Thursday, June 11, 2020	0.001	Passed	0.0410	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap Room 2701	MVW077	Thursday, June 11, 2020	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Fountain by Room 2701	MVW078	Thursday, June 11, 2020	0.001	Passed	0.1000	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 by Room 2103	MVW079	Thursday, June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 2 by Room 2103	MVW080	Thursday, June 11, 2020	0.001	Passed	0.1700	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 3 by Room 2103	MVW081	Thursday, June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Janitors Closet tap Room 2103	MVW082	Thursday, June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 by Room 2309	MVW085	Thursday, June 11, 2020	0.002	Passed	0.1300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 2 by Room 2309	MVW086	Thursday, June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 3 by Room 2309	MVW087	Thursday, June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Physics Lab tap 1 Room 2309	MVW088	Thursday, June 11, 2020	-	Passed	0.2000	Passed	
Musquodoboit Rural High School	Physics Lab tap 2 Room 2309	MVW089	Thursday, June 11, 2020	0.002	Passed	0.0300	Passed	
Musquodoboit Rural High School	Physics Lab tap 3 Room 2309	MVW090	Thursday, June 11, 2020	0.002	Passed	0.2400	Passed	
Musquodoboit Rural High School	Gen Science Lab tap 1 Room 2303	MVW091	Thursday, June 11, 2020	0.001	Passed	0.1300	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Musquodoboit Rural High School	Gen Science Lab tap 2 Room 2303	MVW092	Thursday, June 11, 2020	-	Passed	0.1500	Passed	
Musquodoboit Rural High School	Gen Science Lab tap 3 Room 2303	MVW093	Thursday, June 11, 2020	0.001	Passed	0.0540	Passed	
Musquodoboit Rural High School	Gen Science Lab tap 4 Room 2303	MVW094	Thursday, June 11, 2020	0.001	Passed	0.0790	Passed	
Musquodoboit Rural High School	Gen Science Lab tap 5 Room 2303	MVW095	Thursday, June 11, 2020	-	Passed	0.0980	Passed	
Musquodoboit Rural High School	Chem Lab tap 1 Room 2301	MVW096	Thursday, June 11, 2020	0.005	Exceeded	0.0990	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Rural High School	Chem Lab tap 2 Room 2301	MVW097	Thursday, June 11, 2020	0.014	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Rural High School	Chem Lab tap 3 Room 2301	MVW098	Thursday, June 11, 2020	0.001	Passed	0.2500	Passed	
Musquodoboit Rural High School	Chem Lab tap 4 Room 2301	MVW099	Thursday, June 11, 2020	0.003	Passed	0.0560	Passed	
Musquodoboit Rural High School	Chem Lab tap 5 Room 2301	MVW100	Thursday, June 11, 2020	0.006	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Rural High School	Chem Lab tap 6 Room 2301	MVW101	Thursday, June 11, 2020	-	Passed	0.0320	Passed	
Musquodoboit Rural High School	Chem Lab tap 7 Room 2301	MVW102	Thursday, June 11, 2020	-	Passed	0.3500	Passed	
Musquodoboit Rural High School	Chem Lab tap 8 Room 2301	MVW103	Thursday, June 11, 2020	-	Passed	0.1800	Passed	
Musquodoboit Rural High School	Chem Lab tap 9 Room 2301	MVW104	Thursday, June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Chem Lab tap 10 Room 2301	MVW107	Thursday, June 11, 2020	0.001	Passed	0.0960	Passed	
Musquodoboit Rural High School	Family Studies tap 1 Room 2206	MVW108	Thursday, June 11, 2020	-	Passed	0.1900	Passed	
Musquodoboit Rural High School	Family Studies tap 2 Room 2206	MVW109	Thursday, June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Family Studies tap 3 Room 2206	MVW110	Thursday, June 11, 2020	0.001	Passed	0.2100	Passed	
Musquodoboit Rural High School	Family Studies tap 4 Room 2206	MVW111	Thursday, June 11, 2020	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 Room 2110	MVW112	Thursday, June 11, 2020	0.003	Passed	0.1700	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 2 Room 2110	MVW113	Thursday, June 11, 2020	0.004	Passed	0.2000	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 3 Room 2110	MVW114	Thursday, June 11, 2020	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Janitors Closet tap Room 2112	MVW115	Thursday, June 11, 2020	0.002	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 Room 2111	MVW116	Thursday, June 11, 2020	0.002	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 2 Room 2111	MVW119	Thursday, June 11, 2020	0.002	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 3 Room 2111	MVW120	Thursday, June 11, 2020	0.007	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Rural High School	Learning Centre Wash Room tap	MVW121	Thursday, June 11, 2020	0.001	Passed	0.0590	Passed	
Musquodoboit Rural High School	Music Room tap Room 1426	MVW122	Thursday, June 11, 2020	0.003	Passed	0.4800	Passed	
Musquodoboit Rural High School	Cafeteria tap 1 Room 1422	MVW123	Thursday, June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Cafeteria tap 2 Room 1422	MVW124	Thursday, June 11, 2020	0.001	Passed	0.1400	Passed	
Musquodoboit Rural High School	Cafeteria tap 3 Room 1422	MVW125	Thursday, June 11, 2020	0.001	Passed	0.1700	Passed	
Musquodoboit Rural High School	Cafeteria tap 4 Room 1422	MVW126	Thursday, June 11, 2020	0.002	Passed	0.2000	Passed	
Musquodoboit Rural High School	Cafeteria tap 5 Room 1422	MVW127	Thursday, June 11, 2020	0.001	Passed	0.3400	Passed	
Musquodoboit Rural High School	Male Locker Room tap Room 1413	MVW128	Thursday, June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Female Locker Room tap Room 1415	MVW129	Thursday, June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Fountain by Gym	MVW130	Thursday, June 11, 2020	0.001	Passed	0.1000	Passed	
Musquodoboit Rural High School	Fountain by Wash Room's	MVW131	Thursday, June 11, 2020	0.001	Passed	0.0970	Passed	
Musquodoboit Rural High School	Male Wash Room tap 1 Room 1123	MVW132	Thursday, June 11, 2020	0.003	Passed	0.2200	Passed	
Musquodoboit Rural High School	Male Wash Room tap 2 Room 1123	MVW133	Thursday, June 11, 2020	0.002	Passed	0.1300	Passed	
Musquodoboit Rural High School	Male Wash Room tap 3 Room 1123	MVW134	Thursday, June 11, 2020	0.002	Passed	0.1700	Passed	
Musquodoboit Rural High School	Janitors Closet tap Room 1125	MVW135	Thursday, June 11, 2020	0.005	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Rural High School	Female Wash Room tap 1 Room 1124	MVW136	Thursday, June 11, 2020	0.001	Passed	0.1500	Passed	
Musquodoboit Rural High School	Female Wash Room tap 2 Room 1124	MVW137	Thursday, June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Female Wash Room tap 3 Room 1124	MVW138	Thursday, June 11, 2020	0.002	Passed	0.1600	Passed	
Musquodoboit Rural High School	Tech ed tap Room 1303	MVW139	Thursday, June 11, 2020	0.001	Passed	0.1400	Passed	
Musquodoboit Rural High School	Art Room tap Room 1305	MVW140	Thursday, June 11, 2020	0.001	Passed	0.2100	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Musquodoboit Rural High School	Class Room tap 1 Room 1301	MVV141	Thursday, June 11, 2020	-	Passed	0.2100	Passed	
Musquodoboit Rural High School	Class Room tap 2 Room 1301	MVV142	Thursday, June 11, 2020	0.001	Passed	0.1600	Passed	
Musquodoboit Rural High School	Staff Room tap 1 Room 1112	MVV143	Thursday, June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Staff Room tap 2 Room 1112	MVV144	Thursday, June 11, 2020	0.002	Passed	0.3800	Passed	
Musquodoboit Rural High School	Staff Room tap 3 Room 1112	MVV145	Thursday, June 11, 2020	0.001	Passed	0.3200	Passed	
Musquodoboit Rural High School	Admin Wash Room tap Room 1104	MVV146	Thursday, June 11, 2020	0.001	Passed	0.1400	Passed	
Musquodoboit Rural High School	Seminar Room tap Room 1127	MVV147	Thursday, June 11, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Rural High School	Fountain by Room 1127	MVV148	Thursday, June 11, 2020	-	Passed	0.0980	Passed	
Musquodoboit Rural High School	Staff Wash Room tap hall	MVV182	Thursday, June 11, 2020	0.001	Passed	0.1400	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 Room 1201	MVV183	Thursday, June 11, 2020	0.001	Passed	0.1300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 2 Room 1201	MVV184	Thursday, June 11, 2020	0.001	Passed	0.1200	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 3 Room 1201	MVV185	Thursday, June 11, 2020	0.001	Passed	0.1100	Passed	
Musquodoboit Rural High School	Janitors Closet tap Room 1203	MVV186	Thursday, June 11, 2020	0.004	Passed	0.5300	Passed	
Musquodoboit Rural High School	Gender Neutral Wash Room tap 1 Room 1202	MVV187	Thursday, June 11, 2020	0.004	Passed	0.4200	Passed	
Musquodoboit Valley Education Centre	Kitchen tap 1 Room 173	MVV862	Thursday, June 11, 2020	0.005	Exceeded	0.9300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Valley Education Centre	Kitchen tap 2 Room 173	MVV863	Thursday, June 11, 2020	0.007	Exceeded	0.8100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Valley Education Centre	Kitchen tap 3 Room 173	MVV864	Thursday, June 11, 2020	-	Passed	1.1000	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 173	MVV865	Thursday, June 11, 2020	0.001	Passed	0.9200	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 1 Room 171	MVV866	Thursday, June 11, 2020	-	Passed	0.5300	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 2 Room 171	MVV867	Thursday, June 11, 2020	0.001	Passed	0.7700	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 3 Room 171	MVV868	Thursday, June 11, 2020	0.001	Passed	0.6400	Passed	
Musquodoboit Valley Education Centre	Girls Wash Room tap 4 Room 171	MVV869	Thursday, June 11, 2020	0.006	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Valley Education Centre	Boys Wash Room tap 1 Room 170	MVV870	Thursday, June 11, 2020	0.001	Passed	0.6000	Passed	
Musquodoboit Valley Education Centre	Boys Wash Room tap 2 Room 170	MVV871	Thursday, June 11, 2020	0.001	Passed	0.5100	Passed	
Musquodoboit Valley Education Centre	Boys Wash Room tap 3 Room 170	MVV873	Thursday, June 11, 2020	0.001	Passed	0.6800	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 170	MVV874	Thursday, June 11, 2020	0.001	Passed	1.2000	Passed	
Musquodoboit Valley Education Centre	Boys change Room 185 tap 1	MVV875	Thursday, June 11, 2020	0.002	Passed	0.6900	Passed	
Musquodoboit Valley Education Centre	Boys change Room 185 tap 2	MVV876	Thursday, June 11, 2020	0.001	Passed	0.7400	Passed	
Musquodoboit Valley Education Centre	Gym Office Wash Room tap Room 187	MVV877	Thursday, June 11, 2020	0.002	Passed	0.6600	Passed	
Musquodoboit Valley Education Centre	Girls change Room 189 tap 1	MVV878	Thursday, June 11, 2020	0.046	Exceeded	2.3000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Valley Education Centre	Girls change Room 189 tap 2	MVV879	Thursday, June 11, 2020	0.029	Exceeded	1.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Valley Education Centre	Art/music Room tap	MVV880	Thursday, June 11, 2020	0.015	Exceeded	0.8100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Valley Education Centre	admin Office Wash Room tap	MVV881	Thursday, June 11, 2020	0.002	Passed	2.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap by Office	MVV882	Thursday, June 11, 2020	0.002	Passed	0.6900	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap 1 Room 140	MVV883	Thursday, June 11, 2020	0.001	Passed	0.4100	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap 2 Room 140	MVV884	Thursday, June 11, 2020	0.001	Passed	0.4900	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap 3 Room 140	MVV885	Thursday, June 11, 2020	0.002	Passed	0.9200	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 140	MVV886	Thursday, June 11, 2020	-	Passed	0.2600	Passed	
Musquodoboit Valley Education Centre	Class Room tap Room 142	MVV887	Thursday, June 11, 2020	0.001	Passed	0.3800	Passed	
Musquodoboit Valley Education Centre	Class Room tap Room 153	MVV888	Thursday, June 11, 2020	0.002	Passed	0.9700	Passed	
Musquodoboit Valley Education Centre	Class Room tap Room 155	MVV889	Thursday, June 11, 2020	0.001	Passed	0.7700	Passed	
Musquodoboit Valley Education Centre	Class Room tap Room 156	MVV890	Thursday, June 11, 2020	0.002	Passed	0.8400	Passed	
Musquodoboit Valley Education Centre	Fountain by Room 156	MVV891	Thursday, June 11, 2020	0.003	Passed	0.7000	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap 1 Room 141	MVV892	Thursday, June 11, 2020	0.002	Passed	0.4800	Passed	
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap 2 Room 141	MVV915	Thursday, June 11, 2020	0.001	Passed	0.6500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Musquodoboit Valley Education Centre	Gender Neutral Wash Room tap 3 Room 141	MVV916	Thursday, June 11, 2020	0.001	Passed	0.7200	Passed	
Musquodoboit Valley Education Centre	Janitors Closet tap by Room 141	MVV917	Thursday, June 11, 2020	0.001	Passed	0.2200	Passed	
Musquodoboit Valley Education Centre	Staff Room Wash Room 1 tap	MVV918	Thursday, June 11, 2020	-	Passed	0.1500	Passed	
Musquodoboit Valley Education Centre	Staff Room Wash Room 2 tap	MVV919	Thursday, June 11, 2020	0.005	Passed	0.4300	Passed	
Musquodoboit Valley Education Centre	Staff Room Kitchen tap	MVV920	Thursday, June 11, 2020	0.001	Passed	0.2700	Passed	
Nelson Whynder Elementary School	Mens Wash Room tap Room 105	MXU463	Thursday, June 18, 2020	0.006	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Nelson Whynder Elementary School	Staff Room tap 1 Room 110	MXU464	Thursday, June 18, 2020	0.002	Passed	0.4200	Passed	
Nelson Whynder Elementary School	Staff Room tap 2 Room 110	MXU465	Thursday, June 18, 2020	0.003	Passed	0.3000	Passed	
Nelson Whynder Elementary School	Staff Wash Room tap Room 112	MXU466	Thursday, June 18, 2020	0.001	Passed	0.1700	Passed	
Nelson Whynder Elementary School	Janitors Closet tap Room 113	MXU467	Thursday, June 18, 2020	0.001	Passed	0.1600	Passed	
Nelson Whynder Elementary School	Dentist Room tap 1	MXU468	Thursday, June 18, 2020	0.001	Passed	0.0370	Passed	
Nelson Whynder Elementary School	Dentist Room tap 2	MXU469	Thursday, June 18, 2020	0.003	Passed	0.2800	Passed	
Nelson Whynder Elementary School	Dentist Room tap 3	MXU470	Thursday, June 18, 2020	-	Passed	0.1300	Passed	
Nelson Whynder Elementary School	Janitors Closet tap near Room 113	MXU471	Thursday, June 18, 2020	-	Passed	1.0000	Passed	
Nelson Whynder Elementary School	Class Room tap Room 132	NAI070	Monday, June 29, 2020	0.001	Passed	0.5000	Passed	
Nelson Whynder Elementary School	Class Room Wash Room tap Room 132	NAI071	Monday, June 29, 2020	0.001	Passed	0.5500	Passed	
Nelson Whynder Elementary School	Class Room Wash Room tap Room 136	NAI072	Monday, June 29, 2020	0.003	Passed	0.8600	Passed	
Nelson Whynder Elementary School	Class Room tap Room 136	NAI073	Monday, June 29, 2020	0.002	Passed	0.2900	Passed	
Nelson Whynder Elementary School	Boys Wash Room tap 1 Room 138	NAI074	Monday, June 29, 2020	0.001	Passed	0.3100	Passed	
Nelson Whynder Elementary School	Boys Wash Room tap 2 Room 138	NAI075	Monday, June 29, 2020	0.001	Passed	0.0920	Passed	
Nelson Whynder Elementary School	Boys Wash Room tap 3 Room 138	NMD527	Thursday, August 27, 2020	0.000	Passed	0.0160	Passed	
Nelson Whynder Elementary School	Fountain 1 by Room 138	NMD528	Thursday, August 27, 2020	0.001	Passed	0.0100	Passed	
Nelson Whynder Elementary School	Fountain 2 by Room 138	NMD529	Thursday, August 27, 2020	0.006	Exceeded	0.0150	Passed	New Fountain to be installed. Other sources available.
Nelson Whynder Elementary School	Janitors Closet tap (caretaker Office)	NAI079	Monday, June 29, 2020	0.003	Passed	0.4700	Passed	
Nelson Whynder Elementary School	Girls Wash Room tap 1 Room 140	NAI085	Monday, June 29, 2020	0.001	Passed	0.0920	Passed	
Nelson Whynder Elementary School	Girls Wash Room tap 2 Room 140	NAI086	Monday, June 29, 2020	0.001	Passed	0.1500	Passed	
Nelson Whynder Elementary School	Girls Wash Room tap 3 Room 140	NAI087	Monday, June 29, 2020	-	Passed	0.2300	Passed	
Nelson Whynder Elementary School	Class Room tap Room 158	NAI088	Monday, June 29, 2020	0.005	Passed	0.9000	Passed	
Nelson Whynder Elementary School	Fountain by Gym entrance	NAI089	Monday, June 29, 2020	-	Passed	2.0000	Passed	
Nelson Whynder Elementary School	Girls Locker Room tap	NAI090	Monday, June 29, 2020	0.004	Passed	0.1900	Passed	
Nelson Whynder Elementary School	Gym Office Wash Room tap	NAI091	Monday, June 29, 2020	0.004	Passed	0.2900	Passed	
Nelson Whynder Elementary School	Cafe/Kitchen tap 1 (door off the main Gym)	NMD524	Thursday, August 27, 2020	0.000	Passed	0.0200	Passed	
Nelson Whynder Elementary School	Cafe/Kitchen tap 2 (door off the main Gym)	NMD525	Thursday, August 27, 2020	0.000	Passed	0.0240	Passed	
Nelson Whynder Elementary School	Cafe/Kitchen tap 3 (door off the main Gym)	NMD526	Thursday, August 27, 2020	0.001	Passed	0.0300	Passed	
Nelson Whynder Elementary School	Cafe/Kitchen tap 4 (door off the main Gym)	NAI096	Monday, June 29, 2020	0.001	Passed	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Nelson Whynder Elementary School	Boys Locker Room tap	NAI097	Monday, June 29, 2020	0.031	Exceeded	0.5100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Nelson Whynder Elementary School	Gender Neutral Wash Room tap (by learning skills R	NAI098	Monday, June 29, 2020	0.019	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Nelson Whynder Elementary School	Gender Neutral Wash Room tap (by learning skills R	NAI099	Monday, June 29, 2020	0.010	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Nelson Whynder Elementary School	Class Room tap left of Room 149	NAI100	Monday, June 29, 2020	0.007	Exceeded	0.5700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Nelson Whynder Elementary School	Class Room tap Room 149	NAI101	Monday, June 29, 2020	0.002	Passed	0.6100	Passed	
Nelson Whynder Elementary School	Class Room tap Room 148	NAI102	Monday, June 29, 2020	0.002	Passed	0.3400	Passed	
Nelson Whynder Elementary School	Class Room tap Room 137	NAI103	Monday, June 29, 2020	0.011	Exceeded	3.8000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Nelson Whynder Elementary School	Class Room tap Room 134	NAI104	Monday, June 29, 2020	0.001	Passed	1.7000	Passed	
Nelson Whynder Elementary School	Class Room tap Room 131	NAI105	Monday, June 29, 2020	0.003	Passed	0.8400	Passed	
Nelson Whynder Elementary School	Learning Centre Kitchen tap Room 129	NAI107	Monday, June 29, 2020	-	Passed	0.2100	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Nelson Whynder Elementary School	Learning Centre Wash Room tap Room 129	NAI108	Monday, June 29, 2020	0.001	Passed	0.1800	Passed	
Nelson Whynder Elementary School	Fountain by Room 108	NAI109	Monday, June 29, 2020	0.001	Passed	0.5500	Passed	
Ocean View Elementary School	2nd Floor Boys Wash Room tap 1	MYA659	Monday, June 22, 2020	0.013	Exceeded	0.6500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	2nd Floor Boys Wash Room tap 2	MYA660	Monday, June 22, 2020	0.002	Passed	0.4700	Passed	
Ocean View Elementary School	2nd Floor Boys Wash Room tap 3	MYA661	Monday, June 22, 2020	0.001	Passed	0.2400	Passed	
Ocean View Elementary School	Sink Room	MYA662	Monday, June 22, 2020	0.001	Passed	0.4200	Passed	
Ocean View Elementary School	Fountain Between Wash Rooms	MYA663	Monday, June 22, 2020	0.036	Exceeded	0.5000	Passed	Fountain to be replaced.
Ocean View Elementary School	2nd Floor Girls Wash Room tap 1	MYA664	Monday, June 22, 2020	0.079	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	2nd Floor Girls Wash Room tap 2	MYA665	Monday, June 22, 2020	0.020	Exceeded	0.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	2nd Floor Girls Wash Room tap 3	MYA666	Monday, June 22, 2020	0.007	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	Art Room tap 1	MYA667	Monday, June 22, 2020	0.006	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	Art Room tap 2	MYA668	Monday, June 22, 2020	0.014	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	2nd Floor Girls Wash Room tap 1	MYA670	Monday, June 22, 2020	0.005	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	2nd Floor Girls Wash Room tap 2	MYA671	Monday, June 22, 2020	0.006	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	2nd Floor Girls Wash Room tap 3	MYA672	Monday, June 22, 2020	0.014	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	Janitors Closet tap between Wash Rooms	MYA673	Monday, June 22, 2020	0.002	Passed	0.2900	Passed	
Ocean View Elementary School	2nd Floor Boys Wash Room tap 1	MYA674	Monday, June 22, 2020	0.001	Passed	0.2300	Passed	
Ocean View Elementary School	2nd Floor Boys Wash Room tap 2	MYA675	Monday, June 22, 2020	0.001	Passed	0.2000	Passed	
Ocean View Elementary School	2nd Floor Boys Wash Room tap 3	MYA676	Monday, June 22, 2020	0.001	Passed	0.2600	Passed	
Ocean View Elementary School	Gym Office tap	MYA677	Monday, June 22, 2020	0.006	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	Gender Neutral Wash Room tap near Gym	MYA678	Monday, June 22, 2020	0.003	Passed	0.1100	Passed	
Ocean View Elementary School	Learning Centre Wash Room tap	MYA679	Monday, June 22, 2020	0.002	Passed	0.0790	Passed	
Ocean View Elementary School	1st Floor Caretaker Room tap 1	MYA681	Monday, June 22, 2020	0.002	Passed	0.1100	Passed	
Ocean View Elementary School	1st Floor Caretaker Room tap 2	MYA682	Monday, June 22, 2020	0.001	Passed	0.1200	Passed	
Ocean View Elementary School	Fountain by Room 103	MYA683	Monday, June 22, 2020	0.078	Exceeded	12.0000	Exceeded	New Fountain installed. Lab results pending.
Ocean View Elementary School	Class Room Wash Room tap Room 103	MYA684	Monday, June 22, 2020	0.001	Passed	0.0900	Passed	
Ocean View Elementary School	Class Room tap Room 103	MYA685	Monday, June 22, 2020	0.001	Passed	0.0670	Passed	
Ocean View Elementary School	Class Room Wash Room tap Room 105	MYA686	Monday, June 22, 2020	0.001	Passed	0.0670	Passed	
Ocean View Elementary School	Class Room tap Room 105	MYA687	Monday, June 22, 2020	0.003	Passed	0.0660	Passed	
Ocean View Elementary School	Class Room Wash Room tap Room 107	MYA688	Monday, June 22, 2020	0.001	Passed	0.0500	Passed	
Ocean View Elementary School	Class Room tap Room 107	MYA689	Monday, June 22, 2020	0.001	Passed	0.0590	Passed	
Ocean View Elementary School	1st Floor Boys Wash Room tap 1	MYA690	Monday, June 22, 2020	0.002	Passed	0.2300	Passed	
Ocean View Elementary School	1st Floor Boys Wash Room tap 2	MYA703	Monday, June 22, 2020	0.002	Passed	0.1300	Passed	
Ocean View Elementary School	1st Floor Boys Wash Room tap 3	MYA704	Monday, June 22, 2020	0.001	Passed	0.0510	Passed	
Ocean View Elementary School	1st Floor Boys Wash Room tap 4	MYA705	Monday, June 22, 2020	0.001	Passed	0.0660	Passed	
Ocean View Elementary School	1st Floor Boys Wash Room tap 5	MYA706	Monday, June 22, 2020	0.001	Passed	0.0570	Passed	
Ocean View Elementary School	Janitors Closet tap between Wash Rooms	MYA707	Monday, June 22, 2020	-	Passed	0.0150	Passed	
Ocean View Elementary School	Fountain between Wash Rooms	PXP219	Wednesday, June 23, 2021	0.002	Passed	0.1200	Passed	New Fountain installed
Ocean View Elementary School	1st Floor Girls Wash Room tap 1	MYA709	Monday, June 22, 2020	0.018	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	1st Floor Girls Wash Room tap 2	MYA710	Monday, June 22, 2020	0.009	Exceeded	0.0670	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	1st Floor Girls Wash Room tap 3	MYA711	Monday, June 22, 2020	0.004	Passed	0.0480	Passed	
Ocean View Elementary School	1st Floor Girls Wash Room tap 4	MYA712	Monday, June 22, 2020	0.002	Passed	0.0300	Passed	
Ocean View Elementary School	1st Floor Girls Wash Room tap 5	MYA714	Monday, June 22, 2020	0.002	Passed	0.0140	Passed	
Ocean View Elementary School	Staff Room Kitchen tap	MYA715	Monday, June 22, 2020	-	Passed	0.0570	Passed	
Ocean View Elementary School	Staff Room Wash Room 1 tap	MYA716	Monday, June 22, 2020	0.002	Passed	0.0920	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Ocean View Elementary School	Staff Room Wash Room 2 tap	MYA717	Monday, June 22, 2020	0.001	Passed	0.0550	Passed	
Ocean View Elementary School	Sick Room tap	MYA718	Monday, June 22, 2020	0.004	Passed	0.5500	Passed	
Ocean View Elementary School	Class Room Wash Room tap Room 112	MYA719	Monday, June 22, 2020	0.006	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ocean View Elementary School	Class Room tap Room 112	MYA720	Monday, June 22, 2020	-	Passed	0.0800	Passed	
Ocean View Elementary School	Class Room Wash Room tap Room 110	MYA721	Monday, June 22, 2020	0.001	Passed	0.1000	Passed	
Ocean View Elementary School	Class Room tap Room 110	MYA722	Monday, June 22, 2020	0.002	Passed	0.2100	Passed	
Ocean View Elementary School	Fountain by Room 110	NMV196	Monday, August 31, 2020	0.001	Passed	0.1500	Passed	New Fountain installed. Lab results pending.
O'Connell Drive Elementary School	Library Wash Room tap Room 191	MXK240	Thursday, June 18, 2020	0.001	Passed	0.0920	Passed	
O'Connell Drive Elementary School	Janitors Closet tap Room 181	MXK241	Thursday, June 18, 2020	0.001	Passed	0.0840	Passed	
O'Connell Drive Elementary School	Class Room Wash Room tap Room 175	MXK242	Thursday, June 18, 2020	0.003	Passed	0.1800	Passed	
O'Connell Drive Elementary School	Class Room tap Room 177A	MXK243	Thursday, June 18, 2020	0.002	Passed	0.0870	Passed	
O'Connell Drive Elementary School	Class Room tap Room 173	MXK244	Thursday, June 18, 2020	0.087	Exceeded	0.7300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
O'Connell Drive Elementary School	Class Room Wash Room tap Room 174	MXK245	Thursday, June 18, 2020	0.001	Passed	0.1000	Passed	
O'Connell Drive Elementary School	Boys Wash Room tap 1 Room 166	MXK246	Thursday, June 18, 2020	0.001	Passed	0.0390	Passed	
O'Connell Drive Elementary School	Boys Wash Room tap 2 Room 166	MXK247	Thursday, June 18, 2020	-	Passed	0.0170	Passed	
O'Connell Drive Elementary School	Girls Wash Room tap 1 Room 167	MXK248	Thursday, June 18, 2020	-	Passed	0.0210	Passed	
O'Connell Drive Elementary School	Girls Wash Room tap 2 Room 167	MXK249	Thursday, June 18, 2020	-	Passed	0.0200	Passed	
O'Connell Drive Elementary School	Fountain by Library	MXK250	Thursday, June 18, 2020	0.002	Passed	0.3700	Passed	
O'Connell Drive Elementary School	Cafe/Kitchen tap 1 (by door)	MXK251	Thursday, June 18, 2020	0.001	Passed	0.0820	Passed	
O'Connell Drive Elementary School	Cafe/Kitchen tap 2	MXK252	Thursday, June 18, 2020	0.001	Passed	0.2000	Passed	
O'Connell Drive Elementary School	Boys Class Room Wash Room tap Room 156	MXK253	Thursday, June 18, 2020	0.001	Passed	0.0470	Passed	
O'Connell Drive Elementary School	Girls Class Room Wash Room tap Room 159	MXK254	Thursday, June 18, 2020	0.002	Passed	0.1700	Passed	
O'Connell Drive Elementary School	Gym Office Wash Room tap Room 161	MXK255	Thursday, June 18, 2020	0.001	Passed	0.0530	Passed	
O'Connell Drive Elementary School	Music Room tap Room 149	MXK256	Thursday, June 18, 2020	-	Passed	0.0290	Passed	
O'Connell Drive Elementary School	Class Room tap Room 140	MXK257	Thursday, June 18, 2020	0.004	Passed	0.2700	Passed	
O'Connell Drive Elementary School	Class Room Wash Room tap Room 139	MXK258	Thursday, June 18, 2020	0.009	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
O'Connell Drive Elementary School	Girls Wash Room tap 1 Room 137	MXK259	Thursday, June 18, 2020	0.001	Passed	0.1800	Passed	
O'Connell Drive Elementary School	Girls Wash Room tap 2 Room 137	MXK260	Thursday, June 18, 2020	-	Passed	0.0910	Passed	
O'Connell Drive Elementary School	Girls Wash Room tap 3 Room 137	MXK261	Thursday, June 18, 2020	-	Passed	0.0710	Passed	
O'Connell Drive Elementary School	Boys Wash Room tap 1 Room 135	MXK262	Thursday, June 18, 2020	0.001	Passed	0.1700	Passed	
O'Connell Drive Elementary School	Boys Wash Room tap 2 Room 135	MXK263	Thursday, June 18, 2020	-	Passed	0.0810	Passed	
O'Connell Drive Elementary School	Boys Wash Room tap 3 Room 135	MXK264	Thursday, June 18, 2020	-	Passed	0.0590	Passed	
O'Connell Drive Elementary School	Fountain right of Boys Wash Room	NK1348	Wednesday, August 19, 2020	0.000	Passed	0.0310	Passed	
O'Connell Drive Elementary School	Janitors Closet tap Room 126	MXK266	Thursday, June 18, 2020	0.001	Passed	0.1700	Passed	
O'Connell Drive Elementary School	Staff Room Kitchen tap Room 115A	MXK267	Thursday, June 18, 2020	-	Passed	0.0160	Passed	
O'Connell Drive Elementary School	Main Office Wash Room 1 tap Room 114	MXK268	Thursday, June 18, 2020	-	Passed	0.0230	Passed	
O'Connell Drive Elementary School	Main Office Wash Room 2 tap Room 113	MXK269	Thursday, June 18, 2020	0.001	Passed	0.0280	Passed	
O'Connell Drive Elementary School	Main Office Wash Room #3 Room 111	MXK584	Thursday, June 18, 2020	0.002	Passed	0.0480	Passed	
Oldfield Consolidated School	Teachers Room 16 tap	MWG681	Friday, June 12, 2020	-	Passed	0.0026	Passed	
Oldfield Consolidated School	Staff Wash Room tap Room 14	MWG682	Friday, June 12, 2020	-	Passed	0.0024	Passed	
Oldfield Consolidated School	Girls Wash Room tap 1 Room 12	MWG683	Friday, June 12, 2020	-	Passed	0.0045	Passed	
Oldfield Consolidated School	Girls Wash Room tap 2 Room 12	MWG684	Friday, June 12, 2020	-	Passed	0.0027	Passed	
Oldfield Consolidated School	Girls Wash Room tap 3 Room 12	MWG685	Friday, June 12, 2020	-	Passed	0.0031	Passed	
Oldfield Consolidated School	Girls Wash Room tap 4 Room 12	MWG686	Friday, June 12, 2020	-	Passed	0.0026	Passed	
Oldfield Consolidated School	Janitors Closet tap Room 10	MWG687	Friday, June 12, 2020	0.002	Passed	0.0041	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Oldfield Consolidated School	Boys Wash Room tap 1 Room 8	MWG688	Friday, June 12, 2020	-	Passed	0.0034	Passed	
Oldfield Consolidated School	Boys Wash Room tap 2 Room 8	MWG689	Friday, June 12, 2020	-	Passed	0.0050	Passed	
Oldfield Consolidated School	Boys Wash Room tap 3 Room 8	MWG690	Friday, June 12, 2020	0.001	Passed	0.0078	Passed	
Oldfield Consolidated School	Learning Centre tap Room 6	MWG691	Friday, June 12, 2020	-	Passed	0.0026	Passed	
Oxford School	3rd Floor Girls Wash Room tap 1 (East)	MSZ272	Thursday, May 28, 2020	0.002	Passed	0.4200	Passed	
Oxford School	3rd Floor Girls Wash Room tap 2 (East)	MSZ273	Thursday, May 28, 2020	0.004	Passed	0.2800	Passed	
Oxford School	3rd Floor Staff Wash Room tap	MSZ274	Thursday, May 28, 2020	0.001	Passed	0.0220	Passed	
Oxford School	Fountain by Room 303	MSZ275	Thursday, May 28, 2020	-	Passed	0.1100	Passed	Fountain replaced
Oxford School	3rd Floor Staff Wash Room 2 tap	MSZ276	Thursday, May 28, 2020	0.006	Exceeded	0.0490	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Oxford School	3rd Floor Boys Wash Room tap 1 (East)	MSZ277	Thursday, May 28, 2020	0.002	Passed	0.0690	Passed	
Oxford School	3rd Floor Boys Wash Room tap 2 (East)	MSZ278	Thursday, May 28, 2020	0.004	Passed	0.2000	Passed	
Oxford School	Janitors Closet tap by Room 305	MSZ279	Thursday, May 28, 2020	0.001	Passed	0.0560	Passed	
Oxford School	Staff Room tap Room 312	MSZ280	Thursday, May 28, 2020	0.002	Passed	0.3300	Passed	
Oxford School	3rd Floor Boys Wash Room tap 1 (West)	MSZ281	Thursday, May 28, 2020	-	Passed	0.0430	Passed	
Oxford School	3rd Floor Boys Wash Room tap 2 (West)	MSZ296	Thursday, May 28, 2020	0.001	Passed	0.0560	Passed	
Oxford School	3rd Floor Boys Wash Room tap 3 (West)	MSZ297	Thursday, May 28, 2020	0.001	Passed	0.0480	Passed	
Oxford School	Fountain by Room 317	QCC405	Tuesday, July 13, 2021	0.037	Passed	0.0950	Passed	Fountain replaced
Oxford School	3rd Floor Girls Wash Room tap 1 (West)	MSZ299	Thursday, May 28, 2020	0.002	Passed	0.0460	Passed	
Oxford School	3rd Floor Girls Wash Room tap 2 (West)	MSZ300	Thursday, May 28, 2020	-	Passed	0.0470	Passed	
Oxford School	3rd Floor Girls Wash Room tap 3 (West)	MSZ301	Thursday, May 28, 2020	0.002	Passed	0.1500	Passed	
Oxford School	Class Room Wash Room tap Room 314	MSZ302	Thursday, May 28, 2020	-	Passed	0.0660	Passed	
Oxford School	2nd Floor Boys Wash Room tap 1 (East)	MSZ303	Thursday, May 28, 2020	0.010	Exceeded	0.0520	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Oxford School	2nd Floor Boys Wash Room tap 2 (East)	MSZ304	Thursday, May 28, 2020	-	Passed	0.0032	Passed	
Oxford School	Art Room tap Room 202	MSZ305	Thursday, May 28, 2020	0.017	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Oxford School	Family Studies tap 1 Room 204	MSZ306	Thursday, May 28, 2020	-	Passed	0.2300	Passed	
Oxford School	Family Studies tap 2 Room 204	MSZ307	Thursday, May 28, 2020	-	Passed	0.1900	Passed	
Oxford School	Family Studies tap 3 Room 204	MSZ308	Thursday, May 28, 2020	0.005	Passed	0.2100	Passed	
Oxford School	Family Studies tap 4 Room 204	MSZ309	Thursday, May 28, 2020	0.001	Passed	0.0380	Passed	
Oxford School	Janitors Closet tap by Room 206	MSZ310	Thursday, May 28, 2020	0.002	Passed	0.0270	Passed	
Oxford School	Fountain by Room 206	MSZ311	Thursday, May 28, 2020	-	Passed	0.2600	Passed	Fountain replaced
Oxford School	2nd Floor Girls Wash Room tap 1 (East)	MSZ312	Thursday, May 28, 2020	0.001	Passed	0.1500	Passed	
Oxford School	2nd Floor Girls Wash Room tap 2 (East)	MSZ313	Thursday, May 28, 2020	0.001	Passed	0.1600	Passed	
Oxford School	2nd Floor Janitors Closet tap by Room 206	MSZ314	Thursday, May 28, 2020	0.050	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Oxford School	2nd Floor Staff Wash Room tap 1 by Room 210	MSZ315	Thursday, May 28, 2020	0.001	Passed	0.1400	Passed	
Oxford School	2nd Floor Staff Wash Room tap 2 by Room 210	MSZ316	Thursday, May 28, 2020	0.002	Passed	0.4400	Passed	
Oxford School	2nd Floor Staff Wash Room tap 3 by Room 210	MSZ317	Thursday, May 28, 2020	0.004	Passed	0.3400	Passed	
Oxford School	2nd Floor Boys Wash Room tap 1 by Room 217	MSZ318	Thursday, May 28, 2020	0.001	Passed	0.0690	Passed	
Oxford School	2nd Floor Boys Wash Room tap 2 by Room 217	MSZ319	Thursday, May 28, 2020	0.001	Passed	0.0610	Passed	
Oxford School	2nd Floor Boys Wash Room tap 3 by Room 217	MSZ320	Thursday, May 28, 2020	-	Passed	0.0490	Passed	
Oxford School	Janitors Closet tap by Room 217	MSZ321	Thursday, May 28, 2020	-	Passed	0.0520	Passed	
Oxford School	Fountain by Room 217	MSZ322	Thursday, May 28, 2020	0.001	Passed	0.5400	Passed	Fountain replaced
Oxford School	Girls Wash Room tap 1 by Room 215	MSZ323	Thursday, May 28, 2020	-	Passed	0.0410	Passed	
Oxford School	Girls Wash Room tap 2 by Room 215	MSZ324	Thursday, May 28, 2020	0.002	Passed	0.1000	Passed	
Oxford School	Girls Wash Room tap 3 by Room 215	MSZ325	Thursday, May 28, 2020	0.001	Passed	0.1200	Passed	
Oxford School	Gym Kitchen tap	MSZ326	Thursday, May 28, 2020	-	Passed	0.2300	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Oxford School	Fountain by Gym	QCC409	Tuesday, July 13, 2021	0.001	Passed	0.2200	Passed	Fountain replaced
Oxford School	Gym Girls Locker Room tap	MSZ329	Thursday, May 28, 2020	0.001	Passed	0.2300	Passed	
Oxford School	Basement Boiler Room tap	MSZ330	Thursday, May 28, 2020	0.001	Passed	0.5600	Passed	
Oxford School	1st Floor Boys Wash Room tap 1 by Room 104	MSZ331	Thursday, May 28, 2020	0.004	Passed	0.8000	Passed	
Oxford School	1st Floor Boys Wash Room tap 2 by Room 104	MSZ332	Thursday, May 28, 2020	-	Passed	0.0590	Passed	
Oxford School	Staff Room 109 tap	MSZ333	Thursday, May 28, 2020	-	Passed	0.0380	Passed	
Oxford School	Staff Room 109 Wash Room tap	MSZ334	Thursday, May 28, 2020	-	Passed	0.0220	Passed	
Oxford School	Boys Wash Room tap 1 by Room 111	MSZ335	Thursday, May 28, 2020	0.001	Passed	0.0900	Passed	
Oxford School	Boys Wash Room tap 2 by Room 111	MSZ336	Thursday, May 28, 2020	0.001	Passed	0.1100	Passed	
Oxford School	Boys Wash Room tap 3 by Room 111	MSZ337	Thursday, May 28, 2020	0.001	Passed	0.0640	Passed	
Oxford School	1st Floor Janitors Closet tap by Room 111	MSZ338	Thursday, May 28, 2020	0.001	Passed	0.0790	Passed	
Oxford School	Fountain by Room 111	MSZ339	Thursday, May 28, 2020	0.001	Passed	0.0840	Passed	Fountain replaced
Oxford School	1st Floor Girls Wash Room tap 1 by Room 111	MSZ340	Thursday, May 28, 2020	0.003	Passed	0.2600	Passed	
Oxford School	1st Floor Girls Wash Room tap 2 by Room 111	MSZ341	Thursday, May 28, 2020	0.001	Passed	0.1200	Passed	
Oxford School	1st Floor Girls Wash Room tap 3 by Room 111	MSZ342	Thursday, May 28, 2020	0.001	Passed	0.0480	Passed	
Oxford School	1st Floor Office tap	MSZ343	Thursday, May 28, 2020	-	Passed	0.0180	Passed	
Oxford School	Gym Boys Locker Room tap	MSZ344	Thursday, May 28, 2020	0.001	Passed	0.2700	Passed	
Oyster Pond Academy	Class Room tap 1 Room 2201	NAH599	Monday, June 29, 2020	0.002	Passed	0.2100	Passed	
Oyster Pond Academy	Class Room tap 2 Room 2201	NAH600	Monday, June 29, 2020	0.004	Passed	0.6400	Passed	
Oyster Pond Academy	Staff Wash Room tap Room 2106	NAH601	Monday, June 29, 2020	0.004	Passed	0.8600	Passed	
Oyster Pond Academy	Class Room Wash Room tap Room 2303	NAH602	Monday, June 29, 2020	0.006	Exceeded	0.7800	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 1 by Room 2104	NAH603	Monday, June 29, 2020	0.018	Exceeded	0.6900	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 2 by Room 2104	NAH604	Monday, June 29, 2020	0.037	Exceeded	1.2000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 3 by Room 2104	NAH605	Monday, June 29, 2020	0.032	Exceeded	0.9500	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Janitors Closet tap Room 2104	NAH606	Monday, June 29, 2020	0.071	Exceeded	0.9900	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 1 by Room 2104	NAH607	Monday, June 29, 2020	0.034	Exceeded	0.6400	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 2 by Room 2104	NAH608	Monday, June 29, 2020	0.015	Exceeded	0.8900	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 3 by Room 2104	NAH609	Monday, June 29, 2020	0.022	Exceeded	1.0000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Fountain by Boys Wash Room	NKI426	Wednesday, August 19, 2020	0.004	Passed	1.0000	Passed	
Oyster Pond Academy	Class Room tap 1 Room 2203	NAH611	Monday, June 29, 2020	0.003	Passed	1.5000	Passed	
Oyster Pond Academy	Class Room tap 2 Room 2203	NAH612	Monday, June 29, 2020	0.001	Passed	3.2000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap 3 Room 2203	NAH613	Monday, June 29, 2020	0.002	Passed	2.2000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap 4 Room 2203	NAH614	Monday, June 29, 2020	0.002	Passed	3.2000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 1 by Room 2114	NAH615	Monday, June 29, 2020	0.210	Exceeded	0.8100	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 2 by Room 2114	NAH616	Monday, June 29, 2020	0.062	Exceeded	2.2000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 3 by Room 2114	NAH617	Monday, June 29, 2020	0.070	Exceeded	2.6000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Janitors Closet tap Room 2114	NAH618	Monday, June 29, 2020	0.053	Exceeded	0.9100	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 1 by Room 2114	NAH620	Monday, June 29, 2020	0.270	Exceeded	2.8000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 2 by Room 2114	NAH621	Monday, June 29, 2020	0.130	Exceeded	2.1000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 3 by Room 2114	NAH622	Monday, June 29, 2020	0.038	Exceeded	1.1000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Fountain by Girls Wash Room	NAH623	Monday, June 29, 2020	0.005	Passed	1.7000	Passed	
Oyster Pond Academy	Staff Wash Room tap Room 2111	NAH624	Monday, June 29, 2020	0.006	Exceeded	0.0980	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap 1 Room 2209	NAH625	Monday, June 29, 2020	0.003	Passed	0.4900	Passed	
Oyster Pond Academy	Class Room tap 2 Room 2209	NAH626	Monday, June 29, 2020	0.008	Exceeded	0.4500	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap 3 Room 2209	NAH627	Monday, June 29, 2020	0.003	Passed	1.5000	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Oyster Pond Academy	Class Room tap 4 Room 2209	NAH628	Monday, June 29, 2020	0.002	Passed	1.1000	Passed	
Oyster Pond Academy	Class Room tap 5 Room 2209	NAH629	Monday, June 29, 2020	0.003	Passed	0.4300	Passed	
Oyster Pond Academy	Class Room tap Room 1422	NAH641	Monday, June 29, 2020	-	Passed	0.5700	Passed	
Oyster Pond Academy	Single compartment sink 1 tap Room 1420	NAH642	Monday, June 29, 2020	0.003	Passed	1.1000	Passed	
Oyster Pond Academy	Triple compartment sink tap Room 1420	NKI428	Wednesday, August 19, 2020	0.005	Passed	1.0000	Passed	
Oyster Pond Academy	Single compartment sink 2 tap Room 1420	NAH645	Monday, June 29, 2020	0.002	Passed	1.4000	Passed	
Oyster Pond Academy	Janitors Closet tap Room 1421	NAH647	Monday, June 29, 2020	0.049	Exceeded	1.2000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Laundry tub tap Room 1424	NAH648	Monday, June 29, 2020	0.009	Exceeded	1.5000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Gender Neutral Wash Room tap Room 1303	NAH650	Monday, June 29, 2020	0.002	Passed	0.3600	Passed	
Oyster Pond Academy	Class Room tap Room 1301	NAH651	Monday, June 29, 2020	0.001	Passed	1.9000	Passed	
Oyster Pond Academy	Class Room tap Room 1307	NAH653	Monday, June 29, 2020	0.008	Exceeded	1.6000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap Room 1309	NAH654	Monday, June 29, 2020	0.022	Exceeded	16.0000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap Room 1313	NAH680	Monday, June 29, 2020	0.004	Passed	4.2000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap Room 1314	NAH681	Monday, June 29, 2020	0.002	Passed	1.8000	Passed	
Oyster Pond Academy	Class Room tap Room 1310	NAH682	Monday, June 29, 2020	0.002	Passed	2.1000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap Room 1308	NAH683	Monday, June 29, 2020	0.003	Passed	1.1000	Passed	
Oyster Pond Academy	Class Room Wash Room tap Room 1306	NAH684	Monday, June 29, 2020	0.002	Passed	0.7200	Passed	
Oyster Pond Academy	Class Room Wash Room tap Room 1305	NAH685	Monday, June 29, 2020	0.003	Passed	0.9500	Passed	
Oyster Pond Academy	Class Room tap Room 1302	NAH686	Monday, June 29, 2020	0.003	Passed	0.9400	Passed	
Oyster Pond Academy	Girls Wash Room tap 1 by Room 1133	NAH687	Monday, June 29, 2020	0.023	Exceeded	0.7100	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 2 by Room 1133	NAH688	Monday, June 29, 2020	0.048	Exceeded	1.9000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 3 by Room 1133	NAH689	Monday, June 29, 2020	0.049	Exceeded	2.5000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Janitors Closet tap Room 1133	NAH698	Monday, June 29, 2020	0.006	Exceeded	0.8400	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 1 by Room 1133	NAH699	Monday, June 29, 2020	0.130	Exceeded	1.0000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 2 by Room 1133	NAH704	Monday, June 29, 2020	0.075	Exceeded	2.2000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 3 by Room 1133	NAH712	Monday, June 29, 2020	0.100	Exceeded	3.2000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Fountain by Boys Wash Room	NAH713	Monday, June 29, 2020	0.012	Exceeded	5.0000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Staff Wash Room tap Room 1132	NAH714	Monday, June 29, 2020	0.003	Passed	3.1000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap Room 1129	NAH715	Monday, June 29, 2020	0.003	Passed	1.1000	Passed	
Oyster Pond Academy	Staff Wash Room tap Room 1109	NAH716	Monday, June 29, 2020	0.010	Exceeded	4.6000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap Room 1113	NAH717	Monday, June 29, 2020	0.002	Passed	3.4000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Staff Wash Room tap Room 1115	NAH718	Monday, June 29, 2020	0.003	Passed	5.3000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Staff Wash Room tap Room 1114	NAH730	Monday, June 29, 2020	0.003	Passed	2.5000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap Room 1122	NAH731	Monday, June 29, 2020	0.017	Exceeded	0.1500	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room Wash Room tap Room 1205	NAH732	Monday, June 29, 2020	0.004	Passed	1.6000	Passed	
Oyster Pond Academy	Class Room tap Room 1203	NAH733	Monday, June 29, 2020	0.004	Passed	1.5000	Passed	
Oyster Pond Academy	Laundry tub tap Room 1201	NAH734	Monday, June 29, 2020	0.005	Exceeded	3.2000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Oyster Pond Academy	Girls Wash Room tap 1 by Room 1125	NAH735	Monday, June 29, 2020	0.037	Exceeded	0.9900	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 2 by Room 1125	NAH736	Monday, June 29, 2020	0.029	Exceeded	1.4000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Girls Wash Room tap 3 by Room 1125	NAH737	Monday, June 29, 2020	0.073	Exceeded	0.9500	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Janitors Closet tap Room 1125	NAH738	Monday, June 29, 2020	0.067	Exceeded	2.7000	Exceeded	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 1 by Room 1125	NAH739	Monday, June 29, 2020	0.110	Exceeded	0.8500	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 2 by Room 1125	NAH740	Monday, June 29, 2020	0.089	Exceeded	1.2000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Boys Wash Room tap 3 by Room 1125	NAH741	Monday, June 29, 2020	0.077	Exceeded	0.9800	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Fountain by Boys Wash Room	NKI428	Wednesday, August 19, 2020	0.004	Passed	0.9500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Oyster Pond Academy	Fountain by Gym entrance	NAH743	Monday, June 29, 2020	0.001	Passed	2.3000	Exceeded	New Fountain to be installed. Other sources available.
Oyster Pond Academy	Class Room tap 1 Room 1413	NAH744	Monday, June 29, 2020	0.078	Exceeded	0.2500	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap 2 Room 1413	NAH745	Monday, June 29, 2020	0.061	Exceeded	0.3400	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap 1 Room 1410	NAH746	Monday, June 29, 2020	0.110	Exceeded	1.2000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room tap 2 Room 1410	NAH747	Monday, June 29, 2020	0.088	Exceeded	0.4000	Passed	Signage added to instruct handwashing only
Oyster Pond Academy	Class Room Wash Room tap Room 1404	NAH751	Monday, June 29, 2020	0.093	Exceeded	2.4000	Exceeded	Signage added to instruct handwashing only
Park West PP	Staff Kitchen tap	NTW465	Thursday, October 1, 2020	0.004	Passed	0.0570	Passed	
Park West PP	Gender Neutral Wash Room tap	NTW466	Thursday, October 1, 2020	0.005	Passed	0.1200	Passed	
Park West PP	Wash Room tap 1	NTW467	Thursday, October 1, 2020	0.004	Passed	0.0790	Passed	
Park West PP	Wash Room tap 2	NTW468	Thursday, October 1, 2020	0.005	Passed	0.0780	Passed	
Park West PP	Wash Room tap 3	NTW469	Thursday, October 1, 2020	0.004	Passed	0.0680	Passed	
Park West PP	Wash Room tap 4	NTW470	Thursday, October 1, 2020	0.003	Passed	0.0890	Passed	
Park West PP	Wash Room tap 5	NTW471	Thursday, October 1, 2020	0.003	Passed	0.0810	Passed	
Park West School	Main Office Wash Room tap Room 1090	MQJ269	Friday, May 15, 2020	-	Passed	0.0340	Passed	
Park West School	Kitchen hand sink Room 1080	MQJ270	Friday, May 15, 2020	0.004	Passed	0.1200	Passed	
Park West School	Kitchen MKE sink Room 1080	MQJ271	Friday, May 15, 2020	-	Passed	0.0044	Passed	
Park West School	Kitchen hand dish Room 1080	MQJ272	Friday, May 15, 2020	-	Passed	0.0045	Passed	
Park West School	Girls Wash Room tap Room 1067	MQJ273	Friday, May 15, 2020	0.003	Passed	0.3300	Passed	
Park West School	Boys Wash Room tap Room 1068	MQJ274	Friday, May 15, 2020	-	Passed	0.0910	Passed	
Park West School	Class Room tap 1 Room 1069	MQJ275	Friday, May 15, 2020	-	Passed	0.1100	Passed	
Park West School	Class Room tap 2 Room 1069	MQJ276	Friday, May 15, 2020	-	Passed	0.0760	Passed	
Park West School	Music Room tap Room 1070	MQJ277	Friday, May 15, 2020	-	Passed	0.0780	Passed	
Park West School	Library work Room tap Room 1041	MQJ278	Friday, May 15, 2020	-	Passed	0.3400	Passed	
Park West School	Class Room tap Room 1014	MQJ279	Friday, May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room tap Room 1013	MQJ280	Friday, May 15, 2020	-	Passed	0.0420	Passed	
Park West School	Class Room tap Room 1016	MQJ281	Friday, May 15, 2020	-	Passed	0.1800	Passed	
Park West School	Class Room tap Room 1012	MQJ282	Friday, May 15, 2020	-	Passed	0.1900	Passed	
Park West School	Class Room tap Room 1011	MQJ283	Friday, May 15, 2020	-	Passed	0.1100	Passed	
Park West School	Fountain by Room 1048	MQJ284	Friday, May 15, 2020	-	Passed	0.1500	Passed	
Park West School	Girls Wash Room tap 1 Room 1048	MQJ285	Friday, May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Girls Wash Room tap 2 Room 1048	MQJ286	Friday, May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Girls Wash Room tap 3 Room 1048	MQJ287	Friday, May 15, 2020	-	Passed	0.1300	Passed	
Park West School	Girls Wash Room tap 4 Room 1048	MQJ288	Friday, May 15, 2020	-	Passed	0.1300	Passed	
Park West School	Gender Neutral Wash Room tap Room 1047	MQJ291	Friday, May 15, 2020	-	Passed	0.1400	Passed	
Park West School	Janitors Closet tap Room 1046	MQJ292	Friday, May 15, 2020	-	Passed	0.5500	Passed	
Park West School	Class Room tap Room 1027	MQJ293	Friday, May 15, 2020	-	Passed	0.0440	Passed	
Park West School	Class Room tap Room 1026	MQJ294	Friday, May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room tap Room 1025	MQJ295	Friday, May 15, 2020	-	Passed	0.1900	Passed	
Park West School	Class Room tap Room 1021	MQJ296	Friday, May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Gender Neutral Wash Room tap Room 1029	MQJ297	Friday, May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Class Room tap Room 1034	MQJ298	Friday, May 15, 2020	-	Passed	0.2200	Passed	
Park West School	Gender Neutral Wash Room tap Room 1036	MQJ300	Friday, May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room tap Room 1032	MQJ304	Friday, May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room tap Room 1031	MQJ305	Friday, May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Boys Wash Room tap 1 Room 1043	MQJ306	Friday, May 15, 2020	-	Passed	0.2500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Park West School	Boys Wash Room tap 2 Room 1043	MQJ307	Friday, May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Boys Wash Room tap 3 Room 1043	MQJ308	Friday, May 15, 2020	0.002	Passed	0.1900	Passed	
Park West School	Boys Wash Room tap 4 Room 1043	MQJ309	Friday, May 15, 2020	-	Passed	0.1500	Passed	
Park West School	Fountain by Room 1061	MQJ310	Friday, May 15, 2020	-	Passed	0.1300	Passed	
Park West School	Gym Office Wash Room tap	MQJ311	Friday, May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Boys Locker Room tap 1 Room 1058	MQJ312	Friday, May 15, 2020	-	Passed	0.0860	Passed	
Park West School	Boys Locker Room tap 2 Room 1058	MQJ313	Friday, May 15, 2020	-	Passed	0.2300	Passed	
Park West School	Girls Locker Room tap 1 Room 1058	MQJ318	Friday, May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Girls Locker Room tap 2 Room 1058	MQJ319	Friday, May 15, 2020	-	Passed	0.1800	Passed	
Park West School	Class Room tap Room 2026	MQJ320	Friday, May 15, 2020	-	Passed	0.1500	Passed	
Park West School	Class Room tap Room 2027	MQJ321	Friday, May 15, 2020	-	Passed	0.2400	Passed	
Park West School	Class Room tap 1 Room 2028	MQJ322	Friday, May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room tap 2 Room 2028	MQJ323	Friday, May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room tap 1 Room 2029	MQJ324	Friday, May 15, 2020	-	Passed	0.7700	Passed	
Park West School	Class Room tap 2 Room 2029	MQJ325	Friday, May 15, 2020	-	Passed	0.2300	Passed	
Park West School	Class Room tap 3 Room 2029	MQJ326	Friday, May 15, 2020	-	Passed	0.1000	Passed	
Park West School	Class Room tap 1 Room 2036	MQJ327	Friday, May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Class Room tap 2 Room 2036	MQJ328	Friday, May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room tap Room 2037	MQJ329	Friday, May 15, 2020	-	Passed	0.0940	Passed	
Park West School	Class Room tap Room 2038	MQJ330	Friday, May 15, 2020	-	Passed	0.2300	Passed	
Park West School	Class Room tap 1 Room 2039	MQJ331	Friday, May 15, 2020	0.002	Passed	0.3400	Passed	
Park West School	Janitors Closet tap Room 2064	MQJ333	Friday, May 15, 2020	-	Passed	0.2200	Passed	
Park West School	Gender Neutral Wash Room tap Room 2065	MQJ334	Friday, May 15, 2020	-	Passed	0.0290	Passed	
Park West School	Fountain by Room 2065	QKE693	Monday, August 16, 2021	0.004	Passed	0.2000	Passed	Fountain replaced
Park West School	Fountain by Room 2026	QKE694	Monday, August 16, 2021	0.004	Passed	0.7100	Passed	Fountain replaced
Park West School	Class Room tap Room 2046	MQJ337	Friday, May 15, 2020	-	Passed	0.2100	Passed	
Park West School	Class Room tap Room 2047	MQJ338	Friday, May 15, 2020	-	Passed	0.2100	Passed	
Park West School	Class Room tap Room 2048	MQJ339	Friday, May 15, 2020	-	Passed	0.3400	Passed	
Park West School	Class Room tap Room 2049	MQJ340	Friday, May 15, 2020	-	Passed	0.2200	Passed	
Park West School	Staff Room Wash Room tap Room 2074	MQJ341	Friday, May 15, 2020	0.003	Passed	0.0580	Passed	
Park West School	Staff Room Kitchen tap Room 2075	MQJ342	Friday, May 15, 2020	-	Passed	0.0760	Passed	
Park West School	Staff Room Wash Room tap Room 2073	MQJ343	Friday, May 15, 2020	-	Passed	0.1600	Passed	
Park West School	Class Room tap Room 2071	MQJ344	Friday, May 15, 2020	-	Passed	0.0690	Passed	
Park West School	Girls Wash Room tap 1 Room 2056	MQJ345	Friday, May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Girls Wash Room tap 2 Room 2056	MQJ346	Friday, May 15, 2020	-	Passed	0.2000	Passed	
Park West School	Girls Wash Room tap 3 Room 2056	MQJ347	Friday, May 15, 2020	0.001	Passed	0.1800	Passed	
Park West School	Girls Wash Room tap 2 Room 2056	MQJ348	Friday, May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Girls Wash Room tap 3 Room 2056	MQJ349	Friday, May 15, 2020	-	Passed	0.1500	Passed	
Park West School	Girls Wash Room tap 4 Room 2056	MQJ350	Friday, May 15, 2020	-	Passed	0.1200	Passed	
Park West School	Boys Wash Room tap 1 Room 2055	MQJ351	Friday, May 15, 2020	-	Passed	0.1000	Passed	
Park West School	Boys Wash Room tap 2 Room 2055	MQJ352	Friday, May 15, 2020	0.001	Passed	0.1200	Passed	
Park West School	Boys Wash Room tap 3 Room 2055	MQJ353	Friday, May 15, 2020	-	Passed	0.1100	Passed	
Park West School	Boys Wash Room tap 4 Room 2055	MQJ354	Friday, May 15, 2020	-	Passed	0.0980	Passed	
Park West School	Food Lab tap 1 Room 2012	MQJ355	Friday, May 15, 2020	0.001	Passed	0.1200	Passed	
Park West School	Food Lab tap 2 Room 2012	MQJ356	Friday, May 15, 2020	-	Passed	0.2300	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Park West School	Food Lab tap 3 Room 2012	MQJ357	Friday, May 15, 2020	-	Passed	0.1000	Passed	
Park West School	Food Lab tap 4 Room 2012	MQJ358	Friday, May 15, 2020	-	Passed	0.1700	Passed	
Park West School	Class Room tap Room 1033	NES598	Friday, July 24, 2020	-	Passed	0.2100	Passed	
Park West School	Class Room tap 2 Room 2039	NES599	Friday, July 24, 2020	-	Passed	0.1100	Passed	
Porters Lake Elementary School	Main Office Wash Room tap Room 169	MXS508	Thursday, June 18, 2020	0.003	Passed	0.2500	Passed	
Porters Lake Elementary School	Fountain by Room 168	MXS509	Thursday, June 18, 2020	0.001	Passed	0.1500	Passed	
Porters Lake Elementary School	Class Room tap Room 164	MXS510	Thursday, June 18, 2020	0.001	Passed	0.3000	Passed	
Porters Lake Elementary School	Class Room Wash Room tap Room 163	MXS511	Thursday, June 18, 2020	0.001	Passed	0.2000	Passed	
Porters Lake Elementary School	Class Room Wash Room tap Room 162	MXS512	Thursday, June 18, 2020	0.001	Passed	0.2500	Passed	
Porters Lake Elementary School	Class Room tap Room 161	MXS513	Thursday, June 18, 2020	0.003	Passed	0.3200	Passed	
Porters Lake Elementary School	Class Room tap Room 160	MXS514	Thursday, June 18, 2020	0.003	Passed	0.5300	Passed	
Porters Lake Elementary School	Class Room tap Room 158	MXS515	Thursday, June 18, 2020	0.001	Passed	0.0850	Passed	
Porters Lake Elementary School	Class Room tap Room 155	MXS516	Thursday, June 18, 2020	0.005	Passed	0.0990	Passed	
Porters Lake Elementary School	Class Room tap Room 153	MXS517	Thursday, June 18, 2020	0.002	Passed	0.1600	Passed	
Porters Lake Elementary School	Class Room tap Room 152	MXS520	Thursday, June 18, 2020	0.002	Passed	0.3300	Passed	
Porters Lake Elementary School	Class Room tap Room 150	MXS521	Thursday, June 18, 2020	0.004	Passed	0.2900	Passed	
Porters Lake Elementary School	Janitors Closet tap Room 147	MXS522	Thursday, June 18, 2020	0.001	Passed	0.1100	Passed	
Porters Lake Elementary School	Arts/stage Class Room tap 1 Room 178	MXS523	Thursday, June 18, 2020	0.001	Passed	0.0530	Passed	
Porters Lake Elementary School	Arts/stage Class Room tap 2 Room 178	MXS524	Thursday, June 18, 2020	-	Passed	0.0530	Passed	
Porters Lake Elementary School	Girls Wash Room tap 1 by Room 145	MXS525	Thursday, June 18, 2020	0.003	Passed	0.2300	Passed	
Porters Lake Elementary School	Girls Wash Room tap 2 by Room 145	MXS526	Thursday, June 18, 2020	0.054	Exceeded	0.8400	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Girls Wash Room tap 3 by Room 145	MXS527	Thursday, June 18, 2020	0.019	Exceeded	1.1000	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Boys Wash Room tap 1 by Room 146	MXS528	Thursday, June 18, 2020	0.004	Passed	0.1600	Passed	
Porters Lake Elementary School	Boys Wash Room tap 2 by Room 146	MXS529	Thursday, June 18, 2020	0.003	Passed	0.1200	Passed	
Porters Lake Elementary School	Boys Wash Room tap 3 by Room 146	MXS530	Thursday, June 18, 2020	0.002	Passed	0.1100	Passed	
Porters Lake Elementary School	Janitors Closet tap Room 142	MXS531	Thursday, June 18, 2020	0.003	Passed	0.1200	Passed	
Porters Lake Elementary School	Janitors Closet tap Room 138	MXS532	Thursday, June 18, 2020	0.004	Passed	0.2500	Passed	
Porters Lake Elementary School	Gym Office Wash Room tap Room 161	MXS533	Thursday, June 18, 2020	0.003	Passed	0.2000	Passed	
Porters Lake Elementary School	Boys Locker Room tap 1	MXS534	Thursday, June 18, 2020	0.009	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Porters Lake Elementary School	Boys Locker Room tap 2	MXS535	Thursday, June 18, 2020	0.024	Exceeded	0.9700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Porters Lake Elementary School	Girls Locker Room tap 1	MXS536	Thursday, June 18, 2020	0.016	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Porters Lake Elementary School	Girls Locker Room tap 2	MXS537	Thursday, June 18, 2020	0.010	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Porters Lake Elementary School	Cafe/Kitchen tap 1 (by door)	MXS538	Thursday, June 18, 2020	0.009	Exceeded	0.1800	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Cafe/Kitchen tap 2 (Big Sink)	MXS539	Thursday, June 18, 2020	0.002	Passed	0.1000	Passed	
Porters Lake Elementary School	Cafe/Kitchen tap 3	MXS542	Thursday, June 18, 2020	0.007	Exceeded	0.1500	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Cafe/Kitchen tap 4	MXS543	Thursday, June 18, 2020	0.007	Exceeded	0.1500	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Recycle Room Kitchen tap Room 192	MXS544	Thursday, June 18, 2020	0.004	Passed	0.1200	Passed	
Porters Lake Elementary School	Recycle Room wash-up tap Room 192	MXS545	Thursday, June 18, 2020	0.001	Passed	0.0450	Passed	
Porters Lake Elementary School	Fountain by Room 192	MXS546	Thursday, June 18, 2020	0.001	Passed	0.1400	Passed	
Porters Lake Elementary School	Boys Wash Room tap 1 by library	MXS547	Thursday, June 18, 2020	0.004	Passed	0.2300	Passed	
Porters Lake Elementary School	Boys Wash Room tap 2 by library	MXS548	Thursday, June 18, 2020	0.004	Passed	0.1600	Passed	
Porters Lake Elementary School	Boys Wash Room tap 3 by library	MXS549	Thursday, June 18, 2020	0.016	Exceeded	0.5800	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Janitors Closet tap by fountain/Boys Wash Room	MXS550	Thursday, June 18, 2020	0.002	Passed	0.1200	Passed	
Porters Lake Elementary School	Fountain between Wash Room's	MXS551	Thursday, June 18, 2020	0.001	Passed	0.1400	Passed	
Porters Lake Elementary School	Girls Wash Room tap 1 by seminar Room	MXS554	Thursday, June 18, 2020	0.011	Exceeded	0.3200	Passed	Signage added to instruct handwashing only

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Porters Lake Elementary School	Girls Wash Room tap 2 by seminar Room	MXS555	Thursday, June 18, 2020	0.007	Exceeded	0.2500	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Girls Wash Room tap 3 by seminar Room	MXS556	Thursday, June 18, 2020	0.048	Exceeded	1.2000	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Girls Wash Room tap 4 by seminar Room	MXS557	Thursday, June 18, 2020	0.010	Exceeded	0.2500	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Staff Room tap Room 129	MXS558	Thursday, June 18, 2020	0.001	Passed	0.1400	Passed	
Porters Lake Elementary School	Staff Room Wash Room 1 tap Room 125	MXS559	Thursday, June 18, 2020	0.002	Passed	0.1900	Passed	
Porters Lake Elementary School	Staff Room Wash Room 1 tap Room 126	MXS560	Thursday, June 18, 2020	0.001	Passed	0.1700	Passed	
Porters Lake Elementary School	Gender Neutral Wash Room tap Room 109	MXS561	Thursday, June 18, 2020	0.020	Exceeded	0.4300	Passed	Signage added to instruct handwashing only
Porters Lake Elementary School	Class Room tap Room 108	MXS562	Thursday, June 18, 2020	0.001	Passed	0.1200	Passed	
Porters Lake Elementary School	Library tap Room 106	MXS563	Thursday, June 18, 2020	0.003	Passed	0.1500	Passed	
Portland Estates Elementary School	Gym Locker Room Wash Room tap Room 1077	NCB105	Thursday, July 9, 2020	-	Passed	1.4000	Passed	
Portland Estates Elementary School	Gym Office Wash Room tap Room 1073	NCB106	Thursday, July 9, 2020	0.001	Passed	0.3100	Passed	
Portland Estates Elementary School	Kitchen tap 1 Room 1066	NCB107	Thursday, July 9, 2020	0.001	Passed	0.6600	Passed	
Portland Estates Elementary School	Kitchen tap 2 Room 1066	NCB108	Thursday, July 9, 2020	0.001	Passed	0.0810	Passed	
Portland Estates Elementary School	Kitchen tap 3 Room 1066	NCB109	Thursday, July 9, 2020	0.001	Passed	0.7100	Passed	
Portland Estates Elementary School	Kitchen tap 4 Room 1066	NCB110	Thursday, July 9, 2020	-	Passed	0.2900	Passed	
Portland Estates Elementary School	Janitors Closet tap Room 1059	NCB111	Thursday, July 9, 2020	-	Passed	0.0570	Passed	
Portland Estates Elementary School	Music Room tap Room 1062	NCB112	Thursday, July 9, 2020	-	Passed	1.5000	Passed	
Portland Estates Elementary School	Art Room tap 1 Room 1063	NCB113	Thursday, July 9, 2020	0.001	Passed	0.9500	Passed	
Portland Estates Elementary School	Art Room tap 2 Room 1063	NCB114	Thursday, July 9, 2020	0.001	Passed	0.2500	Passed	
Portland Estates Elementary School	Recycle Room tap Room 1055	NCB115	Thursday, July 9, 2020	0.002	Passed	0.1800	Passed	
Portland Estates Elementary School	Class Room tap Room 1036	NCB116	Thursday, July 9, 2020	-	Passed	0.7500	Passed	
Portland Estates Elementary School	Class Room tap Room 1037	NCB117	Thursday, July 9, 2020	0.002	Passed	0.2900	Passed	
Portland Estates Elementary School	Gender Neutral Wash Room tap Room 1041	NCB118	Thursday, July 9, 2020	0.001	Passed	0.7100	Passed	
Portland Estates Elementary School	Class Room tap Room 1038	NCB119	Thursday, July 9, 2020	-	Passed	0.3900	Passed	
Portland Estates Elementary School	Class Room tap Room 1039	NCB120	Thursday, July 9, 2020	0.001	Passed	0.3000	Passed	
Portland Estates Elementary School	Office health Room tap Room 1021	NCB121	Thursday, July 9, 2020	0.001	Passed	0.2200	Passed	
Portland Estates Elementary School	Office Wash Room tap Room 1018	NCB122	Thursday, July 9, 2020	0.002	Passed	0.1900	Passed	
Portland Estates Elementary School	Fountain by Room 1025	NCB123	Thursday, July 9, 2020	-	Passed	0.2800	Passed	
Portland Estates Elementary School	Female Wash Room 1050 tap 1	NCB124	Thursday, July 9, 2020	0.001	Passed	0.2400	Passed	
Portland Estates Elementary School	Female Wash Room 1050 tap 2	NCB126	Thursday, July 9, 2020	0.001	Passed	0.3400	Passed	
Portland Estates Elementary School	Female Wash Room 1050 tap 3	NCB127	Thursday, July 9, 2020	0.001	Passed	0.2800	Passed	
Portland Estates Elementary School	Male Wash Room 1049 tap 1	NCB128	Thursday, July 9, 2020	-	Passed	0.2500	Passed	
Portland Estates Elementary School	Male Wash Room 1049 tap 2	NCB129	Thursday, July 9, 2020	0.001	Passed	0.4300	Passed	
Portland Estates Elementary School	Male Wash Room 1049 tap 3	NCB130	Thursday, July 9, 2020	0.001	Passed	0.3800	Passed	
Portland Estates Elementary School	Fountain by Room 1049	NCB131	Thursday, July 9, 2020	-	Passed	0.1500	Passed	
Portland Estates Elementary School	Lab Storage Room 1047 tap	NCB132	Thursday, July 9, 2020	0.001	Passed	0.2900	Passed	
Portland Estates Elementary School	Female Wash Room tap 1 Room 1046	NCB133	Thursday, July 9, 2020	0.001	Passed	0.1200	Passed	
Portland Estates Elementary School	Female Wash Room tap 2 Room 1046	NCB134	Thursday, July 9, 2020	0.006	Exceeded	0.4600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Portland Estates Elementary School	Male Wash Room tap 1 Room 1045	NCB135	Thursday, July 9, 2020	0.001	Passed	0.1400	Passed	
Portland Estates Elementary School	Male Wash Room tap 2 Room 1045	NCB136	Thursday, July 9, 2020	0.002	Passed	0.1900	Passed	
Portland Estates Elementary School	Fountain right of Room 1045	NCB137	Thursday, July 9, 2020	0.001	Passed	0.3400	Passed	
Portland Estates Elementary School	Class Room tap Room 2030	NCB138	Thursday, July 9, 2020	-	Passed	0.2600	Passed	
Portland Estates Elementary School	Class Room tap Room 2031	NCB140	Thursday, July 9, 2020	0.001	Passed	0.2600	Passed	
Portland Estates Elementary School	Class Room tap Room 2032	NCB142	Thursday, July 9, 2020	-	Passed	0.4100	Passed	
Portland Estates Elementary School	Class Room tap Room 2033	NCB144	Thursday, July 9, 2020	-	Passed	0.4400	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Portland Estates Elementary School	Class Room tap Room 2017	NCB146	Thursday, July 9, 2020	0.001	Passed	0.2200	Passed	
Portland Estates Elementary School	Class Room tap Room 2018	NCB148	Thursday, July 9, 2020	0.001	Passed	0.5700	Passed	
Portland Estates Elementary School	Class Room tap Room 2019	NCB149	Thursday, July 9, 2020	0.013	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Portland Estates Elementary School	Class Room tap Room 2020	NCB150	Thursday, July 9, 2020	-	Passed	0.5400	Passed	
Portland Estates Elementary School	Staff Room Wash Room tap Room 2009	NCB151	Thursday, July 9, 2020	0.003	Passed	0.4500	Passed	
Portland Estates Elementary School	Staff Room Wash Room tap Room 2008	NCB152	Thursday, July 9, 2020	0.002	Passed	0.3500	Passed	
Portland Estates Elementary School	Staff Room Kitchen tap Room 2007	NCB153	Thursday, July 9, 2020	0.001	Passed	0.1900	Passed	
Portland Estates Elementary School	Male Wash Room tap 1 Room 2026	NCB154	Thursday, July 9, 2020	0.001	Passed	0.3100	Passed	
Portland Estates Elementary School	Male Wash Room tap 2 Room 2026	NCB155	Thursday, July 9, 2020	0.001	Passed	0.2900	Passed	
Portland Estates Elementary School	Male Wash Room tap 3 Room 2026	NCB156	Thursday, July 9, 2020	0.001	Passed	0.2400	Passed	
Portland Estates Elementary School	Fountain right of Room 2026	NCB157	Thursday, July 9, 2020	-	Passed	0.2300	Passed	
Portland Estates Elementary School	Fountain by Room 2017	NCB158	Thursday, July 9, 2020	-	Passed	0.3300	Passed	
Portland Estates Elementary School	Female Wash Room tap 1 Room 2025	NCB159	Thursday, July 9, 2020	0.007	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Portland Estates Elementary School	Female Wash Room tap 2 Room 2025	NCB160	Thursday, July 9, 2020	0.001	Passed	0.3600	Passed	
Portland Estates Elementary School	Female Wash Room tap 3 Room 2025	NCB162	Thursday, July 9, 2020	0.003	Passed	0.3200	Passed	
Prince Andrew High School	2nd Flr Male SR Wash Room tap	MXH491	Wednesday, June 17, 2020	0.001	Passed	0.1200	Passed	
Prince Andrew High School	2nd Flr Female SR Wash Room tap	MXH492	Wednesday, June 17, 2020	0.007	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr SR tap	MXH493	Wednesday, June 17, 2020	-	Passed	0.0940	Passed	
Prince Andrew High School	2nd Flr Janitors Closet	MXH494	Wednesday, June 17, 2020	-	Passed	0.1100	Passed	
Prince Andrew High School	2nd Flr Male Staff Wash Room	MXH495	Wednesday, June 17, 2020	0.009	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr Boys Wash Room tap 1	MXH496	Wednesday, June 17, 2020	0.010	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr Boys Wash Room tap 2	MXH497	Wednesday, June 17, 2020	0.096	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr Boys Wash Room tap 3	MXH498	Wednesday, June 17, 2020	0.032	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr Boys Wash Room tap 4	MXH499	Wednesday, June 17, 2020	0.002	Passed	0.5800	Passed	
Prince Andrew High School	2nd Flr Female Staff Wash Room	MXH500	Wednesday, June 17, 2020	0.003	Passed	0.0540	Passed	
Prince Andrew High School	2nd Flr Girls Wash Room tap 1	MXH501	Wednesday, June 17, 2020	0.042	Exceeded	0.8300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr Girls Wash Room tap 2	MXH502	Wednesday, June 17, 2020	0.150	Exceeded	0.7700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr Girls Wash Room tap 3	MXH503	Wednesday, June 17, 2020	0.011	Exceeded	0.5600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Flr Girls Wash Room tap 4	MXH504	Wednesday, June 17, 2020	0.008	Exceeded	0.8800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Class Room 232 tap	MXH505	Wednesday, June 17, 2020	0.005	Passed	0.1200	Passed	
Prince Andrew High School	Fountain by Rm 232	NLS562	Tuesday, August 25, 2020	0.025	Passed	0.6400	Passed	
Prince Andrew High School	Class Room 230 tap	MXH507	Wednesday, June 17, 2020	0.034	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Chem Lab tap 1 Room 228	MXH508	Wednesday, June 17, 2020	0.001	Passed	1.9000	Passed	
Prince Andrew High School	Chem Lab tap 2 Room 228	MXH509	Wednesday, June 17, 2020	0.009	Exceeded	2.9000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Chem Lab tap 3 Room 228	MXH510	Wednesday, June 17, 2020	0.007	Exceeded	2.6000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Chem Lab tap 4 Room 228	MXH511	Wednesday, June 17, 2020	0.002	Passed	0.8400	Passed	
Prince Andrew High School	Chem Lab tap 5 Room 228	MXH512	Wednesday, June 17, 2020	0.001	Passed	1.1000	Passed	
Prince Andrew High School	Chem Lab tap 6 Room 228	MXH513	Wednesday, June 17, 2020	-	Passed	0.5600	Passed	
Prince Andrew High School	Chem Lab tap 7 Room 228	MXH514	Wednesday, June 17, 2020	0.001	Passed	0.9800	Passed	
Prince Andrew High School	Chem Lab tap 8 Room 228	MXH515	Wednesday, June 17, 2020	0.001	Passed	1.2000	Passed	
Prince Andrew High School	Chem Lab tap 9 Room 228	MXH516	Wednesday, June 17, 2020	-	Passed	1.5000	Passed	
Prince Andrew High School	Chem Lab tap 10 Room 228	MXH517	Wednesday, June 17, 2020	-	Passed	1.2000	Passed	
Prince Andrew High School	Class Room tap 1 Room 226	MXH518	Wednesday, June 17, 2020	0.006	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Class Room tap 2 Room 226	MXH519	Wednesday, June 17, 2020	-	Passed	0.5700	Passed	
Prince Andrew High School	Class Room tap 1 Room 225	MXH520	Wednesday, June 17, 2020	0.001	Passed	0.5100	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Prince Andrew High School	Class Room tap 2 Room 225	MXH521	Wednesday, June 17, 2020	0.001	Passed	0.6100	Passed	
Prince Andrew High School	Youth Room tap Room 219	MXH522	Wednesday, June 17, 2020	0.003	Passed	0.1400	Passed	
Prince Andrew High School	Music Room tap Room 218	MXH523	Wednesday, June 17, 2020	-	Passed	0.0880	Passed	
Prince Andrew High School	Fountain left of Room 217	MXH524	Wednesday, June 17, 2020	-	Passed	0.2600	Passed	
Prince Andrew High School	Class Room tap left of Room 217	MXH525	Wednesday, June 17, 2020	0.004	Passed	1.6000	Passed	
Prince Andrew High School	Class Room tap Room 211	MXH526	Wednesday, June 17, 2020	0.017	Exceeded	0.6600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Fine arts Office #5 Wash Room tap	MXH527	Wednesday, June 17, 2020	0.027	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Fine arts Office #4 Wash Room tap	MXH528	Wednesday, June 17, 2020	0.005	Passed	0.1800	Passed	
Prince Andrew High School	2nd Floor Girls Wash Room tap 1	MXH529	Wednesday, June 17, 2020	0.003	Passed	1.3000	Passed	
Prince Andrew High School	2nd Floor Girls Wash Room tap 2	MXH530	Wednesday, June 17, 2020	0.012	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Floor Girls Wash Room tap 3	MXH531	Wednesday, June 17, 2020	0.016	Exceeded	0.5400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Floor Girls Staff Wash Room tap	MXH532	Wednesday, June 17, 2020	0.012	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Floor Fountain between Wash Room's	MXH533	Wednesday, June 17, 2020	0.011	Exceeded	0.1300	Passed	
Prince Andrew High School	2nd Floor Fountain between Wash Room's	MXH534	Wednesday, June 17, 2020	0.006	Exceeded	0.1400	Passed	
Prince Andrew High School	2nd Floor Boys Staff Wash Room tap	MXH535	Wednesday, June 17, 2020	0.008	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Floor Boys Wash Room tap 1	MXH536	Wednesday, June 17, 2020	0.042	Exceeded	0.7500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Floor Boys Wash Room tap 2	MXH537	Wednesday, June 17, 2020	0.015	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	2nd Floor Boys Wash Room tap 3	MXH538	Wednesday, June 17, 2020	0.006	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Class Room tap Room 229	MXH539	Wednesday, June 17, 2020	0.002	Passed	0.1900	Passed	
Prince Andrew High School	Science Lab tap 1 Room 231	MXH540	Wednesday, June 17, 2020	0.004	Passed	0.4100	Passed	
Prince Andrew High School	Science Lab tap 2 Room 231	MXH541	Wednesday, June 17, 2020	0.018	Exceeded	0.6200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 3 Room 231	MXH542	Wednesday, June 17, 2020	0.021	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 4 Room 231	MXH543	Wednesday, June 17, 2020	0.019	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 5 Room 231	MXH544	Wednesday, June 17, 2020	0.018	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 6 Room 231	MXH545	Wednesday, June 17, 2020	0.014	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 7 Room 231	MXH546	Wednesday, June 17, 2020	0.006	Exceeded	0.6800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 8 Room 231	MXH547	Wednesday, June 17, 2020	0.009	Exceeded	0.8700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 9 Room 231	MXH548	Wednesday, June 17, 2020	0.006	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 10 Room 231	MXH549	Wednesday, June 17, 2020	0.002	Passed	0.7300	Passed	
Prince Andrew High School	Science Lab tap 11 Room 231	MXH550	Wednesday, June 17, 2020	0.007	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Science Lab tap 12 Room 231	MXH551	Wednesday, June 17, 2020	0.006	Exceeded	0.9600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Class Room Kitchen sink tap Room 108	MXH552	Wednesday, June 17, 2020	-	Passed	0.3700	Passed	
Prince Andrew High School	Class Room Wash Room 1 tap Room 108	MXH553	Wednesday, June 17, 2020	0.001	Passed	0.3500	Passed	
Prince Andrew High School	Class Room Wash Room 2 tap Room 108	MXH554	Wednesday, June 17, 2020	0.001	Passed	0.4200	Passed	
Prince Andrew High School	Class Room Wash Room #3 tap Room 108	MXH555	Wednesday, June 17, 2020	-	Passed	0.4000	Passed	
Prince Andrew High School	1st Floor Boys Staff Wash Room tap	MXH556	Wednesday, June 17, 2020	0.001	Passed	0.0700	Passed	
Prince Andrew High School	1st Floor Boys Wash Room tap 1	MXH557	Wednesday, June 17, 2020	0.001	Passed	0.0850	Passed	
Prince Andrew High School	1st Floor Boys Wash Room tap 2	MXH558	Wednesday, June 17, 2020	0.001	Passed	0.1200	Passed	
Prince Andrew High School	1st Floor Boys Wash Room tap 3	MXH559	Wednesday, June 17, 2020	0.001	Passed	0.0550	Passed	
Prince Andrew High School	1st Floor Boys Wash Room tap 4	MXH560	Wednesday, June 17, 2020	0.001	Passed	0.0790	Passed	
Prince Andrew High School	1st Floor Girls Staff Wash Room tap	MXH561	Wednesday, June 17, 2020	0.002	Passed	0.0440	Passed	
Prince Andrew High School	1st Floor Girls Wash Room tap 1	MXH562	Wednesday, June 17, 2020	0.002	Passed	0.1100	Passed	
Prince Andrew High School	1st Floor Girls Wash Room tap 2	MXH563	Wednesday, June 17, 2020	0.002	Passed	0.0850	Passed	
Prince Andrew High School	1st Floor Girls Wash Room tap 3	MXH564	Wednesday, June 17, 2020	0.002	Passed	0.0850	Passed	
Prince Andrew High School	1st Floor Girls Wash Room tap 4	MXH565	Wednesday, June 17, 2020	0.001	Passed	0.0770	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Prince Andrew High School	1st Floor boiler Room tap	MXH567	Wednesday, June 17, 2020	0.002	Passed	0.1400	Passed	
Prince Andrew High School	1st Floor caretaker Room tap	NLS558	Tuesday, August 25, 2020	0.001	Passed	0.0470	Passed	
Prince Andrew High School	Class Room tap 1 Room 127	MXH569	Wednesday, June 17, 2020	0.001	Passed	1.2000	Passed	
Prince Andrew High School	Class Room tap 2 Room 127	MXH570	Wednesday, June 17, 2020	-	Passed	0.8800	Passed	
Prince Andrew High School	Class Room tap 3 Room 127	MXH571	Wednesday, June 17, 2020	0.003	Passed	0.4800	Passed	
Prince Andrew High School	1st Floor Cafeteria tap 1	MXH572	Wednesday, June 17, 2020	0.003	Passed	0.5900	Passed	
Prince Andrew High School	1st Floor Cafeteria tap 2	MXH573	Wednesday, June 17, 2020	0.003	Passed	1.2000	Passed	
Prince Andrew High School	1st Floor Cafeteria tap 3	NLS559	Tuesday, August 25, 2020	0.001	Passed	0.1500	Passed	
Prince Andrew High School	Class Room tap Room 125	MXH575	Wednesday, June 17, 2020	0.002	Passed	0.7300	Passed	
Prince Andrew High School	Class Room tap Room 124	MXH576	Wednesday, June 17, 2020	0.001	Passed	0.7100	Passed	
Prince Andrew High School	Main Office Wash Room 1 tap	MXH577	Wednesday, June 17, 2020	0.007	Exceeded	0.0670	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Main Office Wash Room 2 tap	MXH578	Wednesday, June 17, 2020	0.002	Passed	0.0440	Passed	
Prince Andrew High School	Fountain by Room 116	NLS561	Tuesday, August 25, 2020	0.001	Passed	0.1600	Passed	
Prince Andrew High School	1st Floor Janitors Closet tap by Room 116	MXH580	Wednesday, June 17, 2020	0.005	Passed	0.8100	Passed	
Prince Andrew High School	Fountain near Room 124	MXH581	Wednesday, June 17, 2020	0.026	Exceeded	0.2500	Passed	New Fountain to be installed. Other sources available.
Prince Andrew High School	Gender Neutral Wash Room tap 1 near Room 124	MXH582	Wednesday, June 17, 2020	0.036	Exceeded	0.6000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Gender Neutral Wash Room tap 2 near Room 124	MXH583	Wednesday, June 17, 2020	0.003	Passed	0.0850	Passed	
Prince Andrew High School	1st Floor Staff Wash Room tap by Room 125	MXH584	Wednesday, June 17, 2020	0.010	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	1st Floor Staff Wash Room tap by Room 125	MXH585	Wednesday, June 17, 2020	0.003	Passed	0.0800	Passed	
Prince Andrew High School	Class Room tap 1 Room 128	MXH586	Wednesday, June 17, 2020	0.002	Passed	0.6200	Passed	
Prince Andrew High School	Class Room tap 2 Room 128	MXH587	Wednesday, June 17, 2020	0.006	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Class Room tap 3 Room 128	MXH588	Wednesday, June 17, 2020	0.009	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Class Room tap 4 Room 128	MXH589	Wednesday, June 17, 2020	0.004	Passed	1.0000	Passed	
Prince Andrew High School	Class Room tap 5 Room 128	MXH590	Wednesday, June 17, 2020	0.002	Passed	1.0000	Passed	
Prince Andrew High School	Girls Locker Room back tap	MXH591	Wednesday, June 17, 2020	0.014	Exceeded	0.6100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Girls Locker Room tap 1	MXH592	Wednesday, June 17, 2020	0.046	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Girls Locker Room tap 2	MXH593	Wednesday, June 17, 2020	0.004	Passed	0.2400	Passed	
Prince Andrew High School	Girls Locker Room tap 3	MXH594	Wednesday, June 17, 2020	0.009	Exceeded	0.0760	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Gym Office 11 Wash Room tap	MXH595	Wednesday, June 17, 2020	0.066	Exceeded	1.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Fountain in Gym	MXH596	Wednesday, June 17, 2020	0.001	Passed	0.2500	Passed	
Prince Andrew High School	Boys Locker Room tap 1	MXH597	Wednesday, June 17, 2020	0.033	Exceeded	0.7200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Boys Locker Room tap 2	MXH598	Wednesday, June 17, 2020	0.035	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Prince Andrew High School	Boys Locker Room tap 3	MXH599	Wednesday, June 17, 2020	0.002	Passed	0.1500	Passed	
Prince Andrew High School	Gym Office 1 Wash Room tap	MXH600	Wednesday, June 17, 2020	0.002	Passed	0.0370	Passed	
Prince Andrew High School	Gym Office 12 Wash Room tap	MXH601	Wednesday, June 17, 2020	0.002	Passed	0.0480	Passed	
Prince Andrew High School	1st Floor Fountain by boiler Room	NBS158	Tuesday, July 7, 2020	0.001	Passed	1.0000	Passed	
Prospect Road Elementary School	Staff Room tap Room 113	MUM404	Thursday, June 4, 2020	0.011	Exceeded	2.8000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Staff Room Wash Room tap Room 113	MUM405	Thursday, June 4, 2020	0.013	Exceeded	2.8000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Fountain by Room 110	MUM406	Thursday, June 4, 2020	0.018	Exceeded	4.7000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Girls Wash Room tap 1	MUM407	Thursday, June 4, 2020	0.008	Exceeded	2.6000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Girls Wash Room tap 2	MUM408	Thursday, June 4, 2020	0.013	Exceeded	1.9000	Passed	Signage added to instruct handwashing only
Prospect Road Elementary School	Girls Wash Room tap 3	MUM409	Thursday, June 4, 2020	0.021	Exceeded	2.2000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Janitors Closet tap between Wash Room's	MUM410	Thursday, June 4, 2020	0.002	Passed	3.5000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Boys Wash Room tap 1	MUM411	Thursday, June 4, 2020	0.032	Exceeded	5.0000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Boys Wash Room tap 2	MUM412	Thursday, June 4, 2020	0.019	Exceeded	5.6000	Exceeded	Signage added to instruct handwashing only

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Prospect Road Elementary School	Boys Wash Room tap 3	MUM413	Thursday, June 4, 2020	0.016	Exceeded	4.7000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Class Room tap Room 108	MUM424	Thursday, June 4, 2020	0.016	Exceeded	1.4000	Passed	Signage added to instruct handwashing only
Prospect Road Elementary School	Staff Wash Room tap by Janitors Closet	MUM425	Thursday, June 4, 2020	0.012	Exceeded	17.0000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Mechanical Room ta[	MUM426	Thursday, June 4, 2020	0.038	Exceeded	6.4000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Girls Wash Room tap 1	MUM427	Thursday, June 4, 2020	0.091	Exceeded	1.6000	Passed	Signage added to instruct handwashing only
Prospect Road Elementary School	Girls Wash Room tap 2	MUM428	Thursday, June 4, 2020	0.073	Exceeded	7.1000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Girls Wash Room tap 3	MUM429	Thursday, June 4, 2020	0.068	Exceeded	8.8000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Girls Wash Room tap 4	MUM430	Thursday, June 4, 2020	0.026	Exceeded	14.0000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Boys Wash Room tap 1	MUM431	Thursday, June 4, 2020	0.023	Exceeded	12.0000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Boys Wash Room tap 2	MUM432	Thursday, June 4, 2020	0.015	Exceeded	13.0000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Boys Wash Room tap 3	MUM433	Thursday, June 4, 2020	0.015	Exceeded	4.9000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Boys Wash Room tap 4	MUM434	Thursday, June 4, 2020	0.034	Exceeded	4.1000	Exceeded	Signage added to instruct handwashing only
Prospect Road Elementary School	Teachers lounge tap Room 123A	MUM435	Thursday, June 4, 2020	0.370	Exceeded	1.8000	Passed	Signage added to instruct handwashing only
Ridgecliff Middle School	Class Room 1095 tap	NAM767	Thursday, July 2, 2020	-	Passed	0.2600	Passed	
Ridgecliff Middle School	Class Room 1092 tap 1	NAM768	Thursday, July 2, 2020	0.003	Passed	0.6400	Passed	
Ridgecliff Middle School	Class Room 1092 tap 2	NAM769	Thursday, July 2, 2020	0.001	Passed	0.3400	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 1	NAM770	Thursday, July 2, 2020	0.002	Passed	1.1000	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 2	NAM771	Thursday, July 2, 2020	0.003	Passed	0.3100	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 3	NAM772	Thursday, July 2, 2020	0.001	Passed	1.0000	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 4	NAM773	Thursday, July 2, 2020	0.004	Passed	0.8900	Passed	
Ridgecliff Middle School	Science Lab Room 1086 tap 5	NAM774	Thursday, July 2, 2020	0.002	Passed	0.5500	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 1	NAM775	Thursday, July 2, 2020	0.003	Passed	0.7100	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 2	NAM776	Thursday, July 2, 2020	0.004	Passed	0.5800	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 3	NAM777	Thursday, July 2, 2020	0.005	Passed	0.6800	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 4	NAM778	Thursday, July 2, 2020	0.003	Passed	0.3300	Passed	
Ridgecliff Middle School	Science Lab Room 1085 tap 5	NAM779	Thursday, July 2, 2020	0.003	Passed	0.2200	Passed	
Ridgecliff Middle School	Science Lab Room 4085 tap 6	NAM780	Thursday, July 2, 2020	0.003	Passed	0.1700	Passed	
Ridgecliff Middle School	Learning Centre Room 1081 Wash Room tap	NAM781	Thursday, July 2, 2020	0.001	Passed	0.3000	Passed	
Ridgecliff Middle School	Learning Centre Room 1079 tap	NAM782	Thursday, July 2, 2020	-	Passed	0.4900	Passed	
Ridgecliff Middle School	Class Room 1076 tap	NAM783	Thursday, July 2, 2020	0.001	Passed	0.3200	Passed	
Ridgecliff Middle School	Class Room 1072 tap 1	NAM784	Thursday, July 2, 2020	0.001	Passed	0.3800	Passed	
Ridgecliff Middle School	Class Room 1072 tap 2	NAM785	Thursday, July 2, 2020	0.001	Passed	0.3000	Passed	
Ridgecliff Middle School	Janitors Closet 1100 tap	NAM786	Thursday, July 2, 2020	0.002	Passed	0.2000	Passed	
Ridgecliff Middle School	Fountain right of Room 1100	QCC166	Tuesday, July 13, 2021	0.001	Passed	0.0880	Passed	Fountain replaced
Ridgecliff Middle School	Gender Neutral Wash Room 1101 tap	NAM788	Thursday, July 2, 2020	0.001	Passed	0.1900	Passed	
Ridgecliff Middle School	Music Room 1064 tap	NAM789	Thursday, July 2, 2020	0.002	Passed	1.5000	Passed	
Ridgecliff Middle School	Art Room 1061 tap	NAM790	Thursday, July 2, 2020	-	Passed	0.7000	Passed	
Ridgecliff Middle School	Fountain by Room 1104	NAM791	Thursday, July 2, 2020	-	Passed	0.2700	Passed	
Ridgecliff Middle School	Girls Wash Room tap 1 by Room 1072	NAM792	Thursday, July 2, 2020	0.001	Passed	0.4400	Passed	
Ridgecliff Middle School	Girls Wash Room tap 2 by Room 1072	NAM793	Thursday, July 2, 2020	0.002	Passed	0.3500	Passed	
Ridgecliff Middle School	Girls Wash Room tap 3 by Room 1072	NAM794	Thursday, July 2, 2020	0.006	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ridgecliff Middle School	Girls Wash Room tap 4 by Room 1072	NAM795	Thursday, July 2, 2020	0.004	Passed	0.3500	Passed	
Ridgecliff Middle School	Male Wash Room tap 1 by Room 1103	NAM796	Thursday, July 2, 2020	0.002	Passed	0.1900	Passed	
Ridgecliff Middle School	Male Wash Room tap2 by Room 1103	NAM797	Thursday, July 2, 2020	0.002	Passed	0.2200	Passed	
Ridgecliff Middle School	Male Wash Room tap 3 by Room 1103	NAM798	Thursday, July 2, 2020	0.001	Passed	0.2200	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Ridgecliff Middle School	Male Wash Room tap 4 by Room 1103	NAM799	Thursday, July 2, 2020	-	Passed	0.2100	Passed	
Ridgecliff Middle School	Sick Room 1026 tap	NAM800	Thursday, July 2, 2020	0.003	Passed	0.2700	Passed	
Ridgecliff Middle School	Office Room 1025 Wash Room tap	NAM801	Thursday, July 2, 2020	0.001	Passed	0.2200	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 1	NAM802	Thursday, July 2, 2020	0.001	Passed	0.4300	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 2	NAM803	Thursday, July 2, 2020	0.001	Passed	0.3100	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 3	NAM804	Thursday, July 2, 2020	0.001	Passed	0.2300	Passed	
Ridgecliff Middle School	Family Studies Room 1029 tap 4	NAM805	Thursday, July 2, 2020	0.001	Passed	0.4000	Passed	
Ridgecliff Middle School	Janitors Closet 1035 tap	NAM806	Thursday, July 2, 2020	0.003	Passed	0.2000	Passed	
Ridgecliff Middle School	Mech Room 1039 tap	NAM807	Thursday, July 2, 2020	0.001	Passed	0.3200	Passed	
Ridgecliff Middle School	Fountain by Room 1056	QCC165	Tuesday, July 13, 2021	0.003	Passed	0.4100	Passed	Fountain replaced
Ridgecliff Middle School	Kitchen Room 1056 tap 1	NZB791	Thursday, October 22, 2020	0.005	Passed	0.0410	Passed	Remediation has been completed
Ridgecliff Middle School	Kitchen Room 1056 tap 2	NAM809	Thursday, July 2, 2020	0.001	Passed	0.3200	Passed	
Ridgecliff Middle School	Kitchen Room 1056 tap 3	NAM810	Thursday, July 2, 2020	0.001	Passed	0.6400	Passed	
Ridgecliff Middle School	Female Wash Room 1043 tap 1	NAM811	Thursday, July 2, 2020	0.002	Passed	0.5100	Passed	
Ridgecliff Middle School	Female Wash Room 1043 tap 2	NAM812	Thursday, July 2, 2020	0.001	Passed	0.2500	Passed	
Ridgecliff Middle School	Gym Office Wash Room 1046 tap	NAM813	Thursday, July 2, 2020	-	Passed	0.4400	Passed	
Ridgecliff Middle School	Gym Office Wash Room 1048 tap	NAM814	Thursday, July 2, 2020	-	Passed	0.5000	Passed	
Ridgecliff Middle School	Boys Wash Room 1050 tap 1	NAM815	Thursday, July 2, 2020	0.001	Passed	0.5200	Passed	
Ridgecliff Middle School	Boys Wash Room 1050 tap 2	NAM816	Thursday, July 2, 2020	0.014	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ridgecliff Middle School	Recycle Room 1038 tap	NAM817	Thursday, July 2, 2020	0.006	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ridgecliff Middle School	Gender Neutral Wash Room 1037 tap	NAM818	Thursday, July 2, 2020	0.001	Passed	0.1500	Passed	
Ridgecliff Middle School	Class Room 2065 tap	NAM819	Thursday, July 2, 2020	-	Passed	0.5600	Passed	
Ridgecliff Middle School	Class Room 2061 tap 1	NAM820	Thursday, July 2, 2020	0.006	Exceeded	0.8400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ridgecliff Middle School	Class Room 2061 tap 2	NAM821	Thursday, July 2, 2020	0.002	Passed	0.3600	Passed	
Ridgecliff Middle School	Class Room 2058 tap	NAM822	Thursday, July 2, 2020	0.001	Passed	0.7700	Passed	
Ridgecliff Middle School	Class Room 2053 tap 1	NAM823	Thursday, July 2, 2020	0.001	Passed	0.8700	Passed	
Ridgecliff Middle School	Class Room 2053 tap 2	NAM824	Thursday, July 2, 2020	0.001	Passed	0.3100	Passed	
Ridgecliff Middle School	Class Room 2050 tap	NAM825	Thursday, July 2, 2020	0.001	Passed	0.4500	Passed	
Ridgecliff Middle School	Class Room 2046 tap 1	NAM826	Thursday, July 2, 2020	-	Passed	0.8400	Passed	
Ridgecliff Middle School	Class Room 2046 tap 2	NAM827	Thursday, July 2, 2020	0.001	Passed	0.4800	Passed	
Ridgecliff Middle School	Gender Neutral Wash Room 2072 tap	NAM828	Thursday, July 2, 2020	0.002	Passed	0.2900	Passed	
Ridgecliff Middle School	Fountain by Room 2072	NAM829	Thursday, July 2, 2020	-	Passed	0.8200	Passed	
Ridgecliff Middle School	Janitors Closet tap by Room 2072	NAM830	Thursday, July 2, 2020	0.005	Passed	0.3900	Passed	
Ridgecliff Middle School	Girls Wash Room tap 1 by Room 2046	NAM831	Thursday, July 2, 2020	-	Passed	0.2800	Passed	
Ridgecliff Middle School	Girls Wash Room tap 2 by Room 2046	NAM832	Thursday, July 2, 2020	0.001	Passed	0.3300	Passed	
Ridgecliff Middle School	Girls Wash Room tap 3 by Room 2046	NAM833	Thursday, July 2, 2020	0.001	Passed	0.3500	Passed	
Ridgecliff Middle School	Girls Wash Room tap 4 by Room 2046	NAM834	Thursday, July 2, 2020	0.001	Passed	0.1800	Passed	
Ridgecliff Middle School	Library Room 2021 tap	NAM835	Thursday, July 2, 2020	0.001	Passed	0.2200	Passed	
Ridgecliff Middle School	Fountain by Room 2036	QCC164	Tuesday, July 13, 2021	0.001	Passed	0.0850	Passed	Fountain replaced
Ridgecliff Middle School	Janitors Closet 2036 tap	NAM837	Thursday, July 2, 2020	0.002	Passed	0.1600	Passed	
Ridgecliff Middle School	Staff Room 2025 Wash Room 1 tap	NAM838	Thursday, July 2, 2020	-	Passed	0.2000	Passed	
Ridgecliff Middle School	Staff Room 2025 Wash Room 2 tap	NAM839	Thursday, July 2, 2020	0.001	Passed	0.1800	Passed	
Ridgecliff Middle School	Staff Room 2025 tap	NAM840	Thursday, July 2, 2020	-	Passed	0.3000	Passed	
Ridgecliff Middle School	Tech Ed 2034 tap	NAM842	Thursday, July 2, 2020	0.001	Passed	0.2600	Passed	
Robert K. Turner Elementary School	Kitchen tap by Room 201	MUV980	Monday, June 8, 2020	0.020	Exceeded	0.6700	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Robert K. Turner Elementary School	Boys Wash Room tap 1 by Room 204	MUV981	Monday, June 8, 2020	0.008	Exceeded	0.0099	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Boys Wash Room tap 2 by Room 204	MUV982	Monday, June 8, 2020	0.005	Exceeded	0.0210	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Boys Wash Room tap 3 by Room 204	NMD779	Thursday, August 27, 2020	0.001	Passed	0.0120	Passed	
Robert K. Turner Elementary School	Boys Wash Room tap 4 by Room 204	NMD780	Thursday, August 27, 2020	0.002	Passed	0.0070	Passed	
Robert K. Turner Elementary School	Girls Wash Room tap 1 by Room 205	MUV985	Monday, June 8, 2020	0.004	Passed	0.0099	Passed	
Robert K. Turner Elementary School	Girls Wash Room tap 2 by Room 205	MUV986	Monday, June 8, 2020	0.004	Passed	0.0120	Passed	
Robert K. Turner Elementary School	Girls Wash Room tap 3 by Room 205	MUV987	Monday, June 8, 2020	0.011	Exceeded	0.0320	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Girls Wash Room tap 4 by Room 205	MUV988	Monday, June 8, 2020	0.063	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Fountain by Room 207	MUV989	Monday, June 8, 2020	0.067	Exceeded	0.2000	Passed	New Fountain to be installed. Other sources available.
Robert K. Turner Elementary School	Janitors Closet tap by fountain	MUV993	Monday, June 8, 2020	-	Passed	0.0087	Passed	
Robert K. Turner Elementary School	Fountain by Staff Room	NMD781	Thursday, August 27, 2020	0.000	Passed	0.0140	Passed	
Robert K. Turner Elementary School	Boys Wash Room tap 1 by library	MUV995	Monday, June 8, 2020	0.022	Exceeded	0.0700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Boys Wash Room tap 2 by library	MUV996	Monday, June 8, 2020	0.008	Exceeded	0.0680	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Boys Wash Room tap 3 by library	MUV997	Monday, June 8, 2020	0.006	Exceeded	0.0200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Girls Wash Room tap 1 by library	MUV998	Monday, June 8, 2020	0.340	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Girls Wash Room tap 2 by library	MUV999	Monday, June 8, 2020	0.004	Passed	0.0180	Passed	
Robert K. Turner Elementary School	Girls Wash Room tap 3 by library	MUW000	Monday, June 8, 2020	0.008	Exceeded	0.0610	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Fountain by Room 102	MUW001	Monday, June 8, 2020	0.005	Passed	0.0830	Passed	
Robert K. Turner Elementary School	Janitors Closet tap by fountain	MUW002	Monday, June 8, 2020	0.003	Passed	0.1100	Passed	
Robert K. Turner Elementary School	Gender Neutral Wash Room tap Room 105	MUW010	Monday, June 8, 2020	0.002	Passed	0.2000	Passed	
Robert K. Turner Elementary School	Gender Neutral Wash Room tap Room 104	MUW011	Monday, June 8, 2020	0.009	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Staff Room Kitchen tap	MUW012	Monday, June 8, 2020	0.001	Passed	0.0280	Passed	
Robert K. Turner Elementary School	Gender Neutral Staff Wash Room 1	MUW013	Monday, June 8, 2020	0.009	Exceeded	0.0420	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Robert K. Turner Elementary School	Gender Neutral Staff Wash Room 2	MUW014	Monday, June 8, 2020	0.004	Passed	0.0110	Passed	
Rockingham Elementary School	Boys Wash Room tap 1 Room 57	MUD705	Tuesday, June 2, 2020	0.029	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Boys Wash Room tap 2 Room 57	MUD706	Tuesday, June 2, 2020	0.034	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Janitors Closet tap Room 58	MUD707	Tuesday, June 2, 2020	1.100	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 1 Room 56	MUD708	Tuesday, June 2, 2020	0.011	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 2 Room 56	MUD709	Tuesday, June 2, 2020	0.690	Exceeded	0.6200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Class Room tap Room 55	MUD710	Tuesday, June 2, 2020	0.002	Passed	0.6800	Passed	
Rockingham Elementary School	Fountain by Room 53	NIU578	Wednesday, August 12, 2020	0.002	Passed	0.0270	Passed	Fountain Replacement in progress
Rockingham Elementary School	Lavatory sink tap Room 53	MUD712	Tuesday, June 2, 2020	0.089	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 1 Room 48	MUD713	Tuesday, June 2, 2020	0.067	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 2 Room 48	MUD714	Tuesday, June 2, 2020	0.004	Passed	0.1700	Passed	
Rockingham Elementary School	Boys Wash Room tap 1 Room 47	MUD719	Tuesday, June 2, 2020	0.019	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Boys Wash Room tap 2 Room 47	MUD720	Tuesday, June 2, 2020	0.011	Exceeded	0.6400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Class Room tap Room 26	MUD721	Tuesday, June 2, 2020	0.005	Passed	0.1800	Passed	
Rockingham Elementary School	Fountain by Room 29	NIU579	Wednesday, August 12, 2020	0.003	Passed	0.0380	Passed	
Rockingham Elementary School	Girls Wash Room tap 1 Room 29	MUD723	Tuesday, June 2, 2020	0.007	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 2 Room 29	MUD724	Tuesday, June 2, 2020	0.005	Passed	0.0630	Passed	
Rockingham Elementary School	Boys Wash Room tap 1 Room 30	MUD725	Tuesday, June 2, 2020	0.006	Exceeded	0.0920	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Boys Wash Room tap 2 Room 30	MUD726	Tuesday, June 2, 2020	0.007	Exceeded	0.0330	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Staff Wash Room inside Room 33	MUD727	Tuesday, June 2, 2020	0.001	Passed	0.0270	Passed	
Rockingham Elementary School	Staff Wash Room inside Room 33	MUD728	Tuesday, June 2, 2020	0.002	Passed	0.2400	Passed	
Rockingham Elementary School	Staff Room Kitchen tap Room 33	MUD733	Tuesday, June 2, 2020	0.003	Passed	0.5900	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Rockingham Elementary School	Janitors Closet tap by Room 33	MUD734	Tuesday, June 2, 2020	0.031	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Class Room tap Room 36	MUD735	Tuesday, June 2, 2020	0.012	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Fountain by Room 39	NIU580	Wednesday, August 12, 2020	0.001	Passed	0.0290	Passed	
Rockingham Elementary School	Girls Wash Room tap 1 Room 39	MUD737	Tuesday, June 2, 2020	0.025	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 2 Room 39	MUD738	Tuesday, June 2, 2020	0.007	Exceeded	0.0380	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Boys Wash Room tap 1 Room 40	MUD739	Tuesday, June 2, 2020	0.001	Passed	0.4800	Passed	
Rockingham Elementary School	Boys Wash Room tap 2 Room 40	MUD740	Tuesday, June 2, 2020	0.001	Passed	0.0900	Passed	
Rockingham Elementary School	Janitors Closet tap Room 43	MUD741	Tuesday, June 2, 2020	-	Passed	0.0930	Passed	
Rockingham Elementary School	Fountain between Room 22 and 23	MUD742	Tuesday, June 2, 2020	-	Passed	0.9900	Passed	Fountain Replacement in progress
Rockingham Elementary School	Cafeteria/Kitchen handwashing tap	MUD743	Tuesday, June 2, 2020	0.003	Passed	0.3100	Passed	
Rockingham Elementary School	Cafeteria/Kitchen double compartment sink tap	MUD744	Tuesday, June 2, 2020	0.017	Exceeded	0.6700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Fountain by Room 50	MUD745	Tuesday, June 2, 2020	0.014	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Basin tap Room 6	MUD746	Tuesday, June 2, 2020	0.005	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Basin tap Room 10	MUD747	Tuesday, June 2, 2020	0.020	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 1 Room 11	MUD748	Tuesday, June 2, 2020	0.091	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingham Elementary School	Girls Wash Room tap 2 Room 11	MUD749	Tuesday, June 2, 2020	0.004	Passed	0.2200	Passed	
Rockingham Elementary School	Girls Wash Room tap 3 Room 11	MUD750	Tuesday, June 2, 2020	-	Passed	0.0140	Passed	
Rockingham Elementary School	Girls Wash Room tap 4 Room 11	MUD751	Tuesday, June 2, 2020	0.002	Passed	0.2900	Passed	
Rockingham Elementary School	Fountain by Room 11	MUD752	Tuesday, June 2, 2020	0.001	Passed	0.1100	Passed	
Rockingham Elementary School	Janitors Closet tap by Room 12	MUD767	Tuesday, June 2, 2020	0.001	Passed	0.0500	Passed	
Rockingham Elementary School	Boys Wash Room tap 1 Room 12	MUD768	Tuesday, June 2, 2020	0.002	Passed	0.0670	Passed	
Rockingham Elementary School	Boys Wash Room tap 2 Room 12	MUD769	Tuesday, June 2, 2020	0.002	Passed	0.0270	Passed	Remediation has been completed
Rockingham Elementary School	Boys Wash Room tap 3 Room 12	MUD770	Tuesday, June 2, 2020	0.003	Passed	0.0380	Passed	Remediation has been completed
Rockingham Elementary School	Boys Wash Room tap 4 Room 12	MUD771	Tuesday, June 2, 2020	0.001	Passed	0.0290	Passed	Remediation has been completed
Rockingstone Heights School	Kitchen sink tap 1 Room 300	MUQ707	Thursday, June 4, 2020	-	Passed	0.1800	Passed	
Rockingstone Heights School	Kitchen sink tap 2 Room 300	MUQ708	Thursday, June 4, 2020	-	Passed	0.4100	Passed	
Rockingstone Heights School	Kitchen sink tap 3 Room 300	MUQ709	Thursday, June 4, 2020	-	Passed	0.0980	Passed	
Rockingstone Heights School	Kitchen sink tap 4 Room 300	MUQ710	Thursday, June 4, 2020	-	Passed	0.0700	Passed	
Rockingstone Heights School	Boys Wash Room tap 1 by Room 302	MUQ711	Thursday, June 4, 2020	0.001	Passed	0.1500	Passed	
Rockingstone Heights School	Boys Wash Room tap 2 by Room 302	MUQ712	Thursday, June 4, 2020	0.054	Exceeded	0.0970	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Boys Wash Room tap 3 by Room 302	MUQ713	Thursday, June 4, 2020	0.010	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Janitors Closet tap by Boys Wash Room	MUQ714	Thursday, June 4, 2020	0.001	Passed	0.0510	Passed	
Rockingstone Heights School	Fountain by Room 303	QQP431	Wednesday, September 15, 2021	0.001	Passed	0.0080	Passed	Fountain replaced
Rockingstone Heights School	Staff Wash Room by Girls Wash Room	MUQ716	Thursday, June 4, 2020	0.001	Passed	0.0500	Passed	
Rockingstone Heights School	Girls Wash Room tap 1 by Room 309	MUQ717	Thursday, June 4, 2020	0.007	Exceeded	0.0340	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Girls Wash Room tap 2 by Room 309	MUQ718	Thursday, June 4, 2020	0.002	Passed	0.0240	Passed	
Rockingstone Heights School	Girls Wash Room tap 3 by Room 309	MUQ719	Thursday, June 4, 2020	0.003	Passed	0.0340	Passed	
Rockingstone Heights School	Boys Wash Room tap 1 by Room 202	MUQ721	Thursday, June 4, 2020	0.002	Passed	0.0720	Passed	
Rockingstone Heights School	Boys Wash Room tap 2 by Room 202	MUQ722	Thursday, June 4, 2020	0.003	Passed	0.0680	Passed	
Rockingstone Heights School	Boys Wash Room tap 3 by Room 202	MUQ723	Thursday, June 4, 2020	0.003	Passed	0.0430	Passed	
Rockingstone Heights School	Janitors Closet tap by Boys Wash Room	MUQ724	Thursday, June 4, 2020	0.014	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Fountain by Room 203	QQP430	Wednesday, September 15, 2021	0.002	Exceeded	0.4300	Passed	Fountain replaced
Rockingstone Heights School	Gym cafeteria Kitchen tap	MUQ726	Thursday, June 4, 2020	0.001	Passed	0.0130	Passed	
Rockingstone Heights School	Girls Wash Room tap 2 by Room 203	MUQ727	Thursday, June 4, 2020	0.002	Passed	0.0120	Passed	
Rockingstone Heights School	Girls Wash Room tap 3 by Room 203	MUQ728	Thursday, June 4, 2020	0.010	Exceeded	0.0410	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Rockingstone Heights School	Gender Neutral Wash Room tap by Girls Wash Room	MUQ729	Thursday, June 4, 2020	-	Passed	0.0045	Passed	
Rockingstone Heights School	Staff Male Wash Room tap in Staff Room	MUQ730	Thursday, June 4, 2020	0.012	Exceeded	0.0480	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Staff Female Wash Room tap in Staff Room	MUQ731	Thursday, June 4, 2020	0.011	Exceeded	0.0340	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Staff Room Kitchen tap	MUQ732	Thursday, June 4, 2020	0.002	Passed	0.0770	Passed	
Rockingstone Heights School	Boys Wash Room tap 1 by caretaker Room	MUQ733	Thursday, June 4, 2020	0.002	Passed	0.0630	Passed	
Rockingstone Heights School	Boys Wash Room tap 2 by caretaker Room	MUQ734	Thursday, June 4, 2020	0.004	Passed	0.0650	Passed	
Rockingstone Heights School	Boys Wash Room tap 3 by caretaker Room	MUQ735	Thursday, June 4, 2020	0.011	Exceeded	0.0830	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Janitors Closet tap caretaker Room	MUQ736	Thursday, June 4, 2020	-	Passed	0.0210	Passed	
Rockingstone Heights School	Fountain by Room 103	QQP429	Wednesday, September 15, 2021	0.005	Passed	0.0170	Passed	Fountain replaced
Rockingstone Heights School	Staff Gender Neutral Wash Room tap by Girls Wash	MUQ738	Thursday, June 4, 2020	0.001	Passed	0.0150	Passed	
Rockingstone Heights School	Girls Wash Room tap 1 by Staff Wash Room	MUQ739	Thursday, June 4, 2020	0.001	Passed	0.1400	Passed	
Rockingstone Heights School	Girls Wash Room tap 2 by Staff Wash Room	MUQ740	Thursday, June 4, 2020	0.009	Exceeded	0.0710	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Girls Wash Room tap 3 by Staff Wash Room	MUQ741	Thursday, June 4, 2020	0.076	Exceeded	0.0660	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Gym Office Wash Room tap by Girls Wash Room	MUQ742	Thursday, June 4, 2020	0.140	Exceeded	0.4700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Gym Office Wash Room tap by Boys Wash Room	MUQ743	Thursday, June 4, 2020	0.008	Exceeded	0.0700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Gym Cafeteria handwashing tap	MUQ745	Thursday, June 4, 2020	0.001	Passed	0.8600	Passed	
Rockingstone Heights School	Staff Wash Room inside Main Office	MUQ746	Thursday, June 4, 2020	0.075	Exceeded	0.0790	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Art Room tap 1 Room 100	MUQ747	Thursday, June 4, 2020	0.120	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Art Room tap 2 Room 100	MUQ748	Thursday, June 4, 2020	0.280	Exceeded	0.0900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rockingstone Heights School	Youth health Centre tap	MUQ749	Thursday, June 4, 2020	0.001	Passed	0.0120	Passed	
Rockingstone Heights School	Class Room tap Room 102	MUQ750	Thursday, June 4, 2020	-	Passed	0.3300	Passed	
Rockingstone Heights School	Class Room tap Room 103	MUQ751	Thursday, June 4, 2020	-	Passed	0.3100	Passed	
Rockingstone Heights School	Class Room tap Room 105	MUQ752	Thursday, June 4, 2020	0.001	Passed	0.2900	Passed	
Rockingstone Heights School	Gender Neutral Wash Room tap 1 by Room 203	NAK426	Thursday, July 2, 2020	0.002	Passed	0.0400	Passed	
Rocky Lake Elementary	Boys Wash Room tap 1 Room 303	MSA057	Monday, May 25, 2020	0.018	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Boys Wash Room tap 2 Room 303	MSA058	Monday, May 25, 2020	0.009	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Boys Wash Room tap 3 Room 303	MSA059	Monday, May 25, 2020	0.010	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Boys Wash Room tap 4 Room 303	MSA060	Monday, May 25, 2020	0.002	Passed	0.0330	Passed	
Rocky Lake Elementary	Boys Wash Room tap 5 Room 303	MSA061	Monday, May 25, 2020	0.001	Passed	0.0280	Passed	
Rocky Lake Elementary	Staff Wash Room tap by Room 303	MSA062	Monday, May 25, 2020	0.001	Passed	0.0330	Passed	
Rocky Lake Elementary	Janitors Closet tap by Room 303	MSA063	Monday, May 25, 2020	-	Passed	0.0270	Passed	
Rocky Lake Elementary	Fountain by Room 303	MSA064	Monday, May 25, 2020	0.001	Passed	0.0740	Passed	Fountain Replacement in progress
Rocky Lake Elementary	Girls Wash Room tap 1 Room 305	MSA065	Monday, May 25, 2020	0.006	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Girls Wash Room tap 2 Room 305	MSA066	Monday, May 25, 2020	0.002	Passed	0.1500	Passed	
Rocky Lake Elementary	Girls Wash Room tap 3 Room 305	MSA067	Monday, May 25, 2020	0.001	Passed	0.0830	Passed	
Rocky Lake Elementary	Girls Wash Room tap 4 Room 305	MSA068	Monday, May 25, 2020	0.001	Passed	0.0370	Passed	
Rocky Lake Elementary	Girls Wash Room tap 5 Room 305	MSA069	Monday, May 25, 2020	0.001	Passed	0.0340	Passed	
Rocky Lake Elementary	Lounge Kitchen sink tap	MSA070	Monday, May 25, 2020	0.009	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Kitchen - Kitchen sink tap 1	MSA071	Monday, May 25, 2020	0.011	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Kitchen - Kitchen sink tap 2	MSA072	Monday, May 25, 2020	0.001	Passed	0.0320	Passed	
Rocky Lake Elementary	Kitchen - Kitchen sink tap 3	MSA073	Monday, May 25, 2020	0.001	Passed	0.0250	Passed	
Rocky Lake Elementary	Kitchen - Kitchen sink tap 4	MSA074	Monday, May 25, 2020	0.003	Passed	0.1100	Passed	
Rocky Lake Elementary	Boys Wash Room tap 1 Room 203	MSA075	Monday, May 25, 2020	0.007	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Boys Wash Room tap 2 Room 203	MSA076	Monday, May 25, 2020	0.001	Passed	0.0380	Passed	
Rocky Lake Elementary	Boys Wash Room tap 3 Room 203	MSA077	Monday, May 25, 2020	-	Passed	0.0220	Passed	



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Rocky Lake Elementary	Boys Wash Room tap 4 Room 203	MSA078	Monday, May 25, 2020	0.002	Passed	0.0210	Passed	
Rocky Lake Elementary	Staff Wash Room tap by Room 203	MSA079	Monday, May 25, 2020	0.002	Passed	0.0340	Passed	
Rocky Lake Elementary	Janitors Closet tap by Room 203	MSA080	Monday, May 25, 2020	-	Passed	0.0200	Passed	
Rocky Lake Elementary	Fountain by Room 203	MSA081	Monday, May 25, 2020	0.004	Passed	0.0660	Passed	Fountain Replacement in progress
Rocky Lake Elementary	Girls Wash Room tap 1 by Room 205	MSA082	Monday, May 25, 2020	0.029	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Girls Wash Room tap 2 by Room 205	MSA083	Monday, May 25, 2020	0.005	Passed	0.0350	Passed	
Rocky Lake Elementary	Girls Wash Room tap 3 by Room 205	MSA084	Monday, May 25, 2020	-	Passed	0.0250	Passed	
Rocky Lake Elementary	Girls Wash Room tap 4 by Room 205	MSA085	Monday, May 25, 2020	-	Passed	0.0230	Passed	
Rocky Lake Elementary	Girls Wash Room tap 5 by Room 205	MSA086	Monday, May 25, 2020	0.001	Passed	0.0240	Passed	
Rocky Lake Elementary	Class Room tap Room 205	MSA087	Monday, May 25, 2020	0.001	Passed	0.0240	Passed	
Rocky Lake Elementary	Gender Neutral Wash Room tap by elevator	MSA088	Monday, May 25, 2020	-	Passed	0.0180	Passed	
Rocky Lake Elementary	Kitchen bar sink tap	MSA089	Monday, May 25, 2020	0.006	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Kitchen triple compartment sink tap 1	MSA090	Monday, May 25, 2020	0.001	Passed	0.2000	Passed	
Rocky Lake Elementary	Kitchen triple compartment sink tap 2	MSA091	Monday, May 25, 2020	0.003	Passed	0.2700	Passed	
Rocky Lake Elementary	Kitchen triple compartment sink tap 3	MSA092	Monday, May 25, 2020	0.001	Passed	0.1500	Passed	
Rocky Lake Elementary	Cafeteria laundry tap	MSA093	Monday, May 25, 2020	0.001	Passed	0.0900	Passed	
Rocky Lake Elementary	Girls Wash Room tap 1 Room 5	MSA094	Monday, May 25, 2020	0.002	Passed	0.1100	Passed	
Rocky Lake Elementary	Girls Wash Room tap 2 Room 5	MSA095	Monday, May 25, 2020	0.002	Passed	0.1100	Passed	
Rocky Lake Elementary	Wash Room off Girls Wash Room tap Room 5	MSA096	Monday, May 25, 2020	0.730	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Wash Room tap in Office by exit	MSA097	Monday, May 25, 2020	0.004	Passed	0.0400	Passed	
Rocky Lake Elementary	Fountain in main lobby	MSA098	Monday, May 25, 2020	0.003	Passed	0.0830	Passed	Fountain Replacement in progress
Rocky Lake Elementary	Lab tap 1 Room 100	MSA099	Monday, May 25, 2020	0.020	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Lab tap 2 Room 100	MSA100	Monday, May 25, 2020	0.022	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Lab tap 1 Room 102	MSA101	Monday, May 25, 2020	0.006	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Elementary	Lab tap 2 Room 102	MSA102	Monday, May 25, 2020	0.003	Passed	0.0570	Passed	
Rocky Lake Elementary	Caretaker Room tap Room 105	MSA103	Monday, May 25, 2020	-	Passed	0.0520	Passed	
Rocky Lake Elementary	Staff Wash Room tap Room 103	MSA104	Monday, May 25, 2020	-	Passed	0.0200	Passed	
Rocky Lake Elementary	Staff Room Kitchen tap Room 103	MSA105	Monday, May 25, 2020	-	Passed	0.0200	Passed	
Rocky Lake Elementary	Boys Wash Room tap 1 in Basement	MSA106	Monday, May 25, 2020	0.005	Passed	0.1700	Passed	
Rocky Lake Elementary	Boys Wash Room tap 2 in Basement	MSA107	Monday, May 25, 2020	0.001	Passed	0.0300	Passed	
Rocky Lake Elementary	Boiler Room tap	MSQ477	Wednesday, May 27, 2020	0.000	Passed	0.0240	Passed	
Rocky Lake Elementary	Fountain in Makerspace	MSQ478	Wednesday, May 27, 2020	0.007	Exceeded	0.1900	Passed	Fountain to be remediated
Rocky Lake Elementary	Laundry Tub in Makerspace tap	MSQ479	Wednesday, May 27, 2020	0.001	Passed	0.0250	Passed	
Rocky Lake Junior High School	Learning Centre tap Room 301	MSG714	Tuesday, May 26, 2020	0.004	Passed	0.0250	Passed	
Rocky Lake Junior High School	Gender Neutral Wash Room tap Room 329	MSG715	Tuesday, May 26, 2020	0.001	Passed	0.0330	Passed	
Rocky Lake Junior High School	Sick Room tap by Room 329	MSG716	Tuesday, May 26, 2020	0.005	Passed	0.2100	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 1 by Room 301	MSG717	Tuesday, May 26, 2020	0.002	Passed	0.0460	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 2 by Room 301	MSG718	Tuesday, May 26, 2020	0.001	Passed	0.0120	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 3 by Room 301	MSG719	Tuesday, May 26, 2020	0.001	Passed	0.0100	Passed	
Rocky Lake Junior High School	Janitors Closet tap by Boys Wash Room	MSG720	Tuesday, May 26, 2020	0.001	Passed	0.0130	Passed	
Rocky Lake Junior High School	Fountain between Wash Room's	MSG721	Tuesday, May 26, 2020	0.002	Passed	0.3800	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 1 by fountain	MSG722	Tuesday, May 26, 2020	0.002	Passed	0.0670	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 2 by fountain	MSG723	Tuesday, May 26, 2020	0.001	Passed	0.0140	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 3 by fountain	MSG724	Tuesday, May 26, 2020	0.001	Passed	0.0300	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 4 by fountain	MSG725	Tuesday, May 26, 2020	0.004	Passed	0.0270	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Rocky Lake Junior High School	Staff Room Kitchen tap	MSG726	Tuesday, May 26, 2020	0.002	Passed	0.0760	Passed	
Rocky Lake Junior High School	Staff Room Mens Wash Room tap	MSG727	Tuesday, May 26, 2020	-	Passed	0.0075	Passed	
Rocky Lake Junior High School	Staff Room Female Wash Room tap 1	MSG728	Tuesday, May 26, 2020	0.094	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Staff Room Female Wash Room tap 2	MSG729	Tuesday, May 26, 2020	0.003	Passed	0.0180	Passed	
Rocky Lake Junior High School	Learning Centre Wash Room tap Room 219B	MSG730	Tuesday, May 26, 2020	-	Passed	0.0079	Passed	
Rocky Lake Junior High School	Biology Room tap 1 Room 205	MSG731	Tuesday, May 26, 2020	-	Passed	0.2000	Passed	
Rocky Lake Junior High School	Biology Room tap 2 Room 205	MSG732	Tuesday, May 26, 2020	-	Passed	0.1900	Passed	
Rocky Lake Junior High School	Biology Room tap 3 Room 205	MSG733	Tuesday, May 26, 2020	-	Passed	0.1800	Passed	
Rocky Lake Junior High School	Biology Room tap 4 Room 205	MSG734	Tuesday, May 26, 2020	0.001	Passed	0.1500	Passed	
Rocky Lake Junior High School	Biology Room tap 5 Room 205	MSG735	Tuesday, May 26, 2020	0.001	Passed	0.1100	Passed	
Rocky Lake Junior High School	Biology Room tap 6 Room 205	MSG736	Tuesday, May 26, 2020	-	Passed	0.9100	Passed	
Rocky Lake Junior High School	Class Room tap Room 205	MSG737	Tuesday, May 26, 2020	-	Passed	1.1000	Passed	
Rocky Lake Junior High School	Chemistry Lab tap 1 Room 203	MSG738	Tuesday, May 26, 2020	0.058	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Chemistry Lab tap 2 Room 203	MSG739	Tuesday, May 26, 2020	0.008	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Chemistry Lab tap 3 Room 203	MSG740	Tuesday, May 26, 2020	0.063	Exceeded	0.3300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Chemistry Lab tap 4 Room 203	MSG741	Tuesday, May 26, 2020	0.023	Exceeded	0.4500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Chemistry Lab tap 1 Room 203 (prep Room)	MSG742	Tuesday, May 26, 2020	0.110	Exceeded	0.8600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Janitors Closet tap by Room 203	MSG743	Tuesday, May 26, 2020	0.001	Passed	0.0700	Passed	
Rocky Lake Junior High School	Chemistry Lab tap 1 Room 202	MSG744	Tuesday, May 26, 2020	0.011	Exceeded	0.0710	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Chemistry Lab tap 2 Room 202	MSG745	Tuesday, May 26, 2020	0.007	Exceeded	0.0970	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Chemistry Lab tap 1 Room 201	MSG746	Tuesday, May 26, 2020	0.120	Exceeded	0.8700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Chemistry Lab tap 2 Room 201	MSG747	Tuesday, May 26, 2020	0.004	Passed	0.0550	Passed	
Rocky Lake Junior High School	Chemistry Lab tap 3 Room 201	MSG748	Tuesday, May 26, 2020	0.004	Passed	0.1300	Passed	
Rocky Lake Junior High School	Chemistry Lab tap 4 Room 201	MSG749	Tuesday, May 26, 2020	0.004	Passed	0.0530	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 1 connected to Gym	MSG750	Tuesday, May 26, 2020	0.002	Passed	0.0960	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 2 connected to Gym	MSG751	Tuesday, May 26, 2020	0.001	Passed	0.0510	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 3 connected to Gym	MSG752	Tuesday, May 26, 2020	0.003	Passed	0.1900	Passed	
Rocky Lake Junior High School	Fountain between Wash Room's	MSG753	Tuesday, May 26, 2020	0.002	Passed	0.5000	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 1 connected to Gym	MSG754	Tuesday, May 26, 2020	0.008	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Girls Wash Room tap 2 connected to Gym	MSG755	Tuesday, May 26, 2020	0.013	Exceeded	0.0240	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Girls Wash Room tap 3 connected to Gym	MSG756	Tuesday, May 26, 2020	0.002	Passed	0.0096	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 4 connected to Gym	MSG757	Tuesday, May 26, 2020	0.001	Passed	0.0069	Passed	
Rocky Lake Junior High School	Phys. Ed Office 1 tap in Gym	MSG758	Tuesday, May 26, 2020	0.028	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Phys. Ed Office 2 tap in Gym	MSG759	Tuesday, May 26, 2020	0.011	Exceeded	0.5400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Main Office Staff Wash Room tap	MSG760	Tuesday, May 26, 2020	0.001	Passed	0.0300	Passed	
Rocky Lake Junior High School	Vice Principal Room tap	MSG761	Tuesday, May 26, 2020	0.003	Passed	0.0560	Passed	
Rocky Lake Junior High School	Staff photocopy Room tap	MSG762	Tuesday, May 26, 2020	0.052	Exceeded	0.3600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Cafeteria hand washing sink tap	NMO585	Wednesday, August 26, 2020	0.001	Passed	0.0090	Passed	
Rocky Lake Junior High School	Cafeteria bar sink tap	MSG764	Tuesday, May 26, 2020	-	Passed	0.0220	Passed	
Rocky Lake Junior High School	Cafeteria triple sink tap 1	MSG765	Tuesday, May 26, 2020	-	Passed	0.0370	Passed	
Rocky Lake Junior High School	Cafeteria triple sink tap 2	MSG766	Tuesday, May 26, 2020	-	Passed	0.0180	Passed	
Rocky Lake Junior High School	Cafeteria Janitors Closet tap	MSG767	Tuesday, May 26, 2020	0.012	Exceeded	0.4200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Fountain by cafeteria	NMO584	Wednesday, August 26, 2020	0.001	Passed	0.4600	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 1 by cafeteria	MSG769	Tuesday, May 26, 2020	0.007	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Girls Wash Room tap 2 by cafeteria	MSG770	Tuesday, May 26, 2020	0.001	Passed	0.0160	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Rocky Lake Junior High School	Girls Wash Room tap 3 by cafeteria	MSG771	Tuesday, May 26, 2020	0.001	Passed	0.0110	Passed	
Rocky Lake Junior High School	Girls Wash Room tap 4 by cafeteria	MSG772	Tuesday, May 26, 2020	0.001	Passed	0.0110	Passed	
Rocky Lake Junior High School	Gender Neutral Wash Room tap by Girls Wash Room	MSG773	Tuesday, May 26, 2020	0.001	Passed	0.3100	Passed	
Rocky Lake Junior High School	Janitors Closet tap by Boys Wash Room	MTA205	Thursday, May 28, 2020	0.001	Passed	0.0340	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 1 by Room 103	MTA206	Thursday, May 28, 2020	-	Passed	0.0200	Passed	
Rocky Lake Junior High School	Boys Wash Room tap 2 by Room 103	MTA207	Thursday, May 28, 2020	0.010	Exceeded	0.0440	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Boys Wash Room tap 3 by Room 103	MTA208	Thursday, May 28, 2020	0.001	Passed	0.0170	Passed	
Rocky Lake Junior High School	Class Room tap Room 103	MTA209	Thursday, May 28, 2020	-	Passed	0.0110	Passed	
Rocky Lake Junior High School	Boiler Room tap	MTA210	Thursday, May 28, 2020	-	Passed	0.0200	Passed	
Rocky Lake Junior High School	Janitors Closet tap Room 106	MTA211	Thursday, May 28, 2020	0.014	Exceeded	0.6600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Rocky Lake Junior High School	Triple compartment sink tap 1 Room 105	MTA212	Thursday, May 28, 2020	0.006	Exceeded	0.2800	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Rocky Lake Junior High School	Triple compartment sink tap 2 Room 105	MTA213	Thursday, May 28, 2020	0.001	Passed	0.2200	Passed	
Rocky Lake Junior High School	Class Room tap Room 104	MTA214	Thursday, May 28, 2020	-	Passed	0.9000	Passed	
Ross Road School	Staff Room Wash Room tap Room 111	MXZ638	Monday, June 22, 2020	-	Passed	0.0260	Passed	
Ross Road School	Girls Wash Room tap 1 by Room 111	MXZ639	Monday, June 22, 2020	0.003	Passed	0.1200	Passed	
Ross Road School	Girls Wash Room tap 2 by Room 111	MXZ640	Monday, June 22, 2020	0.001	Passed	0.0280	Passed	
Ross Road School	Boys Wash Room tap 1 by Room 111	MXZ641	Monday, June 22, 2020	0.005	Exceeded	0.0480	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Boys Wash Room tap 2 by Room 111	MXZ642	Monday, June 22, 2020	0.004	Passed	0.2400	Passed	
Ross Road School	Gender Neutral Wash Room tap by Room 107	MXZ643	Monday, June 22, 2020	0.003	Passed	0.1800	Passed	
Ross Road School	Janitors Closet tap by Room 108	MXZ644	Monday, June 22, 2020	0.001	Passed	0.2000	Passed	
Ross Road School	Girls Wash Room tap 1 near Room 111	MXZ645	Monday, June 22, 2020	0.003	Passed	0.2200	Passed	
Ross Road School	Girls Wash Room tap 2 near Room 111	MXZ646	Monday, June 22, 2020	0.002	Passed	0.2100	Passed	
Ross Road School	Girls Wash Room tap 3 near Room 111	MXZ647	Monday, June 22, 2020	0.003	Passed	0.2000	Passed	
Ross Road School	Janitors Closet tap by Boys Wash Room	MXZ648	Monday, June 22, 2020	0.001	Passed	0.0260	Passed	
Ross Road School	1st Floor Boys Wash Room tap 1 near Room 120	MXZ649	Monday, June 22, 2020	0.001	Passed	0.2400	Passed	
Ross Road School	1st Floor Boys Wash Room tap 2 near Room 120	MXZ650	Monday, June 22, 2020	0.003	Passed	0.1800	Passed	
Ross Road School	1st Floor Boys Wash Room tap 3 near Room 120	MXZ651	Monday, June 22, 2020	0.001	Passed	0.0470	Passed	
Ross Road School	Fountain by Boys Wash Room	MXZ652	Monday, June 22, 2020	-	Passed	0.9300	Passed	
Ross Road School	Family Studies tap 1 Room 120	MXZ653	Monday, June 22, 2020	0.002	Passed	0.4200	Passed	
Ross Road School	Family Studies tap 2 Room 120	MXZ654	Monday, June 22, 2020	0.003	Passed	0.2800	Passed	
Ross Road School	Family Studies tap 3 Room 120	MXZ655	Monday, June 22, 2020	0.004	Passed	0.5900	Passed	
Ross Road School	Family Studies tap 4 Room 120	MXZ656	Monday, June 22, 2020	0.002	Passed	0.1100	Passed	
Ross Road School	Family Studies tap 5 Room 120	NMD621	Thursday, August 27, 2020	0.001	Passed	0.0270	Passed	
Ross Road School	Class Room tap Room 128	MXZ658	Monday, June 22, 2020	0.085	Exceeded	0.8900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Janitors Closet tap Room 135	MXZ659	Monday, June 22, 2020	0.001	Passed	0.0560	Passed	
Ross Road School	Fountain by Room 135	MXZ660	Monday, June 22, 2020	0.012	Exceeded	1.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Tech Ed. Room tap	MXZ661	Monday, June 22, 2020	0.001	Passed	0.3300	Passed	
Ross Road School	Gym Area tap Room 138	MXZ662	Monday, June 22, 2020	0.008	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Boys Locker Room tap Room 140	MXZ663	Monday, June 22, 2020	0.009	Exceeded	0.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Girls Locker Room tap Room 141	MXZ664	Monday, June 22, 2020	0.001	Passed	0.9300	Passed	
Ross Road School	Gym Office tap Room 139	MXZ665	Monday, June 22, 2020	0.001	Passed	0.1200	Passed	
Ross Road School	Class Room tap Room 134	MXZ666	Monday, June 22, 2020	0.001	Passed	0.1400	Passed	
Ross Road School	Class Room tap Room 133	MXZ667	Monday, June 22, 2020	0.002	Passed	0.1300	Passed	
Ross Road School	Cafeteria/Kitchen tap 1	MXZ668	Monday, June 22, 2020	0.004	Passed	0.3700	Passed	
Ross Road School	Cafeteria/Kitchen tap 2	MXZ669	Monday, June 22, 2020	0.003	Passed	0.4300	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Ross Road School	Cafeteria/Kitchen tap 3	NMD623	Thursday, August 27, 2020	0.000	Passed	0.0650	Passed	
Ross Road School	Cafeteria/Kitchen tap 4	NMD624	Thursday, August 27, 2020	0.004	Passed	0.0890	Passed	
Ross Road School	Staff Room tap Room 216	MXZ672	Monday, June 22, 2020	0.003	Passed	0.1600	Passed	
Ross Road School	Gender Neutral Wash Room tap Room 217	MXZ673	Monday, June 22, 2020	0.002	Passed	0.0870	Passed	
Ross Road School	Girls Wash Room tap 1 by Room 217	MXZ674	Monday, June 22, 2020	0.004	Passed	0.1800	Passed	
Ross Road School	Girls Wash Room tap 2 by Room 217	MXZ675	Monday, June 22, 2020	0.005	Passed	0.1600	Passed	
Ross Road School	Girls Wash Room tap 3 by Room 217	MXZ676	Monday, June 22, 2020	0.005	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Janitors Closet tap Room 214	MXZ677	Monday, June 22, 2020	0.001	Passed	0.0500	Passed	
Ross Road School	Fountain by Room 214	MXZ678	Monday, June 22, 2020	0.004	Passed	0.6300	Passed	
Ross Road School	Boys Wash Room tap 1 by Room 214	MXZ679	Monday, June 22, 2020	0.007	Exceeded	0.4400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Boys Wash Room tap 2 by Room 214	MXZ680	Monday, June 22, 2020	0.013	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Ross Road School	Boys Wash Room tap 3 by Room 214	MXZ681	Monday, June 22, 2020	0.005	Passed	0.1500	Passed	
Sackville Heights Junior High School	Room 106 tap	NND050	Tuesday, September 1, 2020	0.000	Passed	0.0140	Passed	
Sackville Heights Elementary School	Boys Locker Room tap in Gym	MYH123	Tuesday, June 23, 2020	-	Passed	0.0240	Passed	
Sackville Heights Elementary School	Girls Locker Room tap in Gym	MYH124	Tuesday, June 23, 2020	0.001	Passed	0.4200	Passed	
Sackville Heights Elementary School	Gym Office Wash Room tap	MYH125	Tuesday, June 23, 2020	-	Passed	0.0470	Passed	
Sackville Heights Elementary School	Kitchen/Cafeteria tap 1 Room 1066	NXK290	Thursday, October 15, 2020	0.007	Exceeded	0.7300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville Heights Elementary School	Kitchen/Cafeteria tap 2 Room 1066	MYH127	Tuesday, June 23, 2020	0.001	Passed	0.2600	Passed	
Sackville Heights Elementary School	Kitchen/Cafeteria tap 3 Room 1066	MYH128	Tuesday, June 23, 2020	0.001	Passed	0.0580	Passed	
Sackville Heights Elementary School	Janitors Closet tap Room 1059	MYH129	Tuesday, June 23, 2020	-	Passed	0.0400	Passed	
Sackville Heights Elementary School	Music Room tap by Room 1059	MYH130	Tuesday, June 23, 2020	-	Passed	0.1600	Passed	
Sackville Heights Elementary School	Art Room tap Room 1063	MYH131	Tuesday, June 23, 2020	-	Passed	0.3900	Passed	
Sackville Heights Elementary School	Recycle Room tap Room 1055	MYH132	Tuesday, June 23, 2020	-	Passed	0.0600	Passed	
Sackville Heights Elementary School	Class Room tap Room 1036	MYH133	Tuesday, June 23, 2020	-	Passed	0.6100	Passed	
Sackville Heights Elementary School	Class Room tap Room 1037	MYH134	Tuesday, June 23, 2020	0.001	Passed	0.1200	Passed	
Sackville Heights Elementary School	Class Room tap Room 1038	MYH135	Tuesday, June 23, 2020	0.001	Passed	0.1400	Passed	
Sackville Heights Elementary School	Class Room tap Room 1039	MYH136	Tuesday, June 23, 2020	0.001	Passed	0.2100	Passed	
Sackville Heights Elementary School	Gender Neutral Wash Room tap Room 1041	MYH137	Tuesday, June 23, 2020	0.001	Passed	0.1600	Passed	
Sackville Heights Elementary School	Class Room tap Room 1025	MYH138	Tuesday, June 23, 2020	0.001	Passed	0.1100	Passed	
Sackville Heights Elementary School	Class Room tap Room 1026	MYH139	Tuesday, June 23, 2020	-	Passed	0.0520	Passed	
Sackville Heights Elementary School	Gender Neutral Wash Room tap Room 1031	MYH140	Tuesday, June 23, 2020	0.001	Passed	0.0890	Passed	
Sackville Heights Elementary School	Class Room tap Room 1027	MYH141	Tuesday, June 23, 2020	-	Passed	0.0420	Passed	
Sackville Heights Elementary School	Class Room tap Room 1028	MYH142	Tuesday, June 23, 2020	-	Passed	0.0640	Passed	
Sackville Heights Elementary School	Gender Neutral Wash Room tap Room 1022	MYH143	Tuesday, June 23, 2020	-	Passed	0.0440	Passed	
Sackville Heights Elementary School	Main Office sick Room tap Room 1021	MYH144	Tuesday, June 23, 2020	-	Passed	0.0860	Passed	
Sackville Heights Elementary School	Main Office Wash Room tap Room 1018	MYH145	Tuesday, June 23, 2020	-	Passed	0.0410	Passed	
Sackville Heights Elementary School	Fountain by Room 1050	PUQ465	Wednesday, June 9, 2021	-	Passed	0.003	Passed	Fountain replaced
Sackville Heights Elementary School	Girls Wash Room tap 1 Room 1050	MYH147	Tuesday, June 23, 2020	0.001	Passed	0.3200	Passed	
Sackville Heights Elementary School	Girls Wash Room tap 2 Room 1050	MYH148	Tuesday, June 23, 2020	0.002	Passed	0.1800	Passed	
Sackville Heights Elementary School	Girls Wash Room tap 3 Room 1050	MYH149	Tuesday, June 23, 2020	0.002	Passed	0.1700	Passed	
Sackville Heights Elementary School	Boys Wash Room tap 1 Room 1049	MYH150	Tuesday, June 23, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Elementary School	Boys Wash Room tap 2 Room 1049	NXK291	Thursday, October 15, 2020	-	Passed	0.0640	Passed	Remediation has been completed
Sackville Heights Elementary School	Boys Wash Room tap 3 Room 1049	MYH152	Tuesday, June 23, 2020	0.001	Passed	0.1700	Passed	
Sackville Heights Elementary School	Fountain by Room 1049	PUQ466	Wednesday, June 9, 2021	-	Passed	0.0400	Passed	Fountain replaced
Sackville Heights Elementary School	Library Storage Room tap Room 1047	MYH154	Tuesday, June 23, 2020	0.004	Passed	0.2400	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sackville Heights Elementary School	Girls Wash Room tap 1 Room 1046	MYH155	Tuesday, June 23, 2020	0.002	Passed	0.2000	Passed	
Sackville Heights Elementary School	Girls Wash Room tap 2 Room 1046	MYH156	Tuesday, June 23, 2020	0.001	Passed	0.1500	Passed	
Sackville Heights Elementary School	Boys Wash Room tap 1 Room 1045	MYH157	Tuesday, June 23, 2020	0.002	Passed	0.1800	Passed	
Sackville Heights Elementary School	Boys Wash Room tap 2 Room 1045	MYH158	Tuesday, June 23, 2020	0.003	Passed	0.3200	Passed	
Sackville Heights Elementary School	Fountain by Room 1045	PUQ467	Wednesday, June 9, 2021	-	Passed	0.0250	Passed	Fountain replaced
Sackville Heights Elementary School	Class Room tap Room 2030	MYH160	Tuesday, June 23, 2020	-	Passed	0.3600	Passed	
Sackville Heights Elementary School	Class Room tap Room 2031	MYH161	Tuesday, June 23, 2020	-	Passed	0.2400	Passed	
Sackville Heights Elementary School	Class Room tap Room 2032	MYH162	Tuesday, June 23, 2020	-	Passed	0.2400	Passed	
Sackville Heights Elementary School	Class Room tap Room 2033	MYH163	Tuesday, June 23, 2020	0.001	Passed	0.8300	Passed	
Sackville Heights Elementary School	Class Room tap Room 2017	MYH164	Tuesday, June 23, 2020	0.001	Passed	0.0850	Passed	
Sackville Heights Elementary School	Class Room tap Room 2018	MYH165	Tuesday, June 23, 2020	0.001	Passed	0.2100	Passed	
Sackville Heights Elementary School	Class Room tap Room 2019	MYH166	Tuesday, June 23, 2020	0.001	Passed	0.1200	Passed	
Sackville Heights Elementary School	Class Room tap Room 2020	MYH167	Tuesday, June 23, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Elementary School	Staff Room Wash Room 1 tap Room 2009	MYH168	Tuesday, June 23, 2020	0.001	Passed	0.0820	Passed	
Sackville Heights Elementary School	Staff Room Wash Room 2 tap Room 2008	MYH169	Tuesday, June 23, 2020	-	Passed	0.0510	Passed	
Sackville Heights Elementary School	Staff Room Kitchen tap Room 2007	MYH170	Tuesday, June 23, 2020	0.001	Passed	0.1000	Passed	
Sackville Heights Elementary School	Janitors Closet tap Room 2040	MYH171	Tuesday, June 23, 2020	-	Passed	0.0740	Passed	
Sackville Heights Elementary School	Fountain by Room 2017	PUQ468	Wednesday, June 9, 2021	-	Passed	0.0200	Passed	Fountain replaced
Sackville Heights Elementary School	Girls Wash Room tap 1 Room 2025	MYH173	Tuesday, June 23, 2020	0.001	Passed	0.2000	Passed	
Sackville Heights Elementary School	Girls Wash Room tap 2 Room 2025	MYH174	Tuesday, June 23, 2020	0.001	Passed	0.1800	Passed	
Sackville Heights Elementary School	Girls Wash Room tap 3 Room 2025	MYH175	Tuesday, June 23, 2020	0.002	Passed	0.2000	Passed	
Sackville Heights Elementary School	Boys Wash Room tap 1 Room 2026	MYH176	Tuesday, June 23, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Elementary School	Boys Wash Room tap 2 Room 2026	MYH177	Tuesday, June 23, 2020	0.002	Passed	0.2100	Passed	
Sackville Heights Elementary School	Boys Wash Room tap 3 Room 2026	MYH178	Tuesday, June 23, 2020	0.001	Passed	0.0810	Passed	
Sackville Heights Elementary School	Fountain by Room 2026	MYH179	Tuesday, June 23, 2020	-	Passed	0.0510	Passed	Fountain Replacement in progress
Sackville Heights Junior High School	Laundry Tub tap Room 243	MTV818	Monday, June 1, 2020	-	Passed	0.1200	Passed	
Sackville Heights Junior High School	Art Room tap 1 Room 235	MTV819	Monday, June 1, 2020	0.001	Passed	0.3200	Passed	
Sackville Heights Junior High School	Art Room tap 2 Room 235	MTV820	Monday, June 1, 2020	0.001	Passed	0.2400	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 1 by Room 230	MTV821	Monday, June 1, 2020	0.053	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville Heights Junior High School	Girls Wash Room tap 2 by Room 230	MTV822	Monday, June 1, 2020	0.003	Passed	0.5000	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 3 by Room 230	MTV823	Monday, June 1, 2020	-	Passed	0.1600	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 4 by Room 230	MTV824	Monday, June 1, 2020	-	Passed	0.1300	Passed	
Sackville Heights Junior High School	Janitors Closet tap by Girls Wash Room	MTV825	Monday, June 1, 2020	-	Passed	0.0430	Passed	
Sackville Heights Junior High School	Fountain between Wash Rooms	PUQ460	Wednesday, June 9, 2021	-	Passed	0.3400	Passed	Fountain replaced
Sackville Heights Junior High School	Boys Wash Room tap 1 by Telecom 3	MTV827	Monday, June 1, 2020	-	Passed	0.2900	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Telecom 3	MTV833	Monday, June 1, 2020	0.001	Passed	0.2100	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 3 by Telecom 3	MTV834	Monday, June 1, 2020	-	Passed	0.2300	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 4 by Telecom 3	MTV835	Monday, June 1, 2020	-	Passed	0.1800	Passed	
Sackville Heights Junior High School	Science Room tap 1 by Boys Wash Room	MTV836	Monday, June 1, 2020	0.001	Passed	0.1300	Passed	
Sackville Heights Junior High School	Science Room tap 2 by Boys Wash Room	MTV837	Monday, June 1, 2020	0.001	Passed	0.2000	Passed	
Sackville Heights Junior High School	Family Studies tap 1 Room 222	MTV838	Monday, June 1, 2020	-	Passed	0.1500	Passed	
Sackville Heights Junior High School	Family Studies tap 2 Room 222	MTV839	Monday, June 1, 2020	-	Passed	0.0810	Passed	
Sackville Heights Junior High School	Family Studies tap 3 Room 222	MTV840	Monday, June 1, 2020	-	Passed	0.0730	Passed	
Sackville Heights Junior High School	Family Studies tap 4 Room 222	MTV841	Monday, June 1, 2020	-	Passed	0.0450	Passed	
Sackville Heights Junior High School	Gender Neutral Wash Room tap Room 214C	MTV842	Monday, June 1, 2020	-	Passed	0.2200	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sackville Heights Junior High School	Gender Neutral Wash Room tap Room 216	MTV859	Monday, June 1, 2020	-	Passed	0.0390	Passed	
Sackville Heights Junior High School	Class Room tap Room 214C	MTV860	Monday, June 1, 2020	-	Passed	0.1300	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 1 by Room 207A	MTV861	Monday, June 1, 2020	0.008	Exceeded	0.6300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville Heights Junior High School	Girls Wash Room tap 2 by Room 207A	MTV862	Monday, June 1, 2020	0.004	Passed	0.2700	Passed	
Sackville Heights Junior High School	Fountain by Girls Wash Room	MTV863	Monday, June 1, 2020	-	Passed	0.8900	Passed	
Sackville Heights Junior High School	Janitors Closet tap between Wash Rooms	MTV864	Monday, June 1, 2020	0.001	Passed	0.0590	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 1 by Room 203	MTV865	Monday, June 1, 2020	-	Passed	0.1400	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Room 203	MTV866	Monday, June 1, 2020	-	Passed	0.0810	Passed	
Sackville Heights Junior High School	Laundry tub tap Room 248	MTV867	Monday, June 1, 2020	0.002	Passed	0.1000	Passed	
Sackville Heights Junior High School	Cafeteria single compartment sink tap	MTV868	Monday, June 1, 2020	0.001	Passed	0.5200	Passed	
Sackville Heights Junior High School	Cafeteria double compartment sink tap	MTV869	Monday, June 1, 2020	-	Passed	0.0480	Passed	
Sackville Heights Junior High School	Cafeteria eye washing sink tap	MTV870	Monday, June 1, 2020	-	Passed	0.0930	Passed	
Sackville Heights Junior High School	Cafeteria hand washing sink tap	MTV871	Monday, June 1, 2020	-	Passed	0.2100	Passed	
Sackville Heights Junior High School	Music Room tap Room 161	MTV872	Monday, June 1, 2020	-	Passed	0.4400	Passed	
Sackville Heights Junior High School	Janitors Closet tap Room 154	MTV873	Monday, June 1, 2020	-	Passed	0.2100	Passed	
Sackville Heights Junior High School	Class Room tap Room 141	MTV874	Monday, June 1, 2020	0.024	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville Heights Junior High School	Girls Wash Room tap 1 by Room 151	MTV875	Monday, June 1, 2020	0.004	Passed	0.1600	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 2 by Room 151	MTV876	Monday, June 1, 2020	-	Passed	0.2300	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 3 by Room 151	MTV877	Monday, June 1, 2020	-	Passed	0.1600	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 4 by Room 151	MTV878	Monday, June 1, 2020	-	Passed	0.1400	Passed	
Sackville Heights Junior High School	Staff Wash Room tap in Girls Wash Room 139	MTV886	Monday, June 1, 2020	-	Passed	0.0590	Passed	
Sackville Heights Junior High School	Fountain by Room 135	PUQ462	Wednesday, June 9, 2021	0.004	Passed	0.3500	Passed	Fountain replaced
Sackville Heights Junior High School	Janitors Closet tap Room 135	MTV888	Monday, June 1, 2020	-	Passed	0.0230	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 1 by Room 135	MTV889	Monday, June 1, 2020	0.001	Passed	0.1600	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Room 135	MTV890	Monday, June 1, 2020	-	Passed	0.2200	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 3 by Room 135	MTV891	Monday, June 1, 2020	-	Passed	0.1500	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 4 by Room 135	MTV892	Monday, June 1, 2020	0.001	Passed	0.2400	Passed	
Sackville Heights Junior High School	Gender Neutral Wash Room tap Room 131B in Room 131	MTV893	Monday, June 1, 2020	-	Passed	0.3600	Passed	
Sackville Heights Junior High School	Kitchen tap Room 132B	MTV894	Monday, June 1, 2020	-	Passed	0.0550	Passed	
Sackville Heights Junior High School	Sick Room Gender Neutral Wash Room tap Room 133	MTV895	Monday, June 1, 2020	-	Passed	0.2700	Passed	
Sackville Heights Junior High School	Main Office Gender Neutral Wash Room tap Room 134	MTV910	Monday, June 1, 2020	-	Passed	0.2100	Passed	
Sackville Heights Junior High School	Main Office Gender Neutral Wash Room tap Room 135	MTV911	Monday, June 1, 2020	-	Passed	0.2700	Passed	
Sackville Heights Junior High School	Wood working Room tap Room 111	MTV912	Monday, June 1, 2020	0.001	Passed	0.2900	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 1 by Wood shop	MTV913	Monday, June 1, 2020	-	Passed	0.1000	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 2 by Wood shop	MTV914	Monday, June 1, 2020	-	Passed	0.0810	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 3 by Wood shop	MTV915	Monday, June 1, 2020	0.002	Passed	0.0830	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 4 by Wood shop	MTV916	Monday, June 1, 2020	0.001	Passed	0.0930	Passed	
Sackville Heights Junior High School	Girls Wash Room tap 5 by Wood shop	MTV917	Monday, June 1, 2020	-	Passed	0.0760	Passed	
Sackville Heights Junior High School	Janitors Closet tap Room 107	MUD544	Tuesday, June 2, 2020	0.001	Passed	0.0560	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 1 by Room 103	MUD545	Tuesday, June 2, 2020	-	Passed	0.1900	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 2 by Room 103	MUD546	Tuesday, June 2, 2020	0.002	Passed	0.2100	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 3 by Room 103	MUD547	Tuesday, June 2, 2020	-	Passed	0.1700	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 4 by Room 103	MUD548	Tuesday, June 2, 2020	-	Passed	0.1700	Passed	
Sackville Heights Junior High School	Boys Wash Room tap 5 by Room 103	MUD549	Tuesday, June 2, 2020	-	Passed	0.1200	Passed	
Sackville Heights Junior High School	Girls Locker Room tap 1 in Gym	MUD550	Tuesday, June 2, 2020	0.001	Passed	0.2200	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sackville Heights Junior High School	Girls Locker Room tap 2 in Gym	MUD551	Tuesday, June 2, 2020	0.001	Passed	0.4500	Passed	
Sackville Heights Junior High School	Boys Locker Room tap 1 in Gym	MUD552	Tuesday, June 2, 2020	0.001	Passed	0.1500	Passed	
Sackville Heights Junior High School	Boys Locker Room tap 2 in Gym	MUD553	Tuesday, June 2, 2020	-	Passed	0.1200	Passed	
Sackville Heights Junior High School	Gym Office Wash Room tap Room 170A	MUD554	Tuesday, June 2, 2020	-	Passed	0.4000	Passed	
Sackville Heights Junior High School	Fountain by Boys Wash Room	PUQ463	Wednesday, June 9, 2021	-	Passed	0.2000	Passed	Fountain replaced
Sackville Heights Junior High School	Fountain by Gym	MUD556	Tuesday, June 2, 2020	0.001	Passed	0.3100	Passed	
Sackville High School	Chem Lab tap 1 Room 304	MSP782	Wednesday, May 27, 2020	0.006	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 2 Room 304	MSP783	Wednesday, May 27, 2020	0.009	Exceeded	0.6800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 3 Room 304	MSP784	Wednesday, May 27, 2020	0.005	Exceeded	0.6700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 4 Room 304	MSP785	Wednesday, May 27, 2020	0.007	Exceeded	0.7000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 5 Room 304	MSP786	Wednesday, May 27, 2020	0.004	Passed	0.6100	Passed	
Sackville High School	Chem Storage Room tap Room 305	MSP787	Wednesday, May 27, 2020	0.008	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Storage Room tap Room 306	MSP788	Wednesday, May 27, 2020	0.006	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 1 Room 307	MSP789	Wednesday, May 27, 2020	0.013	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 2 Room 307	MSP790	Wednesday, May 27, 2020	0.026	Exceeded	0.4900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 3 Room 307	MSP791	Wednesday, May 27, 2020	0.005	Passed	0.8900	Passed	
Sackville High School	Chem Lab tap 4 Room 307	MSP870	Wednesday, May 27, 2020	0.006	Exceeded	0.7300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Chem Lab tap 5 Room 307	MSP871	Wednesday, May 27, 2020	0.004	Passed	0.2300	Passed	
Sackville High School	Physics Lab tap 1 Room 309	MSP872	Wednesday, May 27, 2020	0.007	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Physics Lab tap 2 Room 309	MSP873	Wednesday, May 27, 2020	0.045	Exceeded	0.8600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Class Room tap Room 310	MSP874	Wednesday, May 27, 2020	0.007	Exceeded	0.4500	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Sackville High School	Class Room tap Room 311	MSP875	Wednesday, May 27, 2020	0.086	Exceeded	1.5000	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Sackville High School	Class Room tap 1 Room 312	MSP876	Wednesday, May 27, 2020	0.021	Exceeded	0.7600	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Sackville High School	Class Room tap 2 Room 312	MSP877	Wednesday, May 27, 2020	0.005	Passed	0.5800	Passed	
Sackville High School	Class Room tap 3 Room 312	MSP878	Wednesday, May 27, 2020	0.009	Exceeded	0.1500	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Sackville High School	Class Room tap 1 Room 313	MSP879	Wednesday, May 27, 2020	0.003	Passed	0.2600	Passed	
Sackville High School	Class Room tap 2 Room 313	MSP880	Wednesday, May 27, 2020	0.010	Exceeded	0.9700	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Sackville High School	Class Room tap Room 321	MSP881	Wednesday, May 27, 2020	0.004	Passed	0.8600	Passed	
Sackville High School	Class Room tap Room 325	MSP882	Wednesday, May 27, 2020	0.004	Passed	0.1200	Passed	
Sackville High School	Storage Room tap Room 325	MSP883	Wednesday, May 27, 2020	0.021	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Gender Neutral Wash Room tap 1 by Room 325	MSP884	Wednesday, May 27, 2020	0.002	Passed	0.2800	Passed	
Sackville High School	Gender Neutral Wash Room tap 2 by Room 325	MSP885	Wednesday, May 27, 2020	0.002	Passed	0.3600	Passed	
Sackville High School	Gender Neutral Wash Room tap 3 by Room 325	MSP886	Wednesday, May 27, 2020	0.002	Passed	0.1300	Passed	
Sackville High School	Gender Neutral Wash Room tap 4 by Room 325	MSP887	Wednesday, May 27, 2020	0.001	Passed	0.0690	Passed	
Sackville High School	Electrical Room tap Room 326	MSP888	Wednesday, May 27, 2020	0.001	Passed	0.0450	Passed	
Sackville High School	Fountain by Room 326	PZC475	Tuesday, June 29, 2021	0.001	Passed	0.1000	Passed	Fountain replaced
Sackville High School	3rd Floor Janitors Closet	MSQ363	Wednesday, May 27, 2020	0.003	Passed	0.2900	Passed	
Sackville High School	Gender Neutral Wash Room tap 1 by stairs	MSQ365	Wednesday, May 27, 2020	0.002	Passed	0.3500	Passed	
Sackville High School	Gender Neutral Wash Room tap 2 by stairs	MSQ366	Wednesday, May 27, 2020	0.001	Passed	0.0520	Passed	
Sackville High School	Gender Neutral Wash Room tap 3 by stairs	MSQ367	Wednesday, May 27, 2020	0.002	Passed	0.1500	Passed	
Sackville High School	Gender Neutral Wash Room tap 4 by stairs	MSQ368	Wednesday, May 27, 2020	0.002	Passed	0.1000	Passed	
Sackville High School	Gym fountain	PZC477	Tuesday, June 29, 2021	0.002	Passed	0.0730	Passed	Fountain replaced
Sackville High School	Gym Office 1 tap	MSQ372	Wednesday, May 27, 2020	0.001	Passed	0.2500	Passed	
Sackville High School	Gym Office 2 tap	MSQ373	Wednesday, May 27, 2020	0.003	Passed	1.6000	Passed	
Sackville High School	Fountain by Room 204	MSQ374	Wednesday, May 27, 2020	0.001	Passed	0.0930	Passed	Fountain Replacement in progress

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sackville High School	Staff Room tap	MSQ375	Wednesday, May 27, 2020	0.002	Passed	0.1600	Passed	
Sackville High School	Mens Staff Wash Room tap	MSP890	Wednesday, May 27, 2020	0.002	Passed	0.0820	Passed	
Sackville High School	Womens Staff Wash Room tap	MSP891	Wednesday, May 27, 2020	0.002	Passed	0.0660	Passed	
Sackville High School	Class Room tap 1 Room 234	MSP892	Wednesday, May 27, 2020	0.004	Passed	0.4000	Passed	
Sackville High School	Class Room tap 2 Room 234	MSP893	Wednesday, May 27, 2020	0.002	Passed	0.1700	Passed	
Sackville High School	Class Room Wash Room 1 tap Room 234	MSP894	Wednesday, May 27, 2020	0.002	Passed	0.2200	Passed	
Sackville High School	Class Room Wash Room 2 tap Room 234	MSP895	Wednesday, May 27, 2020	0.001	Passed	0.1500	Passed	
Sackville High School	Staff Room tap 1 Room 238	NJH104	Tuesday, August 4, 2020	0.004	Passed	0.0460	Passed	
Sackville High School	Staff Room Wash Room tap Room 238	MSP897	Wednesday, May 27, 2020	0.006	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	2nd Floor Girls Wash Room tap 1	MSP898	Wednesday, May 27, 2020	0.001	Passed	0.0470	Passed	
Sackville High School	2nd Floor Girls Wash Room tap 2	MSP899	Wednesday, May 27, 2020	-	Passed	0.0310	Passed	
Sackville High School	2nd Floor Girls Wash Room tap 3	MSP915	Wednesday, May 27, 2020	-	Passed	0.0230	Passed	
Sackville High School	2nd Floor Girls Wash Room tap 4	MSP916	Wednesday, May 27, 2020	-	Passed	0.0170	Passed	
Sackville High School	Janitors Closet tap between Wash Rooms	MSP917	Wednesday, May 27, 2020	0.001	Passed	0.0380	Passed	
Sackville High School	Fountain between Wash Rooms	MSP918	Wednesday, May 27, 2020	-	Passed	0.5800	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 1	MSP919	Wednesday, May 27, 2020	0.001	Passed	0.0650	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 2	MSP920	Wednesday, May 27, 2020	-	Passed	0.0150	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 3	MSP921	Wednesday, May 27, 2020	0.001	Passed	0.0120	Passed	
Sackville High School	2nd Floor Boys Wash Room tap 4	MSP922	Wednesday, May 27, 2020	-	Passed	0.0120	Passed	
Sackville High School	Caretakers Office tap	MSP923	Wednesday, May 27, 2020	0.004	Passed	0.2600	Passed	
Sackville High School	Boiler Room tap	MSP924	Wednesday, May 27, 2020	-	Passed	0.0044	Passed	
Sackville High School	Boys Locker Room tap	MSP934	Wednesday, May 27, 2020	0.002	Passed	0.0960	Passed	
Sackville High School	Girls Locker Room tap	MSP935	Wednesday, May 27, 2020	0.003	Passed	0.1400	Passed	
Sackville High School	Fountain by Room 104	MTN427	Friday, May 29, 2020	0.016	Exceeded	1.4000	Passed	Fountain Replacement in progress
Sackville High School	Fountain by Cafeteria	MTN428	Friday, May 29, 2020	0.022	Exceeded	0.9400	Passed	Fountain Replacement in progress
Sackville High School	Kitchen cafeteria tap 1 (triple sink)	MTN429	Friday, May 29, 2020	0.014	Exceeded	0.1300	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Sackville High School	Kitchen cafeteria tap 2 (triple sink)	MTN430	Friday, May 29, 2020	0.001	Passed	0.1000	Passed	
Sackville High School	Kitchen cafeteria hand washing tap	MTN431	Friday, May 29, 2020	0.012	Exceeded	0.7500	Passed	Facet to be decommissioned, remediated, and retested. Other sources available
Sackville High School	Wood shop tap	MTN432	Friday, May 29, 2020	0.002	Passed	0.1400	Passed	
Sackville High School	Gender Neutral Wash Room tap between art and w	MTN433	Friday, May 29, 2020	0.001	Passed	0.1400	Passed	
Sackville High School	Art Room sink tap 1	MTN434	Friday, May 29, 2020	0.007	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Art Room sink tap 2	MTN435	Friday, May 29, 2020	0.002	Passed	0.2100	Passed	
Sackville High School	Skilled trades Room tap 1	MTN436	Friday, May 29, 2020	0.005	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Art Room tap Room 129	MTN448	Friday, May 29, 2020	0.005	Passed	0.2100	Passed	
Sackville High School	Electronic Room by cafeteria	MTN449	Friday, May 29, 2020	0.005	Passed	0.1100	Passed	
Sackville High School	Girls Wash Room tap 1 by Cafeteria	MTN450	Friday, May 29, 2020	0.059	Exceeded	0.2000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Girls Wash Room tap 2 by Cafeteria	MTN451	Friday, May 29, 2020	0.460	Exceeded	0.7500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Girls Wash Room tap 3 by Cafeteria	MTN452	Friday, May 29, 2020	0.014	Exceeded	0.2400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Girls Wash Room tap 4 by Cafeteria	MTN453	Friday, May 29, 2020	0.030	Exceeded	0.0560	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Janitors Closet tap between Wash Room's	MTN454	Friday, May 29, 2020	0.001	Passed	0.0590	Passed	
Sackville High School	Fountain by Boys Wash Room	MTN455	Friday, May 29, 2020	0.001	Passed	0.4400	Passed	Fountain Replacement in progress
Sackville High School	Boys Wash Room tap 1 by Cafeteria	MTN371	Friday, May 29, 2020	0.013	Exceeded	0.5500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sackville High School	Boys Wash Room tap 2 by Cafeteria	MTN372	Friday, May 29, 2020	0.001		0.0120	Passed	
Sackville High School	Boys Wash Room tap 3 by Cafeteria	MTN373	Friday, May 29, 2020	0.001		0.0066	Passed	
Sackville High School	Boys Wash Room tap 4 by Cafeteria	MTN374	Friday, May 29, 2020	0.001	Exceeded	0.0700	Passed	Faucet to be remediated. Signage to instruct hand washing only.



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Saint Mary's Elementary School	Staff Room tap 1	MTP607	Thursday, May 28, 2020	0.001	Passed	0.0630	Passed	
Saint Mary's Elementary School	Staff Room tap 2	MTP608	Thursday, May 28, 2020	0.004	Passed	0.1000	Passed	
Saint Mary's Elementary School	Class Room tap Room 206	MTP609	Thursday, May 28, 2020	0.004	Passed	0.0630	Passed	
Saint Mary's Elementary School	Class Room tap Room 205	MTP610	Thursday, May 28, 2020	0.033	Exceeded	0.0600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Saint Mary's Elementary School	Janitors Closet tap Room 204	MTP611	Thursday, May 28, 2020	0.001	Passed	0.0380	Passed	
Saint Mary's Elementary School	Fountain by Janitors Closet	MTP612	Thursday, May 28, 2020	-	Passed	0.0400	Passed	
Saint Mary's Elementary School	1st Floor Girls Wash Room tap 1	MTP613	Thursday, May 28, 2020	0.001	Passed	0.0840	Passed	
Saint Mary's Elementary School	1st Floor Girls Wash Room tap 2	MTP614	Thursday, May 28, 2020	-	Passed	0.0140	Passed	
Saint Mary's Elementary School	1st Floor Girls Wash Room tap 3	MTP615	Thursday, May 28, 2020	-	Passed	0.0062	Passed	
Saint Mary's Elementary School	1st Floor Girls Wash Room tap 4	MTP616	Thursday, May 28, 2020	-	Passed	0.0054	Passed	
Saint Mary's Elementary School	Staff Wash Room in Gym	MTP617	Thursday, May 28, 2020	-	Passed	0.0320	Passed	
Saint Mary's Elementary School	1st Floor Boys Wash Room tap 1	MTP618	Thursday, May 28, 2020	0.001	Passed	0.0420	Passed	
Saint Mary's Elementary School	1st Floor Boys Wash Room tap 2	MTP619	Thursday, May 28, 2020	-	Passed	0.0150	Passed	
Saint Mary's Elementary School	1st Floor Boys Wash Room tap 3	MTP620	Thursday, May 28, 2020	-	Passed	0.0056	Passed	
Saint Mary's Elementary School	Maintenance Closet tap Room 110	MTP621	Thursday, May 28, 2020	0.002	Passed	0.0580	Passed	
Sambro Elementary School	Fountain by Room 202	MRV116	Friday, May 22, 2020	0.001	Passed	0.0260	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Staff Wash Room tap	MRV117	Friday, May 22, 2020	0.003	Passed	0.7100	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Staff Kitchen tap	MRV118	Friday, May 22, 2020	0.002	Passed	0.7500	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Staff Room tap	MRV119	Friday, May 22, 2020	0.002	Passed	0.8100	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Janitors tap in Staff Room	MRV120	Friday, May 22, 2020	0.002	Passed	0.7100	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Girls Wash Room tap 1	MRV121	Friday, May 22, 2020	0.009	Exceeded	2.4000	Exceeded	Signage added to instruct handwashing only
Sambro Elementary School	Girls Wash Room tap 2	MRV122	Friday, May 22, 2020	0.010	Exceeded	2.5000	Exceeded	Signage added to instruct handwashing only
Sambro Elementary School	Girls Wash Room tap 3	MRV123	Friday, May 22, 2020	0.008	Exceeded	2.4000	Exceeded	Signage added to instruct handwashing only
Sambro Elementary School	Boys Wash Room tap 1	MRV124	Friday, May 22, 2020	0.002	Passed	1.2000	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Boys Wash Room tap 1	MRV125	Friday, May 22, 2020	0.014	Exceeded	4.7000	Exceeded	Signage added to instruct handwashing only
Sambro Elementary School	Boys Wash Room tap 2	MRV126	Friday, May 22, 2020	0.005	Exceeded	1.4000	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Boys Wash Room tap 3	MRV127	Friday, May 22, 2020	0.003	Passed	1.2000	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Fountain by Room 112	MRV128	Friday, May 22, 2020	0.001	Passed	0.1400	Passed	Signage added to instruct handwashing only
Sambro Elementary School	Class Room 110 Wash Room tap	MRV129	Friday, May 22, 2020	0.003	Passed	1.9000	Passed	Signage added to instruct handwashing only
Seaside Elementary School	3rd Floor Boys Wash Room tap 1	MYZ230	Thursday, June 25, 2020	0.004	Passed	0.2400	Passed	
Seaside Elementary School	3rd Floor Boys Wash Room tap 2	MYZ231	Thursday, June 25, 2020	0.008	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Seaside Elementary School	Janitors Closet tap by 3rd Floor Wash Rooms	MYZ232	Thursday, June 25, 2020	0.004	Passed	0.1300	Passed	
Seaside Elementary School	Fountain by 3rd Floor Wash Rooms	PXP223	Wednesday, June 23, 2021	0.001	Passed	0.0420	Passed	New Fountain
Seaside Elementary School	3rd Floor Girls Wash Room tap 1	MYZ234	Thursday, June 25, 2020	0.003	Passed	0.0840	Passed	
Seaside Elementary School	3rd Floor Girls Wash Room tap 2	MYZ235	Thursday, June 25, 2020	0.002	Passed	0.0690	Passed	
Seaside Elementary School	Staff Room tap 1 Room 308	MYZ236	Thursday, June 25, 2020	-	Passed	0.0250	Passed	
Seaside Elementary School	Staff Room tap 2 Room 308	MYZ237	Thursday, June 25, 2020	0.001	Passed	0.0340	Passed	
Seaside Elementary School	Staff Room tap 3 Room 308	MYZ238	Thursday, June 25, 2020	0.001	Passed	0.1200	Passed	
Seaside Elementary School	Cafeteria/Kitchen tap 1 (2nd Floor)	MYZ239	Thursday, June 25, 2020	0.003	Passed	0.1700	Passed	
Seaside Elementary School	Cafeteria/Kitchen tap 2 (2nd Floor)	NMV190	Monday, August 31, 2020	0.000	Passed	0.0330	Passed	
Seaside Elementary School	Cafeteria/Kitchen tap 3 (2nd Floor)	NMV191	Monday, August 31, 2020	0.001	Passed	0.0360	Passed	
Seaside Elementary School	Fountain by Kitchen	PXP224	Wednesday, June 23, 2021	0.002	Passed	0.0260	Passed	New Fountain
Seaside Elementary School	2nd Floor Boys Wash Room tap 1	MYZ291	Thursday, June 25, 2020	-	Passed	0.0079	Passed	
Seaside Elementary School	2nd Floor Boys Wash Room tap 2	MYZ292	Thursday, June 25, 2020	0.007	Exceeded	0.0580	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Seaside Elementary School	Janitors Closet tap by Girls Wash Room	MYZ293	Thursday, June 25, 2020	0.001	Passed	0.4800	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Seaside Elementary School	2nd Floor Girls Wash Room tap 1	MYZ294	Thursday, June 25, 2020	0.006	Exceeded	0.3100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Seaside Elementary School	2nd Floor Girls Wash Room tap 2	MYZ296	Thursday, June 25, 2020	0.003	Passed	0.2300	Passed	
Seaside Elementary School	Office Wash Room tap	MYZ297	Thursday, June 25, 2020	0.002	Passed	0.0770	Passed	
Seaside Elementary School	1st Floor Boys Wash Room tap 1	MYZ298	Thursday, June 25, 2020	0.004	Passed	0.0840	Passed	
Seaside Elementary School	1st Floor Boys Wash Room tap 2	MYZ320	Thursday, June 25, 2020	0.003	Passed	0.1200	Passed	
Seaside Elementary School	Fountain by Room 103	PXP234	Wednesday, June 23, 2021	0.001	Passed	0.0110	Passed	New Fountain
Seaside Elementary School	1st Floor Girls Wash Room tap 1	MYZ321	Thursday, June 25, 2020	0.007	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Seaside Elementary School	1st Floor Girls Wash Room tap 2	MYZ322	Thursday, June 25, 2020	0.006	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Wash Room tap 1 by Room 4	MYA331	Monday, June 22, 2020	0.007	Exceeded	0.0820	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Wash Room tap 2 by Room 4	MYA332	Monday, June 22, 2020	0.002	Passed	0.0220	Passed	
Shannon Park Elementary School	Girls Wash Room tap 3 by Room 4	MYA333	Monday, June 22, 2020	0.002	Passed	0.0190	Passed	
Shannon Park Elementary School	Girls Wash Room tap 4 by Room 4	MYA334	Monday, June 22, 2020	0.002	Passed	0.0190	Passed	
Shannon Park Elementary School	Gender Neutral Wash Room tap Room 3	MYA335	Monday, June 22, 2020	0.065	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Janitors Closet tap by Room 3	MYA336	Monday, June 22, 2020	-	Passed	0.0040	Passed	
Shannon Park Elementary School	Girls Wash Room tap 1 by Room 5	MYA338	Monday, June 22, 2020	0.017	Exceeded	0.0810	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Wash Room tap 2 by Room 5	MYA339	Monday, June 22, 2020	0.042	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Wash Room tap 3 by Room 5	MYA340	Monday, June 22, 2020	0.026	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Wash Room tap 1 left of Room 6	MYA341	Monday, June 22, 2020	0.040	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Wash Room tap 2 left of Room 6	MYA342	Monday, June 22, 2020	0.014	Exceeded	0.1100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Gym Locker Room tap 1	MYA343	Monday, June 22, 2020	0.006	Exceeded	0.0330	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Gym Locker Room tap 2	MYA344	Monday, June 22, 2020	0.001	Passed	0.0095	Passed	
Shannon Park Elementary School	Boys Gym Locker Room tap 3	MYA345	Monday, June 22, 2020	0.001	Passed	0.0089	Passed	
Shannon Park Elementary School	Boys Gym Locker Room tap 4	MYA346	Monday, June 22, 2020	0.001	Passed	0.0100	Passed	
Shannon Park Elementary School	Girls Gym Locker Room tap 1	MYA347	Monday, June 22, 2020	0.009	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Gym Locker Room tap 2	MYA348	Monday, June 22, 2020	0.004	Passed	0.0930	Passed	
Shannon Park Elementary School	Girls Gym Locker Room tap 3	MYA349	Monday, June 22, 2020	0.003	Passed	0.1000	Passed	
Shannon Park Elementary School	Girls Gym Locker Room tap 4	MYA350	Monday, June 22, 2020	0.004	Passed	0.0900	Passed	
Shannon Park Elementary School	Girls Wash Room tap 1 left of Room 17	MYA351	Monday, June 22, 2020	0.004	Passed	0.0280	Passed	
Shannon Park Elementary School	Girls Wash Room tap 2 left of Room 17	MYA352	Monday, June 22, 2020	0.008	Exceeded	0.0900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Wash Room tap 3 left of Room 17	MYA353	Monday, June 22, 2020	0.009	Exceeded	0.0200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Wash Room tap 1 left of Room 17	MYA354	Monday, June 22, 2020	0.001	Passed	0.0260	Passed	
Shannon Park Elementary School	Boys Wash Room tap 2 left of Room 17	MYA355	Monday, June 22, 2020	0.002	Passed	0.0400	Passed	
Shannon Park Elementary School	Boys Wash Room tap 3 left of Room 17	MYA356	Monday, June 22, 2020	0.098	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Janitors Closet tap by Room 25	MYA357	Monday, June 22, 2020	-	Passed	0.0240	Passed	
Shannon Park Elementary School	Boys Wash Room tap 1 by Room 25	MYA358	Monday, June 22, 2020	0.015	Exceeded	0.1700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Wash Room tap 2 by Room 25	MYA359	Monday, June 22, 2020	0.011	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Wash Room tap 3 by Room 25	MYA360	Monday, June 22, 2020	0.002	Passed	0.1500	Passed	
Shannon Park Elementary School	Gender Neutral Wash Room tap by Room 25	MYA361	Monday, June 22, 2020	0.004	Passed	0.0670	Passed	
Shannon Park Elementary School	Gender Neutral Wash Room tap by Room 26	MYA362	Monday, June 22, 2020	0.001	Passed	0.0760	Passed	
Shannon Park Elementary School	Girls Wash Room tap 1 left of Room 27	MYA363	Monday, June 22, 2020	0.014	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Wash Room tap 2 left of Room 27	MYA364	Monday, June 22, 2020	0.005	Passed	0.1400	Passed	
Shannon Park Elementary School	Girls Wash Room tap 3 left of Room 27	MYA365	Monday, June 22, 2020	0.004	Passed	0.0900	Passed	
Shannon Park Elementary School	Girls Wash Room tap 4 left of Room 27	MYA366	Monday, June 22, 2020	0.001	Passed	0.0270	Passed	
Shannon Park Elementary School	Class Room tap Room 27	MYA367	Monday, June 22, 2020	0.010	Exceeded	0.2500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Boys Wash Room tap 1 by Room 208	MYA368	Monday, June 22, 2020	0.020	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Shannon Park Elementary School	Boys Wash Room tap 2 by Room 208	MYA369	Monday, June 22, 2020	0.001	Passed	0.0160	Passed	
Shannon Park Elementary School	Boys Wash Room tap 3 by Room 208	MYA370	Monday, June 22, 2020	0.002	Passed	0.0340	Passed	
Shannon Park Elementary School	Janitors Closet tap by Room 208	MYA371	Monday, June 22, 2020	-	Passed	0.0170	Passed	
Shannon Park Elementary School	Gender Neutral Wash Room tap by Room 207	MYA372	Monday, June 22, 2020	0.001	Passed	0.0310	Passed	
Shannon Park Elementary School	Girls Wash Room tap 1 by Room 207	MYA373	Monday, June 22, 2020	0.009	Exceeded	0.0970	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Girls Wash Room tap 2 by Room 207	MYA374	Monday, June 22, 2020	0.002	Passed	0.0150	Passed	
Shannon Park Elementary School	Girls Wash Room tap 3 by Room 207	MYA375	Monday, June 22, 2020	0.072	Exceeded	0.6400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Caretaker Wash Room tap Room 18	MYA376	Monday, June 22, 2020	0.002	Passed	0.0520	Passed	
Shannon Park Elementary School	Janitors Closet tap by Room 18	MYA377	Monday, June 22, 2020	0.001	Passed	0.0280	Passed	
Shannon Park Elementary School	Class Room tap Room 165	MYA378	Monday, June 22, 2020	0.200	Exceeded	1.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Main Office Wash Room tap Room 12	MYA379	Monday, June 22, 2020	0.013	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Shannon Park Elementary School	Fountain by Room 4	MYH184	Tuesday, June 23, 2020	0.001	Passed	0.5100	Passed	
Shannon Park Elementary School	Fountain left of Room 10	MYH185	Tuesday, June 23, 2020	0.031	Exceeded	1.7000	Passed	Fountain to be decommissioned, remediated, and retested. Other sources available
Shannon Park Elementary School	1st Floor fountain left of Room 137	MYH186	Tuesday, June 23, 2020	-	Passed	1.6000	Passed	
Shannon Park Elementary School	Fountain left of Room 17	MYH187	Tuesday, June 23, 2020	-	Passed	0.2900	Passed	
Shannon Park Elementary School	Fountain by Room 25	MYH188	Tuesday, June 23, 2020	0.001	Passed	0.0560	Passed	
Shannon Park Elementary School	Boys Wash Room tap by Room 25	MYH189	Tuesday, June 23, 2020	0.002	Passed	0.2100	Passed	
Shannon Park Elementary School	2nd Floor fountain by Room 208	MYH190	Tuesday, June 23, 2020	0.002	Passed	0.0770	Passed	
Shatford Memorial Elementary School	1st Floor Gender Neutral Wash Room tap by Room 2	MUQ753	Thursday, June 4, 2020	0.002	Passed	0.4200	Passed	
Shatford Memorial Elementary School	Class Room tap Room 1	MUQ754	Thursday, June 4, 2020	0.001	Passed	0.1200	Passed	
Shatford Memorial Elementary School	Fountain by Room 1	QRB341	Thursday, September 16, 2021	-	Passed	0.0019	Passed	Fountain replaced
Shatford Memorial Elementary School	Staff Room Wash Room tap Room 3	MUQ756	Thursday, June 4, 2020	0.002	Passed	0.5800	Passed	
Shatford Memorial Elementary School	Staff Room tap Room 3	MUQ757	Thursday, June 4, 2020	0.001	Passed	0.5100	Passed	
Shatford Memorial Elementary School	Boys Wash Room tap 1	MUQ758	Thursday, June 4, 2020	0.003	Passed	0.0810	Passed	
Shatford Memorial Elementary School	Boys Wash Room tap 2	MUQ759	Thursday, June 4, 2020	0.001	Passed	0.0650	Passed	
Shatford Memorial Elementary School	Janitors Closet tap	MUQ760	Thursday, June 4, 2020	0.001	Passed	0.0600	Passed	
Shatford Memorial Elementary School	Fountain by Wash Rooms	QRB342	Thursday, September 16, 2021	0.005	Passed	0.0087	Passed	Fountain replaced
Shatford Memorial Elementary School	Girls Wash Room tap 1	MUQ762	Thursday, June 4, 2020	0.003	Passed	0.1300	Passed	
Shatford Memorial Elementary School	Girls Wash Room tap 2	MUQ763	Thursday, June 4, 2020	0.001	Passed	0.0710	Passed	
Shatford Memorial Elementary School	Class Room 1 Wash Room tap 1	MUQ764	Thursday, June 4, 2020	0.001	Passed	0.1500	Passed	
Shatford Memorial Elementary School	Class Room 1 Wash Room tap 2	MUQ765	Thursday, June 4, 2020	0.001	Passed	0.0790	Passed	
Shatford Memorial Elementary School	Storage Room 2 tap (wash tub)	MUQ766	Thursday, June 4, 2020	0.019	Exceeded	0.2400	Passed	Signage added to instruct handwashing only
Shatford Memorial Elementary School	Gender Neutral Wash Room 2 tap	MUQ767	Thursday, June 4, 2020	0.210	Exceeded	0.5000	Passed	Signage added to instruct handwashing only
Shatford Memorial Elementary School	Janitors Closet tap	MUQ768	Thursday, June 4, 2020	0.003	Passed	0.5100	Passed	
Shatford Memorial Elementary School	Fountain by Boys Wash Room	QRB343	Thursday, September 16, 2021	-	Exceeded	-	Passed	Fountain replaced
Shatford Memorial Elementary School	Boys Wash Room 5 tap 1	MUQ770	Thursday, June 4, 2020	0.008	Exceeded	0.5400	Passed	Signage added to instruct handwashing only
Shatford Memorial Elementary School	Boys Wash Room 5 tap 2	MUQ771	Thursday, June 4, 2020	0.002	Passed	0.5700	Passed	
Shatford Memorial Elementary School	Girls Wash Room 9 tap 1	MUQ772	Thursday, June 4, 2020	0.004	Passed	0.3600	Passed	
Shatford Memorial Elementary School	Girls Wash Room 9 tap 2	MUQ773	Thursday, June 4, 2020	0.002	Passed	0.2700	Passed	
Shatford Memorial Elementary School	1st Floor Kitchen tap	MUQ774	Thursday, June 4, 2020	0.007	Exceeded	0.0900	Passed	Signage added to instruct handwashing only
Sir Charles Tupper Elementary School	Staff Room tap 1	MTO616	Friday, May 29, 2020	-	Passed	0.0110	Passed	
Sir Charles Tupper Elementary School	Staff Room tap 2	MTO617	Friday, May 29, 2020	-	Passed	0.0100	Passed	
Sir Charles Tupper Elementary School	Staff Room tap 3	MTO618	Friday, May 29, 2020	-	Passed	0.0110	Passed	
Sir Charles Tupper Elementary School	Janitors Closet tap by Staff Room	MTO619	Friday, May 29, 2020	0.001	Passed	0.0910	Passed	
Sir Charles Tupper Elementary School	Staff Gender Neutral Wash Room tap by Boys Wash	MTO620	Friday, May 29, 2020	-	Passed	0.0200	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sir Charles Tupper Elementary School	Boys Wash Room tap 1 near Staff Room	MTO621	Friday, May 29, 2020	0.005	Passed	0.5600	Passed	
Sir Charles Tupper Elementary School	Boys Wash Room tap 2 near Staff Room	MTO622	Friday, May 29, 2020	-	Passed	0.0440	Passed	
Sir Charles Tupper Elementary School	Boys Wash Room tap 3 near Staff Room	MTO623	Friday, May 29, 2020	-	Passed	0.0340	Passed	
Sir Charles Tupper Elementary School	Boys Wash Room tap 4 near Staff Room	MTO624	Friday, May 29, 2020	-	Passed	0.0280	Passed	
Sir Charles Tupper Elementary School	Boys Wash Room tap 5 near Staff Room	MTO625	Friday, May 29, 2020	-	Passed	0.0280	Passed	
Sir Charles Tupper Elementary School	Fountain 1	MTO627	Friday, May 29, 2020	0.001	Passed	0.1100	Passed	
Sir Charles Tupper Elementary School	Fountain 2	MTO628	Friday, May 29, 2020	0.001	Passed	0.2000	Passed	
Sir Charles Tupper Elementary School	Resource Room Wash Room tap	MTO629	Friday, May 29, 2020	-	Passed	0.0600	Passed	
Sir Charles Tupper Elementary School	Principals Office Wash Room tap Room 209	MTO630	Friday, May 29, 2020	-	Passed	0.0300	Passed	
Sir Charles Tupper Elementary School	Janitors Closet tap by Office	MTO631	Friday, May 29, 2020	-	Passed	0.0220	Passed	
Sir Charles Tupper Elementary School	Fountain by Office	MTO632	Friday, May 29, 2020	0.007	Exceeded	0.4100	Passed	New Fountain to be installed. Other sources available.
Sir Charles Tupper Elementary School	Girls Wash Room tap 1 after Office	MTO633	Friday, May 29, 2020	-	Passed	0.1300	Passed	
Sir Charles Tupper Elementary School	Girls Wash Room tap 2 after Office	MTO634	Friday, May 29, 2020	0.001	Passed	0.0660	Passed	
Sir Charles Tupper Elementary School	Girls Wash Room tap 3 after Office	MTO635	Friday, May 29, 2020	-	Passed	0.0400	Passed	
Sir Charles Tupper Elementary School	Girls Wash Room tap 4 after Office	MTO636	Friday, May 29, 2020	-	Passed	0.0530	Passed	
Sir Charles Tupper Elementary School	Girls Wash Room tap 5 after Office	MTO639	Friday, May 29, 2020	-	Passed	0.1000	Passed	
Sir Charles Tupper Elementary School	Sink tap in the hallway	MTO640	Friday, May 29, 2020	0.001	Passed	0.0990	Passed	
Sir Charles Tupper Elementary School	Gender Neutral Wash Room tap Room 1	MTO641	Friday, May 29, 2020	-	Passed	0.0270	Passed	
Sir Charles Tupper Elementary School	Janitors Closet tap after Room 1	MTO642	Friday, May 29, 2020	-	Passed	0.0240	Passed	
Sir Charles Tupper Elementary School	Girls Wash Room tap 1 after Room 1	MTO643	Friday, May 29, 2020	0.001	Passed	0.0160	Passed	
Sir Charles Tupper Elementary School	Girls Wash Room tap 2 after Room 1	MTO644	Friday, May 29, 2020	0.001	Passed	0.0150	Passed	
Sir Charles Tupper Elementary School	Fountain by Girls Wash Room	MTO645	Friday, May 29, 2020	-	Passed	0.8900	Passed	
Sir Charles Tupper Elementary School	Boys Wash Room tap 1 before art Room	MTO646	Friday, May 29, 2020	-	Passed	0.0085	Passed	
Sir Charles Tupper Elementary School	Boys Wash Room tap 2 before art Room	MTO647	Friday, May 29, 2020	-	Passed	0.0067	Passed	
Sir Charles Tupper Elementary School	Art Room tap	MTO648	Friday, May 29, 2020	-	Passed	0.0400	Passed	
Sir John A. Macdonald High School	2nd Floor Fountain	MUV835	Monday, June 8, 2020	-	Passed	0.7100	Passed	
Sir John A. Macdonald High School	2nd Floor Girls Wash Room tap 1	MUV836	Monday, June 8, 2020	0.003	Passed	0.4700	Passed	
Sir John A. Macdonald High School	2nd Floor Girls Wash Room tap 2	MUV837	Monday, June 8, 2020	0.007	Exceeded	0.5600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	2nd Floor Boys Wash Room tap 1	MUV838	Monday, June 8, 2020	0.002	Passed	0.1700	Passed	
Sir John A. Macdonald High School	2nd Floor Boys Wash Room tap 2	MUV839	Monday, June 8, 2020	0.001	Passed	0.1400	Passed	
Sir John A. Macdonald High School	2nd Floor Staff Wash Room tap	MUV840	Monday, June 8, 2020	0.003	Passed	0.1300	Passed	
Sir John A. Macdonald High School	2nd Floor Janitors Closet tap	MUV841	Monday, June 8, 2020	-	Passed	0.1300	Passed	
Sir John A. Macdonald High School	Science Lab tap 1 Room 2056	MUV842	Monday, June 8, 2020	0.005	Exceeded	0.3900	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 2 Room 2056	MUV843	Monday, June 8, 2020	0.002	Passed	0.1600	Passed	
Sir John A. Macdonald High School	Science Lab tap 3 Room 2056	MUV844	Monday, June 8, 2020	0.006	Exceeded	0.1200	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 4 Room 2056	MUV845	Monday, June 8, 2020	0.007	Exceeded	0.1400	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 5 Room 2056	MUV846	Monday, June 8, 2020	0.001	Passed	0.0930	Passed	
Sir John A. Macdonald High School	Chem Lab tap 1 Room 2062	MUV847	Monday, June 8, 2020	0.001	Passed	0.2100	Passed	
Sir John A. Macdonald High School	Chem Lab tap 2 Room 2062	MUV848	Monday, June 8, 2020	0.050	Exceeded	0.2300	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 3 Room 2062	MUV849	Monday, June 8, 2020	0.001	Passed	0.2300	Passed	
Sir John A. Macdonald High School	Chem Lab tap 4 Room 2062	MUV850	Monday, June 8, 2020	0.001	Passed	0.1700	Passed	
Sir John A. Macdonald High School	Chem Lab tap 5 Room 2062	MUV851	Monday, June 8, 2020	0.007	Exceeded	0.2400	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 6 Room 2062	MUV852	Monday, June 8, 2020	0.120	Exceeded	0.7600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 7 Room 2062	MUV853	Monday, June 8, 2020	0.002	Passed	0.2100	Passed	
Sir John A. Macdonald High School	Chem Lab tap 8 Room 2062	MUV854	Monday, June 8, 2020	0.009	Exceeded	0.2600	Passed	Signage added to instruct handwashing only

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sir John A. Macdonald High School	Chem Lab tap 9 Room 2062	MUV855	Monday, June 8, 2020	0.003	Passed	0.1400	Passed	
Sir John A. Macdonald High School	Chem Lab tap 10 Room 2062	MUV856	Monday, June 8, 2020	0.025	Exceeded	0.1300	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab prep Room tap Room 2064	MUV857	Monday, June 8, 2020	0.002	Passed	0.0460	Passed	
Sir John A. Macdonald High School	Chem Lab tap 1 Room 2067	MUV858	Monday, June 8, 2020	0.007	Exceeded	0.1900	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 2 Room 2067	MUV859	Monday, June 8, 2020	0.008	Exceeded	0.1800	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 3 Room 2067	MUV860	Monday, June 8, 2020	0.005	Passed	0.2600	Passed	
Sir John A. Macdonald High School	Chem Lab tap 4 Room 2067	MUV861	Monday, June 8, 2020	0.035	Exceeded	0.5400	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 5 Room 2067	MUV862	Monday, June 8, 2020	0.010	Exceeded	0.1500	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 6 Room 2067	MUV863	Monday, June 8, 2020	0.004	Passed	0.2000	Passed	
Sir John A. Macdonald High School	Chem Lab tap 7 Room 2067	MUV864	Monday, June 8, 2020	0.001	Passed	0.4300	Passed	
Sir John A. Macdonald High School	Chem Lab tap 9 Room 2067	MUV866	Monday, June 8, 2020	0.008	Exceeded	0.1600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Biology Lab tap 1 Room 2068	MUV868	Monday, June 8, 2020	0.007	Exceeded	0.2900	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Biology Lab tap 2 Room 2068	MUV869	Monday, June 8, 2020	0.001	Passed	0.3200	Passed	
Sir John A. Macdonald High School	Biology Lab tap 3 Room 2068	MUV870	Monday, June 8, 2020	0.008	Exceeded	0.3500	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Biology Lab tap 4 Room 2068	MUV871	Monday, June 8, 2020	0.003	Passed	0.4000	Passed	
Sir John A. Macdonald High School	Biology Lab tap 5 Room 2068	MUV872	Monday, June 8, 2020	0.003	Passed	0.3000	Passed	
Sir John A. Macdonald High School	Chem Lab tap 8 Room 2067	MWG705	Friday, June 12, 2020	0.002	Passed	0.3400	Passed	
Sir John A. Macdonald High School	Chem Lab tap 10 Room 2067	MWG706	Friday, June 12, 2020	0.001	Passed	0.2600	Passed	
Sir John A. Macdonald High School	Skilled trades Room Wash Room tap	MWG707	Friday, June 12, 2020	0.001	Passed	0.2500	Passed	
Sir John A. Macdonald High School	Skilled trades Janitors tap	MWG708	Friday, June 12, 2020	0.004	Passed	0.2200	Passed	
Sir John A. Macdonald High School	Skilled trades wash sink tap	MWG709	Friday, June 12, 2020	0.002	Passed	0.3800	Passed	
Sir John A. Macdonald High School	Science Lab tap 1 Room 2066	MWH956	Friday, June 12, 2020	0.007	Exceeded	0.3100	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 2 Room 2066	MWH957	Friday, June 12, 2020	0.004	Passed	0.2300	Passed	
Sir John A. Macdonald High School	Science Lab tap 3 Room 2066	MWH958	Friday, June 12, 2020	0.007	Exceeded	0.5600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 4 Room 2066	MWH959	Friday, June 12, 2020	0.007	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir John A. Macdonald High School	Science Lab tap 3 Room 2063	MWH960	Friday, June 12, 2020	0.007	Exceeded	0.3600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 4 Room 2063	MWH961	Friday, June 12, 2020	0.005	Passed	0.5400	Passed	
Sir John A. Macdonald High School	Science Lab tap 5 Room 2063	MWH962	Friday, June 12, 2020	0.007	Exceeded	0.3400	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 1 Room 2058	MWH963	Friday, June 12, 2020	0.030	Exceeded	0.5600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 2 Room 2058	MWH964	Friday, June 12, 2020	0.016	Exceeded	0.4900	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 3 Room 2058	MWH965	Friday, June 12, 2020	0.003	Passed	0.2100	Passed	
Sir John A. Macdonald High School	Science Lab tap 4 Room 2058	MWH966	Friday, June 12, 2020	0.005	Exceeded	0.3100	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Science Lab tap 5 Room 2058	MWH967	Friday, June 12, 2020	0.006	Exceeded	0.4300	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Physics Lab tap 1 Room 2057	MWH968	Friday, June 12, 2020	0.008	Exceeded	0.1900	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Physics Lab tap 2 Room 2057	MWH969	Friday, June 12, 2020	0.002	Passed	0.1300	Passed	
Sir John A. Macdonald High School	Physics Lab tap 3 Room 2057	MWH970	Friday, June 12, 2020	0.007	Exceeded	0.4200	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Physics Lab tap 4 Room 2057	MWH971	Friday, June 12, 2020	0.009	Exceeded	0.4300	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Physics Lab tap 5 Room 2057	MWH972	Friday, June 12, 2020	0.002	Passed	0.2000	Passed	
Sir John A. Macdonald High School	Nutrition Lab tap 1 Room 2055	MWH973	Friday, June 12, 2020	-	Passed	0.1800	Passed	
Sir John A. Macdonald High School	Nutrition Lab tap 2 Room 2055	MWH974	Friday, June 12, 2020	0.001	Passed	0.1400	Passed	
Sir John A. Macdonald High School	Nutrition Lab tap 3 Room 2055	MWH975	Friday, June 12, 2020	-	Passed	0.1400	Passed	
Sir John A. Macdonald High School	Nutrition Lab tap 4 Room 2055	MWH976	Friday, June 12, 2020	-	Passed	0.1700	Passed	
Sir John A. Macdonald High School	Kitchen tap 1 Room 2045	MWH977	Friday, June 12, 2020	0.001	Passed	0.1400	Passed	
Sir John A. Macdonald High School	Kitchen tap 2 Room 2045	MWH978	Friday, June 12, 2020	0.001	Passed	0.0100	Passed	
Sir John A. Macdonald High School	Kitchen tap 3 Room 2045	MWH979	Friday, June 12, 2020	0.002	Passed	0.0230	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sir John A. Macdonald High School	Kitchen tap 4 Room 2045	MWH980	Friday, June 12, 2020	0.001	Passed	0.0130	Passed	
Sir John A. Macdonald High School	Kitchen tap 5 Room 2045	MWH981	Friday, June 12, 2020	0.002	Passed	0.6600	Passed	
Sir John A. Macdonald High School	Library tap	MWH982	Friday, June 12, 2020	-	Passed	0.4100	Passed	
Sir John A. Macdonald High School	Youth Centre Wash Room tap Room 1021	MWH983	Friday, June 12, 2020	0.002	Passed	0.1700	Passed	
Sir John A. Macdonald High School	1st Floor Male Wash Room tap 1	MWH984	Friday, June 12, 2020	0.015	Exceeded	0.3700	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	1st Floor Male Wash Room tap 2	MWH985	Friday, June 12, 2020	0.001	Passed	0.1700	Passed	
Sir John A. Macdonald High School	Staff Wash Room tap	MWH986	Friday, June 12, 2020	0.002	Passed	0.1800	Passed	
Sir John A. Macdonald High School	Janitors Closet tap by Room 1016	MWH987	Friday, June 12, 2020	0.001	Passed	0.1900	Passed	
Sir John A. Macdonald High School	Class Room tap Room 1016	MWH988	Friday, June 12, 2020	0.008	Exceeded	0.2100	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Staff Wash Room tap	MWH989	Friday, June 12, 2020	0.021	Exceeded	0.4600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	1st Floor Girls Wash Room tap 1	MWH990	Friday, June 12, 2020	-	Passed	0.2000	Passed	
Sir John A. Macdonald High School	1st Floor Girls Wash Room tap 2	MWH991	Friday, June 12, 2020	0.001	Passed	0.4100	Passed	
Sir John A. Macdonald High School	Gym Office Wash Room tap	MWH992	Friday, June 12, 2020	0.004	Passed	0.3200	Passed	
Sir John A. Macdonald High School	Fountain by Gym	NMW041	Monday, August 31, 2020	0.000	Passed	0.0700	Passed	
Sir John A. Macdonald High School	Gym Office Wash Room tap	MWH994	Friday, June 12, 2020	0.001	Passed	0.1500	Passed	
Sir John A. Macdonald High School	Girls Wash Room tap 1 by cafeteria	MWH995	Friday, June 12, 2020	0.002	Passed	0.0900	Passed	
Sir John A. Macdonald High School	Girls Wash Room tap 2 by cafeteria	MWH996	Friday, June 12, 2020	0.001	Passed	0.1500	Passed	
Sir John A. Macdonald High School	Fountain by cafeteria	MWH997	Friday, June 12, 2020	0.001	Passed	0.7400	Passed	
Sir John A. Macdonald High School	Boys Wash Room tap 1 by cafeteria	MWH999	Friday, June 12, 2020	0.001	Passed	0.1300	Passed	
Sir John A. Macdonald High School	Boys Wash Room tap 2 by cafeteria	MWI000	Friday, June 12, 2020	0.001	Passed	0.1100	Passed	
Sir John A. Macdonald High School	Tech Ed. tap Room 1088	MWI001	Friday, June 12, 2020	0.005	Passed	0.3000	Passed	
Sir John A. Macdonald High School	Class Room tap Room 1109	MWI003	Friday, June 12, 2020	0.001	Passed	0.1600	Passed	
Sir John A. Macdonald High School	Staff Kitchen tap 1101	MWI004	Friday, June 12, 2020	0.001	Passed	0.1200	Passed	
Sir John A. Macdonald High School	Staff Wash Room 1 tap Room 1101	MWI005	Friday, June 12, 2020	0.001	Passed	0.1700	Passed	
Sir John A. Macdonald High School	Staff Wash Room 2 tap Room 1101	MWI006	Friday, June 12, 2020	0.002	Passed	0.1800	Passed	
Sir John A. Macdonald High School	Admin Wash Room tap Room 1040	MWI007	Friday, June 12, 2020	0.001	Passed	0.0900	Passed	
Sir John A. Macdonald High School	Chem Lab tap 8 Room 2067	NAO679	Friday, June 12, 2020	0.002	Passed	0.1700	Passed	
Sir John A. Macdonald High School	Chem Lab tap 10 Room 2067	NAO680	Friday, June 12, 2020	0.008	Exceeded	0.2900	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 1 Room 2063	NAO681	Friday, June 12, 2020	0.007	Exceeded	0.4100	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Chem Lab tap 2 Room 2063	NAO682	Friday, June 12, 2020	0.006	Exceeded	0.3600	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Girls Locker Room tap Room 1031	NAO683	Friday, June 12, 2020	0.014	Exceeded	0.4000	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Boys Locker Room tap Room 1032	NAO684	Friday, June 12, 2020	0.008	Exceeded	0.2300	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Gym Office Wash Room tap Room 1033	NAO685	Friday, June 12, 2020	0.037	Exceeded	0.6100	Passed	Signage added to instruct handwashing only
Sir John A. Macdonald High School	Fountain by Room 1033	NAO686	Friday, June 12, 2020	-	Passed	0.4100	Passed	
Sir John A. Macdonald High School	Admin Wash Room tap Room 1040	NAO687	Friday, June 12, 2020	0.003	Passed	0.1000	Passed	
Sir Robert Borden Junior High School	2nd Floor Staff Room tap	NMD774	Thursday, August 27, 2020	0.001	Passed	0.5800	Passed	
Sir Robert Borden Junior High School	Class Room tap Room 201	MWG491	Friday, June 12, 2020	0.012	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Art Room tap Room 202	MWG492	Friday, June 12, 2020	0.018	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Class Room tap Room 203	NMD776	Thursday, August 27, 2020	0.001	Passed	0.0250	Passed	
Sir Robert Borden Junior High School	Janitors Closet tap in HVAC Room	MWG494	Friday, June 12, 2020	0.002	Passed	0.0520	Passed	
Sir Robert Borden Junior High School	2nd Floor Female Staff Wash Room	MWG496	Friday, June 12, 2020	0.190	Exceeded	0.3800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 1	MWG497	Friday, June 12, 2020	0.820	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 2	MWG498	Friday, June 12, 2020	0.440	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 3	MWG499	Friday, June 12, 2020	0.036	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	2nd Floor Girls Wash Room tap 4	MWG500	Friday, June 12, 2020	0.120	Exceeded	0.4100	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sir Robert Borden Junior High School	2nd Floor Male Staff Wash Room	MWG501	Friday, June 12, 2020	0.190	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	2nd Floor Male Wash Room tap 1	MWG502	Friday, June 12, 2020	0.002	Passed	0.1100	Passed	
Sir Robert Borden Junior High School	2nd Floor Male Wash Room tap 2	MWG503	Friday, June 12, 2020	0.080	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	2nd Floor Male Wash Room tap 3	MWG504	Friday, June 12, 2020	0.037	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Wash Room 1 tap inside guidance Room	MWG505	Friday, June 12, 2020	0.087	Exceeded	0.4300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Wash Room 2 tap inside guidance Room	MWG506	Friday, June 12, 2020	0.098	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Wood Shop tap	MWG507	Friday, June 12, 2020	0.590	Exceeded	2.1000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Class Room tap by Wood Shop	MWG508	Friday, June 12, 2020	0.021	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Science Room tap	MWG509	Friday, June 12, 2020	0.018	Exceeded	1.5000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Cafeteria/Kitchen single compartment sink tap	NMD077	Thursday, August 27, 2020	0.001	Passed	0.0600	Passed	
Sir Robert Borden Junior High School	Cafeteria/Kitchen double compartment sink tap	NMD078	Thursday, August 27, 2020	0.001	Passed	0.0590	Passed	
Sir Robert Borden Junior High School	Girls Gym teacher Wash Room tap	MWG512	Friday, June 12, 2020	0.060	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Boys Gym teacher Wash Room tap	MWG513	Friday, June 12, 2020	0.016	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	Fountain by 1st Floor Boys Wash Rooms	MWG514	Friday, June 12, 2020	0.044	Exceeded	0.3200	Passed	New Fountain to be installed. Other sources available.
Sir Robert Borden Junior High School	1st Floor Male Staff Wash Room	MWG515	Friday, June 12, 2020	0.006	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	1st Floor Boys Wash Room tap 1	MWG516	Friday, June 12, 2020	0.002	Passed	0.0520	Passed	
Sir Robert Borden Junior High School	1st Floor Boys Wash Room tap 2	MWG517	Friday, June 12, 2020	0.005	Passed	0.1900	Passed	
Sir Robert Borden Junior High School	1st Floor Boys Wash Room tap 3	MWG518	Friday, June 12, 2020	0.003	Passed	0.1600	Passed	
Sir Robert Borden Junior High School	Janitors Closet tap by Boys Wash Room	MWG519	Friday, June 12, 2020	0.004	Passed	0.0210	Passed	
Sir Robert Borden Junior High School	Fountain by 1st Floor Girls Wash Rooms	MWG520	Friday, June 12, 2020	0.004	Passed	0.1800	Passed	New Fountain to be installed. Other sources available.
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 1	MWG521	Friday, June 12, 2020	0.002	Passed	0.3300	Passed	
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 2	MWG522	Friday, June 12, 2020	0.012	Exceeded	0.3400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 3	MWG523	Friday, June 12, 2020	0.004	Passed	0.2100	Passed	
Sir Robert Borden Junior High School	1st Floor Girls Wash Room tap 4	MWG524	Friday, June 12, 2020	0.010	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sir Robert Borden Junior High School	1st Floor Female Staff Wash Room	MWG525	Friday, June 12, 2020	0.003	Passed	0.0390	Passed	
Sir Robert Borden Junior High School	Fountain by Room 218	PXP168	Wednesday, June 23, 2021	0.002	Passed	0.0260	Passed	New Fountain
Sir Robert Borden Junior High School	Fountain by Room 201	PXP172	Wednesday, June 23, 2021	0.001	Passed	0.0730	Passed	New Fountain
Smokey Drive Elementary School	Staff Room Wash Room 2 tap	MOM564	Tuesday, May 5, 2020	0.002	Passed	0.0370	Passed	
Smokey Drive Elementary School	Staff Room Kitchen tap	MOM565	Tuesday, May 5, 2020	0.004	Passed	0.1000	Passed	
Smokey Drive Elementary School	Class Room tap Room 3	MOM566	Tuesday, May 5, 2020	0.033	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Fountain by Room 3	MOM567	Tuesday, May 5, 2020	0.001	Passed	0.1800	Passed	
Smokey Drive Elementary School	Boys Wash Room tap 1	MOM568	Tuesday, May 5, 2020	0.005	Passed	0.0470	Passed	
Smokey Drive Elementary School	Boys Wash Room tap 2	MOM569	Tuesday, May 5, 2020	0.002	Passed	0.0380	Passed	
Smokey Drive Elementary School	Boys Wash Room tap 3	MOM570	Tuesday, May 5, 2020	0.002	Passed	0.0340	Passed	
Smokey Drive Elementary School	Girls Wash Room tap 1	MOM571	Tuesday, May 5, 2020	0.004	Passed	0.0400	Passed	
Smokey Drive Elementary School	Girls Wash Room tap 2	MOM572	Tuesday, May 5, 2020	0.018	Exceeded	0.0940	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Girls Wash Room tap 3	MOM573	Tuesday, May 5, 2020	0.034	Exceeded	0.0900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Class Room tap Room 212	MOM607	Tuesday, May 5, 2020	0.011	Exceeded	0.1400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Fountain by Room 205	MOM608	Tuesday, May 5, 2020	0.003	Passed	0.3600	Passed	Fountain Replacement in progress.
Smokey Drive Elementary School	Boys Wash Room tap 1	MOM609	Tuesday, May 5, 2020	0.007	Exceeded	0.0390	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Boys Wash Room tap 2	MOM610	Tuesday, May 5, 2020	-	Passed	0.0044	Passed	
Smokey Drive Elementary School	Boys Wash Room tap 3	MOM611	Tuesday, May 5, 2020	0.005	Passed	0.0210	Passed	
Smokey Drive Elementary School	Boys Wash Room tap 4	MOM612	Tuesday, May 5, 2020	0.007	Exceeded	0.0240	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Girls Wash Room tap 1	MOM613	Tuesday, May 5, 2020	0.006	Exceeded	0.0310	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Girls Wash Room tap 2	MOM614	Tuesday, May 5, 2020	0.006	Exceeded	0.2700	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Smokey Drive Elementary School	Girls Wash Room tap 3	MOM615	Tuesday, May 5, 2020	0.006	Exceeded	0.0540	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Girls Wash Room tap 4	MOM616	Tuesday, May 5, 2020	0.040	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Janitors Closet tap	MOM617	Tuesday, May 5, 2020	0.001	Passed	0.0300	Passed	
Smokey Drive Elementary School	Class Room Wash Room tap Room 101	MQK077	Friday, May 15, 2020	0.002	Passed	0.1200	Passed	
Smokey Drive Elementary School	Class Room Wash Room tap Room 102	MQK078	Friday, May 15, 2020	0.006	Exceeded	0.0750	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Smokey Drive Elementary School	Janitors Closet tap by Room 102	MQK079	Friday, May 15, 2020	-	Passed	0.0320	Passed	
Smokey Drive Elementary School	Fountain by Room 104	MQK080	Friday, May 15, 2020	-	Passed	0.0250	Passed	Fountain Replacement in progress.
South Woodside School	Janitors Closet tap Room 7	MYH220	Tuesday, June 23, 2020	0.003	Passed	0.2600	Passed	
South Woodside School	Class Room tap 1 (multi-purpose Room)	MYH222	Tuesday, June 23, 2020	0.008	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Class Room tap 2 (multi-purpose Room)	MYH223	Tuesday, June 23, 2020	0.016	Exceeded	0.8700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Boys Wash Room tap 1 in Rec Centre	MYH224	Tuesday, June 23, 2020	0.001	Passed	0.0940	Passed	
South Woodside School	Boys Wash Room tap 2 in Rec Centre	MYH225	Tuesday, June 23, 2020	0.002	Passed	0.0890	Passed	
South Woodside School	Girls Wash Room tap 1 in Rec Centre	MYH226	Tuesday, June 23, 2020	0.002	Passed	0.4900	Passed	
South Woodside School	Girls Wash Room tap 2 in Rec Centre	MYH227	Tuesday, June 23, 2020	0.003	Passed	0.5200	Passed	
South Woodside School	Fountain by Rec Centre	PXT155	Thursday, June 24, 2021	-	Passed	0.0440	Passed	New Fountain.
South Woodside School	Staff Wash Room tap Room 14	MYH232	Tuesday, June 23, 2020	0.008	Exceeded	0.3200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Staff Wash Room tap Room 15	MYH233	Tuesday, June 23, 2020	0.001	Passed	0.3500	Passed	
South Woodside School	Hand Washing sink in Room 17	MYH234	Tuesday, June 23, 2020	0.001	Passed	0.3100	Passed	
South Woodside School	Class Room tap Room 28	MYH235	Tuesday, June 23, 2020	-	Passed	0.1100	Passed	
South Woodside School	Class Room tap Room 33	MYH236	Tuesday, June 23, 2020	-	Passed	0.1000	Passed	
South Woodside School	Class Room tap Room 36	MYH237	Tuesday, June 23, 2020	0.002	Passed	0.9600	Passed	
South Woodside School	Girls Wash Room tap 1 Room 34	MYH238	Tuesday, June 23, 2020	0.002	Passed	0.1700	Passed	
South Woodside School	Girls Wash Room tap 2 Room 34	MYH239	Tuesday, June 23, 2020	0.001	Passed	0.1600	Passed	
South Woodside School	Girls Wash Room tap 3 Room 34	MYH240	Tuesday, June 23, 2020	0.003	Passed	0.1500	Passed	
South Woodside School	Girls Wash Room tap 4 Room 34	MYH241	Tuesday, June 23, 2020	0.001	Passed	0.1200	Passed	
South Woodside School	Girls Wash Room tap 5 Room 34	MYH242	Tuesday, June 23, 2020	0.010	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Fountain by Room 32	NMK032	Friday, August 28, 2020	0.001	Passed	0.0170	Passed	
South Woodside School	Janitors Closet tap Room 32	MYH244	Tuesday, June 23, 2020	-	Passed	0.0390	Passed	
South Woodside School	Boys Wash Room tap 1 Room 31	MYH245	Tuesday, June 23, 2020	0.001	Passed	0.2200	Passed	
South Woodside School	Boys Wash Room tap 2 Room 31	MYH246	Tuesday, June 23, 2020	0.003	Passed	0.1700	Passed	
South Woodside School	Boys Wash Room tap 3 Room 31	MYH247	Tuesday, June 23, 2020	0.002	Passed	0.2500	Passed	
South Woodside School	Fountain by Room 26	NMK033	Friday, August 28, 2020	0.000	Passed	0.0680	Passed	
South Woodside School	Gender Neutral Wash Room tap Room 5	MYH249	Tuesday, June 23, 2020	0.002	Passed	0.3000	Passed	
South Woodside School	Library tap Room 3	NBT449	Thursday, July 9, 2020	0.750	Exceeded	1.0000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Caretaker tap Room 5	NBT450	Thursday, July 9, 2020	0.008	Exceeded	0.1500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Staff Room Kitchen tap Room 9	NMK034	Friday, August 28, 2020	0.000	Passed	0.0200	Passed	
South Woodside School	Boys Wash Room tap 1 near Room 26	NBT453	Thursday, July 9, 2020	0.140	Exceeded	1.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Boys Wash Room tap 2 near Room 26	NBT454	Thursday, July 9, 2020	0.053	Exceeded	0.8200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
South Woodside School	Boys Wash Room tap 3 near Room 26	NBT455	Thursday, July 9, 2020	0.004	Passed	0.3900	Passed	
Southdale - North Woodside Elementary School	Fountain by Room 18	PXW751	Thursday, June 24, 2021	0.003	Passed	0.1700	Passed	New Fountain.
Southdale - North Woodside Elementary School	Class Room Wash Room tap Room 23	NNS332	Thursday, September 3, 2020	0.003	Passed	0.0440	Passed	
Southdale - North Woodside Elementary School	Class Room tap Room 23	NNS333	Thursday, September 3, 2020	0.001	Passed	0.0520	Passed	
Southdale - North Woodside Elementary School	Fountain by Room 22	NNS334	Thursday, September 3, 2020	0.007	Exceeded	0.9400	Passed	New Fountain installation underway. Other sources available.
Southdale - North Woodside Elementary School	Boys Wash Room tap 1 by Room 22	NNS335	Thursday, September 3, 2020	0.081	Exceeded	1.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Southdale - North Woodside Elementary School	Boys Wash Room tap 2 by Room 22	NNS336	Thursday, September 3, 2020	0.320	Exceeded	2.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Southdale - North Woodside Elementary School	Boys Wash Room tap 3 by Room 22	NNS337	Thursday, September 3, 2020	0.740	Exceeded	3.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
Southdale - North Woodside Elementary School	Girls Wash Room tap 1 by Room 22	NNS338	Thursday, September 3, 2020	0.027	Exceeded	0.7100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Southdale - North Woodside Elementary School	Girls Wash Room tap 2 by Room 22	NNS339	Thursday, September 3, 2020	0.039	Exceeded	0.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Southdale - North Woodside Elementary School	Girls Wash Room tap 3 by Room 22	NNS340	Thursday, September 3, 2020	0.086	Exceeded	1.8000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Southdale - North Woodside Elementary School	Janitors Closet tap by Girls Wash Room	NNS341	Thursday, September 3, 2020	0.001	Passed	0.0410	Passed	
Springvale Elementary School	Fountain by Room 304	MSA197	Monday, May 25, 2020	0.002	Passed	0.9300	Passed	
Springvale Elementary School	Boys Wash Room tap 1 by Room 304	MSA198	Monday, May 25, 2020	0.001	Passed	0.0480	Passed	
Springvale Elementary School	Boys Wash Room tap 2 by Room 304	MSA199	Monday, May 25, 2020	0.001	Passed	0.0440	Passed	
Springvale Elementary School	Boys Wash Room tap 3 by Room 304	MSA200	Monday, May 25, 2020	0.001	Passed	0.0460	Passed	
Springvale Elementary School	Wash Room tap in social worker Room	MSA201	Monday, May 25, 2020	0.001	Passed	0.1400	Passed	
Springvale Elementary School	Wash Room tap in early literacy Room	MSA202	Monday, May 25, 2020	0.001	Passed	0.0690	Passed	
Springvale Elementary School	Janitors Closet tap by Room 314	OWX522	Thursday, February 18, 2021	-	Passed	0.0790	Passed	Tap remediated.
Springvale Elementary School	Class Room tap Room 314	MSA204	Monday, May 25, 2020	0.001	Passed	0.1800	Passed	
Springvale Elementary School	Girls Wash Room tap 1 by Room 309	MSA205	Monday, May 25, 2020	0.004	Passed	0.1500	Passed	
Springvale Elementary School	Girls Wash Room tap 2 by Room 309	MSA206	Monday, May 25, 2020	0.001	Passed	0.0920	Passed	
Springvale Elementary School	Gender Neutral Wash Room tap Room 308	MSA208	Monday, May 25, 2020	0.004	Passed	0.0580	Passed	
Springvale Elementary School	Staff Room Kitchen tap Room 204	MSA209	Monday, May 25, 2020	0.001	Passed	0.0510	Passed	
Springvale Elementary School	Fountain by Room 204	PXS663	Thursday, June 24, 2021	0.001	Passed	0.0150	Passed	New Fountain.
Springvale Elementary School	Girls Wash Room tap 1 by Room 204	MSA211	Monday, May 25, 2020	0.005	Passed	0.2300	Passed	
Springvale Elementary School	Girls Wash Room tap 2 by Room 204	MSA212	Monday, May 25, 2020	0.001	Passed	0.0440	Passed	
Springvale Elementary School	Girls Wash Room tap 3 by Room 204	MSA213	Monday, May 25, 2020	0.000	Passed	0.0260	Passed	
Springvale Elementary School	Boys Wash Room tap 1 by Gym	MSA214	Monday, May 25, 2020	0.000	Passed	0.0360	Passed	
Springvale Elementary School	Boys Wash Room tap 2 by Gym	MSA215	Monday, May 25, 2020	0.000	Passed	0.0330	Passed	
Springvale Elementary School	Janitors Closet tap by Room 207	MSA216	Monday, May 25, 2020	0.001	Passed	0.0190	Passed	
Springvale Elementary School	Fountain by Gym	MSA218	Monday, May 25, 2020	0.000	Passed	0.1800	Passed	
Springvale Elementary School	Class Room tap Room 103	MSA219	Monday, May 25, 2020	0.002	Passed	0.4400	Passed	
Springvale Elementary School	Crawl Space under Stairs tap	MSA220	Monday, May 25, 2020	0.001	Passed	0.3000	Passed	
Springvale Elementary School	Boys Wash Room tap Room 103	MSA221	Monday, May 25, 2020	0.002	Passed	0.0780	Passed	
Springvale Elementary School	Girls Wash Room tap by Room 103	MSA222	Monday, May 25, 2020	0.001	Passed	0.0580	Passed	
Springvale Elementary School	Class Room tap Room 106	MSA223	Monday, May 25, 2020	0.005	Passed	0.2100	Passed	
Springvale Elementary School	Class Room tap Room 109	MSA224	Monday, May 25, 2020	0.001	Passed	0.2200	Passed	
Springvale Elementary School	Fountain by Room 104	PXS662	Thursday, June 24, 2021	-	Passed	0.0230	Passed	New Fountain.
Springvale Elementary School	Principals Office tap Room 218	MSP495	Wednesday, May 27, 2020	0.003	Passed	0.0600	Passed	
Springvale Elementary School	Girls Wash Room tap 3 by Room 309	NFE850	Monday, July 27, 2020	0.004	Passed	0.0410	Passed	
St. Agnes Junior High School	Science Lab Room 10 tap 1	MSA281	Monday, May 25, 2020	0.002	Passed	0.2100	Passed	
St. Agnes Junior High School	Science Lab Room 10 tap 2	MSA282	Monday, May 25, 2020	0.006	Exceeded	0.1300	Passed	Signage added to instruct handwashing only
St. Agnes Junior High School	Girls Wash Room tap 1	MSA283	Monday, May 25, 2020	0.006	Exceeded	0.0280	Passed	Signage added to instruct handwashing only
St. Agnes Junior High School	Girls Wash Room tap 2	MSA284	Monday, May 25, 2020	0.001	Passed	0.0240	Passed	
St. Agnes Junior High School	Girls Wash Room tap 3	MSA285	Monday, May 25, 2020	0.001	Passed	0.0170	Passed	
St. Agnes Junior High School	Girls Wash Room tap 4	MSA286	Monday, May 25, 2020	0.001	Passed	0.0160	Passed	
St. Agnes Junior High School	Janitors Closet tap	MSA287	Monday, May 25, 2020	-	Passed	0.0031	Passed	
St. Agnes Junior High School	Staff Wash Room tap	MSA288	Monday, May 25, 2020	-	Passed	0.0110	Passed	
St. Agnes Junior High School	Gender Neutral Wash Room tap	QDB665	Friday, July 16, 2021	-	Passed	0.0043	Passed	Faucet remediated
St. Agnes Junior High School	Boys Wash Room tap 1	MSA290	Monday, May 25, 2020	0.004	Passed	0.1400	Passed	
St. Agnes Junior High School	Boys Wash Room tap 2	MSA291	Monday, May 25, 2020	0.001	Passed	0.0900	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
St. Agnes Junior High School	Boys Wash Room tap 3	MSA292	Monday, May 25, 2020	-	Passed	0.0150	Passed	
St. Agnes Junior High School	Boys Wash Room tap 4	MSA293	Monday, May 25, 2020	-	Passed	0.0087	Passed	
St. Agnes Junior High School	Staff Learning Centre tap	MSA294	Monday, May 25, 2020	0.001	Passed	0.0720	Passed	
St. Agnes Junior High School	Staff Learning Centre Wash Room tap	MSA295	Monday, May 25, 2020	0.001	Passed	0.0500	Passed	
St. Agnes Junior High School	Fountain by Staff Room	QM0018	Friday, August 27, 2021	0.005	Passed	0.0960	Passed	Fountain replaced
St. Agnes Junior High School	Art Room 3 tap 1	MSA297	Monday, May 25, 2020	0.001	Passed	0.3100	Passed	
St. Agnes Junior High School	Art Room 3 tap 2	MSA298	Monday, May 25, 2020	-	Passed	0.0710	Passed	
St. Agnes Junior High School	Fountain by Gym Hall	MSA299	Monday, May 25, 2020	0.002	Passed	0.1200	Passed	
St. Agnes Junior High School	Girls Locker Room tap 1	QDB664	Friday, July 16, 2021	0.001	Passed	0.0076	Passed	Faucet remediated
St. Agnes Junior High School	Girls Locker Room tap 2	MSA301	Monday, May 25, 2020	0.001	Passed	0.0290	Passed	
St. Agnes Junior High School	Boys Locker Room tap 1	QDB663	Friday, July 16, 2021	-	Passed	0.0056	Passed	Faucet remediated
St. Agnes Junior High School	Boys Locker Room tap 2	MSA303	Monday, May 25, 2020	0.003	Passed	0.0560	Passed	
St. Agnes Junior High School	Library Staff Room tap	QCDB662	Friday, July 16, 2021	0.002	Passed	0.0380	Passed	Faucet remediated
St. Agnes Junior High School	Tech Ed Room 15 tap	MSA305	Monday, May 25, 2020	0.002	Passed	0.0510	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 1	NKX251	Friday, August 21, 2020	0.001	Passed	0.0280	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 2	MSA307	Monday, May 25, 2020	0.002	Passed	0.0720	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 3	NKX252	Friday, August 21, 2020	0.001	Passed	0.0250	Passed	
St. Agnes Junior High School	Family Studies Room 15 tap 4	NKX253	Friday, August 21, 2020	0.001	Passed	0.0290	Passed	
St. Agnes Junior High School	Class Room 16 tap	NKX254	Friday, August 21, 2020	0.001	Passed	0.0310	Passed	
St. Agnes Junior High School	Class Room 18 tap	MSA311	Monday, May 25, 2020	0.003	Passed	0.0820	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 1	MSA312	Monday, May 25, 2020	0.004	Passed	0.0740	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 2	MSA313	Monday, May 25, 2020	0.001	Passed	0.0570	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 3	MSA314	Monday, May 25, 2020	0.004	Passed	0.0190	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 4	MSA315	Monday, May 25, 2020	0.003	Passed	0.0250	Passed	
St. Agnes Junior High School	2nd Floor Girls Wash Room tap 5	MSA316	Monday, May 25, 2020	0.001	Passed	0.0110	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 1	MSA317	Monday, May 25, 2020	0.001	Passed	0.0089	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 2	MSA318	Monday, May 25, 2020	0.001	Passed	0.0086	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 3	MSA319	Monday, May 25, 2020	0.001	Passed	0.0086	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 4	MSA320	Monday, May 25, 2020	0.001	Passed	0.0097	Passed	
St. Agnes Junior High School	2nd Floor Boys Wash Room tap 5	MSA339	Monday, May 25, 2020	0.002	Passed	0.1200	Passed	
St. Agnes Junior High School	2nd Floor Janitors Closet tap	MSA340	Monday, May 25, 2020	0.002	Passed	0.0930	Passed	
St. Agnes Junior High School	2nd Floor Female Staff Wash Room tap	MSA341	Monday, May 25, 2020	0.001	Passed	0.0230	Passed	
St. Agnes Junior High School	2nd Floor Male Staff Wash Room tap	MSA342	Monday, May 25, 2020	-	Passed	0.0230	Passed	
St. Agnes Junior High School	2nd Floor Resource Room 19 tap	MSA343	Monday, May 25, 2020	0.001	Passed	0.0170	Passed	
St. Catherine's Elementary School	Staff Wash Room 216 tap	MSG967	Tuesday, May 26, 2020	0.000	Passed	0.0150	Passed	
St. Catherine's Elementary School	Principals Office 218 tap	MSG968	Tuesday, May 26, 2020	0.000	Passed	0.0061	Passed	
St. Catherine's Elementary School	Boys Wash Room 229 tap 1	NJI590	Friday, August 14, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary School	Boys Wash Room 229 tap 2	MSG970	Tuesday, May 26, 2020	0.003	Passed	0.1300	Passed	
St. Catherine's Elementary School	Boys Wash Room 229 tap 3	MSG971	Tuesday, May 26, 2020	0.002	Passed	0.0560	Passed	
St. Catherine's Elementary School	Male Staff Wash Room by Room 229	MSG972	Tuesday, May 26, 2020	0.002	Passed	0.0260	Passed	
St. Catherine's Elementary School	Fountain by Room 229	NJI589	Friday, August 14, 2020	0.000	Passed	0.0012	Passed	
St. Catherine's Elementary School	Girls Wash Room 227 tap 1	MSG974	Tuesday, May 26, 2020	0.003	Passed	0.1400	Passed	
St. Catherine's Elementary School	Girls Wash Room 227 tap 2	MSG975	Tuesday, May 26, 2020	0.000	Passed	0.0130	Passed	
St. Catherine's Elementary School	Girls Wash Room 227 tap 3	MSG976	Tuesday, May 26, 2020	0.002	Passed	0.0330	Passed	
St. Catherine's Elementary School	Girls Wash Room 227 tap 4	MSG977	Tuesday, May 26, 2020	0.000	Passed	0.0048	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
St. Catherine's Elementary School	Class Room 221 tap	NJI591	Friday, August 14, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary School	VP Office 217 tap	MSG979	Tuesday, May 26, 2020	0.001	Passed	0.0750	Passed	
St. Catherine's Elementary School	Boys Wash Room 215B tap 1	MSG980	Tuesday, May 26, 2020	0.000	Passed	0.0250	Passed	
St. Catherine's Elementary School	Boys Wash Room 215B tap 2	MSG981	Tuesday, May 26, 2020	0.000	Passed	0.0270	Passed	
St. Catherine's Elementary School	Fountain by Room 215B	MSG982	Tuesday, May 26, 2020	0.003	Passed	0.4500	Passed	
St. Catherine's Elementary School	Girls Wash Room 215A tap 1	MSG983	Tuesday, May 26, 2020	0.000	Passed	0.0620	Passed	
St. Catherine's Elementary School	Girls Wash Room 215A tap 2	MSG984	Tuesday, May 26, 2020	0.000	Passed	0.0260	Passed	
St. Catherine's Elementary School	Janitors Closet tap by Room 204	MSG985	Tuesday, May 26, 2020	0.000	Passed	0.0040	Passed	
St. Catherine's Elementary School	Class Room 204 tap	MSG986	Tuesday, May 26, 2020	0.000	Passed	0.0360	Passed	
St. Catherine's Elementary School	Class Room 210 tap	MSG987	Tuesday, May 26, 2020	0.001	Passed	0.1600	Passed	
St. Catherine's Elementary School	Gender Neutral Wash Room 212 tap	MSG988	Tuesday, May 26, 2020	0.000	Passed	0.1200	Passed	
St. Catherine's Elementary School	Fountain by Gym	QOY419	Friday, September 3, 2021	0.001	Passed	0.0380	Passed	Fountain replaced
St. Catherine's Elementary School	Girls Wash Room 106 tap 1	MSG990	Tuesday, May 26, 2020	0.004	Passed	0.6700	Passed	
St. Catherine's Elementary School	Girls Wash Room 106 tap 2	MSG991	Tuesday, May 26, 2020	0.000	Passed	0.1000	Passed	
St. Catherine's Elementary School	Janitors Closet 106A tap	MSG992	Tuesday, May 26, 2020	0.000	Passed	0.0054	Passed	
St. Catherine's Elementary School	Boys Wash Room 108 tap 1	MSG993	Tuesday, May 26, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary School	Boys Wash Room 108 tap 2	MSG994	Tuesday, May 26, 2020	0.000	Passed	0.0160	Passed	
St. Catherine's Elementary School	Teachers Wash Room 108B tap	MSG995	Tuesday, May 26, 2020	0.000	Passed	0.0051	Passed	
St. Catherine's Elementary School	Pottery Room 110 tap 1	MSG996	Tuesday, May 26, 2020	0.000	Passed	0.0260	Passed	
St. Catherine's Elementary School	Pottery Room 110 tap 2	MSG997	Tuesday, May 26, 2020	0.000	Passed	0.0230	Passed	
St. Catherine's Elementary School	Boys Wash Room 119 tap 1	MSG998	Tuesday, May 26, 2020	0.001	Passed	0.0880	Passed	
St. Catherine's Elementary School	Boys Wash Room 119 tap 2	MSG999	Tuesday, May 26, 2020	0.000	Passed	0.0200	Passed	
St. Catherine's Elementary School	Boys Wash Room 119 tap 3	MSH000	Tuesday, May 26, 2020	0.000	Passed	0.0150	Passed	
St. Catherine's Elementary School	Male Staff Wash Room 119 tap	MSH001	Tuesday, May 26, 2020	0.001	Passed	0.0070	Passed	
St. Catherine's Elementary School	Fountain by Room 119	QOY420	Friday, September 3, 2021	0.003	Passed	0.0580	Passed	Fountain replaced
St. Catherine's Elementary School	Female Staff Wash Room 117 tap	MSH003	Tuesday, May 26, 2020	-	Passed	0.0077	Passed	
St. Catherine's Elementary School	Girls Wash Room 117 tap 1	MSH004	Tuesday, May 26, 2020	-	Passed	0.0200	Passed	
St. Catherine's Elementary School	Girls Wash Room 117 tap 2	MSH005	Tuesday, May 26, 2020	-	Passed	0.0180	Passed	
St. Catherine's Elementary School	Girls Wash Room 117 tap 3	MSH006	Tuesday, May 26, 2020	-	Passed	0.0210	Passed	
St. Catherine's Elementary School	Class Room 107 tap	MSH007	Tuesday, May 26, 2020	-	Passed	0.0220	Passed	
St. Catherine's Elementary School	Boiler Room tap	MSH008	Tuesday, May 26, 2020	0.001	Passed	0.0340	Passed	
St. Catherine's Elementary School	Fountain by Room 107	MSH009	Tuesday, May 26, 2020	0.010	Exceeded	1.6000	Passed	New Fountain to be installed. Other sources available.
St. Margaret's Bay Elementary School	Girls Wash Room tap 1 Room 136	MPB504	Friday, May 8, 2020	0.001	Passed	0.2000	Passed	
St. Margaret's Bay Elementary School	Girls Wash Room tap 2 Room 136	MPB505	Friday, May 8, 2020	0.002	Passed	0.1300	Passed	
St. Margaret's Bay Elementary School	Girls Wash Room tap 3 Room 136	MPB506	Friday, May 8, 2020	0.002	Passed	0.1500	Passed	
St. Margaret's Bay Elementary School	Boys Wash Room tap 1 Room 134	MPB507	Friday, May 8, 2020	0.008	Exceeded	0.2900	Passed	Signage added to instruct handwashing only
St. Margaret's Bay Elementary School	Boys Wash Room tap 2 Room 134	MPB508	Friday, May 8, 2020	0.001	Passed	0.1600	Passed	
St. Margaret's Bay Elementary School	Boys Wash Room tap 3 Room 134	MPB509	Friday, May 8, 2020	0.002	Passed	0.2100	Passed	
St. Margaret's Bay Elementary School	Fountain by Room 137	QQR055	Wednesday, September 15, 2021	-	Passed	-	Passed	Fountain Replaced
St. Margaret's Bay Elementary School	Office Wash Room tap Room 184	MPB511	Friday, May 8, 2020	0.001	Passed	0.2300	Passed	
St. Margaret's Bay Elementary School	Health Room tap Room 189	MPB512	Friday, May 8, 2020	0.002	Passed	0.2300	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 107	MPB513	Friday, May 8, 2020	0.001	Passed	0.1300	Passed	
St. Margaret's Bay Elementary School	Gender Neutral Wash Room tap Room 108	MPB514	Friday, May 8, 2020	0.003	Passed	0.2400	Passed	
St. Margaret's Bay Elementary School	Gender Neutral Wash Room tap Room 109	MPB515	Friday, May 8, 2020	0.002	Passed	0.1400	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 110	MPB516	Friday, May 8, 2020	0.001	Passed	0.1800	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
St. Margaret's Bay Elementary School	Class Room tap Room 115 tap 1	MPB517	Friday, May 8, 2020	0.001	Passed	0.1400	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 115 tap 2	MPB518	Friday, May 8, 2020	0.001	Passed	0.1800	Passed	
St. Margaret's Bay Elementary School	Gender Neutral Wash Room tap Room 119	MPB519	Friday, May 8, 2020	0.001	Passed	0.1300	Passed	
St. Margaret's Bay Elementary School	Fountain by Room 118	QQR056	Wednesday, September 15, 2021	-	Passed	-	Passed	Fountain Replaced
St. Margaret's Bay Elementary School	Class Room Kitchen tap Room 118A	MPB521	Friday, May 8, 2020	0.002	Passed	0.1300	Passed	
St. Margaret's Bay Elementary School	Class Room tap 1 Room 123	MPB522	Friday, May 8, 2020	0.000	Passed	0.1800	Passed	
St. Margaret's Bay Elementary School	Class Room tap 2 Room 123	MPB523	Friday, May 8, 2020	0.001	Passed	0.1900	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 154	MPB524	Friday, May 8, 2020	0.001	Passed	0.1800	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 155	MPB525	Friday, May 8, 2020	0.001	Passed	0.1600	Passed	
St. Margaret's Bay Elementary School	Class Room 157 tap 1	MPB526	Friday, May 8, 2020	0.001	Passed	0.1500	Passed	
St. Margaret's Bay Elementary School	Class Room 157 tap 2	MPB527	Friday, May 8, 2020	0.002	Passed	0.2200	Passed	
St. Margaret's Bay Elementary School	Fountain by Room 157	QQR055	Wednesday, September 15, 2021	-	Passed	-	Passed	Fountain Replaced
St. Margaret's Bay Elementary School	Girls Wash Room tap 1 Room 164	MPB529	Friday, May 8, 2020	0.004	Passed	0.1800	Passed	
St. Margaret's Bay Elementary School	Girls Wash Room tap 2 Room 164	MPB530	Friday, May 8, 2020	0.003	Passed	0.1600	Passed	
St. Margaret's Bay Elementary School	Girls Wash Room tap 3 Room 164	MPB531	Friday, May 8, 2020	0.002	Passed	0.2400	Passed	
St. Margaret's Bay Elementary School	Boys Wash Room tap 1 Room 166	MPB532	Friday, May 8, 2020	0.003	Passed	0.1400	Passed	
St. Margaret's Bay Elementary School	Boys Wash Room tap 2 Room 166	MPB559	Friday, May 8, 2020	0.002	Passed	0.1900	Passed	
St. Margaret's Bay Elementary School	Boys Wash Room tap 3 Room 166	MPB560	Friday, May 8, 2020	0.005	Exceeded	0.1800	Passed	Signage added to instruct handwashing only
St. Margaret's Bay Elementary School	Class Room tap Room 172	MPB565	Friday, May 8, 2020	0.002	Passed	0.1500	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 170	MPB566	Friday, May 8, 2020	0.001	Passed	0.1200	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 171	MPB567	Friday, May 8, 2020	0.002	Passed	0.0990	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 174	MPB568	Friday, May 8, 2020	0.045	Exceeded	0.3200	Passed	Signage added to instruct handwashing only
St. Margaret's Bay Elementary School	Class Room tap Room 179	MPB569	Friday, May 8, 2020	0.001	Passed	0.1400	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 180	MPB570	Friday, May 8, 2020	0.001	Passed	0.2100	Passed	
St. Margaret's Bay Elementary School	Wash Room tap 1 Room 149	MPB575	Friday, May 8, 2020	0.005	Passed	0.2700	Passed	
St. Margaret's Bay Elementary School	Wash Room tap 2 Room 149	MPB581	Friday, May 8, 2020	0.001	Passed	0.1000	Passed	
St. Margaret's Bay Elementary School	Wash Room tap 3 Room 149	MPB582	Friday, May 8, 2020	0.006	Passed	0.2200	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 183	MPB583	Friday, May 8, 2020	0.001	Passed	0.1600	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 139	MPB584	Friday, May 8, 2020	0.002	Passed	0.3000	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 144	MPB585	Friday, May 8, 2020	0.002	Passed	0.3300	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 145	MPB586	Friday, May 8, 2020	0.002	Passed	0.1800	Passed	
St. Margaret's Bay Elementary School	Class Room tap Room 133	MPB587	Friday, May 8, 2020	0.300	Exceeded	0.6200	Passed	Signage added to instruct handwashing only
St. Margaret's Bay Elementary School	Class Room 1033 tap	MPB591	Friday, May 8, 2020	0.001	Passed	0.2400	Passed	
St. Stephen's Elementary School	Class Room tap Room 205	MSG933	Tuesday, May 26, 2020	-	Passed	0.0720	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 1 opposite Room 16	MSG934	Tuesday, May 26, 2020	-	Passed	0.1100	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 2 opposite Room 16	MSG935	Tuesday, May 26, 2020	0.001	Passed	0.1200	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 3 opposite Room 16	MSG936	Tuesday, May 26, 2020	0.002	Passed	0.1400	Passed	
St. Stephen's Elementary School	Female Staff Wash Room tap	MSG937	Tuesday, May 26, 2020	0.000	Passed	0.0430	Passed	
St. Stephen's Elementary School	Fountain by Room 16	MSG938	Tuesday, May 26, 2020	0.003	Passed	0.4600	Passed	
St. Stephen's Elementary School	Janitors Closet tap opposite Room 16	MSG939	Tuesday, May 26, 2020	0.000	Passed	0.0370	Passed	
St. Stephen's Elementary School	Male Staff Wash Room opposite Room 14	MSG940	Tuesday, May 26, 2020	0.007	Passed	0.0390	Passed	
St. Stephen's Elementary School	Boys Wash Room tap 1 by Room 14	MSG941	Tuesday, May 26, 2020	0.000	Passed	0.0390	Passed	
St. Stephen's Elementary School	Boys Wash Room tap 2 by Room 14	MSG942	Tuesday, May 26, 2020	0.000	Passed	0.0390	Passed	
St. Stephen's Elementary School	Gym Office Wash Room tap	MSG944	Tuesday, May 26, 2020	0.440	Exceeded	0.0360	Passed	Faucet to be remediated. Signage to instruct hand washing only.
St. Stephen's Elementary School	Gym Office Wash Room tap	MSG945	Tuesday, May 26, 2020	0.000	Passed	0.0300	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
St. Stephen's Elementary School	PTA tap by Gym	MSG946	Tuesday, May 26, 2020	0.004	Passed	0.2400	Passed	
St. Stephen's Elementary School	Boys Wash Room tap 1 by Gym	MSG947	Tuesday, May 26, 2020	0.008	Exceeded	0.3700	Passed	Faucet to be remediated. Signage to instruct hand washing only.
St. Stephen's Elementary School	Boys Wash Room tap 2 by Gym	MSG948	Tuesday, May 26, 2020	0.001	Passed	0.1300	Passed	
St. Stephen's Elementary School	Fountain by Gym	MSG949	Tuesday, May 26, 2020	0.004	Passed	0.1600	Passed	
St. Stephen's Elementary School	Janitors Closet tap by Gym	MSG950	Tuesday, May 26, 2020	0.000	Passed	0.0150	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 1 by Gym	MSG951	Tuesday, May 26, 2020	-	Passed	0.0350	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 2 by Gym	MSG952	Tuesday, May 26, 2020	-	Passed	0.0270	Passed	
St. Stephen's Elementary School	Class Room tap Room 1	MSG953	Tuesday, May 26, 2020	-	Passed	0.0330	Passed	
St. Stephen's Elementary School	Boys Wash Room tap 1 by Room 9	MSG956	Tuesday, May 26, 2020	-	Passed	0.0130	Passed	
St. Stephen's Elementary School	Boys Wash Room tap 2 by Room 9	MSG957	Tuesday, May 26, 2020	-	Passed	0.0130	Passed	
St. Stephen's Elementary School	Male Staff Wash Room tap by Room 9	MSG958	Tuesday, May 26, 2020	-	Passed	0.0060	Passed	
St. Stephen's Elementary School	Janitors Closet tap by Room 7	MSG959	Tuesday, May 26, 2020	-	Passed	0.0074	Passed	
St. Stephen's Elementary School	Fountain by Room 7	NLV915	Wednesday, August 26, 2020	0.009	Exceeded	0.6300	Passed	New Fountain to be installed. Other sources available.
St. Stephen's Elementary School	Female Staff Wash Room tap by Room 7	MSG961	Tuesday, May 26, 2020	0.001	Passed	0.1700	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 1 by Room 7	MSG962	Tuesday, May 26, 2020	0.002	Passed	0.0440	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 2 by Room 7	MSG963	Tuesday, May 26, 2020	-	Passed	0.0200	Passed	
St. Stephen's Elementary School	Fountain	MSP292	Wednesday, May 27, 2020	-	Passed	0.0240	Passed	
St. Stephen's Elementary School	Girls Wash Room tap 3	MSP293	Wednesday, May 27, 2020	-	Passed	0.1400	Passed	
St. Stephen's Elementary School	Staff Wash Room tap	MSP294	Wednesday, May 27, 2020	-	Passed	0.0290	Passed	
St. Stephen's Elementary School	GEN Wash Room tap	MSP295	Wednesday, May 27, 2020	-	Passed	0.0390	Passed	
St. Stephen's Elementary School	VP Wash Room tap	MSP296	Wednesday, May 27, 2020	-	Passed	0.0510	Passed	
Sunnyside - Eaglewood Drive	Class Room 207 tap	MRU935	Friday, May 22, 2020	0.001	Passed	0.0930	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Boys Wash Room tap 1	MRU936	Friday, May 22, 2020	-	Passed	0.0120	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Boys Wash Room tap 2	MRU937	Friday, May 22, 2020	-	Passed	0.0170	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Janitors Closet tap	MRU938	Friday, May 22, 2020	-	Passed	0.0072	Passed	
Sunnyside - Eaglewood Drive	Fountain by Room 202	QH975	Monday, August 9, 2021	-	Passed	0.0078	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Girls Wash Room tap 1	MRU939	Friday, May 22, 2020	-	Passed	0.0230	Passed	
Sunnyside - Eaglewood Drive	2nd Floor Girls Wash Room tap 2	MRU940	Friday, May 22, 2020	-	Passed	0.0160	Passed	
Sunnyside - Eaglewood Drive	Staff Wash Wash Room tap	MRU941	Friday, May 22, 2020	-	Passed	0.0450	Passed	
Sunnyside - Eaglewood Drive	Staff Room tap	MRU942	Friday, May 22, 2020	-	Passed	0.0630	Passed	
Sunnyside - Eaglewood Drive	Music Room tap	MRU943	Friday, May 22, 2020	0.002	Passed	1.0000	Passed	
Sunnyside - Eaglewood Drive	Staff Room tap	MRU944	Friday, May 22, 2020	0.001	Passed	0.0440	Passed	
Sunnyside - Eaglewood Drive	Staff Room Kitchen tap	MRU945	Friday, May 22, 2020	0.001	Passed	1.3000	Passed	
Sunnyside - Eaglewood Drive	Staff Wash Room	MRU946	Friday, May 22, 2020	-	Passed	0.0058	Passed	
Sunnyside - Eaglewood Drive	1ST Floor Boys Wash Room tap 1	MRU947	Friday, May 22, 2020	-	Passed	0.1200	Passed	
Sunnyside - Eaglewood Drive	1st Floor Boys Wash Room tap 2	MRU948	Friday, May 22, 2020	0.001	Passed	0.0440	Passed	
Sunnyside - Eaglewood Drive	1st Floor Janitors Closet tap	MRU949	Friday, May 22, 2020	0.001	Passed	0.0089	Passed	
Sunnyside - Eaglewood Drive	Fountain by Room 102	MRU950	Friday, May 22, 2020	-	Passed	0.0500	Passed	
Sunnyside - Eaglewood Drive	1st Floor Girls Wash Room tap 1	MRU951	Friday, May 22, 2020	-	Passed	0.0210	Passed	
Sunnyside - Eaglewood Drive	1st Floor Girls Wash Room tap 2	MRU952	Friday, May 22, 2020	-	Passed	0.0170	Passed	
Sunnyside - Eaglewood Drive	Main Office tap	MRU953	Friday, May 22, 2020	-	Passed	0.5100	Passed	
Sunnyside - Fort Sackville	Boys Wash Room tap 1	MRM803	Thursday, May 21, 2020	-	Passed	0.0620	Passed	
Sunnyside - Fort Sackville	Boys Wash Room tap 2	MRM804	Thursday, May 21, 2020	0.002	Passed	0.0670	Passed	
Sunnyside - Fort Sackville	Staff Kitchen tap	MRM805	Thursday, May 21, 2020	-	Passed	0.0590	Passed	
Sunnyside - Fort Sackville	Pre Primary Wash Room tap 1	MRM806	Thursday, May 21, 2020	0.001	Passed	0.3500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Sunnyside - Fort Sackville	Pre Primary Wash Room tap 2	MRM807	Thursday, May 21, 2020	-	Passed	0.1000	Passed	
Sunnyside - Fort Sackville	Storage Room Wash Room tap	MRM808	Thursday, May 21, 2020	0.001	Passed	0.1800	Passed	
Sunnyside - Fort Sackville	Janitors Closet tap	MRM809	Thursday, May 21, 2020	-	Passed	0.0570	Passed	
Sunnyside - Fort Sackville	Fountain by Janitors Closet	MRM810	Thursday, May 21, 2020	0.001	Passed	0.4700	Passed	
Sunnyside - Fort Sackville	Girls Wash Room tap 1	MRM811	Thursday, May 21, 2020	-	Passed	0.1600	Passed	
Sunnyside - Fort Sackville	Girls Wash Room tap 2	MRM812	Thursday, May 21, 2020	-	Passed	0.0610	Passed	
Sycamore Lane Elementary School	2nd Floor Boys Wash Room tap 1	MRD949	Wednesday, May 20, 2020	0.009	Exceeded	0.3000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	2nd Floor Boys Wash Room tap 2	MRD950	Wednesday, May 20, 2020	0.005	Passed	0.2000	Passed	
Sycamore Lane Elementary School	2nd Floor Boys Wash Room tap 3	MRD951	Wednesday, May 20, 2020	0.018	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	2nd Floor Janitors Closet tap	MRD952	Wednesday, May 20, 2020	0.000	Passed	0.0066	Passed	
Sycamore Lane Elementary School	Fountain by Room 211	NJG794	Tuesday, August 18, 2020	0.003	Passed	0.0920	Passed	Fountain Replacement in progress.
Sycamore Lane Elementary School	2nd Floor Girls Wash Room tap 1	MRD954	Wednesday, May 20, 2020	0.007	Exceeded	0.6500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	2nd Floor Girls Wash Room tap 2	MRD955	Wednesday, May 20, 2020	0.009	Exceeded	0.0840	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	2nd Floor Girls Wash Room tap 3	MRD956	Wednesday, May 20, 2020	0.003	Passed	0.0220	Passed	
Sycamore Lane Elementary School	2nd Floor Girls Wash Room tap 4	MRD957	Wednesday, May 20, 2020	0.004	Passed	0.0380	Passed	
Sycamore Lane Elementary School	Boys Wash Room 110 tap 1	MRD958	Wednesday, May 20, 2020	0.007	Exceeded	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	Boys Wash Room 110 tap 2	MRD959	Wednesday, May 20, 2020	0.001	Passed	0.0300	Passed	
Sycamore Lane Elementary School	Boys Wash Room 110 tap 3	MRD960	Wednesday, May 20, 2020	0.037	Exceeded	0.5200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	Janitors Closet 111 tap	MRD961	Wednesday, May 20, 2020	0.000	Passed	0.0063	Passed	
Sycamore Lane Elementary School	Fountain by Room 111	MRD962	Wednesday, May 20, 2020	0.001	Passed	0.2800	Passed	
Sycamore Lane Elementary School	Girls Wash Room 112 tap 1	MRD963	Wednesday, May 20, 2020	0.034	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	Girls Wash Room 112 tap 2	MRD964	Wednesday, May 20, 2020	0.014	Exceeded	0.0620	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	Girls Wash Room 112 tap 3	MRD965	Wednesday, May 20, 2020	0.016	Exceeded	0.0940	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Sycamore Lane Elementary School	Girls Wash Room 112 tap 4	MRD966	Wednesday, May 20, 2020	0.005	Passed	0.0150	Passed	
Sycamore Lane Elementary School	Gender Neutral Wash Room 1036 tap	MRD967	Wednesday, May 20, 2020	0.004	Passed	0.1500	Passed	
Sycamore Lane Elementary School	Class Room 101 tap	MRD968	Wednesday, May 20, 2020	0.001	Passed	0.0082	Passed	
Sycamore Lane Elementary School	Class Room 101 Wash Room tap	MRD969	Wednesday, May 20, 2020	0.000	Passed	0.0088	Passed	
Sycamore Lane Elementary School	Fountain by Caretaker Room	MRD970	Wednesday, May 20, 2020	0.004	Passed	0.3600	Passed	Fountain Replacement in progress.
Sycamore Lane Elementary School	Mechanical Room tap Room 121	MRD971	Wednesday, May 20, 2020	0.000	Passed	0.0160	Passed	
Sycamore Lane Elementary School	Main Office Gender Neutral Wash Room tap	MRD972	Wednesday, May 20, 2020	0.008	Passed	0.0690	Passed	
Sycamore Lane Elementary School	Main Office Female Wash Room tap 1	MRD973	Wednesday, May 20, 2020	0.005	Passed	0.5900	Passed	
Sycamore Lane Elementary School	Main Office Female Wash Room tap 2	MRD974	Wednesday, May 20, 2020	0.002	Passed	0.2100	Passed	
Sycamore Lane Elementary School	Staff Room Kitchen tap	NJG795	Tuesday, August 18, 2020	0.001	Passed	0.0170	Passed	
Tallahassee Community School	Janitors Closet tap inside Fan Room	MVY786	Thursday, June 11, 2020	0.002	Passed	0.2100	Passed	
Tallahassee Community School	2nd Floor Boys Wash Room tap 1 by Storage Room	MVY787	Thursday, June 11, 2020	0.007	Exceeded	0.0990	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	2nd Floor Boys Wash Room tap 2 by Storage Room	MVY788	Thursday, June 11, 2020	0.003	Passed	0.1300	Passed	
Tallahassee Community School	2nd Floor Boys Wash Room tap 3 by Storage Room	MVY789	Thursday, June 11, 2020	0.008	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	2nd Floor Boys Wash Room tap 4 by Storage Room	MVY790	Thursday, June 11, 2020	0.012	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Fountain by Boys Wash Room	MVY791	Thursday, June 11, 2020	0.001	Passed	0.2800	Passed	
Tallahassee Community School	Class Room 213 tap 1	MVY792	Thursday, June 11, 2020	0.004	Passed	0.8900	Passed	
Tallahassee Community School	Class Room 213 tap 2	MVY793	Thursday, June 11, 2020	0.140	Exceeded	0.0570	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Fountain by Girls Wash Room	MVY794	Thursday, June 11, 2020	0.004	Passed	0.6800	Passed	
Tallahassee Community School	2nd Floor Girls Wash Room tap 1 by elevator	MVY795	Thursday, June 11, 2020	0.004	Passed	0.0580	Passed	
Tallahassee Community School	2nd Floor Girls Wash Room tap 2 by elevator	MVY796	Thursday, June 11, 2020	0.021	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	2nd Floor Girls Wash Room tap 3 by elevator	MVY797	Thursday, June 11, 2020	0.002	Passed	0.1500	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Tallahassee Community School	2nd Floor Girls Wash Room tap 4 by elevator	MVY798	Thursday, June 11, 2020	0.003	Passed	0.1000	Passed	
Tallahassee Community School	2nd Floor Girls Wash Room tap 5 by elevator	MVY799	Thursday, June 11, 2020	0.000	Passed	0.0390	Passed	
Tallahassee Community School	Class Room 1 tap	MVY800	Thursday, June 11, 2020	0.002	Passed	0.3200	Passed	
Tallahassee Community School	Fountain by Service Room	MVY801	Thursday, June 11, 2020	0.001	Passed	0.3100	Passed	
Tallahassee Community School	Boys Wash Room tap 1 in Rec Centre	MVY802	Thursday, June 11, 2020	0.009	Exceeded	0.2100	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Wash Room tap 2 in Rec Centre	MVY803	Thursday, June 11, 2020	0.002	Passed	0.2200	Passed	
Tallahassee Community School	Rec Centre Kitchen tap	MVY804	Thursday, June 11, 2020	-	Passed	0.0980	Passed	
Tallahassee Community School	Girls Wash Room tap 1 in Rec Centre	MVY805	Thursday, June 11, 2020	-	Passed	0.1200	Passed	
Tallahassee Community School	Girls Wash Room tap 2 in Rec Centre	MVY806	Thursday, June 11, 2020	0.000	Passed	0.0300	Passed	
Tallahassee Community School	Fountain in Dance Studio	MVY807	Thursday, June 11, 2020	0.001	Passed	0.0310	Passed	
Tallahassee Community School	Infant Room Bar Sink tap	MVY808	Thursday, June 11, 2020	0.000	Passed	0.4700	Passed	
Tallahassee Community School	Infant Room Kitchen Sink tap	MVY809	Thursday, June 11, 2020	0.001	Passed	0.4200	Passed	
Tallahassee Community School	Girls Locker Room tap 1 in Rec Centre	MVY810	Thursday, June 11, 2020	0.001	Passed	0.3800	Passed	
Tallahassee Community School	Girls Locker Room tap 2 in Rec Centre	MVY811	Thursday, June 11, 2020	0.024	Exceeded	0.3500	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Girls Locker Room tap 3 in Rec Centre	MVY812	Thursday, June 11, 2020	0.024	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Fountain by Gym South Entrance	MVY813	Thursday, June 11, 2020	0.009	Passed	0.1300	Passed	
Tallahassee Community School	Gym Office (South) Wash Room tap	MVY814	Thursday, June 11, 2020	0.005	Passed	0.1900	Passed	
Tallahassee Community School	Boys Locker Room tap 1 in Rec Centre	MVY815	Thursday, June 11, 2020	0.024	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Locker Room tap 2 in Rec Centre	MVY816	Thursday, June 11, 2020	0.006	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Locker Room tap 3 in Rec Centre	MVY817	Thursday, June 11, 2020	0.003	Passed	0.0490	Passed	
Tallahassee Community School	Toddler Room tap	MVY818	Thursday, June 11, 2020	0.001	Exceeded	0.4800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Toddler Room Gender Neutral Wash Room tap 1	MVY819	Thursday, June 11, 2020	0.009	Passed	0.1900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Toddler Room Gender Neutral Wash Room tap 2	MVY820	Thursday, June 11, 2020	0.001	Passed	0.0330	Passed	
Tallahassee Community School	Boys Wash Room tap 1 by Girls Wash Room	MVY821	Thursday, June 11, 2020	0.006	Exceeded	0.0680	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Wash Room tap 2 by Girls Wash Room	MVY822	Thursday, June 11, 2020	0.059	Exceeded	0.0560	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Fountain in between Gym and Boys Locker Room	MVY823	Thursday, June 11, 2020	-	Passed	0.4100	Passed	
Tallahassee Community School	Music Room 110 tap	MVY824	Thursday, June 11, 2020	0.130	Exceeded	0.6800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Janitors Closet tap inside Mech Room	MVY825	Thursday, June 11, 2020	-	Passed	0.0190	Passed	
Tallahassee Community School	Fountain by Guidance Room	MVY826	Thursday, June 11, 2020	0.002	Passed	0.3800	Passed	Fountain Replacement in progress.
Tallahassee Community School	Class Room 104 tap	MVY827	Thursday, June 11, 2020	0.006	Exceeded	0.4000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Class Room 102 tap	MVY828	Thursday, June 11, 2020	0.007	Exceeded	0.7400	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Room 103 Gender Neutral Wash Room tap	MVY829	Thursday, June 11, 2020	0.011	Exceeded	0.2600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Class Room 105 Gender Neutral Wash Room tap	MVY830	Thursday, June 11, 2020	0.210	Exceeded	0.1600	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Class Room 105 tap	MVY831	Thursday, June 11, 2020	0.002	Passed	0.4000	Passed	
Tallahassee Community School	Cafeteria double compartment sink	NND025	Tuesday, September 1, 2020	0.004	Passed	0.0140	Passed	
Tallahassee Community School	Cafeteria hand washing sink	NND026	Tuesday, September 1, 2020	0.004	Passed	0.0090	Passed	
Tallahassee Community School	Girls Wash Room tap 1 by Library	MVY834	Thursday, June 11, 2020	0.028	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Girls Wash Room tap 2 by Library	MVY835	Thursday, June 11, 2020	0.025	Exceeded	0.2800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Girls Wash Room tap 3 by Library	MVY836	Thursday, June 11, 2020	0.045	Exceeded	0.2200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Wash Room tap 1 by Mech Room	MVY837	Thursday, June 11, 2020	0.023	Exceeded	0.1800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Wash Room tap 2 by Mech Room	MVY838	Thursday, June 11, 2020	0.028	Exceeded	0.0850	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Wash Room tap 3 by Mech Room	MVY839	Thursday, June 11, 2020	0.012	Exceeded	0.0860	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Boys Wash Room tap 4 by Mech Room	MVY840	Thursday, June 11, 2020	0.049	Exceeded	0.1300	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Fountain by Cafeteria	MVY841	Thursday, June 11, 2020	-	Passed	1.0000	Passed	
Tallahassee Community School	Class Room 113 Wash Room tap	MVY842	Thursday, June 11, 2020	0.006	Exceeded	0.2300	Passed	Faucet to be remediated. Signage to instruct hand washing only.

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Tallahassee Community School	Class Room 113 tap	MVY843	Thursday, June 11, 2020	0.005	Exceeded	0.2900	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Class Room 115 Wash Room tap	MVY844	Thursday, June 11, 2020	0.007	Exceeded	0.1000	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Class Room 115 tap 1	MVY845	Thursday, June 11, 2020	-	Passed	0.0670	Passed	
Tallahassee Community School	Class Room 115 tap 2	MVY846	Thursday, June 11, 2020	0.003	Passed	0.3500	Passed	
Tallahassee Community School	Class Room 116 tap	MVY847	Thursday, June 11, 2020	0.410	Exceeded	0.5800	Passed	Faucet to be remediated. Signage to instruct hand washing only.
Tallahassee Community School	Class Room 114 tap	MVY848	Thursday, June 11, 2020	0.004	Passed	0.4300	Passed	
Tallahassee Community School	Staff Room Kitchen tap	MVY849	Thursday, June 11, 2020	0.002	Passed	0.1900	Passed	
Tallahassee Community School	Staff Room Wash Room tap 1	MVY850	Thursday, June 11, 2020	0.003	Passed	0.1300	Passed	
Tallahassee Community School	Staff Room Wash Room tap 2	MVY851	Thursday, June 11, 2020	0.002	Passed	0.0950	Passed	
Tantallon Junior Elementary School	Class Room tap Room 103	MUW181	Monday, June 8, 2020	0.012	Exceeded	1.7000	Passed	Signage added to instruct handwashing only
Tantallon Junior Elementary School	Class Room tap Room 104	MUW182	Monday, June 8, 2020	0.004	Passed	1.6000	Passed	
Tantallon Junior Elementary School	Class Room tap Room 105	MUW183	Monday, June 8, 2020	0.058	Exceeded	0.8500	Passed	Signage added to instruct handwashing only
Tantallon Junior Elementary School	Boys Wash Room tap 1	MUW184	Monday, June 8, 2020	0.001	Passed	1.6000	Passed	
Tantallon Junior Elementary School	Boys Wash Room tap 2	MUW185	Monday, June 8, 2020	0.007	Exceeded	1.7000	Passed	Signage added to instruct handwashing only
Tantallon Junior Elementary School	Boys Wash Room tap 3	MUW186	Monday, June 8, 2020	0.001	Passed	1.6000	Passed	
Tantallon Junior Elementary School	Janitors Closet tap Room 109	MUW187	Monday, June 8, 2020	0.009	Exceeded	0.3100	Passed	Signage added to instruct handwashing only
Tantallon Junior Elementary School	Girls Wash Room tap 1	MUW188	Monday, June 8, 2020	0.007	Exceeded	0.6200	Passed	Signage added to instruct handwashing only
Tantallon Junior Elementary School	Girls Wash Room tap 2	MUW189	Monday, June 8, 2020	0.001	Passed	0.8200	Passed	
Tantallon Junior Elementary School	Girls Wash Room tap 3	MUW190	Monday, June 8, 2020	0.003	Passed	0.5100	Passed	
Tantallon Junior Elementary School	Class Room tap Room 115	MUW191	Monday, June 8, 2020	0.006	Exceeded	2.6000	Exceeded	Signage added to instruct handwashing only
Tantallon Junior Elementary School	Staff Room tap	MUW192	Monday, June 8, 2020	0.001	Passed	0.4300	Passed	
Tantallon Junior Elementary School	Staff Wash Room 1 tap	MUW193	Monday, June 8, 2020	0.001	Passed	0.4000	Passed	
Tantallon Junior Elementary School	Staff Wash Room 2 tap	MUW194	Monday, June 8, 2020	0.001	Passed	0.4700	Passed	
Tantallon Junior Elementary School	2nd Floor Girls Wash Room tap 1	MUW195	Monday, June 8, 2020	0.023	Exceeded	0.8200	Passed	Signage added to instruct handwashing only
Tantallon Junior Elementary School	2nd Floor Girls Wash Room tap 2	MUW196	Monday, June 8, 2020	0.020	Exceeded	1.0000	Passed	Signage added to instruct handwashing only
Tantallon Junior Elementary School	2nd Floor Girls Wash Room tap 3	MUW197	Monday, June 8, 2020	0.005	Passed	1.6000	Passed	
Tantallon Junior Elementary School	2nd Floor Janitors Closet tap	MUW198	Monday, June 8, 2020	0.004	Passed	1.2000	Passed	
Tantallon Junior Elementary School	2nd Floor Boys Wash Room tap 1	MUW199	Monday, June 8, 2020	0.002	Passed	0.6200	Passed	
Tantallon Junior Elementary School	2nd Floor Boys Wash Room tap 2	MUW200	Monday, June 8, 2020	0.001	Passed	0.7900	Passed	
Tantallon Junior Elementary School	Class Room tap Room 212	MUW208	Monday, June 8, 2020	1.800	Exceeded	1.9000	Passed	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Cafeteria tap 1	MUV724	Monday, June 8, 2020	0.003	Passed	1.5000	Passed	
Tantallon Senior Elementary School	Cafeteria tap 2	NNS753	Thursday, September 3, 2020	0.001	Passed	0.6600	Passed	
Tantallon Senior Elementary School	Cafeteria tap 3	NNS754	Thursday, September 3, 2020	0.001	Passed	0.6300	Passed	
Tantallon Senior Elementary School	Boys Wash Room tap 1	MUV727	Monday, June 8, 2020	0.006	Exceeded	1.4000	Passed	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Boys Wash Room tap 2	MUV728	Monday, June 8, 2020	0.005	Passed	1.9000	Passed	
Tantallon Senior Elementary School	Boys Wash Room tap 3	MUV729	Monday, June 8, 2020	0.010	Exceeded	1.5000	Passed	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Fountain by Boys Wash Room	QRB344	Thursday, September 16, 2021	-	Passed	0.0014	Passed	Fountain replaced
Tantallon Senior Elementary School	Staff Wash Room	MUV731	Monday, June 8, 2020	0.005	Passed	2.5000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Staff Wash Room	MUV732	Monday, June 8, 2020	0.007	Exceeded	2.4000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Girls Wash Room tap 1	MUV733	Monday, June 8, 2020	0.022	Exceeded	0.6900	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Girls Wash Room tap 2	MUV734	Monday, June 8, 2020	0.006	Exceeded	2.1000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Girls Wash Room tap 3	MUV735	Monday, June 8, 2020	0.012	Exceeded	2.0000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Class Room 152 tap	PCW270	Thursday, March 18, 2021	0.004	Passed	1.400	Passed	
Tantallon Senior Elementary School	Band Room	PCW271	Thursday, March 18, 2021	0.003	Passed	0.530	Passed	
Tantallon Senior Elementary School	Janitors Closet tap	MUV736	Monday, June 8, 2020	0.012	Exceeded	2.4000	Exceeded	Signage added to instruct handwashing only



# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Tantallon Senior Elementary School	2nd Floor Staff Room tap 1	MUV737	Monday, June 8, 2020	0.002	Passed	3.1000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Staff Room tap 2	MUV738	Monday, June 8, 2020	0.027	Exceeded	0.8800	Passed	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Staff Room tap 3	MUV739	Monday, June 8, 2020	0.030	Exceeded	1.8000	Passed	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Boys Staff Wash Room tap	MUV740	Monday, June 8, 2020	0.011	Exceeded	2.0000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Boys Wash Room tap 1	MUV741	Monday, June 8, 2020	0.008	Exceeded	3.8000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Boys Wash Room tap 2	MUV742	Monday, June 8, 2020	0.010	Exceeded	3.0000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Boys Wash Room tap 3	MUV743	Monday, June 8, 2020	0.007	Exceeded	2.7000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Boys Wash Room tap 4	MUV744	Monday, June 8, 2020	0.008	Exceeded	1.7000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Janitors Closet tap	MUV745	Monday, June 8, 2020	0.005	Exceeded	2.8000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor fountain	QMZ806	Monday, August 30, 2021	-	Passed	0.0067	Passed	Fountain replaced
Tantallon Senior Elementary School	Girls Wash Room tap 1 Room 229	MUV747	Monday, June 8, 2020	0.022	Exceeded	0.9600	Passed	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Girls Wash Room tap 2 Room 229	MUV748	Monday, June 8, 2020	0.004	Passed	4.6000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	Girls Wash Room tap 3 Room 229	MUV749	Monday, June 8, 2020	0.007	Exceeded	3.0000	Exceeded	Signage added to instruct handwashing only
Tantallon Senior Elementary School	2nd Floor Learning Centre tap 1	NNS755	Thursday, September 3, 2020	0.002	Passed	0.4000	Passed	
Tantallon Senior Elementary School	2nd Floor Learning Centre tap 2	NNS756	Thursday, September 3, 2020	0.002	Passed	0.3700	Passed	
Tantallon Senior Elementary School	2nd Floor Learning Centre tap 3	NNS757	Thursday, September 3, 2020	0.002	Passed	0.3800	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Cafeteria tap	MYZ361	Thursday, June 25, 2020	0.001	Passed	0.0410	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Staff Kitchen tap 1	PWV191	Monday, June 21, 2021	0.002	Passed	0.0590	Passed	Tap remediated
Upper Musquodoboit Consolidated Elementary Sch	Staff Kitchen tap 2	MYZ363	Thursday, June 25, 2020	-	Passed	0.0220	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Staff Wash Room tap	MYZ364	Thursday, June 25, 2020	0.002	Passed	0.0270	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Girls Wash Room tap 1	MYZ365	Thursday, June 25, 2020	0.003	Passed	0.0340	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Girls Wash Room tap 2	MYZ366	Thursday, June 25, 2020	0.001	Passed	0.0270	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Girls Wash Room tap 3	MYZ367	Thursday, June 25, 2020	0.001	Passed	0.0130	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Janitors Closet tap by Wash Rooms	MYZ368	Thursday, June 25, 2020	0.001	Passed	0.0920	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Boys Wash Room tap 1	MYZ369	Thursday, June 25, 2020	0.002	Passed	0.1400	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Boys Wash Room tap 2	MYZ370	Thursday, June 25, 2020	0.001	Passed	0.1100	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Boys Wash Room tap 3	MYZ379	Thursday, June 25, 2020	0.001	Passed	0.0890	Passed	
Upper Musquodoboit Consolidated Elementary Sch	Class Room 4 tap	MYZ380	Thursday, June 25, 2020	0.001	Passed	0.0610	Passed	
Waverley Memorial Elementary School	Girls Wash Room tap 1 by staircase	MSP675	Wednesday, May 27, 2020	0.001	Passed	0.3100	Passed	
Waverley Memorial Elementary School	Girls Wash Room tap 2 by staircase	MSP676	Wednesday, May 27, 2020	0.001	Passed	0.3000	Passed	
Waverley Memorial Elementary School	Girls Wash Room tap 3 by staircase	MSP677	Wednesday, May 27, 2020	0.001	Passed	0.2900	Passed	
Waverley Memorial Elementary School	Fountain by Room 203	MSP678	Wednesday, May 27, 2020	-	Passed	0.5100	Passed	
Waverley Memorial Elementary School	Janitors Closet 216 tap	MSP679	Wednesday, May 27, 2020	-	Passed	0.0940	Passed	
Waverley Memorial Elementary School	Staff Wash Room 214 tap	MSP680	Wednesday, May 27, 2020	-	Passed	0.1300	Passed	
Waverley Memorial Elementary School	Special Needs Wash Room 213 tap	MSP681	Wednesday, May 27, 2020	-	Passed	0.0680	Passed	
Waverley Memorial Elementary School	Boys Wash Room 212.1 tap 1	MSP682	Wednesday, May 27, 2020	-	Passed	0.4700	Passed	
Waverley Memorial Elementary School	Boys Wash Room 212.1 tap 2	MSP683	Wednesday, May 27, 2020	-	Passed	0.2900	Passed	
Waverley Memorial Elementary School	Boys Wash Room 212.1 tap 3	MSP684	Wednesday, May 27, 2020	0.001	Passed	0.3100	Passed	
Waverley Memorial Elementary School	Laundry Room 220 tap	MSP685	Wednesday, May 27, 2020	-	Passed	0.1800	Passed	
Waverley Memorial Elementary School	Class Room 201 tap 1	MSP686	Wednesday, May 27, 2020	-	Passed	0.6900	Passed	
Waverley Memorial Elementary School	Class Room 201 tap 2	MSP687	Wednesday, May 27, 2020	-	Passed	0.9600	Passed	
Waverley Memorial Elementary School	Class Room 202 tap	MSP688	Wednesday, May 27, 2020	-	Passed	0.1600	Passed	
Waverley Memorial Elementary School	Class Room 203 tap	MSP689	Wednesday, May 27, 2020	-	Passed	0.0340	Passed	
Waverley Memorial Elementary School	Class Room 204 tap	MSP690	Wednesday, May 27, 2020	-	Passed	0.0600	Passed	
Waverley Memorial Elementary School	Class Room 205 tap	MSP691	Wednesday, May 27, 2020	-	Passed	0.5700	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Waverley Memorial Elementary School	Girls Wash Room tap 1 by Stairs	MSP692	Wednesday, May 27, 2020	0.001	Passed	0.6000	Passed	
Waverley Memorial Elementary School	Girls Wash Room tap 2 by Stairs	MSP693	Wednesday, May 27, 2020	-	Passed	0.9300	Passed	
Waverley Memorial Elementary School	Girls Wash Room tap 3 by Stairs	MSP694	Wednesday, May 27, 2020	-	Passed	0.4200	Passed	
Waverley Memorial Elementary School	Staff Wash Room 120 tap	MSP695	Wednesday, May 27, 2020	-	Passed	0.1400	Passed	
Waverley Memorial Elementary School	Staff Wash Room 119 tap	MSP696	Wednesday, May 27, 2020	-	Passed	0.0770	Passed	
Waverley Memorial Elementary School	Boys Wash Room tap 1 by Room 118.1	MSP697	Wednesday, May 27, 2020	0.001	Passed	0.4700	Passed	
Waverley Memorial Elementary School	Boys Wash Room tap 2 by Room 118.1	MSP698	Wednesday, May 27, 2020	-	Passed	0.4200	Passed	
Waverley Memorial Elementary School	Boys Wash Room tap 3 by Room 118.1	MSP699	Wednesday, May 27, 2020	0.001	Passed	0.3300	Passed	
Waverley Memorial Elementary School	Janitors Closet 118.1 tap	MSP700	Wednesday, May 27, 2020	-	Passed	0.0590	Passed	
Waverley Memorial Elementary School	Class Room 108 tap	MSP701	Wednesday, May 27, 2020	-	Passed	0.1000	Passed	
Waverley Memorial Elementary School	Class Room 109 tap	MSP702	Wednesday, May 27, 2020	-	Passed	0.3600	Passed	
Waverley Memorial Elementary School	Gender Neutral Wash Room 110.2 tap	MSP703	Wednesday, May 27, 2020	-	Passed	0.4600	Passed	
Waverley Memorial Elementary School	Class Room 110 tap	MSP704	Wednesday, May 27, 2020	-	Passed	0.3800	Passed	
Waverley Memorial Elementary School	Fountain by Room 110	MSP705	Wednesday, May 27, 2020	-	Passed	0.3800	Passed	Fountain Replacement in progress.
Waverley Memorial Elementary School	Gender Neutral Wash Room 111.1 tap	MSP706	Wednesday, May 27, 2020	-	Passed	0.4000	Passed	
Waverley Memorial Elementary School	Class Room 111 tap	MSP707	Wednesday, May 27, 2020	-	Passed	0.1900	Passed	
Waverley Memorial Elementary School	Staff Room 112 Kitchen tap	MSP708	Wednesday, May 27, 2020	-	Passed	0.3900	Passed	
Waverley Memorial Elementary School	Gender Neutral Wash Room 114.1B tap	MSP709	Wednesday, May 27, 2020	-	Passed	0.6300	Passed	
Waverley Memorial Elementary School	Class Room 114 tap	MSP710	Wednesday, May 27, 2020	-	Passed	0.8900	Passed	
Waverley Memorial Elementary School	Girls Locker Room 104.2 tap	MSP711	Wednesday, May 27, 2020	0.002	Passed	0.5600	Passed	
Waverley Memorial Elementary School	Boys Locker Room 104.5 tap	MSP712	Wednesday, May 27, 2020	0.002	Passed	0.5200	Passed	
Waverley Memorial Elementary School	Class Room 103.2 tap	MSP713	Wednesday, May 27, 2020	-	Passed	0.2400	Passed	
Waverley Memorial Elementary School	Fountain by Room 103.1A	MSP714	Wednesday, May 27, 2020	-	Passed	0.2100	Passed	
Waverley Memorial Elementary School	Janitors Closet 102.1 tap	MSP715	Wednesday, May 27, 2020	-	Passed	0.1800	Passed	
Waverley Memorial Elementary School	Room 102.1 sink tap	MSP716	Wednesday, May 27, 2020	-	Passed	0.1300	Passed	
Waverley Memorial Elementary School	Room 102.1 triple sink tap	MSP717	Wednesday, May 27, 2020	-	Passed	0.2400	Passed	
Waverley Memorial Elementary School	Cafeteria Kitchen Hand Wash sink tap	MTA424	Thursday, May 28, 2020	-	Passed	0.1400	Passed	
Waverley Memorial Elementary School	Main Office Room 101.4B tap	MTA426	Thursday, May 28, 2020	0.001	Passed	0.8600	Passed	
Westmount Elementary School	Fountain by Room 8	MOS547	Tuesday, May 5, 2020	0.002	Passed	0.3600	Passed	
Westmount Elementary School	Fountain by Room 6	QLG964	Monday, August 23, 2021	0.003	Passed	0.1600	Passed	
Westmount Elementary School	Staff Wash Room by Room 6	MOS549	Tuesday, May 5, 2020	0.001	Passed	0.1800	Passed	
Westmount Elementary School	Boys Wash Room tap 1 by Room 6	MOS550	Tuesday, May 5, 2020	0.001	Passed	0.2300	Passed	
Westmount Elementary School	Boys Wash Room tap 2 by Room 6	MOS551	Tuesday, May 5, 2020	0.001	Passed	0.1300	Passed	
Westmount Elementary School	Boys Wash Room tap 3 by Room 6	MOS552	Tuesday, May 5, 2020	0.002	Passed	0.1600	Passed	
Westmount Elementary School	Staff Wash Room tap by Room 5	MOS553	Tuesday, May 5, 2020	0.003	Passed	0.2100	Passed	
Westmount Elementary School	Girls Wash Room tap 1 by Room 5	MOS554	Tuesday, May 5, 2020	0.003	Passed	0.1400	Passed	
Westmount Elementary School	Girls Wash Room tap 2 by Room 5	NJI782	Friday, August 14, 2020	-	Passed	0.0030	Passed	
Westmount Elementary School	Girls Wash Room tap 3 by Room 5	MOS556	Tuesday, May 5, 2020	0.003	Passed	0.1700	Passed	
Westmount Elementary School	Girls Wash Room tap 4 by Room 5	MOS557	Tuesday, May 5, 2020	0.002	Passed	0.0470	Passed	
Westmount Elementary School	Class Room 8 tap	MOS558	Tuesday, May 5, 2020	0.001	Passed	0.1000	Passed	
Westmount Elementary School	Class Room 9 tap 1	NJI779	Friday, August 14, 2020	-	Passed	0.0090	Passed	
Westmount Elementary School	Class Room 9 tap 2	MOS560	Tuesday, May 5, 2020	0.003	Passed	0.2300	Passed	
Westmount Elementary School	Class Room 10 tap	NJI780	Friday, August 14, 2020	-	Passed	0.0100	Passed	
Westmount Elementary School	Class Room 6 tap	MOS562	Tuesday, May 5, 2020	0.001	Passed	0.1300	Passed	
Westmount Elementary School	Janitors Closet tap by Room 6	MOS563	Tuesday, May 5, 2020	0.002	Passed	0.1600	Passed	

# Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
Westmount Elementary School	Class Room 2	MOS564	Tuesday, May 5, 2020	0.002	Passed	0.0600	Passed	
Westmount Elementary School	Fountain by Caretaker Room	MOS565	Tuesday, May 5, 2020	0.001	Passed	0.4300	Passed	
Westmount Elementary School	Caretaker Room tap	MPB690	Friday, May 8, 2020	0.000	Passed	0.0890	Passed	
Westmount Elementary School	Art Room tap	MPB691	Friday, May 8, 2020	0.002	Passed	0.4500	Passed	
Westmount Elementary School	Gym Office tap	MPB692	Friday, May 8, 2020	0.004	Passed	0.1600	Passed	
Westmount Elementary School	Janitors Closet tap by Room 17	MPB693	Friday, May 8, 2020	0.001	Passed	0.0370	Passed	
Westmount Elementary School	Fountain by Room 17	NJI778	Friday, August 14, 2020	0.002	Passed	0.0710	Passed	
Westmount Elementary School	Staff Wash Room tap by Room 17	MPB695	Friday, May 8, 2020	0.000	Passed	0.0470	Passed	
Westmount Elementary School	Boys Wash Room tap 1 by Room 17	MPB696	Friday, May 8, 2020	0.001	Passed	0.1900	Passed	
Westmount Elementary School	Boys Wash Room tap 2 by Room 17	MPB697	Friday, May 8, 2020	0.001	Passed	0.2300	Passed	
Westmount Elementary School	Boys Wash Room tap 3 by Room 17	MPB698	Friday, May 8, 2020	0.002	Passed	0.2600	Passed	
Westmount Elementary School	Fountain by Room 18	QLG963	Monday, August 23, 2021	0.002	Passed	0.3200	Passed	
Westmount Elementary School	Staff Wash Room tap by Room 18	MPB700	Friday, May 8, 2020	0.002	Passed	0.3200	Passed	
Westmount Elementary School	Girls Wash Room tap 1 by Room 18	MPB701	Friday, May 8, 2020	0.004	Passed	0.1500	Passed	
Westmount Elementary School	Girls Wash Room tap 2 by Room 18	MPB702	Friday, May 8, 2020	0.003	Passed	0.0800	Passed	
Westmount Elementary School	Girls Wash Room tap 3 by Room 18	MPB703	Friday, May 8, 2020	0.001	Passed	0.1400	Passed	
Westmount Elementary School	Gender Neutral Wash Room tap by Gym	MPB704	Friday, May 8, 2020	0.001	Passed	0.0390	Passed	
Westmount Elementary School	Staff Wash Room 1 tap by Gym	MPB705	Friday, May 8, 2020	0.002	Passed	0.1300	Passed	
Westmount Elementary School	Staff Wash Room 2 tap by Gym	MPB706	Friday, May 8, 2020	0.001	Passed	0.0960	Passed	
Westmount Elementary School	Main Office Wash Room tap	MPB707	Friday, May 8, 2020	0.001	Passed	0.4800	Passed	
Westmount Elementary School	Principal's Office Wash Room tap	NJI781	Friday, August 14, 2020	-	Passed	0.0160	Passed	
William King Elementary School	Boys Wash Room 153 tap 1	MQS659	Tuesday, May 19, 2020	0.002	Passed	3.0000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
William King Elementary School	Boys Wash Room 153 tap 2	MQS660	Tuesday, May 19, 2020	0.002	Passed	0.2400	Passed	
William King Elementary School	Boys Wash Room 153 tap 3	MQS661	Tuesday, May 19, 2020	0.001	Passed	0.2200	Passed	
William King Elementary School	Fountain by Room 153	MQS662	Tuesday, May 19, 2020	-	Passed	0.3900	Passed	
William King Elementary School	Girls Wash Room 155 tap 1	MQS663	Tuesday, May 19, 2020	-	Passed	0.2900	Passed	
William King Elementary School	Girls Wash Room 155 tap 2	MQS664	Tuesday, May 19, 2020	-	Passed	0.0320	Passed	
William King Elementary School	Girls Wash Room 155 tap 3	MQS665	Tuesday, May 19, 2020	0.014	Exceeded	2.5000	Exceeded	Faucet to be remediated. Signage to instruct hand washing only.
William King Elementary School	Class Room 159 tap	MQS666	Tuesday, May 19, 2020	0.004	Passed	0.3000	Passed	
William King Elementary School	Class Room 161 tap	MQS667	Tuesday, May 19, 2020	0.000	Passed	0.7400	Passed	
William King Elementary School	Class Room 161 Wash Room tap	MQS668	Tuesday, May 19, 2020	0.003	Passed	0.5600	Passed	
William King Elementary School	Class Room 158 tap	MQS669	Tuesday, May 19, 2020	0.005	Passed	0.4400	Passed	
William King Elementary School	Gender Neutral Wash Room 158 tap	MQS670	Tuesday, May 19, 2020	0.006	Exceeded	0.1200	Passed	Faucet to be remediated. Signage to instruct hand washing only.
William King Elementary School	Janitors Closet Room 154 tap	MQS671	Tuesday, May 19, 2020	-	Passed	0.0320	Passed	
William King Elementary School	Boys Locker Room 149 tap 1	MQS672	Tuesday, May 19, 2020	0.001	Passed	0.1700	Passed	
William King Elementary School	Boys Locker Room 149 tap 2	MQS673	Tuesday, May 19, 2020	-	Passed	0.1200	Passed	
William King Elementary School	Boys Locker Room 149 tap 3	MQS674	Tuesday, May 19, 2020	0.001	Passed	0.1200	Passed	
William King Elementary School	Gym Office Wash Room tap	MQS675	Tuesday, May 19, 2020	0.001	Passed	0.1200	Passed	
William King Elementary School	Girls Locker Room tap 1	MQS676	Tuesday, May 19, 2020	0.001	Passed	0.3800	Passed	
William King Elementary School	Girls Locker Room tap 2	MQS677	Tuesday, May 19, 2020	0.001	Passed	0.1500	Passed	
William King Elementary School	Girls Locker Room tap 3	MQS678	Tuesday, May 19, 2020	0.002	Passed	0.8300	Passed	
William King Elementary School	Class Room 137 tap	MQS679	Tuesday, May 19, 2020	0.002	Passed	0.1000	Passed	
William King Elementary School	Kitchen Room 135 three compartment sink tap	MQS680	Tuesday, May 19, 2020	-	Passed	0.0520	Passed	
William King Elementary School	Kitchen Room 135 sink tap	MQS681	Tuesday, May 19, 2020	-	Passed	0.4700	Passed	
William King Elementary School	Fountain (Lower) by Room 135	MQS682	Tuesday, May 19, 2020	0.013	Exceeded	0.4000	Passed	New Fountain to be installed. Other sources available.

## Halifax Regional Centre for Education

Water Test Results Update - September 30, 2021

School Name	Location	Sample ID	Sample Date	Lead mg/L	Lead Result	Copper mg/L	Copper Result	Remediation / Updated as Work Progresses All Schools Have Drinking Water Available
William King Elementary School	Fountain (Upper) by Room 135	MQS683	Tuesday, May 19, 2020	0.750	Exceeded	1.3000	Passed	New Fountain to be installed. Other sources available.
William King Elementary School	Janitors Closet Room 130 tap	MQS684	Tuesday, May 19, 2020	-	Passed	0.0970	Passed	
William King Elementary School	Class Room 122 Wash Room tap	MQS685	Tuesday, May 19, 2020	-	Passed	0.0780	Passed	
William King Elementary School	Class Room 122 tap	MQS686	Tuesday, May 19, 2020	-	Passed	0.0950	Passed	
William King Elementary School	Class Room 108 tap	MQS687	Tuesday, May 19, 2020	0.003	Passed	0.3100	Passed	
William King Elementary School	Class Room 107 tap	MQS688	Tuesday, May 19, 2020	0.001	Passed	0.4900	Passed	
William King Elementary School	Boys Wash Room 115 tap 1	MQS689	Tuesday, May 19, 2020	-	Passed	0.3700	Passed	
William King Elementary School	Boys Wash Room 115 tap 2	MQS690	Tuesday, May 19, 2020	-	Passed	0.1700	Passed	
William King Elementary School	Boys Wash Room 115 tap 3	MQS691	Tuesday, May 19, 2020	-	Passed	0.1100	Passed	
William King Elementary School	Janitors Closet Room 116 tap	MQS692	Tuesday, May 19, 2020	-	Passed	0.2400	Passed	
William King Elementary School	Fountain by Room 116	MQS693	Tuesday, May 19, 2020	0.001	Passed	0.3800	Passed	
William King Elementary School	Girls Wash Room 117 tap 1	MQS694	Tuesday, May 19, 2020	-	Passed	0.2000	Passed	
William King Elementary School	Girls Wash Room 117 tap 2	MQS695	Tuesday, May 19, 2020	-	Passed	0.0910	Passed	
William King Elementary School	Girls Wash Room 117 tap 3	MQS696	Tuesday, May 19, 2020	-	Passed	0.3000	Passed	
William King Elementary School	Class Room 119 tap	MQS697	Tuesday, May 19, 2020	-	Passed	0.1400	Passed	
William King Elementary School	Class Room 129 tap	MQS698	Tuesday, May 19, 2020	0.001	Passed	0.0960	Passed	
William King Elementary School	Class Room 125 Wash Room tap	MQS699	Tuesday, May 19, 2020	0.001	Passed	0.1800	Passed	
William King Elementary School	Class Room 126 Wash Room tap	MQS700	Tuesday, May 19, 2020	-	Passed	0.0610	Passed	